



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-71,21
-0,70	0,31	-70,65
-0,69	0,32	-70,10
-0,68	0,33	-69,57
-0,67	0,34	-69,05
-0,66	0,35	-68,54
-0,65	0,36	-68,04
-0,64	0,37	-67,56
-0,63	0,38	-67,08
-0,62	0,39	-66,61
-0,61	0,40	-66,16
-0,60	0,41	-65,71
-0,59	0,42	-65,27
-0,58	0,43	-64,84
-0,57	0,44	-64,42
-0,56	0,45	-64,00
-0,55	0,46	-63,59
-0,54	0,47	-63,19
-0,53	0,48	-62,80
-0,52	0,49	-62,41
-0,51	0,50	-62,03
-0,50	0,51	-61,65
-0,49	0,52	-61,28
-0,48	0,53	-60,92
-0,47	0,54	-60,56
-0,46	0,55	-60,21
-0,45	0,56	-59,86
-0,44	0,57	-59,51
-0,43	0,58	-59,18
-0,42	0,59	-58,84
-0,41	0,60	-58,51
-0,40	0,61	-58,19
-0,39	0,62	-57,86
-0,38	0,63	-57,55
-0,37	0,64	-57,23
-0,36	0,65	-56,93
-0,35	0,66	-56,62
-0,34	0,67	-56,32
-0,33	0,68	-56,02
-0,32	0,69	-55,72
-0,31	0,70	-55,43
-0,30	0,71	-55,14
-0,29	0,72	-54,86
-0,28	0,73	-54,58



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-54,30
-0,26	0,75	-54,02
-0,25	0,76	-53,75
-0,24	0,77	-53,48
-0,23	0,78	-53,21
-0,22	0,79	-52,95
-0,21	0,80	-52,68
-0,20	0,81	-52,42
-0,19	0,82	-52,17
-0,18	0,83	-51,91
-0,17	0,84	-51,66
-0,16	0,85	-51,41
-0,15	0,86	-51,16
-0,14	0,87	-50,92
-0,13	0,88	-50,67
-0,12	0,89	-50,43
-0,11	0,90	-50,19
-0,10	0,91	-49,95
-0,09	0,92	-49,72
-0,08	0,93	-49,49
-0,07	0,94	-49,26
-0,06	0,95	-49,03
-0,05	0,96	-48,80
-0,04	0,97	-48,57
-0,03	0,98	-48,35
-0,02	0,99	-48,13
-0,01	1,00	-47,91
0,00	1,01	-47,69
0,01	1,02	-47,47
0,02	1,03	-47,26
0,03	1,04	-47,04
0,04	1,05	-46,83
0,05	1,06	-46,62
0,06	1,07	-46,41
0,07	1,08	-46,21
0,08	1,09	-46,00
0,09	1,10	-45,80
0,10	1,11	-45,59
0,11	1,12	-45,39
0,12	1,13	-45,19
0,13	1,14	-44,99
0,14	1,15	-44,80
0,15	1,16	-44,60
0,16	1,17	-44,41



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,17	1,18	-44,21
0,18	1,19	-44,02
0,19	1,20	-43,83
0,20	1,21	-43,64
0,21	1,22	-43,45
0,22	1,23	-43,26
0,23	1,24	-43,08
0,24	1,25	-42,89
0,25	1,26	-42,71
0,26	1,27	-42,53
0,27	1,28	-42,34
0,28	1,29	-42,16
0,29	1,30	-41,99
0,30	1,31	-41,81
0,31	1,32	-41,63
0,32	1,33	-41,45
0,33	1,34	-41,28
0,34	1,35	-41,10
0,35	1,36	-40,93
0,36	1,37	-40,76
0,37	1,38	-40,59
0,38	1,39	-40,42
0,39	1,40	-40,25
0,40	1,41	-40,08
0,41	1,42	-39,91
0,42	1,43	-39,75
0,43	1,44	-39,58
0,44	1,45	-39,41
0,45	1,46	-39,25
0,46	1,47	-39,09
0,47	1,48	-38,93
0,48	1,49	-38,76
0,49	1,50	-38,60
0,50	1,51	-38,44
0,51	1,52	-38,29
0,52	1,53	-38,13
0,53	1,54	-37,97
0,54	1,55	-37,81
0,55	1,56	-37,66
0,56	1,57	-37,50
0,57	1,58	-37,35
0,58	1,59	-37,20
0,59	1,60	-37,04
0,60	1,61	-36,89



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,61	1,62	-36,74
0,62	1,63	-36,59
0,63	1,64	-36,44
0,64	1,65	-36,29
0,65	1,66	-36,14
0,66	1,67	-35,99
0,67	1,68	-35,85
0,68	1,69	-35,70
0,69	1,70	-35,55
0,70	1,71	-35,41
0,71	1,72	-35,26
0,72	1,73	-35,12
0,73	1,74	-34,98
0,74	1,75	-34,84
0,75	1,76	-34,69
0,76	1,77	-34,55
0,77	1,78	-34,41
0,78	1,79	-34,27
0,79	1,80	-34,13
0,80	1,81	-33,99
0,81	1,82	-33,85
0,82	1,83	-33,72
0,83	1,84	-33,58
0,84	1,85	-33,44
0,85	1,86	-33,31
0,86	1,87	-33,17
0,87	1,88	-33,04
0,88	1,89	-32,90
0,89	1,90	-32,77
0,90	1,91	-32,64
0,91	1,92	-32,50
0,92	1,93	-32,37
0,93	1,94	-32,24
0,94	1,95	-32,11
0,95	1,96	-31,98
0,96	1,97	-31,85
0,97	1,98	-31,72
0,98	1,99	-31,59
0,99	2,00	-31,46
1,00	2,01	-31,33
1,01	2,02	-31,20
1,02	2,03	-31,08
1,03	2,04	-30,95
1,04	2,05	-30,82



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,05	2,06	-30,70
1,06	2,07	-30,57
1,07	2,08	-30,45
1,08	2,09	-30,32
1,09	2,10	-30,20
1,10	2,11	-30,08
1,11	2,12	-29,95
1,12	2,13	-29,83
1,13	2,14	-29,71
1,14	2,15	-29,59
1,15	2,16	-29,47
1,16	2,17	-29,34
1,17	2,18	-29,22
1,18	2,19	-29,10
1,19	2,20	-28,98
1,20	2,21	-28,87
1,21	2,22	-28,75
1,22	2,23	-28,63
1,23	2,24	-28,51
1,24	2,25	-28,39
1,25	2,26	-28,28
1,26	2,27	-28,16
1,27	2,28	-28,04
1,28	2,29	-27,93
1,29	2,30	-27,81
1,30	2,31	-27,70
1,31	2,32	-27,58
1,32	2,33	-27,47
1,33	2,34	-27,35
1,34	2,35	-27,24
1,35	2,36	-27,13
1,36	2,37	-27,01
1,37	2,38	-26,90
1,38	2,39	-26,79
1,39	2,40	-26,68
1,40	2,41	-26,56
1,41	2,42	-26,45
1,42	2,43	-26,34
1,43	2,44	-26,23
1,44	2,45	-26,12
1,45	2,46	-26,01
1,46	2,47	-25,90
1,47	2,48	-25,79
1,48	2,49	-25,68



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,49	2,50	-25,58
1,50	2,51	-25,47
1,51	2,52	-25,36
1,52	2,53	-25,25
1,53	2,54	-25,14
1,54	2,55	-25,04
1,55	2,56	-24,93
1,56	2,57	-24,82
1,57	2,58	-24,72
1,58	2,59	-24,61
1,59	2,60	-24,51
1,60	2,61	-24,40
1,61	2,62	-24,30
1,62	2,63	-24,19
1,63	2,64	-24,09
1,64	2,65	-23,99
1,65	2,66	-23,88
1,66	2,67	-23,78
1,67	2,68	-23,68
1,68	2,69	-23,57
1,69	2,70	-23,47
1,70	2,71	-23,37
1,71	2,72	-23,27
1,72	2,73	-23,17
1,73	2,74	-23,06
1,74	2,75	-22,96
1,75	2,76	-22,86
1,76	2,77	-22,76
1,77	2,78	-22,66
1,78	2,79	-22,56
1,79	2,80	-22,46
1,80	2,81	-22,36
1,81	2,82	-22,27
1,82	2,83	-22,17
1,83	2,84	-22,07
1,84	2,85	-21,97
1,85	2,86	-21,87
1,86	2,87	-21,77
1,87	2,88	-21,68
1,88	2,89	-21,58
1,89	2,90	-21,48
1,90	2,91	-21,39
1,91	2,92	-21,29
1,92	2,93	-21,19



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,93	2,94	-21,10
1,94	2,95	-21,00
1,95	2,96	-20,91
1,96	2,97	-20,81
1,97	2,98	-20,72
1,98	2,99	-20,62
1,99	3,00	-20,53
2,00	3,01	-20,43
2,01	3,02	-20,34
2,02	3,03	-20,24
2,03	3,04	-20,15
2,04	3,05	-20,06
2,05	3,06	-19,96
2,06	3,07	-19,87
2,07	3,08	-19,78
2,08	3,09	-19,69
2,09	3,10	-19,59
2,10	3,11	-19,50
2,11	3,12	-19,41
2,12	3,13	-19,32
2,13	3,14	-19,23
2,14	3,15	-19,14
2,15	3,16	-19,05
2,16	3,17	-18,96
2,17	3,18	-18,87
2,18	3,19	-18,78
2,19	3,20	-18,69
2,20	3,21	-18,60
2,21	3,22	-18,51
2,22	3,23	-18,42
2,23	3,24	-18,33
2,24	3,25	-18,24
2,25	3,26	-18,15
2,26	3,27	-18,06
2,27	3,28	-17,97
2,28	3,29	-17,88
2,29	3,30	-17,80
2,30	3,31	-17,71
2,31	3,32	-17,62
2,32	3,33	-17,53
2,33	3,34	-17,45
2,34	3,35	-17,36
2,35	3,36	-17,27
2,36	3,37	-17,19



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
2,37	3,38	-17,10
2,38	3,39	-17,01
2,39	3,40	-16,93
2,40	3,41	-16,84
2,41	3,42	-16,76
2,42	3,43	-16,67
2,43	3,44	-16,59
2,44	3,45	-16,50
2,45	3,46	-16,42
2,46	3,47	-16,33
2,47	3,48	-16,25
2,48	3,49	-16,16
2,49	3,50	-16,08
2,50	3,51	-15,99
2,51	3,52	-15,91
2,52	3,53	-15,83
2,53	3,54	-15,74
2,54	3,55	-15,66
2,55	3,56	-15,58
2,56	3,57	-15,49
2,57	3,58	-15,41
2,58	3,59	-15,33
2,59	3,60	-15,25
2,60	3,61	-15,17
2,61	3,62	-15,08
2,62	3,63	-15,00
2,63	3,64	-14,92
2,64	3,65	-14,84
2,65	3,66	-14,76
2,66	3,67	-14,68
2,67	3,68	-14,59
2,68	3,69	-14,51
2,69	3,70	-14,43
2,70	3,71	-14,35
2,71	3,72	-14,27
2,72	3,73	-14,19
2,73	3,74	-14,11
2,74	3,75	-14,03
2,75	3,76	-13,95
2,76	3,77	-13,87
2,77	3,78	-13,79
2,78	3,79	-13,71
2,79	3,80	-13,64
2,80	3,81	-13,56



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
2,81	3,82	-13,48
2,82	3,83	-13,40
2,83	3,84	-13,32
2,84	3,85	-13,24
2,85	3,86	-13,16
2,86	3,87	-13,09
2,87	3,88	-13,01
2,88	3,89	-12,93
2,89	3,90	-12,85
2,90	3,91	-12,78
2,91	3,92	-12,70
2,92	3,93	-12,62
2,93	3,94	-12,54
2,94	3,95	-12,47
2,95	3,96	-12,39
2,96	3,97	-12,31
2,97	3,98	-12,24
2,98	3,99	-12,16
2,99	4,00	-12,09
3,00	4,01	-12,01
3,01	4,02	-11,93
3,02	4,03	-11,86
3,03	4,04	-11,78
3,04	4,05	-11,71
3,05	4,06	-11,63
3,06	4,07	-11,56
3,07	4,08	-11,48
3,08	4,09	-11,41
3,09	4,10	-11,33
3,10	4,11	-11,26
3,11	4,12	-11,18
3,12	4,13	-11,11
3,13	4,14	-11,03
3,14	4,15	-10,96
3,15	4,16	-10,89
3,16	4,17	-10,81
3,17	4,18	-10,74
3,18	4,19	-10,67
3,19	4,20	-10,59
3,20	4,21	-10,52
3,21	4,22	-10,45
3,22	4,23	-10,37
3,23	4,24	-10,30
3,24	4,25	-10,23



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
3,25	4,26	-10,16
3,26	4,27	-10,08
3,27	4,28	-10,01
3,28	4,29	-9,94
3,29	4,30	-9,87
3,30	4,31	-9,79
3,31	4,32	-9,72
3,32	4,33	-9,65
3,33	4,34	-9,58
3,34	4,35	-9,51
3,35	4,36	-9,44
3,36	4,37	-9,36
3,37	4,38	-9,29
3,38	4,39	-9,22
3,39	4,40	-9,15
3,40	4,41	-9,08
3,41	4,42	-9,01
3,42	4,43	-8,94
3,43	4,44	-8,87
3,44	4,45	-8,80
3,45	4,46	-8,73
3,46	4,47	-8,66
3,47	4,48	-8,59
3,48	4,49	-8,52
3,49	4,50	-8,45
3,50	4,51	-8,38
3,51	4,52	-8,31
3,52	4,53	-8,24
3,53	4,54	-8,17
3,54	4,55	-8,10
3,55	4,56	-8,03
3,56	4,57	-7,97
3,57	4,58	-7,90
3,58	4,59	-7,83
3,59	4,60	-7,76
3,60	4,61	-7,69
3,61	4,62	-7,62
3,62	4,63	-7,55
3,63	4,64	-7,49
3,64	4,65	-7,42
3,65	4,66	-7,35
3,66	4,67	-7,28
3,67	4,68	-7,21
3,68	4,69	-7,15



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
3,69	4,70	-7,08
3,70	4,71	-7,01
3,71	4,72	-6,95
3,72	4,73	-6,88
3,73	4,74	-6,81
3,74	4,75	-6,74
3,75	4,76	-6,68
3,76	4,77	-6,61
3,77	4,78	-6,54
3,78	4,79	-6,48
3,79	4,80	-6,41
3,80	4,81	-6,34
3,81	4,82	-6,28
3,82	4,83	-6,21
3,83	4,84	-6,15
3,84	4,85	-6,08
3,85	4,86	-6,01
3,86	4,87	-5,95
3,87	4,88	-5,88
3,88	4,89	-5,82
3,89	4,90	-5,75
3,90	4,91	-5,69
3,91	4,92	-5,62
3,92	4,93	-5,56
3,93	4,94	-5,49
3,94	4,95	-5,43
3,95	4,96	-5,36
3,96	4,97	-5,30
3,97	4,98	-5,23
3,98	4,99	-5,17
3,99	5,00	-5,10
4,00	5,01	-5,04
4,01	5,02	-4,98
4,02	5,03	-4,91
4,03	5,04	-4,85
4,04	5,05	-4,78
4,05	5,06	-4,72
4,06	5,07	-4,66
4,07	5,08	-4,59
4,08	5,09	-4,53
4,09	5,10	-4,47
4,10	5,11	-4,40
4,11	5,12	-4,34
4,12	5,13	-4,28



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
4,13	5,14	-4,21
4,14	5,15	-4,15
4,15	5,16	-4,09
4,16	5,17	-4,02
4,17	5,18	-3,96
4,18	5,19	-3,90
4,19	5,20	-3,84
4,20	5,21	-3,77
4,21	5,22	-3,71
4,22	5,23	-3,65
4,23	5,24	-3,59
4,24	5,25	-3,52
4,25	5,26	-3,46
4,26	5,27	-3,40
4,27	5,28	-3,34
4,28	5,29	-3,28
4,29	5,30	-3,21
4,30	5,31	-3,15
4,31	5,32	-3,09
4,32	5,33	-3,03
4,33	5,34	-2,97
4,34	5,35	-2,91
4,35	5,36	-2,85
4,36	5,37	-2,79
4,37	5,38	-2,72
4,38	5,39	-2,66
4,39	5,40	-2,60
4,40	5,41	-2,54
4,41	5,42	-2,48
4,42	5,43	-2,42
4,43	5,44	-2,36
4,44	5,45	-2,30
4,45	5,46	-2,24
4,46	5,47	-2,18
4,47	5,48	-2,12
4,48	5,49	-2,06
4,49	5,50	-2,00
4,50	5,51	-1,94
4,51	5,52	-1,88
4,52	5,53	-1,82
4,53	5,54	-1,76
4,54	5,55	-1,70
4,55	5,56	-1,64
4,56	5,57	-1,58



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	-1,52
4,58	5,59	-1,46
4,59	5,60	-1,40
4,60	5,61	-1,34
4,61	5,62	-1,29
4,62	5,63	-1,23
4,63	5,64	-1,17
4,64	5,65	-1,11
4,65	5,66	-1,05
4,66	5,67	-0,99
4,67	5,68	-0,93
4,68	5,69	-0,87
4,69	5,70	-0,82
4,70	5,71	-0,76
4,71	5,72	-0,70
4,72	5,73	-0,64
4,73	5,74	-0,58
4,74	5,75	-0,52
4,75	5,76	-0,47
4,76	5,77	-0,41
4,77	5,78	-0,35
4,78	5,79	-0,29
4,79	5,80	-0,24
4,80	5,81	-0,18
4,81	5,82	-0,12
4,82	5,83	-0,06
4,83	5,84	-0,01
4,84	5,85	0,05
4,85	5,86	0,11
4,86	5,87	0,17
4,87	5,88	0,22
4,88	5,89	0,28
4,89	5,90	0,34
4,90	5,91	0,39
4,91	5,92	0,45
4,92	5,93	0,51
4,93	5,94	0,56
4,94	5,95	0,62
4,95	5,96	0,68
4,96	5,97	0,73
4,97	5,98	0,79
4,98	5,99	0,85
4,99	6,00	0,90
5,00	6,01	0,96



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	1,02
5,02	6,03	1,07
5,03	6,04	1,13
5,04	6,05	1,18
5,05	6,06	1,24
5,06	6,07	1,30
5,07	6,08	1,35
5,08	6,09	1,41
5,09	6,10	1,46
5,10	6,11	1,52
5,11	6,12	1,57
5,12	6,13	1,63
5,13	6,14	1,68
5,14	6,15	1,74
5,15	6,16	1,79
5,16	6,17	1,85
5,17	6,18	1,90
5,18	6,19	1,96
5,19	6,20	2,01
5,20	6,21	2,07
5,21	6,22	2,12
5,22	6,23	2,18
5,23	6,24	2,23
5,24	6,25	2,29
5,25	6,26	2,34
5,26	6,27	2,40
5,27	6,28	2,45
5,28	6,29	2,51
5,29	6,30	2,56
5,30	6,31	2,61
5,31	6,32	2,67
5,32	6,33	2,72
5,33	6,34	2,78
5,34	6,35	2,83
5,35	6,36	2,88
5,36	6,37	2,94
5,37	6,38	2,99
5,38	6,39	3,05
5,39	6,40	3,10
5,40	6,41	3,15
5,41	6,42	3,21
5,42	6,43	3,26
5,43	6,44	3,31
5,44	6,45	3,37



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,45	6,46	3,42
5,46	6,47	3,47
5,47	6,48	3,53
5,48	6,49	3,58
5,49	6,50	3,63
5,50	6,51	3,69
5,51	6,52	3,74
5,52	6,53	3,79
5,53	6,54	3,84
5,54	6,55	3,90
5,55	6,56	3,95
5,56	6,57	4,00
5,57	6,58	4,05
5,58	6,59	4,11
5,59	6,60	4,16
5,60	6,61	4,21
5,61	6,62	4,26
5,62	6,63	4,32
5,63	6,64	4,37
5,64	6,65	4,42
5,65	6,66	4,47
5,66	6,67	4,52
5,67	6,68	4,58
5,68	6,69	4,63
5,69	6,70	4,68
5,70	6,71	4,73
5,71	6,72	4,78
5,72	6,73	4,84
5,73	6,74	4,89
5,74	6,75	4,94
5,75	6,76	4,99
5,76	6,77	5,04
5,77	6,78	5,09
5,78	6,79	5,14
5,79	6,80	5,20
5,80	6,81	5,25
5,81	6,82	5,30
5,82	6,83	5,35
5,83	6,84	5,40
5,84	6,85	5,45
5,85	6,86	5,50
5,86	6,87	5,55
5,87	6,88	5,60
5,88	6,89	5,65



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	5,71
5,90	6,91	5,76
5,91	6,92	5,81
5,92	6,93	5,86
5,93	6,94	5,91
5,94	6,95	5,96
5,95	6,96	6,01
5,96	6,97	6,06
5,97	6,98	6,11
5,98	6,99	6,16
5,99	7,00	6,21
6,00	7,01	6,26
6,01	7,02	6,31
6,02	7,03	6,36
6,03	7,04	6,41
6,04	7,05	6,46
6,05	7,06	6,51
6,06	7,07	6,56
6,07	7,08	6,61
6,08	7,09	6,66
6,09	7,10	6,71
6,10	7,11	6,76
6,11	7,12	6,81
6,12	7,13	6,86
6,13	7,14	6,91
6,14	7,15	6,96
6,15	7,16	7,01
6,16	7,17	7,06
6,17	7,18	7,10
6,18	7,19	7,15
6,19	7,20	7,20
6,20	7,21	7,25
6,21	7,22	7,30
6,22	7,23	7,35
6,23	7,24	7,40
6,24	7,25	7,45
6,25	7,26	7,50
6,26	7,27	7,55
6,27	7,28	7,59
6,28	7,29	7,64
6,29	7,30	7,69
6,30	7,31	7,74
6,31	7,32	7,79
6,32	7,33	7,84



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,33	7,34	7,89
6,34	7,35	7,93
6,35	7,36	7,98
6,36	7,37	8,03
6,37	7,38	8,08
6,38	7,39	8,13
6,39	7,40	8,18
6,40	7,41	8,22
6,41	7,42	8,27
6,42	7,43	8,32
6,43	7,44	8,37
6,44	7,45	8,42
6,45	7,46	8,46
6,46	7,47	8,51
6,47	7,48	8,56
6,48	7,49	8,61
6,49	7,50	8,65
6,50	7,51	8,70
6,51	7,52	8,75
6,52	7,53	8,80
6,53	7,54	8,85
6,54	7,55	8,89
6,55	7,56	8,94
6,56	7,57	8,99
6,57	7,58	9,03
6,58	7,59	9,08
6,59	7,60	9,13
6,60	7,61	9,18
6,61	7,62	9,22
6,62	7,63	9,27
6,63	7,64	9,32
6,64	7,65	9,37
6,65	7,66	9,41
6,66	7,67	9,46
6,67	7,68	9,51
6,68	7,69	9,55
6,69	7,70	9,60
6,70	7,71	9,65
6,71	7,72	9,69
6,72	7,73	9,74
6,73	7,74	9,79
6,74	7,75	9,83
6,75	7,76	9,88
6,76	7,77	9,93



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,77	7,78	9,97
6,78	7,79	10,02
6,79	7,80	10,07
6,80	7,81	10,11
6,81	7,82	10,16
6,82	7,83	10,20
6,83	7,84	10,25
6,84	7,85	10,30
6,85	7,86	10,34
6,86	7,87	10,39
6,87	7,88	10,43
6,88	7,89	10,48
6,89	7,90	10,53
6,90	7,91	10,57
6,91	7,92	10,62
6,92	7,93	10,66
6,93	7,94	10,71
6,94	7,95	10,76
6,95	7,96	10,80
6,96	7,97	10,85
6,97	7,98	10,89
6,98	7,99	10,94
6,99	8,00	10,98
7,00	8,01	11,03
7,01	8,02	11,07
7,02	8,03	11,12
7,03	8,04	11,16
7,04	8,05	11,21
7,05	8,06	11,26
7,06	8,07	11,30
7,07	8,08	11,35
7,08	8,09	11,39
7,09	8,10	11,44
7,10	8,11	11,48
7,11	8,12	11,53
7,12	8,13	11,57
7,13	8,14	11,62
7,14	8,15	11,66
7,15	8,16	11,71
7,16	8,17	11,75
7,17	8,18	11,79
7,18	8,19	11,84
7,19	8,20	11,88
7,20	8,21	11,93



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	11,97
7,22	8,23	12,02
7,23	8,24	12,06
7,24	8,25	12,11
7,25	8,26	12,15
7,26	8,27	12,20
7,27	8,28	12,24
7,28	8,29	12,28
7,29	8,30	12,33
7,30	8,31	12,37
7,31	8,32	12,42
7,32	8,33	12,46
7,33	8,34	12,51
7,34	8,35	12,55
7,35	8,36	12,59
7,36	8,37	12,64
7,37	8,38	12,68
7,38	8,39	12,73
7,39	8,40	12,77
7,40	8,41	12,81
7,41	8,42	12,86
7,42	8,43	12,90
7,43	8,44	12,94
7,44	8,45	12,99
7,45	8,46	13,03
7,46	8,47	13,08
7,47	8,48	13,12
7,48	8,49	13,16
7,49	8,50	13,21
7,50	8,51	13,25
7,51	8,52	13,29
7,52	8,53	13,34
7,53	8,54	13,38
7,54	8,55	13,42
7,55	8,56	13,47
7,56	8,57	13,51
7,57	8,58	13,55
7,58	8,59	13,60
7,59	8,60	13,64
7,60	8,61	13,68
7,61	8,62	13,73
7,62	8,63	13,77
7,63	8,64	13,81
7,64	8,65	13,85



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,65	8,66	13,90
7,66	8,67	13,94
7,67	8,68	13,98
7,68	8,69	14,03
7,69	8,70	14,07
7,70	8,71	14,11
7,71	8,72	14,15
7,72	8,73	14,20
7,73	8,74	14,24
7,74	8,75	14,28
7,75	8,76	14,32
7,76	8,77	14,37
7,77	8,78	14,41
7,78	8,79	14,45
7,79	8,80	14,49
7,80	8,81	14,54
7,81	8,82	14,58
7,82	8,83	14,62
7,83	8,84	14,66
7,84	8,85	14,71
7,85	8,86	14,75
7,86	8,87	14,79
7,87	8,88	14,83
7,88	8,89	14,87
7,89	8,90	14,92
7,90	8,91	14,96
7,91	8,92	15,00
7,92	8,93	15,04
7,93	8,94	15,08
7,94	8,95	15,13
7,95	8,96	15,17
7,96	8,97	15,21
7,97	8,98	15,25
7,98	8,99	15,29
7,99	9,00	15,34
8,00	9,01	15,38
8,01	9,02	15,42
8,02	9,03	15,46
8,03	9,04	15,50
8,04	9,05	15,54
8,05	9,06	15,59
8,06	9,07	15,63
8,07	9,08	15,67
8,08	9,09	15,71



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,09	9,10	15,75
8,10	9,11	15,79
8,11	9,12	15,83
8,12	9,13	15,88
8,13	9,14	15,92
8,14	9,15	15,96
8,15	9,16	16,00
8,16	9,17	16,04
8,17	9,18	16,08
8,18	9,19	16,12
8,19	9,20	16,16
8,20	9,21	16,20
8,21	9,22	16,25
8,22	9,23	16,29
8,23	9,24	16,33
8,24	9,25	16,37
8,25	9,26	16,41
8,26	9,27	16,45
8,27	9,28	16,49
8,28	9,29	16,53
8,29	9,30	16,57
8,30	9,31	16,61
8,31	9,32	16,65
8,32	9,33	16,69
8,33	9,34	16,73
8,34	9,35	16,78
8,35	9,36	16,82
8,36	9,37	16,86
8,37	9,38	16,90
8,38	9,39	16,94
8,39	9,40	16,98
8,40	9,41	17,02
8,41	9,42	17,06
8,42	9,43	17,10
8,43	9,44	17,14
8,44	9,45	17,18
8,45	9,46	17,22
8,46	9,47	17,26
8,47	9,48	17,30
8,48	9,49	17,34
8,49	9,50	17,38
8,50	9,51	17,42
8,51	9,52	17,46
8,52	9,53	17,50



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,53	9,54	17,54
8,54	9,55	17,58
8,55	9,56	17,62
8,56	9,57	17,66
8,57	9,58	17,70
8,58	9,59	17,74
8,59	9,60	17,78
8,60	9,61	17,82
8,61	9,62	17,86
8,62	9,63	17,90
8,63	9,64	17,94
8,64	9,65	17,98
8,65	9,66	18,02
8,66	9,67	18,06
8,67	9,68	18,10
8,68	9,69	18,14
8,69	9,70	18,18
8,70	9,71	18,22
8,71	9,72	18,25
8,72	9,73	18,29
8,73	9,74	18,33
8,74	9,75	18,37
8,75	9,76	18,41
8,76	9,77	18,45
8,77	9,78	18,49
8,78	9,79	18,53
8,79	9,80	18,57
8,80	9,81	18,61
8,81	9,82	18,65
8,82	9,83	18,69
8,83	9,84	18,73
8,84	9,85	18,76
8,85	9,86	18,80
8,86	9,87	18,84
8,87	9,88	18,88
8,88	9,89	18,92
8,89	9,90	18,96
8,90	9,91	19,00
8,91	9,92	19,04
8,92	9,93	19,08
8,93	9,94	19,11
8,94	9,95	19,15
8,95	9,96	19,19
8,96	9,97	19,23



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,97	9,98	19,27
8,98	9,99	19,31
8,99	10,00	19,35
9,00	10,01	19,39
9,01	10,02	19,42
9,02	10,03	19,46
9,03	10,04	19,50
9,04	10,05	19,54
9,05	10,06	19,58
9,06	10,07	19,62
9,07	10,08	19,65
9,08	10,09	19,69
9,09	10,10	19,73
9,10	10,11	19,77
9,11	10,12	19,81
9,12	10,13	19,85
9,13	10,14	19,88
9,14	10,15	19,92
9,15	10,16	19,96
9,16	10,17	20,00
9,17	10,18	20,04
9,18	10,19	20,08
9,19	10,20	20,11
9,20	10,21	20,15
9,21	10,22	20,19
9,22	10,23	20,23
9,23	10,24	20,27
9,24	10,25	20,30
9,25	10,26	20,34
9,26	10,27	20,38
9,27	10,28	20,42
9,28	10,29	20,45
9,29	10,30	20,49
9,30	10,31	20,53
9,31	10,32	20,57
9,32	10,33	20,61
9,33	10,34	20,64
9,34	10,35	20,68
9,35	10,36	20,72
9,36	10,37	20,76
9,37	10,38	20,79
9,38	10,39	20,83
9,39	10,40	20,87
9,40	10,41	20,91



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
9,41	10,42	20,94
9,42	10,43	20,98
9,43	10,44	21,02
9,44	10,45	21,06
9,45	10,46	21,09
9,46	10,47	21,13
9,47	10,48	21,17
9,48	10,49	21,21
9,49	10,50	21,24
9,50	10,51	21,28
9,51	10,52	21,32
9,52	10,53	21,35
9,53	10,54	21,39
9,54	10,55	21,43
9,55	10,56	21,47
9,56	10,57	21,50
9,57	10,58	21,54
9,58	10,59	21,58
9,59	10,60	21,61
9,60	10,61	21,65
9,61	10,62	21,69
9,62	10,63	21,73
9,63	10,64	21,76
9,64	10,65	21,80
9,65	10,66	21,84
9,66	10,67	21,87
9,67	10,68	21,91
9,68	10,69	21,95
9,69	10,70	21,98
9,70	10,71	22,02
9,71	10,72	22,06
9,72	10,73	22,09
9,73	10,74	22,13
9,74	10,75	22,17
9,75	10,76	22,20
9,76	10,77	22,24
9,77	10,78	22,28
9,78	10,79	22,31
9,79	10,80	22,35
9,80	10,81	22,39
9,81	10,82	22,42
9,82	10,83	22,46
9,83	10,84	22,49
9,84	10,85	22,53



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
9,85	10,86	22,57
9,86	10,87	22,60
9,87	10,88	22,64
9,88	10,89	22,68
9,89	10,90	22,71
9,90	10,91	22,75
9,91	10,92	22,79
9,92	10,93	22,82
9,93	10,94	22,86
9,94	10,95	22,89
9,95	10,96	22,93
9,96	10,97	22,97
9,97	10,98	23,00
9,98	10,99	23,04
9,99	11,00	23,07
10,00	11,01	23,11
10,01	11,02	23,15
10,02	11,03	23,18
10,03	11,04	23,22
10,04	11,05	23,25
10,05	11,06	23,29
10,06	11,07	23,33
10,07	11,08	23,36
10,08	11,09	23,40
10,09	11,10	23,43
10,10	11,11	23,47
10,11	11,12	23,50
10,12	11,13	23,54
10,13	11,14	23,58
10,14	11,15	23,61
10,15	11,16	23,65
10,16	11,17	23,68
10,17	11,18	23,72
10,18	11,19	23,75
10,19	11,20	23,79
10,20	11,21	23,82
10,21	11,22	23,86
10,22	11,23	23,90
10,23	11,24	23,93
10,24	11,25	23,97
10,25	11,26	24,00
10,26	11,27	24,04
10,27	11,28	24,07
10,28	11,29	24,11



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,29	11,30	24,14
10,30	11,31	24,18
10,31	11,32	24,21
10,32	11,33	24,25
10,33	11,34	24,28
10,34	11,35	24,32
10,35	11,36	24,36
10,36	11,37	24,39
10,37	11,38	24,43
10,38	11,39	24,46
10,39	11,40	24,50
10,40	11,41	24,53
10,41	11,42	24,57
10,42	11,43	24,60
10,43	11,44	24,64
10,44	11,45	24,67
10,45	11,46	24,71
10,46	11,47	24,74
10,47	11,48	24,78
10,48	11,49	24,81
10,49	11,50	24,85
10,50	11,51	24,88
10,51	11,52	24,91
10,52	11,53	24,95
10,53	11,54	24,98
10,54	11,55	25,02
10,55	11,56	25,05
10,56	11,57	25,09
10,57	11,58	25,12
10,58	11,59	25,16
10,59	11,60	25,19
10,60	11,61	25,23
10,61	11,62	25,26
10,62	11,63	25,30
10,63	11,64	25,33
10,64	11,65	25,37
10,65	11,66	25,40
10,66	11,67	25,43
10,67	11,68	25,47
10,68	11,69	25,50
10,69	11,70	25,54
10,70	11,71	25,57
10,71	11,72	25,61
10,72	11,73	25,64



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	25,68
10,74	11,75	25,71
10,75	11,76	25,74
10,76	11,77	25,78
10,77	11,78	25,81
10,78	11,79	25,85
10,79	11,80	25,88
10,80	11,81	25,92
10,81	11,82	25,95
10,82	11,83	25,98
10,83	11,84	26,02
10,84	11,85	26,05
10,85	11,86	26,09
10,86	11,87	26,12
10,87	11,88	26,15
10,88	11,89	26,19
10,89	11,90	26,22
10,90	11,91	26,26
10,91	11,92	26,29
10,92	11,93	26,32
10,93	11,94	26,36
10,94	11,95	26,39
10,95	11,96	26,43
10,96	11,97	26,46
10,97	11,98	26,49
10,98	11,99	26,53
10,99	12,00	26,56
11,00	12,01	26,59
11,01	12,02	26,63
11,02	12,03	26,66
11,03	12,04	26,70
11,04	12,05	26,73
11,05	12,06	26,76
11,06	12,07	26,80
11,07	12,08	26,83
11,08	12,09	26,86
11,09	12,10	26,90
11,10	12,11	26,93
11,11	12,12	26,96
11,12	12,13	27,00
11,13	12,14	27,03
11,14	12,15	27,07
11,15	12,16	27,10
11,16	12,17	27,13



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
11,17	12,18	27,17
11,18	12,19	27,20
11,19	12,20	27,23
11,20	12,21	27,27
11,21	12,22	27,30
11,22	12,23	27,33
11,23	12,24	27,37
11,24	12,25	27,40
11,25	12,26	27,43
11,26	12,27	27,47
11,27	12,28	27,50
11,28	12,29	27,53
11,29	12,30	27,57
11,30	12,31	27,60
11,31	12,32	27,63
11,32	12,33	27,66
11,33	12,34	27,70
11,34	12,35	27,73
11,35	12,36	27,76
11,36	12,37	27,80
11,37	12,38	27,83
11,38	12,39	27,86
11,39	12,40	27,90
11,40	12,41	27,93
11,41	12,42	27,96
11,42	12,43	28,00
11,43	12,44	28,03
11,44	12,45	28,06
11,45	12,46	28,09
11,46	12,47	28,13
11,47	12,48	28,16
11,48	12,49	28,19
11,49	12,50	28,23
11,50	12,51	28,26
11,51	12,52	28,29
11,52	12,53	28,32
11,53	12,54	28,36
11,54	12,55	28,39
11,55	12,56	28,42
11,56	12,57	28,45
11,57	12,58	28,49
11,58	12,59	28,52
11,59	12,60	28,55
11,60	12,61	28,58



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	28,62
11,62	12,63	28,65
11,63	12,64	28,68
11,64	12,65	28,71
11,65	12,66	28,75
11,66	12,67	28,78
11,67	12,68	28,81
11,68	12,69	28,84
11,69	12,70	28,88
11,70	12,71	28,91
11,71	12,72	28,94
11,72	12,73	28,97
11,73	12,74	29,01
11,74	12,75	29,04
11,75	12,76	29,07
11,76	12,77	29,10
11,77	12,78	29,14
11,78	12,79	29,17
11,79	12,80	29,20
11,80	12,81	29,23
11,81	12,82	29,26
11,82	12,83	29,30
11,83	12,84	29,33
11,84	12,85	29,36
11,85	12,86	29,39
11,86	12,87	29,43
11,87	12,88	29,46
11,88	12,89	29,49
11,89	12,90	29,52
11,90	12,91	29,55
11,91	12,92	29,59
11,92	12,93	29,62
11,93	12,94	29,65
11,94	12,95	29,68
11,95	12,96	29,71
11,96	12,97	29,75
11,97	12,98	29,78
11,98	12,99	29,81
11,99	13,00	29,84
12,00	13,01	29,87
12,01	13,02	29,91
12,02	13,03	29,94
12,03	13,04	29,97
12,04	13,05	30,00



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,05	13,06	30,03
12,06	13,07	30,06
12,07	13,08	30,10
12,08	13,09	30,13
12,09	13,10	30,16
12,10	13,11	30,19
12,11	13,12	30,22
12,12	13,13	30,25
12,13	13,14	30,29
12,14	13,15	30,32
12,15	13,16	30,35
12,16	13,17	30,38
12,17	13,18	30,41
12,18	13,19	30,44
12,19	13,20	30,48
12,20	13,21	30,51
12,21	13,22	30,54
12,22	13,23	30,57
12,23	13,24	30,60
12,24	13,25	30,63
12,25	13,26	30,66
12,26	13,27	30,70
12,27	13,28	30,73
12,28	13,29	30,76
12,29	13,30	30,79
12,30	13,31	30,82
12,31	13,32	30,85
12,32	13,33	30,88
12,33	13,34	30,91
12,34	13,35	30,95
12,35	13,36	30,98
12,36	13,37	31,01
12,37	13,38	31,04
12,38	13,39	31,07
12,39	13,40	31,10
12,40	13,41	31,13
12,41	13,42	31,16
12,42	13,43	31,20
12,43	13,44	31,23
12,44	13,45	31,26
12,45	13,46	31,29
12,46	13,47	31,32
12,47	13,48	31,35
12,48	13,49	31,38



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	31,41
12,50	13,51	31,44
12,51	13,52	31,47
12,52	13,53	31,51
12,53	13,54	31,54
12,54	13,55	31,57
12,55	13,56	31,60
12,56	13,57	31,63
12,57	13,58	31,66
12,58	13,59	31,69
12,59	13,60	31,72
12,60	13,61	31,75
12,61	13,62	31,78
12,62	13,63	31,81
12,63	13,64	31,85
12,64	13,65	31,88
12,65	13,66	31,91
12,66	13,67	31,94
12,67	13,68	31,97
12,68	13,69	32,00
12,69	13,70	32,03
12,70	13,71	32,06
12,71	13,72	32,09
12,72	13,73	32,12
12,73	13,74	32,15
12,74	13,75	32,18
12,75	13,76	32,21
12,76	13,77	32,24
12,77	13,78	32,27
12,78	13,79	32,30
12,79	13,80	32,34
12,80	13,81	32,37
12,81	13,82	32,40
12,82	13,83	32,43
12,83	13,84	32,46
12,84	13,85	32,49
12,85	13,86	32,52
12,86	13,87	32,55
12,87	13,88	32,58
12,88	13,89	32,61
12,89	13,90	32,64
12,90	13,91	32,67
12,91	13,92	32,70
12,92	13,93	32,73



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	32,76
12,94	13,95	32,79
12,95	13,96	32,82
12,96	13,97	32,85
12,97	13,98	32,88
12,98	13,99	32,91
12,99	14,00	32,94
13,00	14,01	32,97
13,01	14,02	33,00
13,02	14,03	33,03
13,03	14,04	33,06
13,04	14,05	33,09
13,05	14,06	33,12
13,06	14,07	33,15
13,07	14,08	33,18
13,08	14,09	33,21
13,09	14,10	33,24
13,10	14,11	33,27
13,11	14,12	33,30
13,12	14,13	33,33
13,13	14,14	33,36
13,14	14,15	33,39
13,15	14,16	33,42
13,16	14,17	33,45
13,17	14,18	33,48
13,18	14,19	33,51
13,19	14,20	33,54
13,20	14,21	33,57
13,21	14,22	33,60
13,22	14,23	33,63
13,23	14,24	33,66
13,24	14,25	33,69
13,25	14,26	33,72
13,26	14,27	33,75
13,27	14,28	33,78
13,28	14,29	33,81
13,29	14,30	33,84
13,30	14,31	33,87
13,31	14,32	33,90
13,32	14,33	33,93
13,33	14,34	33,96
13,34	14,35	33,99
13,35	14,36	34,02
13,36	14,37	34,05



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,37	14,38	34,08
13,38	14,39	34,11
13,39	14,40	34,14
13,40	14,41	34,17
13,41	14,42	34,20
13,42	14,43	34,23
13,43	14,44	34,26
13,44	14,45	34,29
13,45	14,46	34,31
13,46	14,47	34,34
13,47	14,48	34,37
13,48	14,49	34,40
13,49	14,50	34,43
13,50	14,51	34,46
13,51	14,52	34,49
13,52	14,53	34,52
13,53	14,54	34,55
13,54	14,55	34,58
13,55	14,56	34,61
13,56	14,57	34,64
13,57	14,58	34,67
13,58	14,59	34,70
13,59	14,60	34,73
13,60	14,61	34,76
13,61	14,62	34,78
13,62	14,63	34,81
13,63	14,64	34,84
13,64	14,65	34,87
13,65	14,66	34,90
13,66	14,67	34,93
13,67	14,68	34,96
13,68	14,69	34,99
13,69	14,70	35,02
13,70	14,71	35,05
13,71	14,72	35,08
13,72	14,73	35,11
13,73	14,74	35,13
13,74	14,75	35,16
13,75	14,76	35,19
13,76	14,77	35,22
13,77	14,78	35,25
13,78	14,79	35,28
13,79	14,80	35,31
13,80	14,81	35,34



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,81	14,82	35,37
13,82	14,83	35,40
13,83	14,84	35,42
13,84	14,85	35,45
13,85	14,86	35,48
13,86	14,87	35,51
13,87	14,88	35,54
13,88	14,89	35,57
13,89	14,90	35,60
13,90	14,91	35,63
13,91	14,92	35,66
13,92	14,93	35,68
13,93	14,94	35,71
13,94	14,95	35,74
13,95	14,96	35,77
13,96	14,97	35,80
13,97	14,98	35,83
13,98	14,99	35,86
13,99	15,00	35,89
14,00	15,01	35,91
14,01	15,02	35,94
14,02	15,03	35,97
14,03	15,04	36,00
14,04	15,05	36,03
14,05	15,06	36,06
14,06	15,07	36,09
14,07	15,08	36,11
14,08	15,09	36,14
14,09	15,10	36,17
14,10	15,11	36,20
14,11	15,12	36,23
14,12	15,13	36,26
14,13	15,14	36,29
14,14	15,15	36,31
14,15	15,16	36,34
14,16	15,17	36,37
14,17	15,18	36,40
14,18	15,19	36,43
14,19	15,20	36,46
14,20	15,21	36,49
14,21	15,22	36,51
14,22	15,23	36,54
14,23	15,24	36,57
14,24	15,25	36,60



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
14,25	15,26	36,63
14,26	15,27	36,66
14,27	15,28	36,68
14,28	15,29	36,71
14,29	15,30	36,74
14,30	15,31	36,77
14,31	15,32	36,80
14,32	15,33	36,83
14,33	15,34	36,85
14,34	15,35	36,88
14,35	15,36	36,91
14,36	15,37	36,94
14,37	15,38	36,97
14,38	15,39	36,99
14,39	15,40	37,02
14,40	15,41	37,05
14,41	15,42	37,08
14,42	15,43	37,11
14,43	15,44	37,14
14,44	15,45	37,16
14,45	15,46	37,19
14,46	15,47	37,22
14,47	15,48	37,25
14,48	15,49	37,28
14,49	15,50	37,30
14,50	15,51	37,33
14,51	15,52	37,36
14,52	15,53	37,39
14,53	15,54	37,42
14,54	15,55	37,44
14,55	15,56	37,47
14,56	15,57	37,50
14,57	15,58	37,53
14,58	15,59	37,56
14,59	15,60	37,58
14,60	15,61	37,61
14,61	15,62	37,64
14,62	15,63	37,67
14,63	15,64	37,69
14,64	15,65	37,72
14,65	15,66	37,75
14,66	15,67	37,78
14,67	15,68	37,81
14,68	15,69	37,83



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	37,86
14,70	15,71	37,89
14,71	15,72	37,92
14,72	15,73	37,94
14,73	15,74	37,97
14,74	15,75	38,00
14,75	15,76	38,03
14,76	15,77	38,06
14,77	15,78	38,08
14,78	15,79	38,11
14,79	15,80	38,14
14,80	15,81	38,17
14,81	15,82	38,19
14,82	15,83	38,22
14,83	15,84	38,25
14,84	15,85	38,28
14,85	15,86	38,30
14,86	15,87	38,33
14,87	15,88	38,36
14,88	15,89	38,39
14,89	15,90	38,41
14,90	15,91	38,44
14,91	15,92	38,47
14,92	15,93	38,50
14,93	15,94	38,52
14,94	15,95	38,55
14,95	15,96	38,58
14,96	15,97	38,61
14,97	15,98	38,63
14,98	15,99	38,66
14,99	16,00	38,69
15,00	16,01	38,72
15,01	16,02	38,74
15,02	16,03	38,77
15,03	16,04	38,80
15,04	16,05	38,83
15,05	16,06	38,85
15,06	16,07	38,88
15,07	16,08	38,91
15,08	16,09	38,93
15,09	16,10	38,96
15,10	16,11	38,99
15,11	16,12	39,02
15,12	16,13	39,04



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	39,07
15,14	16,15	39,10
15,15	16,16	39,12
15,16	16,17	39,15
15,17	16,18	39,18
15,18	16,19	39,21
15,19	16,20	39,23
15,20	16,21	39,26
15,21	16,22	39,29
15,22	16,23	39,31
15,23	16,24	39,34
15,24	16,25	39,37
15,25	16,26	39,40
15,26	16,27	39,42
15,27	16,28	39,45
15,28	16,29	39,48
15,29	16,30	39,50
15,30	16,31	39,53
15,31	16,32	39,56
15,32	16,33	39,59
15,33	16,34	39,61
15,34	16,35	39,64
15,35	16,36	39,67
15,36	16,37	39,69
15,37	16,38	39,72
15,38	16,39	39,75
15,39	16,40	39,77
15,40	16,41	39,80
15,41	16,42	39,83
15,42	16,43	39,85
15,43	16,44	39,88
15,44	16,45	39,91
15,45	16,46	39,93
15,46	16,47	39,96
15,47	16,48	39,99
15,48	16,49	40,02
15,49	16,50	40,04
15,50	16,51	40,07
15,51	16,52	40,10
15,52	16,53	40,12
15,53	16,54	40,15
15,54	16,55	40,18
15,55	16,56	40,20
15,56	16,57	40,23



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,57	16,58	40,26
15,58	16,59	40,28
15,59	16,60	40,31
15,60	16,61	40,34
15,61	16,62	40,36
15,62	16,63	40,39
15,63	16,64	40,42
15,64	16,65	40,44
15,65	16,66	40,47
15,66	16,67	40,50
15,67	16,68	40,52
15,68	16,69	40,55
15,69	16,70	40,58
15,70	16,71	40,60
15,71	16,72	40,63
15,72	16,73	40,65
15,73	16,74	40,68
15,74	16,75	40,71
15,75	16,76	40,73
15,76	16,77	40,76
15,77	16,78	40,79
15,78	16,79	40,81
15,79	16,80	40,84
15,80	16,81	40,87
15,81	16,82	40,89
15,82	16,83	40,92
15,83	16,84	40,95
15,84	16,85	40,97
15,85	16,86	41,00
15,86	16,87	41,02
15,87	16,88	41,05
15,88	16,89	41,08
15,89	16,90	41,10
15,90	16,91	41,13
15,91	16,92	41,16
15,92	16,93	41,18
15,93	16,94	41,21
15,94	16,95	41,23
15,95	16,96	41,26
15,96	16,97	41,29
15,97	16,98	41,31
15,98	16,99	41,34
15,99	17,00	41,37
16,00	17,01	41,39



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	41,42
16,02	17,03	41,44
16,03	17,04	41,47
16,04	17,05	41,50
16,05	17,06	41,52
16,06	17,07	41,55
16,07	17,08	41,58
16,08	17,09	41,60
16,09	17,10	41,63
16,10	17,11	41,65
16,11	17,12	41,68
16,12	17,13	41,71
16,13	17,14	41,73
16,14	17,15	41,76
16,15	17,16	41,78
16,16	17,17	41,81
16,17	17,18	41,84
16,18	17,19	41,86
16,19	17,20	41,89
16,20	17,21	41,91
16,21	17,22	41,94
16,22	17,23	41,97
16,23	17,24	41,99
16,24	17,25	42,02
16,25	17,26	42,04
16,26	17,27	42,07
16,27	17,28	42,09
16,28	17,29	42,12
16,29	17,30	42,15
16,30	17,31	42,17
16,31	17,32	42,20
16,32	17,33	42,22
16,33	17,34	42,25
16,34	17,35	42,28
16,35	17,36	42,30
16,36	17,37	42,33
16,37	17,38	42,35
16,38	17,39	42,38
16,39	17,40	42,40
16,40	17,41	42,43
16,41	17,42	42,46
16,42	17,43	42,48
16,43	17,44	42,51
16,44	17,45	42,53



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
16,45	17,46	42,56
16,46	17,47	42,58
16,47	17,48	42,61
16,48	17,49	42,64
16,49	17,50	42,66
16,50	17,51	42,69
16,51	17,52	42,71
16,52	17,53	42,74
16,53	17,54	42,76
16,54	17,55	42,79
16,55	17,56	42,82
16,56	17,57	42,84
16,57	17,58	42,87
16,58	17,59	42,89
16,59	17,60	42,92
16,60	17,61	42,94
16,61	17,62	42,97
16,62	17,63	42,99
16,63	17,64	43,02
16,64	17,65	43,05
16,65	17,66	43,07
16,66	17,67	43,10
16,67	17,68	43,12
16,68	17,69	43,15
16,69	17,70	43,17
16,70	17,71	43,20
16,71	17,72	43,22
16,72	17,73	43,25
16,73	17,74	43,27
16,74	17,75	43,30
16,75	17,76	43,32
16,76	17,77	43,35
16,77	17,78	43,38
16,78	17,79	43,40
16,79	17,80	43,43
16,80	17,81	43,45
16,81	17,82	43,48
16,82	17,83	43,50
16,83	17,84	43,53
16,84	17,85	43,55
16,85	17,86	43,58
16,86	17,87	43,60
16,87	17,88	43,63
16,88	17,89	43,65



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	43,68
16,90	17,91	43,70
16,91	17,92	43,73
16,92	17,93	43,75
16,93	17,94	43,78
16,94	17,95	43,80
16,95	17,96	43,83
16,96	17,97	43,86
16,97	17,98	43,88
16,98	17,99	43,91
16,99	18,00	43,93
17,00	18,01	43,96
17,01	18,02	43,98
17,02	18,03	44,01
17,03	18,04	44,03
17,04	18,05	44,06
17,05	18,06	44,08
17,06	18,07	44,11
17,07	18,08	44,13
17,08	18,09	44,16
17,09	18,10	44,18
17,10	18,11	44,21
17,11	18,12	44,23
17,12	18,13	44,26
17,13	18,14	44,28
17,14	18,15	44,31
17,15	18,16	44,33
17,16	18,17	44,36
17,17	18,18	44,38
17,18	18,19	44,41
17,19	18,20	44,43
17,20	18,21	44,46
17,21	18,22	44,48
17,22	18,23	44,51
17,23	18,24	44,53
17,24	18,25	44,56
17,25	18,26	44,58
17,26	18,27	44,60
17,27	18,28	44,63
17,28	18,29	44,65
17,29	18,30	44,68
17,30	18,31	44,70
17,31	18,32	44,73
17,32	18,33	44,75



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	44,78
17,34	18,35	44,80
17,35	18,36	44,83
17,36	18,37	44,85
17,37	18,38	44,88
17,38	18,39	44,90
17,39	18,40	44,93
17,40	18,41	44,95
17,41	18,42	44,98
17,42	18,43	45,00
17,43	18,44	45,03
17,44	18,45	45,05
17,45	18,46	45,08
17,46	18,47	45,10
17,47	18,48	45,12
17,48	18,49	45,15
17,49	18,50	45,17
17,50	18,51	45,20
17,51	18,52	45,22
17,52	18,53	45,25
17,53	18,54	45,27
17,54	18,55	45,30
17,55	18,56	45,32
17,56	18,57	45,35
17,57	18,58	45,37
17,58	18,59	45,39
17,59	18,60	45,42
17,60	18,61	45,44
17,61	18,62	45,47
17,62	18,63	45,49
17,63	18,64	45,52
17,64	18,65	45,54
17,65	18,66	45,57
17,66	18,67	45,59
17,67	18,68	45,62
17,68	18,69	45,64
17,69	18,70	45,66
17,70	18,71	45,69
17,71	18,72	45,71
17,72	18,73	45,74
17,73	18,74	45,76
17,74	18,75	45,79
17,75	18,76	45,81
17,76	18,77	45,83



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,77	18,78	45,86
17,78	18,79	45,88
17,79	18,80	45,91
17,80	18,81	45,93
17,81	18,82	45,96
17,82	18,83	45,98
17,83	18,84	46,01
17,84	18,85	46,03
17,85	18,86	46,05
17,86	18,87	46,08
17,87	18,88	46,10
17,88	18,89	46,13
17,89	18,90	46,15
17,90	18,91	46,18
17,91	18,92	46,20
17,92	18,93	46,22
17,93	18,94	46,25
17,94	18,95	46,27
17,95	18,96	46,30
17,96	18,97	46,32
17,97	18,98	46,34
17,98	18,99	46,37
17,99	19,00	46,39
18,00	19,01	46,42
18,01	19,02	46,44
18,02	19,03	46,47
18,03	19,04	46,49
18,04	19,05	46,51
18,05	19,06	46,54
18,06	19,07	46,56
18,07	19,08	46,59
18,08	19,09	46,61
18,09	19,10	46,63
18,10	19,11	46,66
18,11	19,12	46,68
18,12	19,13	46,71
18,13	19,14	46,73
18,14	19,15	46,75
18,15	19,16	46,78
18,16	19,17	46,80
18,17	19,18	46,83
18,18	19,19	46,85
18,19	19,20	46,87
18,20	19,21	46,90



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,21	19,22	46,92
18,22	19,23	46,95
18,23	19,24	46,97
18,24	19,25	46,99
18,25	19,26	47,02
18,26	19,27	47,04
18,27	19,28	47,06
18,28	19,29	47,09
18,29	19,30	47,11
18,30	19,31	47,14
18,31	19,32	47,16
18,32	19,33	47,18
18,33	19,34	47,21
18,34	19,35	47,23
18,35	19,36	47,26
18,36	19,37	47,28
18,37	19,38	47,30
18,38	19,39	47,33
18,39	19,40	47,35
18,40	19,41	47,37
18,41	19,42	47,40
18,42	19,43	47,42
18,43	19,44	47,45
18,44	19,45	47,47
18,45	19,46	47,49
18,46	19,47	47,52
18,47	19,48	47,54
18,48	19,49	47,56
18,49	19,50	47,59
18,50	19,51	47,61
18,51	19,52	47,64
18,52	19,53	47,66
18,53	19,54	47,68
18,54	19,55	47,71
18,55	19,56	47,73
18,56	19,57	47,75
18,57	19,58	47,78
18,58	19,59	47,80
18,59	19,60	47,82
18,60	19,61	47,85
18,61	19,62	47,87
18,62	19,63	47,90
18,63	19,64	47,92
18,64	19,65	47,94



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,65	19,66	47,97
18,66	19,67	47,99
18,67	19,68	48,01
18,68	19,69	48,04
18,69	19,70	48,06
18,70	19,71	48,08
18,71	19,72	48,11
18,72	19,73	48,13
18,73	19,74	48,15
18,74	19,75	48,18
18,75	19,76	48,20
18,76	19,77	48,22
18,77	19,78	48,25
18,78	19,79	48,27
18,79	19,80	48,29
18,80	19,81	48,32
18,81	19,82	48,34
18,82	19,83	48,36
18,83	19,84	48,39
18,84	19,85	48,41
18,85	19,86	48,44
18,86	19,87	48,46
18,87	19,88	48,48
18,88	19,89	48,51
18,89	19,90	48,53
18,90	19,91	48,55
18,91	19,92	48,58
18,92	19,93	48,60
18,93	19,94	48,62
18,94	19,95	48,65
18,95	19,96	48,67
18,96	19,97	48,69
18,97	19,98	48,71
18,98	19,99	48,74
18,99	20,00	48,76
19,00	20,01	48,78
19,01	20,02	48,81
19,02	20,03	48,83
19,03	20,04	48,85
19,04	20,05	48,88
19,05	20,06	48,90
19,06	20,07	48,92
19,07	20,08	48,95
19,08	20,09	48,97



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,09	20,10	48,99
19,10	20,11	49,02
19,11	20,12	49,04
19,12	20,13	49,06
19,13	20,14	49,09
19,14	20,15	49,11
19,15	20,16	49,13
19,16	20,17	49,16
19,17	20,18	49,18
19,18	20,19	49,20
19,19	20,20	49,22
19,20	20,21	49,25
19,21	20,22	49,27
19,22	20,23	49,29
19,23	20,24	49,32
19,24	20,25	49,34
19,25	20,26	49,36
19,26	20,27	49,39
19,27	20,28	49,41
19,28	20,29	49,43
19,29	20,30	49,45
19,30	20,31	49,48
19,31	20,32	49,50
19,32	20,33	49,52
19,33	20,34	49,55
19,34	20,35	49,57
19,35	20,36	49,59
19,36	20,37	49,62
19,37	20,38	49,64
19,38	20,39	49,66
19,39	20,40	49,68
19,40	20,41	49,71
19,41	20,42	49,73
19,42	20,43	49,75
19,43	20,44	49,78
19,44	20,45	49,80
19,45	20,46	49,82
19,46	20,47	49,84
19,47	20,48	49,87
19,48	20,49	49,89
19,49	20,50	49,91
19,50	20,51	49,94
19,51	20,52	49,96
19,52	20,53	49,98



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,53	20,54	50,00
19,54	20,55	50,03
19,55	20,56	50,05
19,56	20,57	50,07
19,57	20,58	50,10
19,58	20,59	50,12
19,59	20,60	50,14
19,60	20,61	50,16
19,61	20,62	50,19
19,62	20,63	50,21
19,63	20,64	50,23
19,64	20,65	50,25
19,65	20,66	50,28
19,66	20,67	50,30
19,67	20,68	50,32
19,68	20,69	50,35
19,69	20,70	50,37
19,70	20,71	50,39
19,71	20,72	50,41
19,72	20,73	50,44
19,73	20,74	50,46
19,74	20,75	50,48
19,75	20,76	50,50
19,76	20,77	50,53
19,77	20,78	50,55
19,78	20,79	50,57
19,79	20,80	50,59
19,80	20,81	50,62
19,81	20,82	50,64
19,82	20,83	50,66
19,83	20,84	50,68
19,84	20,85	50,71
19,85	20,86	50,73
19,86	20,87	50,75
19,87	20,88	50,77
19,88	20,89	50,80
19,89	20,90	50,82
19,90	20,91	50,84
19,91	20,92	50,86
19,92	20,93	50,89
19,93	20,94	50,91
19,94	20,95	50,93
19,95	20,96	50,95
19,96	20,97	50,98



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,97	20,98	51,00
19,98	20,99	51,02
19,99	21,00	51,04
20,00	21,01	51,07
20,01	21,02	51,09
20,02	21,03	51,11
20,03	21,04	51,13
20,04	21,05	51,16
20,05	21,06	51,18
20,06	21,07	51,20
20,07	21,08	51,22
20,08	21,09	51,25
20,09	21,10	51,27
20,10	21,11	51,29
20,11	21,12	51,31
20,12	21,13	51,34
20,13	21,14	51,36
20,14	21,15	51,38
20,15	21,16	51,40
20,16	21,17	51,42
20,17	21,18	51,45
20,18	21,19	51,47
20,19	21,20	51,49
20,20	21,21	51,51
20,21	21,22	51,54
20,22	21,23	51,56
20,23	21,24	51,58
20,24	21,25	51,60
20,25	21,26	51,62
20,26	21,27	51,65
20,27	21,28	51,67
20,28	21,29	51,69
20,29	21,30	51,71
20,30	21,31	51,74
20,31	21,32	51,76
20,32	21,33	51,78
20,33	21,34	51,80
20,34	21,35	51,82
20,35	21,36	51,85
20,36	21,37	51,87
20,37	21,38	51,89
20,38	21,39	51,91
20,39	21,40	51,94
20,40	21,41	51,96



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,41	21,42	51,98
20,42	21,43	52,00
20,43	21,44	52,02
20,44	21,45	52,05
20,45	21,46	52,07
20,46	21,47	52,09
20,47	21,48	52,11
20,48	21,49	52,13
20,49	21,50	52,16
20,50	21,51	52,18
20,51	21,52	52,20
20,52	21,53	52,22
20,53	21,54	52,24
20,54	21,55	52,27
20,55	21,56	52,29
20,56	21,57	52,31
20,57	21,58	52,33
20,58	21,59	52,35
20,59	21,60	52,38
20,60	21,61	52,40
20,61	21,62	52,42
20,62	21,63	52,44
20,63	21,64	52,46
20,64	21,65	52,49
20,65	21,66	52,51
20,66	21,67	52,53
20,67	21,68	52,55
20,68	21,69	52,57
20,69	21,70	52,60
20,70	21,71	52,62
20,71	21,72	52,64
20,72	21,73	52,66
20,73	21,74	52,68
20,74	21,75	52,70
20,75	21,76	52,73
20,76	21,77	52,75
20,77	21,78	52,77
20,78	21,79	52,79
20,79	21,80	52,81
20,80	21,81	52,84
20,81	21,82	52,86
20,82	21,83	52,88
20,83	21,84	52,90
20,84	21,85	52,92



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	52,94
20,86	21,87	52,97
20,87	21,88	52,99
20,88	21,89	53,01
20,89	21,90	53,03
20,90	21,91	53,05
20,91	21,92	53,08
20,92	21,93	53,10
20,93	21,94	53,12
20,94	21,95	53,14
20,95	21,96	53,16
20,96	21,97	53,18
20,97	21,98	53,21
20,98	21,99	53,23
20,99	22,00	53,25
21,00	22,01	53,27
21,01	22,02	53,29
21,02	22,03	53,31
21,03	22,04	53,34
21,04	22,05	53,36
21,05	22,06	53,38
21,06	22,07	53,40
21,07	22,08	53,42
21,08	22,09	53,44
21,09	22,10	53,47
21,10	22,11	53,49
21,11	22,12	53,51
21,12	22,13	53,53
21,13	22,14	53,55
21,14	22,15	53,57
21,15	22,16	53,59
21,16	22,17	53,62
21,17	22,18	53,64
21,18	22,19	53,66
21,19	22,20	53,68
21,20	22,21	53,70
21,21	22,22	53,72
21,22	22,23	53,75
21,23	22,24	53,77
21,24	22,25	53,79
21,25	22,26	53,81
21,26	22,27	53,83
21,27	22,28	53,85
21,28	22,29	53,87



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
21,29	22,30	53,90
21,30	22,31	53,92
21,31	22,32	53,94
21,32	22,33	53,96
21,33	22,34	53,98
21,34	22,35	54,00
21,35	22,36	54,02
21,36	22,37	54,05
21,37	22,38	54,07
21,38	22,39	54,09
21,39	22,40	54,11
21,40	22,41	54,13
21,41	22,42	54,15
21,42	22,43	54,17
21,43	22,44	54,20
21,44	22,45	54,22
21,45	22,46	54,24
21,46	22,47	54,26
21,47	22,48	54,28
21,48	22,49	54,30
21,49	22,50	54,32
21,50	22,51	54,34
21,51	22,52	54,37
21,52	22,53	54,39
21,53	22,54	54,41
21,54	22,55	54,43
21,55	22,56	54,45
21,56	22,57	54,47
21,57	22,58	54,49
21,58	22,59	54,51
21,59	22,60	54,54
21,60	22,61	54,56
21,61	22,62	54,58
21,62	22,63	54,60
21,63	22,64	54,62
21,64	22,65	54,64
21,65	22,66	54,66
21,66	22,67	54,68
21,67	22,68	54,71
21,68	22,69	54,73
21,69	22,70	54,75
21,70	22,71	54,77
21,71	22,72	54,79
21,72	22,73	54,81



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	54,83
21,74	22,75	54,85
21,75	22,76	54,88
21,76	22,77	54,90
21,77	22,78	54,92
21,78	22,79	54,94
21,79	22,80	54,96
21,80	22,81	54,98
21,81	22,82	55,00
21,82	22,83	55,02
21,83	22,84	55,04
21,84	22,85	55,07
21,85	22,86	55,09
21,86	22,87	55,11
21,87	22,88	55,13
21,88	22,89	55,15
21,89	22,90	55,17
21,90	22,91	55,19
21,91	22,92	55,21
21,92	22,93	55,23
21,93	22,94	55,25
21,94	22,95	55,28
21,95	22,96	55,30
21,96	22,97	55,32
21,97	22,98	55,34
21,98	22,99	55,36
21,99	23,00	55,38
22,00	23,01	55,40
22,01	23,02	55,42
22,02	23,03	55,44
22,03	23,04	55,46
22,04	23,05	55,49
22,05	23,06	55,51
22,06	23,07	55,53
22,07	23,08	55,55
22,08	23,09	55,57
22,09	23,10	55,59
22,10	23,11	55,61
22,11	23,12	55,63
22,12	23,13	55,65
22,13	23,14	55,67
22,14	23,15	55,69
22,15	23,16	55,71
22,16	23,17	55,74



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,17	23,18	55,76
22,18	23,19	55,78
22,19	23,20	55,80
22,20	23,21	55,82
22,21	23,22	55,84
22,22	23,23	55,86
22,23	23,24	55,88
22,24	23,25	55,90
22,25	23,26	55,92
22,26	23,27	55,94
22,27	23,28	55,96
22,28	23,29	55,99
22,29	23,30	56,01
22,30	23,31	56,03
22,31	23,32	56,05
22,32	23,33	56,07
22,33	23,34	56,09
22,34	23,35	56,11
22,35	23,36	56,13
22,36	23,37	56,15
22,37	23,38	56,17
22,38	23,39	56,19
22,39	23,40	56,21
22,40	23,41	56,23
22,41	23,42	56,26
22,42	23,43	56,28
22,43	23,44	56,30
22,44	23,45	56,32
22,45	23,46	56,34
22,46	23,47	56,36
22,47	23,48	56,38
22,48	23,49	56,40
22,49	23,50	56,42
22,50	23,51	56,44
22,51	23,52	56,46
22,52	23,53	56,48
22,53	23,54	56,50
22,54	23,55	56,52
22,55	23,56	56,54
22,56	23,57	56,56
22,57	23,58	56,59
22,58	23,59	56,61
22,59	23,60	56,63
22,60	23,61	56,65



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	56,67
22,62	23,63	56,69
22,63	23,64	56,71
22,64	23,65	56,73
22,65	23,66	56,75
22,66	23,67	56,77
22,67	23,68	56,79
22,68	23,69	56,81
22,69	23,70	56,83
22,70	23,71	56,85
22,71	23,72	56,87
22,72	23,73	56,89
22,73	23,74	56,91
22,74	23,75	56,93
22,75	23,76	56,95
22,76	23,77	56,98
22,77	23,78	57,00
22,78	23,79	57,02
22,79	23,80	57,04
22,80	23,81	57,06
22,81	23,82	57,08
22,82	23,83	57,10
22,83	23,84	57,12
22,84	23,85	57,14
22,85	23,86	57,16
22,86	23,87	57,18
22,87	23,88	57,20
22,88	23,89	57,22
22,89	23,90	57,24
22,90	23,91	57,26
22,91	23,92	57,28
22,92	23,93	57,30
22,93	23,94	57,32
22,94	23,95	57,34
22,95	23,96	57,36
22,96	23,97	57,38
22,97	23,98	57,40
22,98	23,99	57,42
22,99	24,00	57,44
23,00	24,01	57,46
23,01	24,02	57,48
23,02	24,03	57,51
23,03	24,04	57,53
23,04	24,05	57,55



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
23,05	24,06	57,57
23,06	24,07	57,59
23,07	24,08	57,61
23,08	24,09	57,63
23,09	24,10	57,65
23,10	24,11	57,67
23,11	24,12	57,69
23,12	24,13	57,71
23,13	24,14	57,73
23,14	24,15	57,75
23,15	24,16	57,77
23,16	24,17	57,79
23,17	24,18	57,81
23,18	24,19	57,83
23,19	24,20	57,85
23,20	24,21	57,87
23,21	24,22	57,89
23,22	24,23	57,91
23,23	24,24	57,93
23,24	24,25	57,95
23,25	24,26	57,97
23,26	24,27	57,99
23,27	24,28	58,01
23,28	24,29	58,03
23,29	24,30	58,05
23,30	24,31	58,07
23,31	24,32	58,09
23,32	24,33	58,11
23,33	24,34	58,13
23,34	24,35	58,15
23,35	24,36	58,17
23,36	24,37	58,19
23,37	24,38	58,21
23,38	24,39	58,23
23,39	24,40	58,25
23,40	24,41	58,27
23,41	24,42	58,29
23,42	24,43	58,31
23,43	24,44	58,33
23,44	24,45	58,35
23,45	24,46	58,37
23,46	24,47	58,39
23,47	24,48	58,41
23,48	24,49	58,43



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,49	24,50	58,45
23,50	24,51	58,47
23,51	24,52	58,49
23,52	24,53	58,51
23,53	24,54	58,53
23,54	24,55	58,55
23,55	24,56	58,57
23,56	24,57	58,59
23,57	24,58	58,61
23,58	24,59	58,63
23,59	24,60	58,65
23,60	24,61	58,67
23,61	24,62	58,69
23,62	24,63	58,71
23,63	24,64	58,73
23,64	24,65	58,75
23,65	24,66	58,77
23,66	24,67	58,79
23,67	24,68	58,81
23,68	24,69	58,83
23,69	24,70	58,85
23,70	24,71	58,87
23,71	24,72	58,89
23,72	24,73	58,91
23,73	24,74	58,93
23,74	24,75	58,95
23,75	24,76	58,97
23,76	24,77	58,99
23,77	24,78	59,01
23,78	24,79	59,03
23,79	24,80	59,05
23,80	24,81	59,07
23,81	24,82	59,09
23,82	24,83	59,11
23,83	24,84	59,13
23,84	24,85	59,15
23,85	24,86	59,17
23,86	24,87	59,19
23,87	24,88	59,21
23,88	24,89	59,23
23,89	24,90	59,25
23,90	24,91	59,27
23,91	24,92	59,29
23,92	24,93	59,31



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,93	24,94	59,33
23,94	24,95	59,35
23,95	24,96	59,37
23,96	24,97	59,39
23,97	24,98	59,41
23,98	24,99	59,43
23,99	25,00	59,45
24,00	25,01	59,46
24,01	25,02	59,48
24,02	25,03	59,50
24,03	25,04	59,52
24,04	25,05	59,54
24,05	25,06	59,56
24,06	25,07	59,58
24,07	25,08	59,60
24,08	25,09	59,62
24,09	25,10	59,64
24,10	25,11	59,66
24,11	25,12	59,68
24,12	25,13	59,70
24,13	25,14	59,72
24,14	25,15	59,74
24,15	25,16	59,76
24,16	25,17	59,78
24,17	25,18	59,80
24,18	25,19	59,82
24,19	25,20	59,84
24,20	25,21	59,86
24,21	25,22	59,88
24,22	25,23	59,90
24,23	25,24	59,92
24,24	25,25	59,94
24,25	25,26	59,96
24,26	25,27	59,98
24,27	25,28	59,99
24,28	25,29	60,01
24,29	25,30	60,03
24,30	25,31	60,05
24,31	25,32	60,07
24,32	25,33	60,09
24,33	25,34	60,11
24,34	25,35	60,13
24,35	25,36	60,15
24,36	25,37	60,17



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,37	25,38	60,19
24,38	25,39	60,21
24,39	25,40	60,23
24,40	25,41	60,25
24,41	25,42	60,27
24,42	25,43	60,29
24,43	25,44	60,31
24,44	25,45	60,33
24,45	25,46	60,35
24,46	25,47	60,36
24,47	25,48	60,38
24,48	25,49	60,40
24,49	25,50	60,42
24,50	25,51	60,44
24,51	25,52	60,46
24,52	25,53	60,48
24,53	25,54	60,50
24,54	25,55	60,52
24,55	25,56	60,54
24,56	25,57	60,56
24,57	25,58	60,58
24,58	25,59	60,60
24,59	25,60	60,62
24,60	25,61	60,64
24,61	25,62	60,66
24,62	25,63	60,68
24,63	25,64	60,69
24,64	25,65	60,71
24,65	25,66	60,73
24,66	25,67	60,75
24,67	25,68	60,77
24,68	25,69	60,79
24,69	25,70	60,81
24,70	25,71	60,83
24,71	25,72	60,85
24,72	25,73	60,87
24,73	25,74	60,89
24,74	25,75	60,91
24,75	25,76	60,93
24,76	25,77	60,95
24,77	25,78	60,96
24,78	25,79	60,98
24,79	25,80	61,00
24,80	25,81	61,02



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	61,04
24,82	25,83	61,06
24,83	25,84	61,08
24,84	25,85	61,10
24,85	25,86	61,12
24,86	25,87	61,14
24,87	25,88	61,16
24,88	25,89	61,18
24,89	25,90	61,20
24,90	25,91	61,21
24,91	25,92	61,23
24,92	25,93	61,25
24,93	25,94	61,27
24,94	25,95	61,29
24,95	25,96	61,31
24,96	25,97	61,33
24,97	25,98	61,35
24,98	25,99	61,37
24,99	26,00	61,39
25,00	26,01	61,41
25,01	26,02	61,43
25,02	26,03	61,44
25,03	26,04	61,46
25,04	26,05	61,48
25,05	26,06	61,50
25,06	26,07	61,52
25,07	26,08	61,54
25,08	26,09	61,56
25,09	26,10	61,58
25,10	26,11	61,60
25,11	26,12	61,62
25,12	26,13	61,64
25,13	26,14	61,65
25,14	26,15	61,67
25,15	26,16	61,69
25,16	26,17	61,71
25,17	26,18	61,73
25,18	26,19	61,75
25,19	26,20	61,77
25,20	26,21	61,79
25,21	26,22	61,81
25,22	26,23	61,83
25,23	26,24	61,84
25,24	26,25	61,86



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	61,88
25,26	26,27	61,90
25,27	26,28	61,92
25,28	26,29	61,94
25,29	26,30	61,96
25,30	26,31	61,98
25,31	26,32	62,00
25,32	26,33	62,02
25,33	26,34	62,03
25,34	26,35	62,05
25,35	26,36	62,07
25,36	26,37	62,09
25,37	26,38	62,11
25,38	26,39	62,13
25,39	26,40	62,15
25,40	26,41	62,17
25,41	26,42	62,19
25,42	26,43	62,21
25,43	26,44	62,22
25,44	26,45	62,24
25,45	26,46	62,26
25,46	26,47	62,28
25,47	26,48	62,30
25,48	26,49	62,32
25,49	26,50	62,34
25,50	26,51	62,36
25,51	26,52	62,38
25,52	26,53	62,39
25,53	26,54	62,41
25,54	26,55	62,43
25,55	26,56	62,45
25,56	26,57	62,47
25,57	26,58	62,49
25,58	26,59	62,51
25,59	26,60	62,53
25,60	26,61	62,54
25,61	26,62	62,56
25,62	26,63	62,58
25,63	26,64	62,60
25,64	26,65	62,62
25,65	26,66	62,64
25,66	26,67	62,66
25,67	26,68	62,68
25,68	26,69	62,69



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
25,69	26,70	62,71
25,70	26,71	62,73
25,71	26,72	62,75
25,72	26,73	62,77
25,73	26,74	62,79
25,74	26,75	62,81
25,75	26,76	62,83
25,76	26,77	62,84
25,77	26,78	62,86
25,78	26,79	62,88
25,79	26,80	62,90
25,80	26,81	62,92
25,81	26,82	62,94
25,82	26,83	62,96
25,83	26,84	62,98
25,84	26,85	62,99
25,85	26,86	63,01
25,86	26,87	63,03
25,87	26,88	63,05
25,88	26,89	63,07
25,89	26,90	63,09
25,90	26,91	63,11
25,91	26,92	63,13
25,92	26,93	63,14
25,93	26,94	63,16
25,94	26,95	63,18
25,95	26,96	63,20
25,96	26,97	63,22
25,97	26,98	63,24
25,98	26,99	63,26
25,99	27,00	63,27
26,00	27,01	63,29
26,01	27,02	63,31
26,02	27,03	63,33
26,03	27,04	63,35
26,04	27,05	63,37
26,05	27,06	63,39
26,06	27,07	63,40
26,07	27,08	63,42
26,08	27,09	63,44
26,09	27,10	63,46
26,10	27,11	63,48
26,11	27,12	63,50
26,12	27,13	63,52



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	63,53
26,14	27,15	63,55
26,15	27,16	63,57
26,16	27,17	63,59
26,17	27,18	63,61
26,18	27,19	63,63
26,19	27,20	63,65
26,20	27,21	63,66
26,21	27,22	63,68
26,22	27,23	63,70
26,23	27,24	63,72
26,24	27,25	63,74
26,25	27,26	63,76
26,26	27,27	63,77
26,27	27,28	63,79
26,28	27,29	63,81
26,29	27,30	63,83
26,30	27,31	63,85
26,31	27,32	63,87
26,32	27,33	63,89
26,33	27,34	63,90
26,34	27,35	63,92
26,35	27,36	63,94
26,36	27,37	63,96
26,37	27,38	63,98
26,38	27,39	64,00
26,39	27,40	64,01
26,40	27,41	64,03
26,41	27,42	64,05
26,42	27,43	64,07
26,43	27,44	64,09
26,44	27,45	64,11
26,45	27,46	64,12
26,46	27,47	64,14
26,47	27,48	64,16
26,48	27,49	64,18
26,49	27,50	64,20
26,50	27,51	64,22
26,51	27,52	64,23
26,52	27,53	64,25
26,53	27,54	64,27
26,54	27,55	64,29
26,55	27,56	64,31
26,56	27,57	64,33



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,57	27,58	64,34
26,58	27,59	64,36
26,59	27,60	64,38
26,60	27,61	64,40
26,61	27,62	64,42
26,62	27,63	64,44
26,63	27,64	64,45
26,64	27,65	64,47
26,65	27,66	64,49
26,66	27,67	64,51
26,67	27,68	64,53
26,68	27,69	64,55
26,69	27,70	64,56
26,70	27,71	64,58
26,71	27,72	64,60
26,72	27,73	64,62
26,73	27,74	64,64
26,74	27,75	64,66
26,75	27,76	64,67
26,76	27,77	64,69
26,77	27,78	64,71
26,78	27,79	64,73
26,79	27,80	64,75
26,80	27,81	64,76
26,81	27,82	64,78
26,82	27,83	64,80
26,83	27,84	64,82
26,84	27,85	64,84
26,85	27,86	64,86
26,86	27,87	64,87
26,87	27,88	64,89
26,88	27,89	64,91
26,89	27,90	64,93
26,90	27,91	64,95
26,91	27,92	64,96
26,92	27,93	64,98
26,93	27,94	65,00
26,94	27,95	65,02
26,95	27,96	65,04
26,96	27,97	65,05
26,97	27,98	65,07
26,98	27,99	65,09
26,99	28,00	65,11
27,00	28,01	65,13



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	65,15
27,02	28,03	65,16
27,03	28,04	65,18
27,04	28,05	65,20
27,05	28,06	65,22
27,06	28,07	65,24
27,07	28,08	65,25
27,08	28,09	65,27
27,09	28,10	65,29
27,10	28,11	65,31
27,11	28,12	65,33
27,12	28,13	65,34
27,13	28,14	65,36
27,14	28,15	65,38
27,15	28,16	65,40
27,16	28,17	65,42
27,17	28,18	65,43
27,18	28,19	65,45
27,19	28,20	65,47
27,20	28,21	65,49
27,21	28,22	65,51
27,22	28,23	65,52
27,23	28,24	65,54
27,24	28,25	65,56
27,25	28,26	65,58
27,26	28,27	65,60
27,27	28,28	65,61
27,28	28,29	65,63
27,29	28,30	65,65
27,30	28,31	65,67
27,31	28,32	65,69
27,32	28,33	65,70
27,33	28,34	65,72
27,34	28,35	65,74
27,35	28,36	65,76
27,36	28,37	65,78
27,37	28,38	65,79
27,38	28,39	65,81
27,39	28,40	65,83
27,40	28,41	65,85
27,41	28,42	65,87
27,42	28,43	65,88
27,43	28,44	65,90
27,44	28,45	65,92



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	65,94
27,46	28,47	65,95
27,47	28,48	65,97
27,48	28,49	65,99
27,49	28,50	66,01
27,50	28,51	66,03
27,51	28,52	66,04
27,52	28,53	66,06
27,53	28,54	66,08
27,54	28,55	66,10
27,55	28,56	66,12
27,56	28,57	66,13
27,57	28,58	66,15
27,58	28,59	66,17
27,59	28,60	66,19
27,60	28,61	66,20
27,61	28,62	66,22
27,62	28,63	66,24
27,63	28,64	66,26
27,64	28,65	66,28
27,65	28,66	66,29
27,66	28,67	66,31
27,67	28,68	66,33
27,68	28,69	66,35
27,69	28,70	66,36
27,70	28,71	66,38
27,71	28,72	66,40
27,72	28,73	66,42
27,73	28,74	66,44
27,74	28,75	66,45
27,75	28,76	66,47
27,76	28,77	66,49
27,77	28,78	66,51
27,78	28,79	66,52
27,79	28,80	66,54
27,80	28,81	66,56
27,81	28,82	66,58
27,82	28,83	66,60
27,83	28,84	66,61
27,84	28,85	66,63
27,85	28,86	66,65
27,86	28,87	66,67
27,87	28,88	66,68
27,88	28,89	66,70



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	66,72
27,90	28,91	66,74
27,91	28,92	66,75
27,92	28,93	66,77
27,93	28,94	66,79
27,94	28,95	66,81
27,95	28,96	66,82
27,96	28,97	66,84
27,97	28,98	66,86
27,98	28,99	66,88
27,99	29,00	66,90
28,00	29,01	66,91
28,01	29,02	66,93
28,02	29,03	66,95
28,03	29,04	66,97
28,04	29,05	66,98
28,05	29,06	67,00
28,06	29,07	67,02
28,07	29,08	67,04
28,08	29,09	67,05
28,09	29,10	67,07
28,10	29,11	67,09
28,11	29,12	67,11
28,12	29,13	67,12
28,13	29,14	67,14
28,14	29,15	67,16
28,15	29,16	67,18
28,16	29,17	67,19
28,17	29,18	67,21
28,18	29,19	67,23
28,19	29,20	67,25
28,20	29,21	67,26
28,21	29,22	67,28
28,22	29,23	67,30
28,23	29,24	67,32
28,24	29,25	67,33
28,25	29,26	67,35
28,26	29,27	67,37
28,27	29,28	67,39
28,28	29,29	67,40
28,29	29,30	67,42
28,30	29,31	67,44
28,31	29,32	67,46
28,32	29,33	67,47



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	67,49
28,34	29,35	67,51
28,35	29,36	67,53
28,36	29,37	67,54
28,37	29,38	67,56
28,38	29,39	67,58
28,39	29,40	67,60
28,40	29,41	67,61
28,41	29,42	67,63
28,42	29,43	67,65
28,43	29,44	67,67
28,44	29,45	67,68
28,45	29,46	67,70
28,46	29,47	67,72
28,47	29,48	67,74
28,48	29,49	67,75
28,49	29,50	67,77
28,50	29,51	67,79
28,51	29,52	67,81
28,52	29,53	67,82
28,53	29,54	67,84
28,54	29,55	67,86
28,55	29,56	67,88
28,56	29,57	67,89
28,57	29,58	67,91
28,58	29,59	67,93
28,59	29,60	67,94
28,60	29,61	67,96
28,61	29,62	67,98
28,62	29,63	68,00
28,63	29,64	68,01
28,64	29,65	68,03
28,65	29,66	68,05
28,66	29,67	68,07
28,67	29,68	68,08
28,68	29,69	68,10
28,69	29,70	68,12
28,70	29,71	68,14
28,71	29,72	68,15
28,72	29,73	68,17
28,73	29,74	68,19
28,74	29,75	68,20
28,75	29,76	68,22
28,76	29,77	68,24



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	68,26
28,78	29,79	68,27
28,79	29,80	68,29
28,80	29,81	68,31
28,81	29,82	68,33
28,82	29,83	68,34
28,83	29,84	68,36
28,84	29,85	68,38
28,85	29,86	68,39
28,86	29,87	68,41
28,87	29,88	68,43
28,88	29,89	68,45
28,89	29,90	68,46
28,90	29,91	68,48
28,91	29,92	68,50
28,92	29,93	68,52
28,93	29,94	68,53
28,94	29,95	68,55
28,95	29,96	68,57
28,96	29,97	68,58
28,97	29,98	68,60
28,98	29,99	68,62
28,99	30,00	68,64
29,00	30,01	68,65
29,01	30,02	68,67
29,02	30,03	68,69
29,03	30,04	68,70
29,04	30,05	68,72
29,05	30,06	68,74
29,06	30,07	68,76
29,07	30,08	68,77
29,08	30,09	68,79
29,09	30,10	68,81
29,10	30,11	68,82
29,11	30,12	68,84
29,12	30,13	68,86
29,13	30,14	68,88
29,14	30,15	68,89
29,15	30,16	68,91
29,16	30,17	68,93
29,17	30,18	68,94
29,18	30,19	68,96
29,19	30,20	68,98
29,20	30,21	69,00



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
29,21	30,22	69,01
29,22	30,23	69,03
29,23	30,24	69,05
29,24	30,25	69,06
29,25	30,26	69,08
29,26	30,27	69,10
29,27	30,28	69,11
29,28	30,29	69,13
29,29	30,30	69,15
29,30	30,31	69,17
29,31	30,32	69,18
29,32	30,33	69,20
29,33	30,34	69,22
29,34	30,35	69,23
29,35	30,36	69,25
29,36	30,37	69,27
29,37	30,38	69,29
29,38	30,39	69,30
29,39	30,40	69,32
29,40	30,41	69,34
29,41	30,42	69,35
29,42	30,43	69,37
29,43	30,44	69,39
29,44	30,45	69,40
29,45	30,46	69,42
29,46	30,47	69,44
29,47	30,48	69,45
29,48	30,49	69,47
29,49	30,50	69,49
29,50	30,51	69,51
29,51	30,52	69,52
29,52	30,53	69,54
29,53	30,54	69,56
29,54	30,55	69,57
29,55	30,56	69,59
29,56	30,57	69,61
29,57	30,58	69,62
29,58	30,59	69,64
29,59	30,60	69,66
29,60	30,61	69,68
29,61	30,62	69,69
29,62	30,63	69,71
29,63	30,64	69,73
29,64	30,65	69,74



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,65	30,66	69,76
29,66	30,67	69,78
29,67	30,68	69,79
29,68	30,69	69,81
29,69	30,70	69,83
29,70	30,71	69,84
29,71	30,72	69,86
29,72	30,73	69,88
29,73	30,74	69,89
29,74	30,75	69,91
29,75	30,76	69,93
29,76	30,77	69,95
29,77	30,78	69,96
29,78	30,79	69,98
29,79	30,80	70,00
29,80	30,81	70,01
29,81	30,82	70,03
29,82	30,83	70,05
29,83	30,84	70,06
29,84	30,85	70,08
29,85	30,86	70,10
29,86	30,87	70,11
29,87	30,88	70,13
29,88	30,89	70,15
29,89	30,90	70,16
29,90	30,91	70,18
29,91	30,92	70,20
29,92	30,93	70,21
29,93	30,94	70,23
29,94	30,95	70,25
29,95	30,96	70,26
29,96	30,97	70,28
29,97	30,98	70,30
29,98	30,99	70,32
29,99	31,00	70,33
30,00	31,01	70,35
30,01	31,02	70,37
30,02	31,03	70,38
30,03	31,04	70,40
30,04	31,05	70,42
30,05	31,06	70,43
30,06	31,07	70,45
30,07	31,08	70,47
30,08	31,09	70,48



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,09	31,10	70,50
30,10	31,11	70,52
30,11	31,12	70,53
30,12	31,13	70,55
30,13	31,14	70,57
30,14	31,15	70,58
30,15	31,16	70,60
30,16	31,17	70,62
30,17	31,18	70,63
30,18	31,19	70,65
30,19	31,20	70,67
30,20	31,21	70,68
30,21	31,22	70,70
30,22	31,23	70,72
30,23	31,24	70,73
30,24	31,25	70,75
30,25	31,26	70,77
30,26	31,27	70,78
30,27	31,28	70,80
30,28	31,29	70,82
30,29	31,30	70,83
30,30	31,31	70,85
30,31	31,32	70,87
30,32	31,33	70,88
30,33	31,34	70,90
30,34	31,35	70,92
30,35	31,36	70,93
30,36	31,37	70,95
30,37	31,38	70,97
30,38	31,39	70,98
30,39	31,40	71,00
30,40	31,41	71,02
30,41	31,42	71,03
30,42	31,43	71,05
30,43	31,44	71,06
30,44	31,45	71,08
30,45	31,46	71,10
30,46	31,47	71,11
30,47	31,48	71,13
30,48	31,49	71,15
30,49	31,50	71,16
30,50	31,51	71,18
30,51	31,52	71,20
30,52	31,53	71,21



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	71,23
30,54	31,55	71,25
30,55	31,56	71,26
30,56	31,57	71,28
30,57	31,58	71,30
30,58	31,59	71,31
30,59	31,60	71,33
30,60	31,61	71,35
30,61	31,62	71,36
30,62	31,63	71,38
30,63	31,64	71,40
30,64	31,65	71,41
30,65	31,66	71,43
30,66	31,67	71,44
30,67	31,68	71,46
30,68	31,69	71,48
30,69	31,70	71,49
30,70	31,71	71,51
30,71	31,72	71,53
30,72	31,73	71,54
30,73	31,74	71,56
30,74	31,75	71,58
30,75	31,76	71,59
30,76	31,77	71,61
30,77	31,78	71,63
30,78	31,79	71,64
30,79	31,80	71,66
30,80	31,81	71,68
30,81	31,82	71,69
30,82	31,83	71,71
30,83	31,84	71,72
30,84	31,85	71,74
30,85	31,86	71,76
30,86	31,87	71,77
30,87	31,88	71,79
30,88	31,89	71,81
30,89	31,90	71,82
30,90	31,91	71,84
30,91	31,92	71,86
30,92	31,93	71,87
30,93	31,94	71,89
30,94	31,95	71,90
30,95	31,96	71,92
30,96	31,97	71,94



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,97	31,98	71,95
30,98	31,99	71,97
30,99	32,00	71,99
31,00	32,01	72,00
31,01	32,02	72,02
31,02	32,03	72,04
31,03	32,04	72,05
31,04	32,05	72,07
31,05	32,06	72,08
31,06	32,07	72,10
31,07	32,08	72,12
31,08	32,09	72,13
31,09	32,10	72,15
31,10	32,11	72,17
31,11	32,12	72,18
31,12	32,13	72,20
31,13	32,14	72,22
31,14	32,15	72,23
31,15	32,16	72,25
31,16	32,17	72,26
31,17	32,18	72,28
31,18	32,19	72,30
31,19	32,20	72,31
31,20	32,21	72,33
31,21	32,22	72,35
31,22	32,23	72,36
31,23	32,24	72,38
31,24	32,25	72,39
31,25	32,26	72,41
31,26	32,27	72,43
31,27	32,28	72,44
31,28	32,29	72,46
31,29	32,30	72,48
31,30	32,31	72,49
31,31	32,32	72,51
31,32	32,33	72,52
31,33	32,34	72,54
31,34	32,35	72,56
31,35	32,36	72,57
31,36	32,37	72,59
31,37	32,38	72,60
31,38	32,39	72,62
31,39	32,40	72,64
31,40	32,41	72,65



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	72,67
31,42	32,43	72,69
31,43	32,44	72,70
31,44	32,45	72,72
31,45	32,46	72,73
31,46	32,47	72,75
31,47	32,48	72,77
31,48	32,49	72,78
31,49	32,50	72,80
31,50	32,51	72,82
31,51	32,52	72,83
31,52	32,53	72,85
31,53	32,54	72,86
31,54	32,55	72,88
31,55	32,56	72,90
31,56	32,57	72,91
31,57	32,58	72,93
31,58	32,59	72,94
31,59	32,60	72,96
31,60	32,61	72,98
31,61	32,62	72,99
31,62	32,63	73,01
31,63	32,64	73,02
31,64	32,65	73,04
31,65	32,66	73,06
31,66	32,67	73,07
31,67	32,68	73,09
31,68	32,69	73,11
31,69	32,70	73,12
31,70	32,71	73,14
31,71	32,72	73,15
31,72	32,73	73,17
31,73	32,74	73,19
31,74	32,75	73,20
31,75	32,76	73,22
31,76	32,77	73,23
31,77	32,78	73,25
31,78	32,79	73,27
31,79	32,80	73,28
31,80	32,81	73,30
31,81	32,82	73,31
31,82	32,83	73,33
31,83	32,84	73,35
31,84	32,85	73,36



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	73,38
31,86	32,87	73,39
31,87	32,88	73,41
31,88	32,89	73,43
31,89	32,90	73,44
31,90	32,91	73,46
31,91	32,92	73,47
31,92	32,93	73,49
31,93	32,94	73,51
31,94	32,95	73,52
31,95	32,96	73,54
31,96	32,97	73,55
31,97	32,98	73,57
31,98	32,99	73,59
31,99	33,00	73,60
32,00	33,01	73,62
32,01	33,02	73,63
32,02	33,03	73,65
32,03	33,04	73,67
32,04	33,05	73,68
32,05	33,06	73,70
32,06	33,07	73,71
32,07	33,08	73,73
32,08	33,09	73,75
32,09	33,10	73,76
32,10	33,11	73,78
32,11	33,12	73,79
32,12	33,13	73,81
32,13	33,14	73,82
32,14	33,15	73,84
32,15	33,16	73,86
32,16	33,17	73,87
32,17	33,18	73,89
32,18	33,19	73,90
32,19	33,20	73,92
32,20	33,21	73,94
32,21	33,22	73,95
32,22	33,23	73,97
32,23	33,24	73,98
32,24	33,25	74,00
32,25	33,26	74,02
32,26	33,27	74,03
32,27	33,28	74,05
32,28	33,29	74,06



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	74,08
32,30	33,31	74,09
32,31	33,32	74,11
32,32	33,33	74,13
32,33	33,34	74,14
32,34	33,35	74,16
32,35	33,36	74,17
32,36	33,37	74,19
32,37	33,38	74,21
32,38	33,39	74,22
32,39	33,40	74,24
32,40	33,41	74,25
32,41	33,42	74,27
32,42	33,43	74,28
32,43	33,44	74,30
32,44	33,45	74,32
32,45	33,46	74,33
32,46	33,47	74,35
32,47	33,48	74,36
32,48	33,49	74,38
32,49	33,50	74,40
32,50	33,51	74,41
32,51	33,52	74,43
32,52	33,53	74,44
32,53	33,54	74,46
32,54	33,55	74,47
32,55	33,56	74,49
32,56	33,57	74,51
32,57	33,58	74,52
32,58	33,59	74,54
32,59	33,60	74,55
32,60	33,61	74,57
32,61	33,62	74,58
32,62	33,63	74,60
32,63	33,64	74,62
32,64	33,65	74,63
32,65	33,66	74,65
32,66	33,67	74,66
32,67	33,68	74,68
32,68	33,69	74,69
32,69	33,70	74,71
32,70	33,71	74,73
32,71	33,72	74,74
32,72	33,73	74,76



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,73	33,74	74,77
32,74	33,75	74,79
32,75	33,76	74,80
32,76	33,77	74,82
32,77	33,78	74,84
32,78	33,79	74,85
32,79	33,80	74,87
32,80	33,81	74,88
32,81	33,82	74,90
32,82	33,83	74,91
32,83	33,84	74,93
32,84	33,85	74,95
32,85	33,86	74,96
32,86	33,87	74,98
32,87	33,88	74,99
32,88	33,89	75,01
32,89	33,90	75,02
32,90	33,91	75,04
32,91	33,92	75,05
32,92	33,93	75,07
32,93	33,94	75,09
32,94	33,95	75,10
32,95	33,96	75,12
32,96	33,97	75,13
32,97	33,98	75,15
32,98	33,99	75,16
32,99	34,00	75,18
33,00	34,01	75,19
33,01	34,02	75,21
33,02	34,03	75,23
33,03	34,04	75,24
33,04	34,05	75,26
33,05	34,06	75,27
33,06	34,07	75,29
33,07	34,08	75,30
33,08	34,09	75,32
33,09	34,10	75,34
33,10	34,11	75,35
33,11	34,12	75,37
33,12	34,13	75,38
33,13	34,14	75,40
33,14	34,15	75,41
33,15	34,16	75,43
33,16	34,17	75,44



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,17	34,18	75,46
33,18	34,19	75,48
33,19	34,20	75,49
33,20	34,21	75,51
33,21	34,22	75,52
33,22	34,23	75,54
33,23	34,24	75,55
33,24	34,25	75,57
33,25	34,26	75,58
33,26	34,27	75,60
33,27	34,28	75,61
33,28	34,29	75,63
33,29	34,30	75,65
33,30	34,31	75,66
33,31	34,32	75,68
33,32	34,33	75,69
33,33	34,34	75,71
33,34	34,35	75,72
33,35	34,36	75,74
33,36	34,37	75,75
33,37	34,38	75,77
33,38	34,39	75,78
33,39	34,40	75,80
33,40	34,41	75,82
33,41	34,42	75,83
33,42	34,43	75,85
33,43	34,44	75,86
33,44	34,45	75,88
33,45	34,46	75,89
33,46	34,47	75,91
33,47	34,48	75,92
33,48	34,49	75,94
33,49	34,50	75,95
33,50	34,51	75,97
33,51	34,52	75,99
33,52	34,53	76,00
33,53	34,54	76,02
33,54	34,55	76,03
33,55	34,56	76,05
33,56	34,57	76,06
33,57	34,58	76,08
33,58	34,59	76,09
33,59	34,60	76,11
33,60	34,61	76,12



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,61	34,62	76,14
33,62	34,63	76,15
33,63	34,64	76,17
33,64	34,65	76,19
33,65	34,66	76,20
33,66	34,67	76,22
33,67	34,68	76,23
33,68	34,69	76,25
33,69	34,70	76,26
33,70	34,71	76,28
33,71	34,72	76,29
33,72	34,73	76,31
33,73	34,74	76,32
33,74	34,75	76,34
33,75	34,76	76,35
33,76	34,77	76,37
33,77	34,78	76,38
33,78	34,79	76,40
33,79	34,80	76,42
33,80	34,81	76,43
33,81	34,82	76,45
33,82	34,83	76,46
33,83	34,84	76,48
33,84	34,85	76,49
33,85	34,86	76,51
33,86	34,87	76,52
33,87	34,88	76,54
33,88	34,89	76,55
33,89	34,90	76,57
33,90	34,91	76,58
33,91	34,92	76,60
33,92	34,93	76,61
33,93	34,94	76,63
33,94	34,95	76,64
33,95	34,96	76,66
33,96	34,97	76,68
33,97	34,98	76,69
33,98	34,99	76,71
33,99	35,00	76,72
34,00	35,01	76,74
34,01	35,02	76,75
34,02	35,03	76,77
34,03	35,04	76,78
34,04	35,05	76,80



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,05	35,06	76,81
34,06	35,07	76,83
34,07	35,08	76,84
34,08	35,09	76,86
34,09	35,10	76,87
34,10	35,11	76,89
34,11	35,12	76,90
34,12	35,13	76,92
34,13	35,14	76,93
34,14	35,15	76,95
34,15	35,16	76,96
34,16	35,17	76,98
34,17	35,18	76,99
34,18	35,19	77,01
34,19	35,20	77,02
34,20	35,21	77,04
34,21	35,22	77,06
34,22	35,23	77,07
34,23	35,24	77,09
34,24	35,25	77,10
34,25	35,26	77,12
34,26	35,27	77,13
34,27	35,28	77,15
34,28	35,29	77,16
34,29	35,30	77,18
34,30	35,31	77,19
34,31	35,32	77,21
34,32	35,33	77,22
34,33	35,34	77,24
34,34	35,35	77,25
34,35	35,36	77,27
34,36	35,37	77,28
34,37	35,38	77,30
34,38	35,39	77,31
34,39	35,40	77,33
34,40	35,41	77,34
34,41	35,42	77,36
34,42	35,43	77,37
34,43	35,44	77,39
34,44	35,45	77,40
34,45	35,46	77,42
34,46	35,47	77,43
34,47	35,48	77,45
34,48	35,49	77,46



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,49	35,50	77,48
34,50	35,51	77,49
34,51	35,52	77,51
34,52	35,53	77,52
34,53	35,54	77,54
34,54	35,55	77,55
34,55	35,56	77,57
34,56	35,57	77,58
34,57	35,58	77,60
34,58	35,59	77,61
34,59	35,60	77,63
34,60	35,61	77,64
34,61	35,62	77,66
34,62	35,63	77,67
34,63	35,64	77,69
34,64	35,65	77,70
34,65	35,66	77,72
34,66	35,67	77,73
34,67	35,68	77,75
34,68	35,69	77,76
34,69	35,70	77,78
34,70	35,71	77,79
34,71	35,72	77,81
34,72	35,73	77,82
34,73	35,74	77,84
34,74	35,75	77,85
34,75	35,76	77,87
34,76	35,77	77,88
34,77	35,78	77,90
34,78	35,79	77,91
34,79	35,80	77,93
34,80	35,81	77,94
34,81	35,82	77,96
34,82	35,83	77,97
34,83	35,84	77,99
34,84	35,85	78,00
34,85	35,86	78,02
34,86	35,87	78,03
34,87	35,88	78,05
34,88	35,89	78,06
34,89	35,90	78,08
34,90	35,91	78,09
34,91	35,92	78,11
34,92	35,93	78,12



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,93	35,94	78,14
34,94	35,95	78,15
34,95	35,96	78,17
34,96	35,97	78,18
34,97	35,98	78,20
34,98	35,99	78,21
34,99	36,00	78,23
35,00	36,01	78,24
35,01	36,02	78,26
35,02	36,03	78,27
35,03	36,04	78,29
35,04	36,05	78,30
35,05	36,06	78,32
35,06	36,07	78,33
35,07	36,08	78,35
35,08	36,09	78,36
35,09	36,10	78,38
35,10	36,11	78,39
35,11	36,12	78,41
35,12	36,13	78,42
35,13	36,14	78,44
35,14	36,15	78,45
35,15	36,16	78,47
35,16	36,17	78,48
35,17	36,18	78,50
35,18	36,19	78,51
35,19	36,20	78,53
35,20	36,21	78,54
35,21	36,22	78,55
35,22	36,23	78,57
35,23	36,24	78,58
35,24	36,25	78,60
35,25	36,26	78,61
35,26	36,27	78,63
35,27	36,28	78,64
35,28	36,29	78,66
35,29	36,30	78,67
35,30	36,31	78,69
35,31	36,32	78,70
35,32	36,33	78,72
35,33	36,34	78,73
35,34	36,35	78,75
35,35	36,36	78,76
35,36	36,37	78,78



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
35,37	36,38	78,79
35,38	36,39	78,81
35,39	36,40	78,82
35,40	36,41	78,84
35,41	36,42	78,85
35,42	36,43	78,87
35,43	36,44	78,88
35,44	36,45	78,89
35,45	36,46	78,91
35,46	36,47	78,92
35,47	36,48	78,94
35,48	36,49	78,95
35,49	36,50	78,97
35,50	36,51	78,98
35,51	36,52	79,00
35,52	36,53	79,01
35,53	36,54	79,03
35,54	36,55	79,04
35,55	36,56	79,06
35,56	36,57	79,07
35,57	36,58	79,09
35,58	36,59	79,10
35,59	36,60	79,12
35,60	36,61	79,13
35,61	36,62	79,15
35,62	36,63	79,16
35,63	36,64	79,17
35,64	36,65	79,19
35,65	36,66	79,20
35,66	36,67	79,22
35,67	36,68	79,23
35,68	36,69	79,25
35,69	36,70	79,26
35,70	36,71	79,28
35,71	36,72	79,29
35,72	36,73	79,31
35,73	36,74	79,32
35,74	36,75	79,34
35,75	36,76	79,35
35,76	36,77	79,37
35,77	36,78	79,38
35,78	36,79	79,39
35,79	36,80	79,41
35,80	36,81	79,42



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
35,81	36,82	79,44
35,82	36,83	79,45
35,83	36,84	79,47
35,84	36,85	79,48
35,85	36,86	79,50
35,86	36,87	79,51
35,87	36,88	79,53
35,88	36,89	79,54
35,89	36,90	79,56
35,90	36,91	79,57
35,91	36,92	79,58
35,92	36,93	79,60
35,93	36,94	79,61
35,94	36,95	79,63
35,95	36,96	79,64
35,96	36,97	79,66
35,97	36,98	79,67
35,98	36,99	79,69
35,99	37,00	79,70
36,00	37,01	79,72
36,01	37,02	79,73
36,02	37,03	79,75
36,03	37,04	79,76
36,04	37,05	79,77
36,05	37,06	79,79
36,06	37,07	79,80
36,07	37,08	79,82
36,08	37,09	79,83
36,09	37,10	79,85
36,10	37,11	79,86
36,11	37,12	79,88
36,12	37,13	79,89
36,13	37,14	79,91
36,14	37,15	79,92
36,15	37,16	79,93
36,16	37,17	79,95
36,17	37,18	79,96
36,18	37,19	79,98
36,19	37,20	79,99
36,20	37,21	80,01
36,21	37,22	80,02
36,22	37,23	80,04
36,23	37,24	80,05
36,24	37,25	80,06



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
36,25	37,26	80,08
36,26	37,27	80,09
36,27	37,28	80,11
36,28	37,29	80,12
36,29	37,30	80,14
36,30	37,31	80,15
36,31	37,32	80,17
36,32	37,33	80,18
36,33	37,34	80,19
36,34	37,35	80,21
36,35	37,36	80,22
36,36	37,37	80,24
36,37	37,38	80,25
36,38	37,39	80,27
36,39	37,40	80,28
36,40	37,41	80,30
36,41	37,42	80,31
36,42	37,43	80,33
36,43	37,44	80,34
36,44	37,45	80,35
36,45	37,46	80,37
36,46	37,47	80,38
36,47	37,48	80,40
36,48	37,49	80,41
36,49	37,50	80,43
36,50	37,51	80,44
36,51	37,52	80,45
36,52	37,53	80,47
36,53	37,54	80,48
36,54	37,55	80,50
36,55	37,56	80,51
36,56	37,57	80,53
36,57	37,58	80,54
36,58	37,59	80,56
36,59	37,60	80,57
36,60	37,61	80,58
36,61	37,62	80,60
36,62	37,63	80,61
36,63	37,64	80,63
36,64	37,65	80,64
36,65	37,66	80,66
36,66	37,67	80,67
36,67	37,68	80,68
36,68	37,69	80,70



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
36,69	37,70	80,71
36,70	37,71	80,73
36,71	37,72	80,74
36,72	37,73	80,76
36,73	37,74	80,77
36,74	37,75	80,79
36,75	37,76	80,80
36,76	37,77	80,81
36,77	37,78	80,83
36,78	37,79	80,84
36,79	37,80	80,86
36,80	37,81	80,87
36,81	37,82	80,89
36,82	37,83	80,90
36,83	37,84	80,91
36,84	37,85	80,93
36,85	37,86	80,94
36,86	37,87	80,96
36,87	37,88	80,97
36,88	37,89	80,99
36,89	37,90	81,00
36,90	37,91	81,01
36,91	37,92	81,03
36,92	37,93	81,04
36,93	37,94	81,06
36,94	37,95	81,07
36,95	37,96	81,09
36,96	37,97	81,10
36,97	37,98	81,11
36,98	37,99	81,13
36,99	38,00	81,14
37,00	38,01	81,16
37,01	38,02	81,17
37,02	38,03	81,19
37,03	38,04	81,20
37,04	38,05	81,21
37,05	38,06	81,23
37,06	38,07	81,24
37,07	38,08	81,26
37,08	38,09	81,27
37,09	38,10	81,29
37,10	38,11	81,30
37,11	38,12	81,31
37,12	38,13	81,33



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
37,13	38,14	81,34
37,14	38,15	81,36
37,15	38,16	81,37
37,16	38,17	81,38
37,17	38,18	81,40
37,18	38,19	81,41
37,19	38,20	81,43
37,20	38,21	81,44
37,21	38,22	81,46
37,22	38,23	81,47
37,23	38,24	81,48
37,24	38,25	81,50
37,25	38,26	81,51
37,26	38,27	81,53
37,27	38,28	81,54
37,28	38,29	81,56
37,29	38,30	81,57
37,30	38,31	81,58
37,31	38,32	81,60
37,32	38,33	81,61
37,33	38,34	81,63
37,34	38,35	81,64
37,35	38,36	81,65
37,36	38,37	81,67
37,37	38,38	81,68
37,38	38,39	81,70
37,39	38,40	81,71
37,40	38,41	81,72
37,41	38,42	81,74
37,42	38,43	81,75
37,43	38,44	81,77
37,44	38,45	81,78
37,45	38,46	81,80
37,46	38,47	81,81
37,47	38,48	81,82
37,48	38,49	81,84
37,49	38,50	81,85
37,50	38,51	81,87
37,51	38,52	81,88
37,52	38,53	81,89
37,53	38,54	81,91
37,54	38,55	81,92
37,55	38,56	81,94
37,56	38,57	81,95



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
37,57	38,58	81,96
37,58	38,59	81,98
37,59	38,60	81,99
37,60	38,61	82,01
37,61	38,62	82,02
37,62	38,63	82,03
37,63	38,64	82,05
37,64	38,65	82,06
37,65	38,66	82,08
37,66	38,67	82,09
37,67	38,68	82,11
37,68	38,69	82,12
37,69	38,70	82,13
37,70	38,71	82,15
37,71	38,72	82,16
37,72	38,73	82,18
37,73	38,74	82,19
37,74	38,75	82,20
37,75	38,76	82,22
37,76	38,77	82,23
37,77	38,78	82,25
37,78	38,79	82,26
37,79	38,80	82,27
37,80	38,81	82,29
37,81	38,82	82,30
37,82	38,83	82,32
37,83	38,84	82,33
37,84	38,85	82,34
37,85	38,86	82,36
37,86	38,87	82,37
37,87	38,88	82,39
37,88	38,89	82,40
37,89	38,90	82,41
37,90	38,91	82,43
37,91	38,92	82,44
37,92	38,93	82,46
37,93	38,94	82,47
37,94	38,95	82,48
37,95	38,96	82,50
37,96	38,97	82,51
37,97	38,98	82,53
37,98	38,99	82,54
37,99	39,00	82,55
38,00	39,01	82,57



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
38,01	39,02	82,58
38,02	39,03	82,60
38,03	39,04	82,61
38,04	39,05	82,62
38,05	39,06	82,64
38,06	39,07	82,65
38,07	39,08	82,66
38,08	39,09	82,68
38,09	39,10	82,69
38,10	39,11	82,71
38,11	39,12	82,72
38,12	39,13	82,73
38,13	39,14	82,75
38,14	39,15	82,76
38,15	39,16	82,78
38,16	39,17	82,79
38,17	39,18	82,80
38,18	39,19	82,82
38,19	39,20	82,83
38,20	39,21	82,85
38,21	39,22	82,86
38,22	39,23	82,87
38,23	39,24	82,89
38,24	39,25	82,90
38,25	39,26	82,92
38,26	39,27	82,93
38,27	39,28	82,94
38,28	39,29	82,96
38,29	39,30	82,97
38,30	39,31	82,98
38,31	39,32	83,00
38,32	39,33	83,01
38,33	39,34	83,03
38,34	39,35	83,04
38,35	39,36	83,05
38,36	39,37	83,07
38,37	39,38	83,08
38,38	39,39	83,10
38,39	39,40	83,11
38,40	39,41	83,12
38,41	39,42	83,14
38,42	39,43	83,15
38,43	39,44	83,16
38,44	39,45	83,18



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
38,45	39,46	83,19
38,46	39,47	83,21
38,47	39,48	83,22
38,48	39,49	83,23
38,49	39,50	83,25
38,50	39,51	83,26
38,51	39,52	83,27
38,52	39,53	83,29
38,53	39,54	83,30
38,54	39,55	83,32
38,55	39,56	83,33
38,56	39,57	83,34
38,57	39,58	83,36
38,58	39,59	83,37
38,59	39,60	83,39
38,60	39,61	83,40
38,61	39,62	83,41
38,62	39,63	83,43
38,63	39,64	83,44
38,64	39,65	83,45
38,65	39,66	83,47
38,66	39,67	83,48
38,67	39,68	83,50
38,68	39,69	83,51
38,69	39,70	83,52
38,70	39,71	83,54
38,71	39,72	83,55
38,72	39,73	83,56
38,73	39,74	83,58
38,74	39,75	83,59
38,75	39,76	83,61
38,76	39,77	83,62
38,77	39,78	83,63
38,78	39,79	83,65
38,79	39,80	83,66
38,80	39,81	83,67
38,81	39,82	83,69
38,82	39,83	83,70
38,83	39,84	83,71
38,84	39,85	83,73
38,85	39,86	83,74
38,86	39,87	83,76
38,87	39,88	83,77
38,88	39,89	83,78



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
38,89	39,90	83,80
38,90	39,91	83,81
38,91	39,92	83,82
38,92	39,93	83,84
38,93	39,94	83,85
38,94	39,95	83,87
38,95	39,96	83,88
38,96	39,97	83,89
38,97	39,98	83,91
38,98	39,99	83,92
38,99	40,00	83,93
39,00	40,01	83,95
39,01	40,02	83,96
39,02	40,03	83,97
39,03	40,04	83,99
39,04	40,05	84,00
39,05	40,06	84,02
39,06	40,07	84,03
39,07	40,08	84,04
39,08	40,09	84,06
39,09	40,10	84,07
39,10	40,11	84,08
39,11	40,12	84,10
39,12	40,13	84,11
39,13	40,14	84,12
39,14	40,15	84,14
39,15	40,16	84,15
39,16	40,17	84,17
39,17	40,18	84,18
39,18	40,19	84,19
39,19	40,20	84,21
39,20	40,21	84,22
39,21	40,22	84,23
39,22	40,23	84,25
39,23	40,24	84,26
39,24	40,25	84,27
39,25	40,26	84,29
39,26	40,27	84,30
39,27	40,28	84,31
39,28	40,29	84,33
39,29	40,30	84,34
39,30	40,31	84,36
39,31	40,32	84,37
39,32	40,33	84,38



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
39,33	40,34	84,40
39,34	40,35	84,41
39,35	40,36	84,42
39,36	40,37	84,44
39,37	40,38	84,45
39,38	40,39	84,46
39,39	40,40	84,48
39,40	40,41	84,49
39,41	40,42	84,50
39,42	40,43	84,52
39,43	40,44	84,53
39,44	40,45	84,55
39,45	40,46	84,56
39,46	40,47	84,57
39,47	40,48	84,59
39,48	40,49	84,60
39,49	40,50	84,61
39,50	40,51	84,63
39,51	40,52	84,64
39,52	40,53	84,65
39,53	40,54	84,67
39,54	40,55	84,68
39,55	40,56	84,69
39,56	40,57	84,71
39,57	40,58	84,72
39,58	40,59	84,73
39,59	40,60	84,75
39,60	40,61	84,76
39,61	40,62	84,77
39,62	40,63	84,79
39,63	40,64	84,80
39,64	40,65	84,81
39,65	40,66	84,83
39,66	40,67	84,84
39,67	40,68	84,86
39,68	40,69	84,87
39,69	40,70	84,88
39,70	40,71	84,90
39,71	40,72	84,91
39,72	40,73	84,92
39,73	40,74	84,94
39,74	40,75	84,95
39,75	40,76	84,96
39,76	40,77	84,98



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
39,77	40,78	84,99
39,78	40,79	85,00
39,79	40,80	85,02
39,80	40,81	85,03
39,81	40,82	85,04
39,82	40,83	85,06
39,83	40,84	85,07
39,84	40,85	85,08
39,85	40,86	85,10
39,86	40,87	85,11
39,87	40,88	85,12
39,88	40,89	85,14
39,89	40,90	85,15
39,90	40,91	85,16
39,91	40,92	85,18
39,92	40,93	85,19
39,93	40,94	85,20
39,94	40,95	85,22
39,95	40,96	85,23
39,96	40,97	85,24
39,97	40,98	85,26
39,98	40,99	85,27
39,99	41,00	85,28
40,00	41,01	85,30
40,01	41,02	85,31
40,02	41,03	85,32
40,03	41,04	85,34
40,04	41,05	85,35
40,05	41,06	85,36
40,06	41,07	85,38
40,07	41,08	85,39
40,08	41,09	85,40
40,09	41,10	85,42
40,10	41,11	85,43
40,11	41,12	85,44
40,12	41,13	85,46
40,13	41,14	85,47
40,14	41,15	85,48
40,15	41,16	85,50
40,16	41,17	85,51
40,17	41,18	85,52
40,18	41,19	85,54
40,19	41,20	85,55
40,20	41,21	85,56



R1270		
V1.0_R1270		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
40,21	41,22	85,58
40,22	41,23	85,59
40,23	41,24	85,60
40,24	41,25	85,62
40,25	41,26	85,63
40,26	41,27	85,64
40,27	41,28	85,66
40,28	41,29	85,67
40,29	41,30	85,68
40,30	41,31	85,70
40,31	41,32	85,71
40,32	41,33	85,72
40,33	41,34	85,74
40,34	41,35	85,75
40,35	41,36	85,76
40,36	41,37	85,78
40,37	41,38	85,79
40,38	41,39	85,80
40,39	41,40	85,82
40,40	41,41	85,83
40,41	41,42	85,84
40,42	41,43	85,86
40,43	41,44	85,87
40,44	41,45	85,88
40,45	41,46	85,90
40,46	41,47	85,91
40,47	41,48	85,92
40,48	41,49	85,94
40,49	41,50	85,95
40,50	41,51	85,96
40,51	41,52	85,98
40,52	41,53	85,99
40,53	41,54	86,00
40,54	41,55	86,02
40,55	41,56	86,03
40,56	41,57	86,04
40,57	41,58	86,05