



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-80,27
-0,70	0,31	-79,73
-0,69	0,32	-79,20
-0,68	0,33	-78,69
-0,67	0,34	-78,19
-0,66	0,35	-77,71
-0,65	0,36	-77,23
-0,64	0,37	-76,76
-0,63	0,38	-76,31
-0,62	0,39	-75,86
-0,61	0,40	-75,43
-0,60	0,41	-75,00
-0,59	0,42	-74,58
-0,58	0,43	-74,16
-0,57	0,44	-73,76
-0,56	0,45	-73,36
-0,55	0,46	-72,97
-0,54	0,47	-72,59
-0,53	0,48	-72,21
-0,52	0,49	-71,84
-0,51	0,50	-71,48
-0,50	0,51	-71,12
-0,49	0,52	-70,77
-0,48	0,53	-70,42
-0,47	0,54	-70,07
-0,46	0,55	-69,74
-0,45	0,56	-69,40
-0,44	0,57	-69,08
-0,43	0,58	-68,75
-0,42	0,59	-68,43
-0,41	0,60	-68,12
-0,40	0,61	-67,81
-0,39	0,62	-67,50
-0,38	0,63	-67,20
-0,37	0,64	-66,90
-0,36	0,65	-66,60
-0,35	0,66	-66,31
-0,34	0,67	-66,02
-0,33	0,68	-65,74
-0,32	0,69	-65,46
-0,31	0,70	-65,18
-0,30	0,71	-64,90
-0,29	0,72	-64,63
-0,28	0,73	-64,36



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-64,10
-0,26	0,75	-63,83
-0,25	0,76	-63,57
-0,24	0,77	-63,32
-0,23	0,78	-63,06
-0,22	0,79	-62,81
-0,21	0,80	-62,56
-0,20	0,81	-62,31
-0,19	0,82	-62,06
-0,18	0,83	-61,82
-0,17	0,84	-61,58
-0,16	0,85	-61,34
-0,15	0,86	-61,11
-0,14	0,87	-60,87
-0,13	0,88	-60,64
-0,12	0,89	-60,41
-0,11	0,90	-60,18
-0,10	0,91	-59,95
-0,09	0,92	-59,73
-0,08	0,93	-59,51
-0,07	0,94	-59,29
-0,06	0,95	-59,07
-0,05	0,96	-58,85
-0,04	0,97	-58,64
-0,03	0,98	-58,43
-0,02	0,99	-58,21
-0,01	1,00	-58,00
0,00	1,01	-57,80
0,01	1,02	-57,59
0,02	1,03	-57,38
0,03	1,04	-57,18
0,04	1,05	-56,98
0,05	1,06	-56,78
0,06	1,07	-56,58
0,07	1,08	-56,38
0,08	1,09	-56,19
0,09	1,10	-55,99
0,10	1,11	-55,80
0,11	1,12	-55,61
0,12	1,13	-55,42
0,13	1,14	-55,23
0,14	1,15	-55,04
0,15	1,16	-54,85
0,16	1,17	-54,67



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,17	1,18	-54,48
0,18	1,19	-54,30
0,19	1,20	-54,12
0,20	1,21	-53,94
0,21	1,22	-53,76
0,22	1,23	-53,58
0,23	1,24	-53,40
0,24	1,25	-53,23
0,25	1,26	-53,05
0,26	1,27	-52,88
0,27	1,28	-52,70
0,28	1,29	-52,53
0,29	1,30	-52,36
0,30	1,31	-52,19
0,31	1,32	-52,02
0,32	1,33	-51,86
0,33	1,34	-51,69
0,34	1,35	-51,52
0,35	1,36	-51,36
0,36	1,37	-51,19
0,37	1,38	-51,03
0,38	1,39	-50,87
0,39	1,40	-50,71
0,40	1,41	-50,55
0,41	1,42	-50,39
0,42	1,43	-50,23
0,43	1,44	-50,07
0,44	1,45	-49,91
0,45	1,46	-49,76
0,46	1,47	-49,60
0,47	1,48	-49,45
0,48	1,49	-49,30
0,49	1,50	-49,14
0,50	1,51	-48,99
0,51	1,52	-48,84
0,52	1,53	-48,69
0,53	1,54	-48,54
0,54	1,55	-48,39
0,55	1,56	-48,24
0,56	1,57	-48,09
0,57	1,58	-47,95
0,58	1,59	-47,80
0,59	1,60	-47,66
0,60	1,61	-47,51



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,61	1,62	-47,37
0,62	1,63	-47,22
0,63	1,64	-47,08
0,64	1,65	-46,94
0,65	1,66	-46,80
0,66	1,67	-46,66
0,67	1,68	-46,52
0,68	1,69	-46,38
0,69	1,70	-46,24
0,70	1,71	-46,10
0,71	1,72	-45,96
0,72	1,73	-45,83
0,73	1,74	-45,69
0,74	1,75	-45,56
0,75	1,76	-45,42
0,76	1,77	-45,29
0,77	1,78	-45,15
0,78	1,79	-45,02
0,79	1,80	-44,89
0,80	1,81	-44,75
0,81	1,82	-44,62
0,82	1,83	-44,49
0,83	1,84	-44,36
0,84	1,85	-44,23
0,85	1,86	-44,10
0,86	1,87	-43,97
0,87	1,88	-43,84
0,88	1,89	-43,72
0,89	1,90	-43,59
0,90	1,91	-43,46
0,91	1,92	-43,34
0,92	1,93	-43,21
0,93	1,94	-43,08
0,94	1,95	-42,96
0,95	1,96	-42,84
0,96	1,97	-42,71
0,97	1,98	-42,59
0,98	1,99	-42,47
0,99	2,00	-42,34
1,00	2,01	-42,22
1,01	2,02	-42,10
1,02	2,03	-41,98
1,03	2,04	-41,86
1,04	2,05	-41,74



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,05	2,06	-41,62
1,06	2,07	-41,50
1,07	2,08	-41,38
1,08	2,09	-41,26
1,09	2,10	-41,14
1,10	2,11	-41,03
1,11	2,12	-40,91
1,12	2,13	-40,79
1,13	2,14	-40,68
1,14	2,15	-40,56
1,15	2,16	-40,45
1,16	2,17	-40,33
1,17	2,18	-40,22
1,18	2,19	-40,10
1,19	2,20	-39,99
1,20	2,21	-39,87
1,21	2,22	-39,76
1,22	2,23	-39,65
1,23	2,24	-39,54
1,24	2,25	-39,42
1,25	2,26	-39,31
1,26	2,27	-39,20
1,27	2,28	-39,09
1,28	2,29	-38,98
1,29	2,30	-38,87
1,30	2,31	-38,76
1,31	2,32	-38,65
1,32	2,33	-38,54
1,33	2,34	-38,43
1,34	2,35	-38,33
1,35	2,36	-38,22
1,36	2,37	-38,11
1,37	2,38	-38,00
1,38	2,39	-37,90
1,39	2,40	-37,79
1,40	2,41	-37,68
1,41	2,42	-37,58
1,42	2,43	-37,47
1,43	2,44	-37,37
1,44	2,45	-37,26
1,45	2,46	-37,16
1,46	2,47	-37,05
1,47	2,48	-36,95
1,48	2,49	-36,85



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,49	2,50	-36,74
1,50	2,51	-36,64
1,51	2,52	-36,54
1,52	2,53	-36,44
1,53	2,54	-36,33
1,54	2,55	-36,23
1,55	2,56	-36,13
1,56	2,57	-36,03
1,57	2,58	-35,93
1,58	2,59	-35,83
1,59	2,60	-35,73
1,60	2,61	-35,63
1,61	2,62	-35,53
1,62	2,63	-35,43
1,63	2,64	-35,33
1,64	2,65	-35,23
1,65	2,66	-35,13
1,66	2,67	-35,04
1,67	2,68	-34,94
1,68	2,69	-34,84
1,69	2,70	-34,74
1,70	2,71	-34,65
1,71	2,72	-34,55
1,72	2,73	-34,45
1,73	2,74	-34,36
1,74	2,75	-34,26
1,75	2,76	-34,16
1,76	2,77	-34,07
1,77	2,78	-33,97
1,78	2,79	-33,88
1,79	2,80	-33,78
1,80	2,81	-33,69
1,81	2,82	-33,59
1,82	2,83	-33,50
1,83	2,84	-33,41
1,84	2,85	-33,31
1,85	2,86	-33,22
1,86	2,87	-33,13
1,87	2,88	-33,03
1,88	2,89	-32,94
1,89	2,90	-32,85
1,90	2,91	-32,76
1,91	2,92	-32,67
1,92	2,93	-32,57



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,93	2,94	-32,48
1,94	2,95	-32,39
1,95	2,96	-32,30
1,96	2,97	-32,21
1,97	2,98	-32,12
1,98	2,99	-32,03
1,99	3,00	-31,94
2,00	3,01	-31,85
2,01	3,02	-31,76
2,02	3,03	-31,67
2,03	3,04	-31,58
2,04	3,05	-31,49
2,05	3,06	-31,41
2,06	3,07	-31,32
2,07	3,08	-31,23
2,08	3,09	-31,14
2,09	3,10	-31,05
2,10	3,11	-30,97
2,11	3,12	-30,88
2,12	3,13	-30,79
2,13	3,14	-30,70
2,14	3,15	-30,62
2,15	3,16	-30,53
2,16	3,17	-30,45
2,17	3,18	-30,36
2,18	3,19	-30,27
2,19	3,20	-30,19
2,20	3,21	-30,10
2,21	3,22	-30,02
2,22	3,23	-29,93
2,23	3,24	-29,85
2,24	3,25	-29,76
2,25	3,26	-29,68
2,26	3,27	-29,59
2,27	3,28	-29,51
2,28	3,29	-29,43
2,29	3,30	-29,34
2,30	3,31	-29,26
2,31	3,32	-29,18
2,32	3,33	-29,09
2,33	3,34	-29,01
2,34	3,35	-28,93
2,35	3,36	-28,84
2,36	3,37	-28,76



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	-28,68
2,38	3,39	-28,60
2,39	3,40	-28,52
2,40	3,41	-28,43
2,41	3,42	-28,35
2,42	3,43	-28,27
2,43	3,44	-28,19
2,44	3,45	-28,11
2,45	3,46	-28,03
2,46	3,47	-27,95
2,47	3,48	-27,87
2,48	3,49	-27,79
2,49	3,50	-27,71
2,50	3,51	-27,63
2,51	3,52	-27,55
2,52	3,53	-27,47
2,53	3,54	-27,39
2,54	3,55	-27,31
2,55	3,56	-27,23
2,56	3,57	-27,15
2,57	3,58	-27,07
2,58	3,59	-26,99
2,59	3,60	-26,92
2,60	3,61	-26,84
2,61	3,62	-26,76
2,62	3,63	-26,68
2,63	3,64	-26,60
2,64	3,65	-26,53
2,65	3,66	-26,45
2,66	3,67	-26,37
2,67	3,68	-26,29
2,68	3,69	-26,22
2,69	3,70	-26,14
2,70	3,71	-26,06
2,71	3,72	-25,99
2,72	3,73	-25,91
2,73	3,74	-25,84
2,74	3,75	-25,76
2,75	3,76	-25,68
2,76	3,77	-25,61
2,77	3,78	-25,53
2,78	3,79	-25,46
2,79	3,80	-25,38
2,80	3,81	-25,31



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
2,81	3,82	-25,23
2,82	3,83	-25,16
2,83	3,84	-25,08
2,84	3,85	-25,01
2,85	3,86	-24,93
2,86	3,87	-24,86
2,87	3,88	-24,78
2,88	3,89	-24,71
2,89	3,90	-24,64
2,90	3,91	-24,56
2,91	3,92	-24,49
2,92	3,93	-24,42
2,93	3,94	-24,34
2,94	3,95	-24,27
2,95	3,96	-24,20
2,96	3,97	-24,12
2,97	3,98	-24,05
2,98	3,99	-23,98
2,99	4,00	-23,91
3,00	4,01	-23,83
3,01	4,02	-23,76
3,02	4,03	-23,69
3,03	4,04	-23,62
3,04	4,05	-23,55
3,05	4,06	-23,47
3,06	4,07	-23,40
3,07	4,08	-23,33
3,08	4,09	-23,26
3,09	4,10	-23,19
3,10	4,11	-23,12
3,11	4,12	-23,05
3,12	4,13	-22,98
3,13	4,14	-22,91
3,14	4,15	-22,84
3,15	4,16	-22,77
3,16	4,17	-22,70
3,17	4,18	-22,62
3,18	4,19	-22,55
3,19	4,20	-22,49
3,20	4,21	-22,42
3,21	4,22	-22,35
3,22	4,23	-22,28
3,23	4,24	-22,21
3,24	4,25	-22,14



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,25	4,26	-22,07
3,26	4,27	-22,00
3,27	4,28	-21,93
3,28	4,29	-21,86
3,29	4,30	-21,79
3,30	4,31	-21,72
3,31	4,32	-21,66
3,32	4,33	-21,59
3,33	4,34	-21,52
3,34	4,35	-21,45
3,35	4,36	-21,38
3,36	4,37	-21,32
3,37	4,38	-21,25
3,38	4,39	-21,18
3,39	4,40	-21,11
3,40	4,41	-21,05
3,41	4,42	-20,98
3,42	4,43	-20,91
3,43	4,44	-20,84
3,44	4,45	-20,78
3,45	4,46	-20,71
3,46	4,47	-20,64
3,47	4,48	-20,58
3,48	4,49	-20,51
3,49	4,50	-20,45
3,50	4,51	-20,38
3,51	4,52	-20,31
3,52	4,53	-20,25
3,53	4,54	-20,18
3,54	4,55	-20,12
3,55	4,56	-20,05
3,56	4,57	-19,98
3,57	4,58	-19,92
3,58	4,59	-19,85
3,59	4,60	-19,79
3,60	4,61	-19,72
3,61	4,62	-19,66
3,62	4,63	-19,59
3,63	4,64	-19,53
3,64	4,65	-19,46
3,65	4,66	-19,40
3,66	4,67	-19,33
3,67	4,68	-19,27
3,68	4,69	-19,20



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,69	4,70	-19,14
3,70	4,71	-19,08
3,71	4,72	-19,01
3,72	4,73	-18,95
3,73	4,74	-18,88
3,74	4,75	-18,82
3,75	4,76	-18,76
3,76	4,77	-18,69
3,77	4,78	-18,63
3,78	4,79	-18,57
3,79	4,80	-18,50
3,80	4,81	-18,44
3,81	4,82	-18,38
3,82	4,83	-18,31
3,83	4,84	-18,25
3,84	4,85	-18,19
3,85	4,86	-18,13
3,86	4,87	-18,06
3,87	4,88	-18,00
3,88	4,89	-17,94
3,89	4,90	-17,88
3,90	4,91	-17,81
3,91	4,92	-17,75
3,92	4,93	-17,69
3,93	4,94	-17,63
3,94	4,95	-17,57
3,95	4,96	-17,51
3,96	4,97	-17,44
3,97	4,98	-17,38
3,98	4,99	-17,32
3,99	5,00	-17,26
4,00	5,01	-17,20
4,01	5,02	-17,14
4,02	5,03	-17,08
4,03	5,04	-17,01
4,04	5,05	-16,95
4,05	5,06	-16,89
4,06	5,07	-16,83
4,07	5,08	-16,77
4,08	5,09	-16,71
4,09	5,10	-16,65
4,10	5,11	-16,59
4,11	5,12	-16,53
4,12	5,13	-16,47



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
4,13	5,14	-16,41
4,14	5,15	-16,35
4,15	5,16	-16,29
4,16	5,17	-16,23
4,17	5,18	-16,17
4,18	5,19	-16,11
4,19	5,20	-16,05
4,20	5,21	-15,99
4,21	5,22	-15,93
4,22	5,23	-15,87
4,23	5,24	-15,81
4,24	5,25	-15,75
4,25	5,26	-15,70
4,26	5,27	-15,64
4,27	5,28	-15,58
4,28	5,29	-15,52
4,29	5,30	-15,46
4,30	5,31	-15,40
4,31	5,32	-15,34
4,32	5,33	-15,28
4,33	5,34	-15,23
4,34	5,35	-15,17
4,35	5,36	-15,11
4,36	5,37	-15,05
4,37	5,38	-14,99
4,38	5,39	-14,93
4,39	5,40	-14,88
4,40	5,41	-14,82
4,41	5,42	-14,76
4,42	5,43	-14,70
4,43	5,44	-14,65
4,44	5,45	-14,59
4,45	5,46	-14,53
4,46	5,47	-14,47
4,47	5,48	-14,42
4,48	5,49	-14,36
4,49	5,50	-14,30
4,50	5,51	-14,24
4,51	5,52	-14,19
4,52	5,53	-14,13
4,53	5,54	-14,07
4,54	5,55	-14,02
4,55	5,56	-13,96
4,56	5,57	-13,90



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	-13,85
4,58	5,59	-13,79
4,59	5,60	-13,73
4,60	5,61	-13,68
4,61	5,62	-13,62
4,62	5,63	-13,57
4,63	5,64	-13,51
4,64	5,65	-13,45
4,65	5,66	-13,40
4,66	5,67	-13,34
4,67	5,68	-13,29
4,68	5,69	-13,23
4,69	5,70	-13,17
4,70	5,71	-13,12
4,71	5,72	-13,06
4,72	5,73	-13,01
4,73	5,74	-12,95
4,74	5,75	-12,90
4,75	5,76	-12,84
4,76	5,77	-12,79
4,77	5,78	-12,73
4,78	5,79	-12,68
4,79	5,80	-12,62
4,80	5,81	-12,57
4,81	5,82	-12,51
4,82	5,83	-12,46
4,83	5,84	-12,40
4,84	5,85	-12,35
4,85	5,86	-12,29
4,86	5,87	-12,24
4,87	5,88	-12,18
4,88	5,89	-12,13
4,89	5,90	-12,08
4,90	5,91	-12,02
4,91	5,92	-11,97
4,92	5,93	-11,91
4,93	5,94	-11,86
4,94	5,95	-11,81
4,95	5,96	-11,75
4,96	5,97	-11,70
4,97	5,98	-11,64
4,98	5,99	-11,59
4,99	6,00	-11,54
5,00	6,01	-11,48



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,01	6,02	-11,43
5,02	6,03	-11,38
5,03	6,04	-11,32
5,04	6,05	-11,27
5,05	6,06	-11,22
5,06	6,07	-11,16
5,07	6,08	-11,11
5,08	6,09	-11,06
5,09	6,10	-11,00
5,10	6,11	-10,95
5,11	6,12	-10,90
5,12	6,13	-10,85
5,13	6,14	-10,79
5,14	6,15	-10,74
5,15	6,16	-10,69
5,16	6,17	-10,64
5,17	6,18	-10,58
5,18	6,19	-10,53
5,19	6,20	-10,48
5,20	6,21	-10,43
5,21	6,22	-10,37
5,22	6,23	-10,32
5,23	6,24	-10,27
5,24	6,25	-10,22
5,25	6,26	-10,17
5,26	6,27	-10,11
5,27	6,28	-10,06
5,28	6,29	-10,01
5,29	6,30	-9,96
5,30	6,31	-9,91
5,31	6,32	-9,85
5,32	6,33	-9,80
5,33	6,34	-9,75
5,34	6,35	-9,70
5,35	6,36	-9,65
5,36	6,37	-9,60
5,37	6,38	-9,55
5,38	6,39	-9,50
5,39	6,40	-9,44
5,40	6,41	-9,39
5,41	6,42	-9,34
5,42	6,43	-9,29
5,43	6,44	-9,24
5,44	6,45	-9,19



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,45	6,46	-9,14
5,46	6,47	-9,09
5,47	6,48	-9,04
5,48	6,49	-8,99
5,49	6,50	-8,94
5,50	6,51	-8,89
5,51	6,52	-8,84
5,52	6,53	-8,79
5,53	6,54	-8,73
5,54	6,55	-8,68
5,55	6,56	-8,63
5,56	6,57	-8,58
5,57	6,58	-8,53
5,58	6,59	-8,48
5,59	6,60	-8,43
5,60	6,61	-8,38
5,61	6,62	-8,33
5,62	6,63	-8,28
5,63	6,64	-8,23
5,64	6,65	-8,19
5,65	6,66	-8,14
5,66	6,67	-8,09
5,67	6,68	-8,04
5,68	6,69	-7,99
5,69	6,70	-7,94
5,70	6,71	-7,89
5,71	6,72	-7,84
5,72	6,73	-7,79
5,73	6,74	-7,74
5,74	6,75	-7,69
5,75	6,76	-7,64
5,76	6,77	-7,59
5,77	6,78	-7,54
5,78	6,79	-7,50
5,79	6,80	-7,45
5,80	6,81	-7,40
5,81	6,82	-7,35
5,82	6,83	-7,30
5,83	6,84	-7,25
5,84	6,85	-7,20
5,85	6,86	-7,15
5,86	6,87	-7,11
5,87	6,88	-7,06
5,88	6,89	-7,01



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	-6,96
5,90	6,91	-6,91
5,91	6,92	-6,86
5,92	6,93	-6,82
5,93	6,94	-6,77
5,94	6,95	-6,72
5,95	6,96	-6,67
5,96	6,97	-6,62
5,97	6,98	-6,58
5,98	6,99	-6,53
5,99	7,00	-6,48
6,00	7,01	-6,43
6,01	7,02	-6,38
6,02	7,03	-6,34
6,03	7,04	-6,29
6,04	7,05	-6,24
6,05	7,06	-6,19
6,06	7,07	-6,15
6,07	7,08	-6,10
6,08	7,09	-6,05
6,09	7,10	-6,00
6,10	7,11	-5,96
6,11	7,12	-5,91
6,12	7,13	-5,86
6,13	7,14	-5,81
6,14	7,15	-5,77
6,15	7,16	-5,72
6,16	7,17	-5,67
6,17	7,18	-5,63
6,18	7,19	-5,58
6,19	7,20	-5,53
6,20	7,21	-5,49
6,21	7,22	-5,44
6,22	7,23	-5,39
6,23	7,24	-5,35
6,24	7,25	-5,30
6,25	7,26	-5,25
6,26	7,27	-5,21
6,27	7,28	-5,16
6,28	7,29	-5,11
6,29	7,30	-5,07
6,30	7,31	-5,02
6,31	7,32	-4,97
6,32	7,33	-4,93



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,33	7,34	-4,88
6,34	7,35	-4,84
6,35	7,36	-4,79
6,36	7,37	-4,74
6,37	7,38	-4,70
6,38	7,39	-4,65
6,39	7,40	-4,61
6,40	7,41	-4,56
6,41	7,42	-4,51
6,42	7,43	-4,47
6,43	7,44	-4,42
6,44	7,45	-4,38
6,45	7,46	-4,33
6,46	7,47	-4,29
6,47	7,48	-4,24
6,48	7,49	-4,19
6,49	7,50	-4,15
6,50	7,51	-4,10
6,51	7,52	-4,06
6,52	7,53	-4,01
6,53	7,54	-3,97
6,54	7,55	-3,92
6,55	7,56	-3,88
6,56	7,57	-3,83
6,57	7,58	-3,79
6,58	7,59	-3,74
6,59	7,60	-3,70
6,60	7,61	-3,65
6,61	7,62	-3,61
6,62	7,63	-3,56
6,63	7,64	-3,52
6,64	7,65	-3,47
6,65	7,66	-3,43
6,66	7,67	-3,38
6,67	7,68	-3,34
6,68	7,69	-3,29
6,69	7,70	-3,25
6,70	7,71	-3,20
6,71	7,72	-3,16
6,72	7,73	-3,11
6,73	7,74	-3,07
6,74	7,75	-3,03
6,75	7,76	-2,98
6,76	7,77	-2,94



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,77	7,78	-2,89
6,78	7,79	-2,85
6,79	7,80	-2,80
6,80	7,81	-2,76
6,81	7,82	-2,72
6,82	7,83	-2,67
6,83	7,84	-2,63
6,84	7,85	-2,58
6,85	7,86	-2,54
6,86	7,87	-2,50
6,87	7,88	-2,45
6,88	7,89	-2,41
6,89	7,90	-2,36
6,90	7,91	-2,32
6,91	7,92	-2,28
6,92	7,93	-2,23
6,93	7,94	-2,19
6,94	7,95	-2,15
6,95	7,96	-2,10
6,96	7,97	-2,06
6,97	7,98	-2,02
6,98	7,99	-1,97
6,99	8,00	-1,93
7,00	8,01	-1,89
7,01	8,02	-1,84
7,02	8,03	-1,80
7,03	8,04	-1,76
7,04	8,05	-1,71
7,05	8,06	-1,67
7,06	8,07	-1,63
7,07	8,08	-1,58
7,08	8,09	-1,54
7,09	8,10	-1,50
7,10	8,11	-1,45
7,11	8,12	-1,41
7,12	8,13	-1,37
7,13	8,14	-1,33
7,14	8,15	-1,28
7,15	8,16	-1,24
7,16	8,17	-1,20
7,17	8,18	-1,16
7,18	8,19	-1,11
7,19	8,20	-1,07
7,20	8,21	-1,03



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
7,21	8,22	-0,98
7,22	8,23	-0,94
7,23	8,24	-0,90
7,24	8,25	-0,86
7,25	8,26	-0,82
7,26	8,27	-0,77
7,27	8,28	-0,73
7,28	8,29	-0,69
7,29	8,30	-0,65
7,30	8,31	-0,60
7,31	8,32	-0,56
7,32	8,33	-0,52
7,33	8,34	-0,48
7,34	8,35	-0,44
7,35	8,36	-0,39
7,36	8,37	-0,35
7,37	8,38	-0,31
7,38	8,39	-0,27
7,39	8,40	-0,23
7,40	8,41	-0,18
7,41	8,42	-0,14
7,42	8,43	-0,10
7,43	8,44	-0,06
7,44	8,45	-0,02
7,45	8,46	0,02
7,46	8,47	0,07
7,47	8,48	0,11
7,48	8,49	0,15
7,49	8,50	0,19
7,50	8,51	0,23
7,51	8,52	0,27
7,52	8,53	0,31
7,53	8,54	0,36
7,54	8,55	0,40
7,55	8,56	0,44
7,56	8,57	0,48
7,57	8,58	0,52
7,58	8,59	0,56
7,59	8,60	0,60
7,60	8,61	0,64
7,61	8,62	0,69
7,62	8,63	0,73
7,63	8,64	0,77
7,64	8,65	0,81



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
7,65	8,66	0,85
7,66	8,67	0,89
7,67	8,68	0,93
7,68	8,69	0,97
7,69	8,70	1,01
7,70	8,71	1,05
7,71	8,72	1,09
7,72	8,73	1,14
7,73	8,74	1,18
7,74	8,75	1,22
7,75	8,76	1,26
7,76	8,77	1,30
7,77	8,78	1,34
7,78	8,79	1,38
7,79	8,80	1,42
7,80	8,81	1,46
7,81	8,82	1,50
7,82	8,83	1,54
7,83	8,84	1,58
7,84	8,85	1,62
7,85	8,86	1,66
7,86	8,87	1,70
7,87	8,88	1,74
7,88	8,89	1,78
7,89	8,90	1,82
7,90	8,91	1,86
7,91	8,92	1,90
7,92	8,93	1,94
7,93	8,94	1,98
7,94	8,95	2,02
7,95	8,96	2,06
7,96	8,97	2,10
7,97	8,98	2,14
7,98	8,99	2,18
7,99	9,00	2,22
8,00	9,01	2,26
8,01	9,02	2,30
8,02	9,03	2,34
8,03	9,04	2,38
8,04	9,05	2,42
8,05	9,06	2,46
8,06	9,07	2,50
8,07	9,08	2,54
8,08	9,09	2,58



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,09	9,10	2,62
8,10	9,11	2,66
8,11	9,12	2,70
8,12	9,13	2,74
8,13	9,14	2,77
8,14	9,15	2,81
8,15	9,16	2,85
8,16	9,17	2,89
8,17	9,18	2,93
8,18	9,19	2,97
8,19	9,20	3,01
8,20	9,21	3,05
8,21	9,22	3,09
8,22	9,23	3,13
8,23	9,24	3,17
8,24	9,25	3,21
8,25	9,26	3,24
8,26	9,27	3,28
8,27	9,28	3,32
8,28	9,29	3,36
8,29	9,30	3,40
8,30	9,31	3,44
8,31	9,32	3,48
8,32	9,33	3,52
8,33	9,34	3,56
8,34	9,35	3,59
8,35	9,36	3,63
8,36	9,37	3,67
8,37	9,38	3,71
8,38	9,39	3,75
8,39	9,40	3,79
8,40	9,41	3,83
8,41	9,42	3,86
8,42	9,43	3,90
8,43	9,44	3,94
8,44	9,45	3,98
8,45	9,46	4,02
8,46	9,47	4,06
8,47	9,48	4,09
8,48	9,49	4,13
8,49	9,50	4,17
8,50	9,51	4,21
8,51	9,52	4,25
8,52	9,53	4,29



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,53	9,54	4,32
8,54	9,55	4,36
8,55	9,56	4,40
8,56	9,57	4,44
8,57	9,58	4,48
8,58	9,59	4,51
8,59	9,60	4,55
8,60	9,61	4,59
8,61	9,62	4,63
8,62	9,63	4,67
8,63	9,64	4,70
8,64	9,65	4,74
8,65	9,66	4,78
8,66	9,67	4,82
8,67	9,68	4,85
8,68	9,69	4,89
8,69	9,70	4,93
8,70	9,71	4,97
8,71	9,72	5,00
8,72	9,73	5,04
8,73	9,74	5,08
8,74	9,75	5,12
8,75	9,76	5,15
8,76	9,77	5,19
8,77	9,78	5,23
8,78	9,79	5,27
8,79	9,80	5,30
8,80	9,81	5,34
8,81	9,82	5,38
8,82	9,83	5,42
8,83	9,84	5,45
8,84	9,85	5,49
8,85	9,86	5,53
8,86	9,87	5,57
8,87	9,88	5,60
8,88	9,89	5,64
8,89	9,90	5,68
8,90	9,91	5,71
8,91	9,92	5,75
8,92	9,93	5,79
8,93	9,94	5,82
8,94	9,95	5,86
8,95	9,96	5,90
8,96	9,97	5,94



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,97	9,98	5,97
8,98	9,99	6,01
8,99	10,00	6,05
9,00	10,01	6,08
9,01	10,02	6,12
9,02	10,03	6,16
9,03	10,04	6,19
9,04	10,05	6,23
9,05	10,06	6,27
9,06	10,07	6,30
9,07	10,08	6,34
9,08	10,09	6,38
9,09	10,10	6,41
9,10	10,11	6,45
9,11	10,12	6,49
9,12	10,13	6,52
9,13	10,14	6,56
9,14	10,15	6,60
9,15	10,16	6,63
9,16	10,17	6,67
9,17	10,18	6,70
9,18	10,19	6,74
9,19	10,20	6,78
9,20	10,21	6,81
9,21	10,22	6,85
9,22	10,23	6,89
9,23	10,24	6,92
9,24	10,25	6,96
9,25	10,26	6,99
9,26	10,27	7,03
9,27	10,28	7,07
9,28	10,29	7,10
9,29	10,30	7,14
9,30	10,31	7,17
9,31	10,32	7,21
9,32	10,33	7,25
9,33	10,34	7,28
9,34	10,35	7,32
9,35	10,36	7,35
9,36	10,37	7,39
9,37	10,38	7,43
9,38	10,39	7,46
9,39	10,40	7,50
9,40	10,41	7,53



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,41	10,42	7,57
9,42	10,43	7,61
9,43	10,44	7,64
9,44	10,45	7,68
9,45	10,46	7,71
9,46	10,47	7,75
9,47	10,48	7,78
9,48	10,49	7,82
9,49	10,50	7,85
9,50	10,51	7,89
9,51	10,52	7,93
9,52	10,53	7,96
9,53	10,54	8,00
9,54	10,55	8,03
9,55	10,56	8,07
9,56	10,57	8,10
9,57	10,58	8,14
9,58	10,59	8,17
9,59	10,60	8,21
9,60	10,61	8,24
9,61	10,62	8,28
9,62	10,63	8,31
9,63	10,64	8,35
9,64	10,65	8,38
9,65	10,66	8,42
9,66	10,67	8,45
9,67	10,68	8,49
9,68	10,69	8,53
9,69	10,70	8,56
9,70	10,71	8,60
9,71	10,72	8,63
9,72	10,73	8,67
9,73	10,74	8,70
9,74	10,75	8,73
9,75	10,76	8,77
9,76	10,77	8,80
9,77	10,78	8,84
9,78	10,79	8,87
9,79	10,80	8,91
9,80	10,81	8,94
9,81	10,82	8,98
9,82	10,83	9,01
9,83	10,84	9,05
9,84	10,85	9,08



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,85	10,86	9,12
9,86	10,87	9,15
9,87	10,88	9,19
9,88	10,89	9,22
9,89	10,90	9,26
9,90	10,91	9,29
9,91	10,92	9,33
9,92	10,93	9,36
9,93	10,94	9,39
9,94	10,95	9,43
9,95	10,96	9,46
9,96	10,97	9,50
9,97	10,98	9,53
9,98	10,99	9,57
9,99	11,00	9,60
10,00	11,01	9,63
10,01	11,02	9,67
10,02	11,03	9,70
10,03	11,04	9,74
10,04	11,05	9,77
10,05	11,06	9,81
10,06	11,07	9,84
10,07	11,08	9,87
10,08	11,09	9,91
10,09	11,10	9,94
10,10	11,11	9,98
10,11	11,12	10,01
10,12	11,13	10,05
10,13	11,14	10,08
10,14	11,15	10,11
10,15	11,16	10,15
10,16	11,17	10,18
10,17	11,18	10,22
10,18	11,19	10,25
10,19	11,20	10,28
10,20	11,21	10,32
10,21	11,22	10,35
10,22	11,23	10,38
10,23	11,24	10,42
10,24	11,25	10,45
10,25	11,26	10,49
10,26	11,27	10,52
10,27	11,28	10,55
10,28	11,29	10,59



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,29	11,30	10,62
10,30	11,31	10,65
10,31	11,32	10,69
10,32	11,33	10,72
10,33	11,34	10,76
10,34	11,35	10,79
10,35	11,36	10,82
10,36	11,37	10,86
10,37	11,38	10,89
10,38	11,39	10,92
10,39	11,40	10,96
10,40	11,41	10,99
10,41	11,42	11,02
10,42	11,43	11,06
10,43	11,44	11,09
10,44	11,45	11,12
10,45	11,46	11,16
10,46	11,47	11,19
10,47	11,48	11,22
10,48	11,49	11,26
10,49	11,50	11,29
10,50	11,51	11,32
10,51	11,52	11,36
10,52	11,53	11,39
10,53	11,54	11,42
10,54	11,55	11,46
10,55	11,56	11,49
10,56	11,57	11,52
10,57	11,58	11,55
10,58	11,59	11,59
10,59	11,60	11,62
10,60	11,61	11,65
10,61	11,62	11,69
10,62	11,63	11,72
10,63	11,64	11,75
10,64	11,65	11,79
10,65	11,66	11,82
10,66	11,67	11,85
10,67	11,68	11,88
10,68	11,69	11,92
10,69	11,70	11,95
10,70	11,71	11,98
10,71	11,72	12,02
10,72	11,73	12,05



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	12,08
10,74	11,75	12,11
10,75	11,76	12,15
10,76	11,77	12,18
10,77	11,78	12,21
10,78	11,79	12,24
10,79	11,80	12,28
10,80	11,81	12,31
10,81	11,82	12,34
10,82	11,83	12,38
10,83	11,84	12,41
10,84	11,85	12,44
10,85	11,86	12,47
10,86	11,87	12,51
10,87	11,88	12,54
10,88	11,89	12,57
10,89	11,90	12,60
10,90	11,91	12,63
10,91	11,92	12,67
10,92	11,93	12,70
10,93	11,94	12,73
10,94	11,95	12,76
10,95	11,96	12,80
10,96	11,97	12,83
10,97	11,98	12,86
10,98	11,99	12,89
10,99	12,00	12,93
11,00	12,01	12,96
11,01	12,02	12,99
11,02	12,03	13,02
11,03	12,04	13,05
11,04	12,05	13,09
11,05	12,06	13,12
11,06	12,07	13,15
11,07	12,08	13,18
11,08	12,09	13,21
11,09	12,10	13,25
11,10	12,11	13,28
11,11	12,12	13,31
11,12	12,13	13,34
11,13	12,14	13,37
11,14	12,15	13,41
11,15	12,16	13,44
11,16	12,17	13,47



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,17	12,18	13,50
11,18	12,19	13,53
11,19	12,20	13,57
11,20	12,21	13,60
11,21	12,22	13,63
11,22	12,23	13,66
11,23	12,24	13,69
11,24	12,25	13,72
11,25	12,26	13,76
11,26	12,27	13,79
11,27	12,28	13,82
11,28	12,29	13,85
11,29	12,30	13,88
11,30	12,31	13,91
11,31	12,32	13,95
11,32	12,33	13,98
11,33	12,34	14,01
11,34	12,35	14,04
11,35	12,36	14,07
11,36	12,37	14,10
11,37	12,38	14,14
11,38	12,39	14,17
11,39	12,40	14,20
11,40	12,41	14,23
11,41	12,42	14,26
11,42	12,43	14,29
11,43	12,44	14,32
11,44	12,45	14,36
11,45	12,46	14,39
11,46	12,47	14,42
11,47	12,48	14,45
11,48	12,49	14,48
11,49	12,50	14,51
11,50	12,51	14,54
11,51	12,52	14,57
11,52	12,53	14,61
11,53	12,54	14,64
11,54	12,55	14,67
11,55	12,56	14,70
11,56	12,57	14,73
11,57	12,58	14,76
11,58	12,59	14,79
11,59	12,60	14,82
11,60	12,61	14,86



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	14,89
11,62	12,63	14,92
11,63	12,64	14,95
11,64	12,65	14,98
11,65	12,66	15,01
11,66	12,67	15,04
11,67	12,68	15,07
11,68	12,69	15,10
11,69	12,70	15,13
11,70	12,71	15,16
11,71	12,72	15,20
11,72	12,73	15,23
11,73	12,74	15,26
11,74	12,75	15,29
11,75	12,76	15,32
11,76	12,77	15,35
11,77	12,78	15,38
11,78	12,79	15,41
11,79	12,80	15,44
11,80	12,81	15,47
11,81	12,82	15,50
11,82	12,83	15,53
11,83	12,84	15,56
11,84	12,85	15,60
11,85	12,86	15,63
11,86	12,87	15,66
11,87	12,88	15,69
11,88	12,89	15,72
11,89	12,90	15,75
11,90	12,91	15,78
11,91	12,92	15,81
11,92	12,93	15,84
11,93	12,94	15,87
11,94	12,95	15,90
11,95	12,96	15,93
11,96	12,97	15,96
11,97	12,98	15,99
11,98	12,99	16,02
11,99	13,00	16,05
12,00	13,01	16,08
12,01	13,02	16,11
12,02	13,03	16,14
12,03	13,04	16,17
12,04	13,05	16,20



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,05	13,06	16,24
12,06	13,07	16,27
12,07	13,08	16,30
12,08	13,09	16,33
12,09	13,10	16,36
12,10	13,11	16,39
12,11	13,12	16,42
12,12	13,13	16,45
12,13	13,14	16,48
12,14	13,15	16,51
12,15	13,16	16,54
12,16	13,17	16,57
12,17	13,18	16,60
12,18	13,19	16,63
12,19	13,20	16,66
12,20	13,21	16,69
12,21	13,22	16,72
12,22	13,23	16,75
12,23	13,24	16,78
12,24	13,25	16,81
12,25	13,26	16,84
12,26	13,27	16,87
12,27	13,28	16,90
12,28	13,29	16,93
12,29	13,30	16,96
12,30	13,31	16,99
12,31	13,32	17,02
12,32	13,33	17,05
12,33	13,34	17,08
12,34	13,35	17,11
12,35	13,36	17,14
12,36	13,37	17,17
12,37	13,38	17,20
12,38	13,39	17,22
12,39	13,40	17,25
12,40	13,41	17,28
12,41	13,42	17,31
12,42	13,43	17,34
12,43	13,44	17,37
12,44	13,45	17,40
12,45	13,46	17,43
12,46	13,47	17,46
12,47	13,48	17,49
12,48	13,49	17,52



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,49	13,50	17,55
12,50	13,51	17,58
12,51	13,52	17,61
12,52	13,53	17,64
12,53	13,54	17,67
12,54	13,55	17,70
12,55	13,56	17,73
12,56	13,57	17,76
12,57	13,58	17,79
12,58	13,59	17,82
12,59	13,60	17,85
12,60	13,61	17,87
12,61	13,62	17,90
12,62	13,63	17,93
12,63	13,64	17,96
12,64	13,65	17,99
12,65	13,66	18,02
12,66	13,67	18,05
12,67	13,68	18,08
12,68	13,69	18,11
12,69	13,70	18,14
12,70	13,71	18,17
12,71	13,72	18,20
12,72	13,73	18,23
12,73	13,74	18,26
12,74	13,75	18,28
12,75	13,76	18,31
12,76	13,77	18,34
12,77	13,78	18,37
12,78	13,79	18,40
12,79	13,80	18,43
12,80	13,81	18,46
12,81	13,82	18,49
12,82	13,83	18,52
12,83	13,84	18,55
12,84	13,85	18,58
12,85	13,86	18,60
12,86	13,87	18,63
12,87	13,88	18,66
12,88	13,89	18,69
12,89	13,90	18,72
12,90	13,91	18,75
12,91	13,92	18,78
12,92	13,93	18,81



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	18,84
12,94	13,95	18,86
12,95	13,96	18,89
12,96	13,97	18,92
12,97	13,98	18,95
12,98	13,99	18,98
12,99	14,00	19,01
13,00	14,01	19,04
13,01	14,02	19,07
13,02	14,03	19,09
13,03	14,04	19,12
13,04	14,05	19,15
13,05	14,06	19,18
13,06	14,07	19,21
13,07	14,08	19,24
13,08	14,09	19,27
13,09	14,10	19,30
13,10	14,11	19,32
13,11	14,12	19,35
13,12	14,13	19,38
13,13	14,14	19,41
13,14	14,15	19,44
13,15	14,16	19,47
13,16	14,17	19,50
13,17	14,18	19,52
13,18	14,19	19,55
13,19	14,20	19,58
13,20	14,21	19,61
13,21	14,22	19,64
13,22	14,23	19,67
13,23	14,24	19,69
13,24	14,25	19,72
13,25	14,26	19,75
13,26	14,27	19,78
13,27	14,28	19,81
13,28	14,29	19,84
13,29	14,30	19,86
13,30	14,31	19,89
13,31	14,32	19,92
13,32	14,33	19,95
13,33	14,34	19,98
13,34	14,35	20,01
13,35	14,36	20,03
13,36	14,37	20,06



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,37	14,38	20,09
13,38	14,39	20,12
13,39	14,40	20,15
13,40	14,41	20,18
13,41	14,42	20,20
13,42	14,43	20,23
13,43	14,44	20,26
13,44	14,45	20,29
13,45	14,46	20,32
13,46	14,47	20,34
13,47	14,48	20,37
13,48	14,49	20,40
13,49	14,50	20,43
13,50	14,51	20,46
13,51	14,52	20,48
13,52	14,53	20,51
13,53	14,54	20,54
13,54	14,55	20,57
13,55	14,56	20,60
13,56	14,57	20,62
13,57	14,58	20,65
13,58	14,59	20,68
13,59	14,60	20,71
13,60	14,61	20,74
13,61	14,62	20,76
13,62	14,63	20,79
13,63	14,64	20,82
13,64	14,65	20,85
13,65	14,66	20,87
13,66	14,67	20,90
13,67	14,68	20,93
13,68	14,69	20,96
13,69	14,70	20,99
13,70	14,71	21,01
13,71	14,72	21,04
13,72	14,73	21,07
13,73	14,74	21,10
13,74	14,75	21,12
13,75	14,76	21,15
13,76	14,77	21,18
13,77	14,78	21,21
13,78	14,79	21,24
13,79	14,80	21,26
13,80	14,81	21,29



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,81	14,82	21,32
13,82	14,83	21,35
13,83	14,84	21,37
13,84	14,85	21,40
13,85	14,86	21,43
13,86	14,87	21,46
13,87	14,88	21,48
13,88	14,89	21,51
13,89	14,90	21,54
13,90	14,91	21,57
13,91	14,92	21,59
13,92	14,93	21,62
13,93	14,94	21,65
13,94	14,95	21,68
13,95	14,96	21,70
13,96	14,97	21,73
13,97	14,98	21,76
13,98	14,99	21,79
13,99	15,00	21,81
14,00	15,01	21,84
14,01	15,02	21,87
14,02	15,03	21,89
14,03	15,04	21,92
14,04	15,05	21,95
14,05	15,06	21,98
14,06	15,07	22,00
14,07	15,08	22,03
14,08	15,09	22,06
14,09	15,10	22,09
14,10	15,11	22,11
14,11	15,12	22,14
14,12	15,13	22,17
14,13	15,14	22,19
14,14	15,15	22,22
14,15	15,16	22,25
14,16	15,17	22,28
14,17	15,18	22,30
14,18	15,19	22,33
14,19	15,20	22,36
14,20	15,21	22,38
14,21	15,22	22,41
14,22	15,23	22,44
14,23	15,24	22,46
14,24	15,25	22,49



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
14,25	15,26	22,52
14,26	15,27	22,55
14,27	15,28	22,57
14,28	15,29	22,60
14,29	15,30	22,63
14,30	15,31	22,65
14,31	15,32	22,68
14,32	15,33	22,71
14,33	15,34	22,73
14,34	15,35	22,76
14,35	15,36	22,79
14,36	15,37	22,81
14,37	15,38	22,84
14,38	15,39	22,87
14,39	15,40	22,90
14,40	15,41	22,92
14,41	15,42	22,95
14,42	15,43	22,98
14,43	15,44	23,00
14,44	15,45	23,03
14,45	15,46	23,06
14,46	15,47	23,08
14,47	15,48	23,11
14,48	15,49	23,14
14,49	15,50	23,16
14,50	15,51	23,19
14,51	15,52	23,22
14,52	15,53	23,24
14,53	15,54	23,27
14,54	15,55	23,30
14,55	15,56	23,32
14,56	15,57	23,35
14,57	15,58	23,38
14,58	15,59	23,40
14,59	15,60	23,43
14,60	15,61	23,46
14,61	15,62	23,48
14,62	15,63	23,51
14,63	15,64	23,54
14,64	15,65	23,56
14,65	15,66	23,59
14,66	15,67	23,61
14,67	15,68	23,64
14,68	15,69	23,67



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	23,69
14,70	15,71	23,72
14,71	15,72	23,75
14,72	15,73	23,77
14,73	15,74	23,80
14,74	15,75	23,83
14,75	15,76	23,85
14,76	15,77	23,88
14,77	15,78	23,91
14,78	15,79	23,93
14,79	15,80	23,96
14,80	15,81	23,98
14,81	15,82	24,01
14,82	15,83	24,04
14,83	15,84	24,06
14,84	15,85	24,09
14,85	15,86	24,12
14,86	15,87	24,14
14,87	15,88	24,17
14,88	15,89	24,19
14,89	15,90	24,22
14,90	15,91	24,25
14,91	15,92	24,27
14,92	15,93	24,30
14,93	15,94	24,32
14,94	15,95	24,35
14,95	15,96	24,38
14,96	15,97	24,40
14,97	15,98	24,43
14,98	15,99	24,46
14,99	16,00	24,48
15,00	16,01	24,51
15,01	16,02	24,53
15,02	16,03	24,56
15,03	16,04	24,59
15,04	16,05	24,61
15,05	16,06	24,64
15,06	16,07	24,66
15,07	16,08	24,69
15,08	16,09	24,72
15,09	16,10	24,74
15,10	16,11	24,77
15,11	16,12	24,79
15,12	16,13	24,82



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	24,85
15,14	16,15	24,87
15,15	16,16	24,90
15,16	16,17	24,92
15,17	16,18	24,95
15,18	16,19	24,97
15,19	16,20	25,00
15,20	16,21	25,03
15,21	16,22	25,05
15,22	16,23	25,08
15,23	16,24	25,10
15,24	16,25	25,13
15,25	16,26	25,16
15,26	16,27	25,18
15,27	16,28	25,21
15,28	16,29	25,23
15,29	16,30	25,26
15,30	16,31	25,28
15,31	16,32	25,31
15,32	16,33	25,34
15,33	16,34	25,36
15,34	16,35	25,39
15,35	16,36	25,41
15,36	16,37	25,44
15,37	16,38	25,46
15,38	16,39	25,49
15,39	16,40	25,51
15,40	16,41	25,54
15,41	16,42	25,57
15,42	16,43	25,59
15,43	16,44	25,62
15,44	16,45	25,64
15,45	16,46	25,67
15,46	16,47	25,69
15,47	16,48	25,72
15,48	16,49	25,74
15,49	16,50	25,77
15,50	16,51	25,80
15,51	16,52	25,82
15,52	16,53	25,85
15,53	16,54	25,87
15,54	16,55	25,90
15,55	16,56	25,92
15,56	16,57	25,95



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,57	16,58	25,97
15,58	16,59	26,00
15,59	16,60	26,02
15,60	16,61	26,05
15,61	16,62	26,07
15,62	16,63	26,10
15,63	16,64	26,13
15,64	16,65	26,15
15,65	16,66	26,18
15,66	16,67	26,20
15,67	16,68	26,23
15,68	16,69	26,25
15,69	16,70	26,28
15,70	16,71	26,30
15,71	16,72	26,33
15,72	16,73	26,35
15,73	16,74	26,38
15,74	16,75	26,40
15,75	16,76	26,43
15,76	16,77	26,45
15,77	16,78	26,48
15,78	16,79	26,50
15,79	16,80	26,53
15,80	16,81	26,55
15,81	16,82	26,58
15,82	16,83	26,60
15,83	16,84	26,63
15,84	16,85	26,65
15,85	16,86	26,68
15,86	16,87	26,70
15,87	16,88	26,73
15,88	16,89	26,76
15,89	16,90	26,78
15,90	16,91	26,81
15,91	16,92	26,83
15,92	16,93	26,86
15,93	16,94	26,88
15,94	16,95	26,91
15,95	16,96	26,93
15,96	16,97	26,95
15,97	16,98	26,98
15,98	16,99	27,00
15,99	17,00	27,03
16,00	17,01	27,05



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	27,08
16,02	17,03	27,10
16,03	17,04	27,13
16,04	17,05	27,15
16,05	17,06	27,18
16,06	17,07	27,20
16,07	17,08	27,23
16,08	17,09	27,25
16,09	17,10	27,28
16,10	17,11	27,30
16,11	17,12	27,33
16,12	17,13	27,35
16,13	17,14	27,38
16,14	17,15	27,40
16,15	17,16	27,43
16,16	17,17	27,45
16,17	17,18	27,48
16,18	17,19	27,50
16,19	17,20	27,53
16,20	17,21	27,55
16,21	17,22	27,58
16,22	17,23	27,60
16,23	17,24	27,62
16,24	17,25	27,65
16,25	17,26	27,67
16,26	17,27	27,70
16,27	17,28	27,72
16,28	17,29	27,75
16,29	17,30	27,77
16,30	17,31	27,80
16,31	17,32	27,82
16,32	17,33	27,85
16,33	17,34	27,87
16,34	17,35	27,90
16,35	17,36	27,92
16,36	17,37	27,94
16,37	17,38	27,97
16,38	17,39	27,99
16,39	17,40	28,02
16,40	17,41	28,04
16,41	17,42	28,07
16,42	17,43	28,09
16,43	17,44	28,12
16,44	17,45	28,14



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,45	17,46	28,16
16,46	17,47	28,19
16,47	17,48	28,21
16,48	17,49	28,24
16,49	17,50	28,26
16,50	17,51	28,29
16,51	17,52	28,31
16,52	17,53	28,34
16,53	17,54	28,36
16,54	17,55	28,38
16,55	17,56	28,41
16,56	17,57	28,43
16,57	17,58	28,46
16,58	17,59	28,48
16,59	17,60	28,51
16,60	17,61	28,53
16,61	17,62	28,55
16,62	17,63	28,58
16,63	17,64	28,60
16,64	17,65	28,63
16,65	17,66	28,65
16,66	17,67	28,68
16,67	17,68	28,70
16,68	17,69	28,72
16,69	17,70	28,75
16,70	17,71	28,77
16,71	17,72	28,80
16,72	17,73	28,82
16,73	17,74	28,84
16,74	17,75	28,87
16,75	17,76	28,89
16,76	17,77	28,92
16,77	17,78	28,94
16,78	17,79	28,97
16,79	17,80	28,99
16,80	17,81	29,01
16,81	17,82	29,04
16,82	17,83	29,06
16,83	17,84	29,09
16,84	17,85	29,11
16,85	17,86	29,13
16,86	17,87	29,16
16,87	17,88	29,18
16,88	17,89	29,21



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	29,23
16,90	17,91	29,25
16,91	17,92	29,28
16,92	17,93	29,30
16,93	17,94	29,33
16,94	17,95	29,35
16,95	17,96	29,37
16,96	17,97	29,40
16,97	17,98	29,42
16,98	17,99	29,45
16,99	18,00	29,47
17,00	18,01	29,49
17,01	18,02	29,52
17,02	18,03	29,54
17,03	18,04	29,56
17,04	18,05	29,59
17,05	18,06	29,61
17,06	18,07	29,64
17,07	18,08	29,66
17,08	18,09	29,68
17,09	18,10	29,71
17,10	18,11	29,73
17,11	18,12	29,75
17,12	18,13	29,78
17,13	18,14	29,80
17,14	18,15	29,83
17,15	18,16	29,85
17,16	18,17	29,87
17,17	18,18	29,90
17,18	18,19	29,92
17,19	18,20	29,94
17,20	18,21	29,97
17,21	18,22	29,99
17,22	18,23	30,02
17,23	18,24	30,04
17,24	18,25	30,06
17,25	18,26	30,09
17,26	18,27	30,11
17,27	18,28	30,13
17,28	18,29	30,16
17,29	18,30	30,18
17,30	18,31	30,20
17,31	18,32	30,23
17,32	18,33	30,25



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	30,28
17,34	18,35	30,30
17,35	18,36	30,32
17,36	18,37	30,35
17,37	18,38	30,37
17,38	18,39	30,39
17,39	18,40	30,42
17,40	18,41	30,44
17,41	18,42	30,46
17,42	18,43	30,49
17,43	18,44	30,51
17,44	18,45	30,53
17,45	18,46	30,56
17,46	18,47	30,58
17,47	18,48	30,60
17,48	18,49	30,63
17,49	18,50	30,65
17,50	18,51	30,67
17,51	18,52	30,70
17,52	18,53	30,72
17,53	18,54	30,74
17,54	18,55	30,77
17,55	18,56	30,79
17,56	18,57	30,81
17,57	18,58	30,84
17,58	18,59	30,86
17,59	18,60	30,88
17,60	18,61	30,91
17,61	18,62	30,93
17,62	18,63	30,95
17,63	18,64	30,98
17,64	18,65	31,00
17,65	18,66	31,02
17,66	18,67	31,05
17,67	18,68	31,07
17,68	18,69	31,09
17,69	18,70	31,12
17,70	18,71	31,14
17,71	18,72	31,16
17,72	18,73	31,19
17,73	18,74	31,21
17,74	18,75	31,23
17,75	18,76	31,26
17,76	18,77	31,28



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,77	18,78	31,30
17,78	18,79	31,33
17,79	18,80	31,35
17,80	18,81	31,37
17,81	18,82	31,39
17,82	18,83	31,42
17,83	18,84	31,44
17,84	18,85	31,46
17,85	18,86	31,49
17,86	18,87	31,51
17,87	18,88	31,53
17,88	18,89	31,56
17,89	18,90	31,58
17,90	18,91	31,60
17,91	18,92	31,63
17,92	18,93	31,65
17,93	18,94	31,67
17,94	18,95	31,69
17,95	18,96	31,72
17,96	18,97	31,74
17,97	18,98	31,76
17,98	18,99	31,79
17,99	19,00	31,81
18,00	19,01	31,83
18,01	19,02	31,86
18,02	19,03	31,88
18,03	19,04	31,90
18,04	19,05	31,92
18,05	19,06	31,95
18,06	19,07	31,97
18,07	19,08	31,99
18,08	19,09	32,02
18,09	19,10	32,04
18,10	19,11	32,06
18,11	19,12	32,08
18,12	19,13	32,11
18,13	19,14	32,13
18,14	19,15	32,15
18,15	19,16	32,18
18,16	19,17	32,20
18,17	19,18	32,22
18,18	19,19	32,24
18,19	19,20	32,27
18,20	19,21	32,29



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,21	19,22	32,31
18,22	19,23	32,33
18,23	19,24	32,36
18,24	19,25	32,38
18,25	19,26	32,40
18,26	19,27	32,43
18,27	19,28	32,45
18,28	19,29	32,47
18,29	19,30	32,49
18,30	19,31	32,52
18,31	19,32	32,54
18,32	19,33	32,56
18,33	19,34	32,58
18,34	19,35	32,61
18,35	19,36	32,63
18,36	19,37	32,65
18,37	19,38	32,67
18,38	19,39	32,70
18,39	19,40	32,72
18,40	19,41	32,74
18,41	19,42	32,76
18,42	19,43	32,79
18,43	19,44	32,81
18,44	19,45	32,83
18,45	19,46	32,85
18,46	19,47	32,88
18,47	19,48	32,90
18,48	19,49	32,92
18,49	19,50	32,95
18,50	19,51	32,97
18,51	19,52	32,99
18,52	19,53	33,01
18,53	19,54	33,03
18,54	19,55	33,06
18,55	19,56	33,08
18,56	19,57	33,10
18,57	19,58	33,12
18,58	19,59	33,15
18,59	19,60	33,17
18,60	19,61	33,19
18,61	19,62	33,21
18,62	19,63	33,24
18,63	19,64	33,26
18,64	19,65	33,28



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,65	19,66	33,30
18,66	19,67	33,33
18,67	19,68	33,35
18,68	19,69	33,37
18,69	19,70	33,39
18,70	19,71	33,42
18,71	19,72	33,44
18,72	19,73	33,46
18,73	19,74	33,48
18,74	19,75	33,50
18,75	19,76	33,53
18,76	19,77	33,55
18,77	19,78	33,57
18,78	19,79	33,59
18,79	19,80	33,62
18,80	19,81	33,64
18,81	19,82	33,66
18,82	19,83	33,68
18,83	19,84	33,70
18,84	19,85	33,73
18,85	19,86	33,75
18,86	19,87	33,77
18,87	19,88	33,79
18,88	19,89	33,82
18,89	19,90	33,84
18,90	19,91	33,86
18,91	19,92	33,88
18,92	19,93	33,90
18,93	19,94	33,93
18,94	19,95	33,95
18,95	19,96	33,97
18,96	19,97	33,99
18,97	19,98	34,01
18,98	19,99	34,04
18,99	20,00	34,06
19,00	20,01	34,08
19,01	20,02	34,10
19,02	20,03	34,13
19,03	20,04	34,15
19,04	20,05	34,17
19,05	20,06	34,19
19,06	20,07	34,21
19,07	20,08	34,24
19,08	20,09	34,26



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	34,28
19,10	20,11	34,30
19,11	20,12	34,32
19,12	20,13	34,35
19,13	20,14	34,37
19,14	20,15	34,39
19,15	20,16	34,41
19,16	20,17	34,43
19,17	20,18	34,46
19,18	20,19	34,48
19,19	20,20	34,50
19,20	20,21	34,52
19,21	20,22	34,54
19,22	20,23	34,56
19,23	20,24	34,59
19,24	20,25	34,61
19,25	20,26	34,63
19,26	20,27	34,65
19,27	20,28	34,67
19,28	20,29	34,70
19,29	20,30	34,72
19,30	20,31	34,74
19,31	20,32	34,76
19,32	20,33	34,78
19,33	20,34	34,80
19,34	20,35	34,83
19,35	20,36	34,85
19,36	20,37	34,87
19,37	20,38	34,89
19,38	20,39	34,91
19,39	20,40	34,94
19,40	20,41	34,96
19,41	20,42	34,98
19,42	20,43	35,00
19,43	20,44	35,02
19,44	20,45	35,04
19,45	20,46	35,07
19,46	20,47	35,09
19,47	20,48	35,11
19,48	20,49	35,13
19,49	20,50	35,15
19,50	20,51	35,17
19,51	20,52	35,20
19,52	20,53	35,22



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	35,24
19,54	20,55	35,26
19,55	20,56	35,28
19,56	20,57	35,30
19,57	20,58	35,33
19,58	20,59	35,35
19,59	20,60	35,37
19,60	20,61	35,39
19,61	20,62	35,41
19,62	20,63	35,43
19,63	20,64	35,45
19,64	20,65	35,48
19,65	20,66	35,50
19,66	20,67	35,52
19,67	20,68	35,54
19,68	20,69	35,56
19,69	20,70	35,58
19,70	20,71	35,61
19,71	20,72	35,63
19,72	20,73	35,65
19,73	20,74	35,67
19,74	20,75	35,69
19,75	20,76	35,71
19,76	20,77	35,73
19,77	20,78	35,76
19,78	20,79	35,78
19,79	20,80	35,80
19,80	20,81	35,82
19,81	20,82	35,84
19,82	20,83	35,86
19,83	20,84	35,88
19,84	20,85	35,91
19,85	20,86	35,93
19,86	20,87	35,95
19,87	20,88	35,97
19,88	20,89	35,99
19,89	20,90	36,01
19,90	20,91	36,03
19,91	20,92	36,06
19,92	20,93	36,08
19,93	20,94	36,10
19,94	20,95	36,12
19,95	20,96	36,14
19,96	20,97	36,16



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,97	20,98	36,18
19,98	20,99	36,20
19,99	21,00	36,23
20,00	21,01	36,25
20,01	21,02	36,27
20,02	21,03	36,29
20,03	21,04	36,31
20,04	21,05	36,33
20,05	21,06	36,35
20,06	21,07	36,37
20,07	21,08	36,40
20,08	21,09	36,42
20,09	21,10	36,44
20,10	21,11	36,46
20,11	21,12	36,48
20,12	21,13	36,50
20,13	21,14	36,52
20,14	21,15	36,54
20,15	21,16	36,57
20,16	21,17	36,59
20,17	21,18	36,61
20,18	21,19	36,63
20,19	21,20	36,65
20,20	21,21	36,67
20,21	21,22	36,69
20,22	21,23	36,71
20,23	21,24	36,73
20,24	21,25	36,76
20,25	21,26	36,78
20,26	21,27	36,80
20,27	21,28	36,82
20,28	21,29	36,84
20,29	21,30	36,86
20,30	21,31	36,88
20,31	21,32	36,90
20,32	21,33	36,92
20,33	21,34	36,94
20,34	21,35	36,97
20,35	21,36	36,99
20,36	21,37	37,01
20,37	21,38	37,03
20,38	21,39	37,05
20,39	21,40	37,07
20,40	21,41	37,09



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,41	21,42	37,11
20,42	21,43	37,13
20,43	21,44	37,15
20,44	21,45	37,18
20,45	21,46	37,20
20,46	21,47	37,22
20,47	21,48	37,24
20,48	21,49	37,26
20,49	21,50	37,28
20,50	21,51	37,30
20,51	21,52	37,32
20,52	21,53	37,34
20,53	21,54	37,36
20,54	21,55	37,38
20,55	21,56	37,41
20,56	21,57	37,43
20,57	21,58	37,45
20,58	21,59	37,47
20,59	21,60	37,49
20,60	21,61	37,51
20,61	21,62	37,53
20,62	21,63	37,55
20,63	21,64	37,57
20,64	21,65	37,59
20,65	21,66	37,61
20,66	21,67	37,63
20,67	21,68	37,66
20,68	21,69	37,68
20,69	21,70	37,70
20,70	21,71	37,72
20,71	21,72	37,74
20,72	21,73	37,76
20,73	21,74	37,78
20,74	21,75	37,80
20,75	21,76	37,82
20,76	21,77	37,84
20,77	21,78	37,86
20,78	21,79	37,88
20,79	21,80	37,90
20,80	21,81	37,92
20,81	21,82	37,95
20,82	21,83	37,97
20,83	21,84	37,99
20,84	21,85	38,01



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	38,03
20,86	21,87	38,05
20,87	21,88	38,07
20,88	21,89	38,09
20,89	21,90	38,11
20,90	21,91	38,13
20,91	21,92	38,15
20,92	21,93	38,17
20,93	21,94	38,19
20,94	21,95	38,21
20,95	21,96	38,23
20,96	21,97	38,25
20,97	21,98	38,27
20,98	21,99	38,30
20,99	22,00	38,32
21,00	22,01	38,34
21,01	22,02	38,36
21,02	22,03	38,38
21,03	22,04	38,40
21,04	22,05	38,42
21,05	22,06	38,44
21,06	22,07	38,46
21,07	22,08	38,48
21,08	22,09	38,50
21,09	22,10	38,52
21,10	22,11	38,54
21,11	22,12	38,56
21,12	22,13	38,58
21,13	22,14	38,60
21,14	22,15	38,62
21,15	22,16	38,64
21,16	22,17	38,66
21,17	22,18	38,68
21,18	22,19	38,71
21,19	22,20	38,73
21,20	22,21	38,75
21,21	22,22	38,77
21,22	22,23	38,79
21,23	22,24	38,81
21,24	22,25	38,83
21,25	22,26	38,85
21,26	22,27	38,87
21,27	22,28	38,89
21,28	22,29	38,91



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
21,29	22,30	38,93
21,30	22,31	38,95
21,31	22,32	38,97
21,32	22,33	38,99
21,33	22,34	39,01
21,34	22,35	39,03
21,35	22,36	39,05
21,36	22,37	39,07
21,37	22,38	39,09
21,38	22,39	39,11
21,39	22,40	39,13
21,40	22,41	39,15
21,41	22,42	39,17
21,42	22,43	39,19
21,43	22,44	39,21
21,44	22,45	39,23
21,45	22,46	39,25
21,46	22,47	39,27
21,47	22,48	39,29
21,48	22,49	39,31
21,49	22,50	39,33
21,50	22,51	39,35
21,51	22,52	39,37
21,52	22,53	39,39
21,53	22,54	39,41
21,54	22,55	39,44
21,55	22,56	39,46
21,56	22,57	39,48
21,57	22,58	39,50
21,58	22,59	39,52
21,59	22,60	39,54
21,60	22,61	39,56
21,61	22,62	39,58
21,62	22,63	39,60
21,63	22,64	39,62
21,64	22,65	39,64
21,65	22,66	39,66
21,66	22,67	39,68
21,67	22,68	39,70
21,68	22,69	39,72
21,69	22,70	39,74
21,70	22,71	39,76
21,71	22,72	39,78
21,72	22,73	39,80



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	39,82
21,74	22,75	39,84
21,75	22,76	39,86
21,76	22,77	39,88
21,77	22,78	39,90
21,78	22,79	39,92
21,79	22,80	39,94
21,80	22,81	39,96
21,81	22,82	39,98
21,82	22,83	40,00
21,83	22,84	40,02
21,84	22,85	40,04
21,85	22,86	40,06
21,86	22,87	40,08
21,87	22,88	40,10
21,88	22,89	40,12
21,89	22,90	40,14
21,90	22,91	40,16
21,91	22,92	40,18
21,92	22,93	40,20
21,93	22,94	40,22
21,94	22,95	40,24
21,95	22,96	40,26
21,96	22,97	40,28
21,97	22,98	40,30
21,98	22,99	40,32
21,99	23,00	40,34
22,00	23,01	40,36
22,01	23,02	40,38
22,02	23,03	40,39
22,03	23,04	40,41
22,04	23,05	40,43
22,05	23,06	40,45
22,06	23,07	40,47
22,07	23,08	40,49
22,08	23,09	40,51
22,09	23,10	40,53
22,10	23,11	40,55
22,11	23,12	40,57
22,12	23,13	40,59
22,13	23,14	40,61
22,14	23,15	40,63
22,15	23,16	40,65
22,16	23,17	40,67



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
22,17	23,18	40,69
22,18	23,19	40,71
22,19	23,20	40,73
22,20	23,21	40,75
22,21	23,22	40,77
22,22	23,23	40,79
22,23	23,24	40,81
22,24	23,25	40,83
22,25	23,26	40,85
22,26	23,27	40,87
22,27	23,28	40,89
22,28	23,29	40,91
22,29	23,30	40,93
22,30	23,31	40,95
22,31	23,32	40,97
22,32	23,33	40,99
22,33	23,34	41,01
22,34	23,35	41,03
22,35	23,36	41,05
22,36	23,37	41,07
22,37	23,38	41,09
22,38	23,39	41,10
22,39	23,40	41,12
22,40	23,41	41,14
22,41	23,42	41,16
22,42	23,43	41,18
22,43	23,44	41,20
22,44	23,45	41,22
22,45	23,46	41,24
22,46	23,47	41,26
22,47	23,48	41,28
22,48	23,49	41,30
22,49	23,50	41,32
22,50	23,51	41,34
22,51	23,52	41,36
22,52	23,53	41,38
22,53	23,54	41,40
22,54	23,55	41,42
22,55	23,56	41,44
22,56	23,57	41,46
22,57	23,58	41,48
22,58	23,59	41,50
22,59	23,60	41,52
22,60	23,61	41,53



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	41,55
22,62	23,63	41,57
22,63	23,64	41,59
22,64	23,65	41,61
22,65	23,66	41,63
22,66	23,67	41,65
22,67	23,68	41,67
22,68	23,69	41,69
22,69	23,70	41,71
22,70	23,71	41,73
22,71	23,72	41,75
22,72	23,73	41,77
22,73	23,74	41,79
22,74	23,75	41,81
22,75	23,76	41,83
22,76	23,77	41,85
22,77	23,78	41,86
22,78	23,79	41,88
22,79	23,80	41,90
22,80	23,81	41,92
22,81	23,82	41,94
22,82	23,83	41,96
22,83	23,84	41,98
22,84	23,85	42,00
22,85	23,86	42,02
22,86	23,87	42,04
22,87	23,88	42,06
22,88	23,89	42,08
22,89	23,90	42,10
22,90	23,91	42,12
22,91	23,92	42,13
22,92	23,93	42,15
22,93	23,94	42,17
22,94	23,95	42,19
22,95	23,96	42,21
22,96	23,97	42,23
22,97	23,98	42,25
22,98	23,99	42,27
22,99	24,00	42,29
23,00	24,01	42,31
23,01	24,02	42,33
23,02	24,03	42,35
23,03	24,04	42,37
23,04	24,05	42,38



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,05	24,06	42,40
23,06	24,07	42,42
23,07	24,08	42,44
23,08	24,09	42,46
23,09	24,10	42,48
23,10	24,11	42,50
23,11	24,12	42,52
23,12	24,13	42,54
23,13	24,14	42,56
23,14	24,15	42,58
23,15	24,16	42,60
23,16	24,17	42,61
23,17	24,18	42,63
23,18	24,19	42,65
23,19	24,20	42,67
23,20	24,21	42,69
23,21	24,22	42,71
23,22	24,23	42,73
23,23	24,24	42,75
23,24	24,25	42,77
23,25	24,26	42,79
23,26	24,27	42,81
23,27	24,28	42,82
23,28	24,29	42,84
23,29	24,30	42,86
23,30	24,31	42,88
23,31	24,32	42,90
23,32	24,33	42,92
23,33	24,34	42,94
23,34	24,35	42,96
23,35	24,36	42,98
23,36	24,37	43,00
23,37	24,38	43,01
23,38	24,39	43,03
23,39	24,40	43,05
23,40	24,41	43,07
23,41	24,42	43,09
23,42	24,43	43,11
23,43	24,44	43,13
23,44	24,45	43,15
23,45	24,46	43,17
23,46	24,47	43,19
23,47	24,48	43,20
23,48	24,49	43,22



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,49	24,50	43,24
23,50	24,51	43,26
23,51	24,52	43,28
23,52	24,53	43,30
23,53	24,54	43,32
23,54	24,55	43,34
23,55	24,56	43,36
23,56	24,57	43,37
23,57	24,58	43,39
23,58	24,59	43,41
23,59	24,60	43,43
23,60	24,61	43,45
23,61	24,62	43,47
23,62	24,63	43,49
23,63	24,64	43,51
23,64	24,65	43,53
23,65	24,66	43,54
23,66	24,67	43,56
23,67	24,68	43,58
23,68	24,69	43,60
23,69	24,70	43,62
23,70	24,71	43,64
23,71	24,72	43,66
23,72	24,73	43,68
23,73	24,74	43,69
23,74	24,75	43,71
23,75	24,76	43,73
23,76	24,77	43,75
23,77	24,78	43,77
23,78	24,79	43,79
23,79	24,80	43,81
23,80	24,81	43,83
23,81	24,82	43,84
23,82	24,83	43,86
23,83	24,84	43,88
23,84	24,85	43,90
23,85	24,86	43,92
23,86	24,87	43,94
23,87	24,88	43,96
23,88	24,89	43,98
23,89	24,90	43,99
23,90	24,91	44,01
23,91	24,92	44,03
23,92	24,93	44,05



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,93	24,94	44,07
23,94	24,95	44,09
23,95	24,96	44,11
23,96	24,97	44,13
23,97	24,98	44,14
23,98	24,99	44,16
23,99	25,00	44,18
24,00	25,01	44,20
24,01	25,02	44,22
24,02	25,03	44,24
24,03	25,04	44,26
24,04	25,05	44,27
24,05	25,06	44,29
24,06	25,07	44,31
24,07	25,08	44,33
24,08	25,09	44,35
24,09	25,10	44,37
24,10	25,11	44,39
24,11	25,12	44,40
24,12	25,13	44,42
24,13	25,14	44,44
24,14	25,15	44,46
24,15	25,16	44,48
24,16	25,17	44,50
24,17	25,18	44,52
24,18	25,19	44,53
24,19	25,20	44,55
24,20	25,21	44,57
24,21	25,22	44,59
24,22	25,23	44,61
24,23	25,24	44,63
24,24	25,25	44,65
24,25	25,26	44,66
24,26	25,27	44,68
24,27	25,28	44,70
24,28	25,29	44,72
24,29	25,30	44,74
24,30	25,31	44,76
24,31	25,32	44,77
24,32	25,33	44,79
24,33	25,34	44,81
24,34	25,35	44,83
24,35	25,36	44,85
24,36	25,37	44,87



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,37	25,38	44,88
24,38	25,39	44,90
24,39	25,40	44,92
24,40	25,41	44,94
24,41	25,42	44,96
24,42	25,43	44,98
24,43	25,44	45,00
24,44	25,45	45,01
24,45	25,46	45,03
24,46	25,47	45,05
24,47	25,48	45,07
24,48	25,49	45,09
24,49	25,50	45,11
24,50	25,51	45,12
24,51	25,52	45,14
24,52	25,53	45,16
24,53	25,54	45,18
24,54	25,55	45,20
24,55	25,56	45,22
24,56	25,57	45,23
24,57	25,58	45,25
24,58	25,59	45,27
24,59	25,60	45,29
24,60	25,61	45,31
24,61	25,62	45,33
24,62	25,63	45,34
24,63	25,64	45,36
24,64	25,65	45,38
24,65	25,66	45,40
24,66	25,67	45,42
24,67	25,68	45,43
24,68	25,69	45,45
24,69	25,70	45,47
24,70	25,71	45,49
24,71	25,72	45,51
24,72	25,73	45,53
24,73	25,74	45,54
24,74	25,75	45,56
24,75	25,76	45,58
24,76	25,77	45,60
24,77	25,78	45,62
24,78	25,79	45,64
24,79	25,80	45,65
24,80	25,81	45,67



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,81	25,82	45,69
24,82	25,83	45,71
24,83	25,84	45,73
24,84	25,85	45,74
24,85	25,86	45,76
24,86	25,87	45,78
24,87	25,88	45,80
24,88	25,89	45,82
24,89	25,90	45,83
24,90	25,91	45,85
24,91	25,92	45,87
24,92	25,93	45,89
24,93	25,94	45,91
24,94	25,95	45,93
24,95	25,96	45,94
24,96	25,97	45,96
24,97	25,98	45,98
24,98	25,99	46,00
24,99	26,00	46,02
25,00	26,01	46,03
25,01	26,02	46,05
25,02	26,03	46,07
25,03	26,04	46,09
25,04	26,05	46,11
25,05	26,06	46,12
25,06	26,07	46,14
25,07	26,08	46,16
25,08	26,09	46,18
25,09	26,10	46,20
25,10	26,11	46,21
25,11	26,12	46,23
25,12	26,13	46,25
25,13	26,14	46,27
25,14	26,15	46,29
25,15	26,16	46,30
25,16	26,17	46,32
25,17	26,18	46,34
25,18	26,19	46,36
25,19	26,20	46,38
25,20	26,21	46,39
25,21	26,22	46,41
25,22	26,23	46,43
25,23	26,24	46,45
25,24	26,25	46,47



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
25,25	26,26	46,48
25,26	26,27	46,50
25,27	26,28	46,52
25,28	26,29	46,54
25,29	26,30	46,56
25,30	26,31	46,57
25,31	26,32	46,59
25,32	26,33	46,61
25,33	26,34	46,63
25,34	26,35	46,65
25,35	26,36	46,66
25,36	26,37	46,68
25,37	26,38	46,70
25,38	26,39	46,72
25,39	26,40	46,73
25,40	26,41	46,75
25,41	26,42	46,77
25,42	26,43	46,79
25,43	26,44	46,81
25,44	26,45	46,82
25,45	26,46	46,84
25,46	26,47	46,86
25,47	26,48	46,88
25,48	26,49	46,90
25,49	26,50	46,91
25,50	26,51	46,93
25,51	26,52	46,95
25,52	26,53	46,97
25,53	26,54	46,98
25,54	26,55	47,00
25,55	26,56	47,02
25,56	26,57	47,04
25,57	26,58	47,06
25,58	26,59	47,07
25,59	26,60	47,09
25,60	26,61	47,11
25,61	26,62	47,13
25,62	26,63	47,14
25,63	26,64	47,16
25,64	26,65	47,18
25,65	26,66	47,20
25,66	26,67	47,21
25,67	26,68	47,23
25,68	26,69	47,25



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,69	26,70	47,27
25,70	26,71	47,29
25,71	26,72	47,30
25,72	26,73	47,32
25,73	26,74	47,34
25,74	26,75	47,36
25,75	26,76	47,37
25,76	26,77	47,39
25,77	26,78	47,41
25,78	26,79	47,43
25,79	26,80	47,44
25,80	26,81	47,46
25,81	26,82	47,48
25,82	26,83	47,50
25,83	26,84	47,52
25,84	26,85	47,53
25,85	26,86	47,55
25,86	26,87	47,57
25,87	26,88	47,59
25,88	26,89	47,60
25,89	26,90	47,62
25,90	26,91	47,64
25,91	26,92	47,66
25,92	26,93	47,67
25,93	26,94	47,69
25,94	26,95	47,71
25,95	26,96	47,73
25,96	26,97	47,74
25,97	26,98	47,76
25,98	26,99	47,78
25,99	27,00	47,80
26,00	27,01	47,81
26,01	27,02	47,83
26,02	27,03	47,85
26,03	27,04	47,87
26,04	27,05	47,88
26,05	27,06	47,90
26,06	27,07	47,92
26,07	27,08	47,94
26,08	27,09	47,95
26,09	27,10	47,97
26,10	27,11	47,99
26,11	27,12	48,01
26,12	27,13	48,02



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	48,04
26,14	27,15	48,06
26,15	27,16	48,08
26,16	27,17	48,09
26,17	27,18	48,11
26,18	27,19	48,13
26,19	27,20	48,15
26,20	27,21	48,16
26,21	27,22	48,18
26,22	27,23	48,20
26,23	27,24	48,22
26,24	27,25	48,23
26,25	27,26	48,25
26,26	27,27	48,27
26,27	27,28	48,29
26,28	27,29	48,30
26,29	27,30	48,32
26,30	27,31	48,34
26,31	27,32	48,36
26,32	27,33	48,37
26,33	27,34	48,39
26,34	27,35	48,41
26,35	27,36	48,43
26,36	27,37	48,44
26,37	27,38	48,46
26,38	27,39	48,48
26,39	27,40	48,49
26,40	27,41	48,51
26,41	27,42	48,53
26,42	27,43	48,55
26,43	27,44	48,56
26,44	27,45	48,58
26,45	27,46	48,60
26,46	27,47	48,62
26,47	27,48	48,63
26,48	27,49	48,65
26,49	27,50	48,67
26,50	27,51	48,69
26,51	27,52	48,70
26,52	27,53	48,72
26,53	27,54	48,74
26,54	27,55	48,75
26,55	27,56	48,77
26,56	27,57	48,79



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
26,57	27,58	48,81
26,58	27,59	48,82
26,59	27,60	48,84
26,60	27,61	48,86
26,61	27,62	48,88
26,62	27,63	48,89
26,63	27,64	48,91
26,64	27,65	48,93
26,65	27,66	48,94
26,66	27,67	48,96
26,67	27,68	48,98
26,68	27,69	49,00
26,69	27,70	49,01
26,70	27,71	49,03
26,71	27,72	49,05
26,72	27,73	49,06
26,73	27,74	49,08
26,74	27,75	49,10
26,75	27,76	49,12
26,76	27,77	49,13
26,77	27,78	49,15
26,78	27,79	49,17
26,79	27,80	49,19
26,80	27,81	49,20
26,81	27,82	49,22
26,82	27,83	49,24
26,83	27,84	49,25
26,84	27,85	49,27
26,85	27,86	49,29
26,86	27,87	49,31
26,87	27,88	49,32
26,88	27,89	49,34
26,89	27,90	49,36
26,90	27,91	49,37
26,91	27,92	49,39
26,92	27,93	49,41
26,93	27,94	49,42
26,94	27,95	49,44
26,95	27,96	49,46
26,96	27,97	49,48
26,97	27,98	49,49
26,98	27,99	49,51
26,99	28,00	49,53
27,00	28,01	49,54



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	49,56
27,02	28,03	49,58
27,03	28,04	49,60
27,04	28,05	49,61
27,05	28,06	49,63
27,06	28,07	49,65
27,07	28,08	49,66
27,08	28,09	49,68
27,09	28,10	49,70
27,10	28,11	49,71
27,11	28,12	49,73
27,12	28,13	49,75
27,13	28,14	49,77
27,14	28,15	49,78
27,15	28,16	49,80
27,16	28,17	49,82
27,17	28,18	49,83
27,18	28,19	49,85
27,19	28,20	49,87
27,20	28,21	49,88
27,21	28,22	49,90
27,22	28,23	49,92
27,23	28,24	49,94
27,24	28,25	49,95
27,25	28,26	49,97
27,26	28,27	49,99
27,27	28,28	50,00
27,28	28,29	50,02
27,29	28,30	50,04
27,30	28,31	50,05
27,31	28,32	50,07
27,32	28,33	50,09
27,33	28,34	50,10
27,34	28,35	50,12
27,35	28,36	50,14
27,36	28,37	50,16
27,37	28,38	50,17
27,38	28,39	50,19
27,39	28,40	50,21
27,40	28,41	50,22
27,41	28,42	50,24
27,42	28,43	50,26
27,43	28,44	50,27
27,44	28,45	50,29



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	50,31
27,46	28,47	50,32
27,47	28,48	50,34
27,48	28,49	50,36
27,49	28,50	50,37
27,50	28,51	50,39
27,51	28,52	50,41
27,52	28,53	50,42
27,53	28,54	50,44
27,54	28,55	50,46
27,55	28,56	50,48
27,56	28,57	50,49
27,57	28,58	50,51
27,58	28,59	50,53
27,59	28,60	50,54
27,60	28,61	50,56
27,61	28,62	50,58
27,62	28,63	50,59
27,63	28,64	50,61
27,64	28,65	50,63
27,65	28,66	50,64
27,66	28,67	50,66
27,67	28,68	50,68
27,68	28,69	50,69
27,69	28,70	50,71
27,70	28,71	50,73
27,71	28,72	50,74
27,72	28,73	50,76
27,73	28,74	50,78
27,74	28,75	50,79
27,75	28,76	50,81
27,76	28,77	50,83
27,77	28,78	50,84
27,78	28,79	50,86
27,79	28,80	50,88
27,80	28,81	50,89
27,81	28,82	50,91
27,82	28,83	50,93
27,83	28,84	50,94
27,84	28,85	50,96
27,85	28,86	50,98
27,86	28,87	50,99
27,87	28,88	51,01
27,88	28,89	51,03



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	51,04
27,90	28,91	51,06
27,91	28,92	51,08
27,92	28,93	51,09
27,93	28,94	51,11
27,94	28,95	51,13
27,95	28,96	51,14
27,96	28,97	51,16
27,97	28,98	51,18
27,98	28,99	51,19
27,99	29,00	51,21
28,00	29,01	51,23
28,01	29,02	51,24
28,02	29,03	51,26
28,03	29,04	51,28
28,04	29,05	51,29
28,05	29,06	51,31
28,06	29,07	51,33
28,07	29,08	51,34
28,08	29,09	51,36
28,09	29,10	51,38
28,10	29,11	51,39
28,11	29,12	51,41
28,12	29,13	51,43
28,13	29,14	51,44
28,14	29,15	51,46
28,15	29,16	51,48
28,16	29,17	51,49
28,17	29,18	51,51
28,18	29,19	51,52
28,19	29,20	51,54
28,20	29,21	51,56
28,21	29,22	51,57
28,22	29,23	51,59
28,23	29,24	51,61
28,24	29,25	51,62
28,25	29,26	51,64
28,26	29,27	51,66
28,27	29,28	51,67
28,28	29,29	51,69
28,29	29,30	51,71
28,30	29,31	51,72
28,31	29,32	51,74
28,32	29,33	51,76



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	51,77
28,34	29,35	51,79
28,35	29,36	51,80
28,36	29,37	51,82
28,37	29,38	51,84
28,38	29,39	51,85
28,39	29,40	51,87
28,40	29,41	51,89
28,41	29,42	51,90
28,42	29,43	51,92
28,43	29,44	51,94
28,44	29,45	51,95
28,45	29,46	51,97
28,46	29,47	51,99
28,47	29,48	52,00
28,48	29,49	52,02
28,49	29,50	52,03
28,50	29,51	52,05
28,51	29,52	52,07
28,52	29,53	52,08
28,53	29,54	52,10
28,54	29,55	52,12
28,55	29,56	52,13
28,56	29,57	52,15
28,57	29,58	52,17
28,58	29,59	52,18
28,59	29,60	52,20
28,60	29,61	52,21
28,61	29,62	52,23
28,62	29,63	52,25
28,63	29,64	52,26
28,64	29,65	52,28
28,65	29,66	52,30
28,66	29,67	52,31
28,67	29,68	52,33
28,68	29,69	52,34
28,69	29,70	52,36
28,70	29,71	52,38
28,71	29,72	52,39
28,72	29,73	52,41
28,73	29,74	52,43
28,74	29,75	52,44
28,75	29,76	52,46
28,76	29,77	52,48



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	52,49
28,78	29,79	52,51
28,79	29,80	52,52
28,80	29,81	52,54
28,81	29,82	52,56
28,82	29,83	52,57
28,83	29,84	52,59
28,84	29,85	52,60
28,85	29,86	52,62
28,86	29,87	52,64
28,87	29,88	52,65
28,88	29,89	52,67
28,89	29,90	52,69
28,90	29,91	52,70
28,91	29,92	52,72
28,92	29,93	52,73
28,93	29,94	52,75
28,94	29,95	52,77
28,95	29,96	52,78
28,96	29,97	52,80
28,97	29,98	52,82
28,98	29,99	52,83
28,99	30,00	52,85
29,00	30,01	52,86
29,01	30,02	52,88
29,02	30,03	52,90
29,03	30,04	52,91
29,04	30,05	52,93
29,05	30,06	52,94
29,06	30,07	52,96
29,07	30,08	52,98
29,08	30,09	52,99
29,09	30,10	53,01
29,10	30,11	53,03
29,11	30,12	53,04
29,12	30,13	53,06
29,13	30,14	53,07
29,14	30,15	53,09
29,15	30,16	53,11
29,16	30,17	53,12
29,17	30,18	53,14
29,18	30,19	53,15
29,19	30,20	53,17
29,20	30,21	53,19



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	53,20
29,22	30,23	53,22
29,23	30,24	53,23
29,24	30,25	53,25
29,25	30,26	53,27
29,26	30,27	53,28
29,27	30,28	53,30
29,28	30,29	53,31
29,29	30,30	53,33
29,30	30,31	53,35
29,31	30,32	53,36
29,32	30,33	53,38
29,33	30,34	53,39
29,34	30,35	53,41
29,35	30,36	53,43
29,36	30,37	53,44
29,37	30,38	53,46
29,38	30,39	53,47
29,39	30,40	53,49
29,40	30,41	53,51
29,41	30,42	53,52
29,42	30,43	53,54
29,43	30,44	53,55
29,44	30,45	53,57
29,45	30,46	53,59
29,46	30,47	53,60
29,47	30,48	53,62
29,48	30,49	53,63
29,49	30,50	53,65
29,50	30,51	53,67
29,51	30,52	53,68
29,52	30,53	53,70
29,53	30,54	53,71
29,54	30,55	53,73
29,55	30,56	53,75
29,56	30,57	53,76
29,57	30,58	53,78
29,58	30,59	53,79
29,59	30,60	53,81
29,60	30,61	53,83
29,61	30,62	53,84
29,62	30,63	53,86
29,63	30,64	53,87
29,64	30,65	53,89



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,65	30,66	53,91
29,66	30,67	53,92
29,67	30,68	53,94
29,68	30,69	53,95
29,69	30,70	53,97
29,70	30,71	53,98
29,71	30,72	54,00
29,72	30,73	54,02
29,73	30,74	54,03
29,74	30,75	54,05
29,75	30,76	54,06
29,76	30,77	54,08
29,77	30,78	54,10
29,78	30,79	54,11
29,79	30,80	54,13
29,80	30,81	54,14
29,81	30,82	54,16
29,82	30,83	54,17
29,83	30,84	54,19
29,84	30,85	54,21
29,85	30,86	54,22
29,86	30,87	54,24
29,87	30,88	54,25
29,88	30,89	54,27
29,89	30,90	54,29
29,90	30,91	54,30
29,91	30,92	54,32
29,92	30,93	54,33
29,93	30,94	54,35
29,94	30,95	54,36
29,95	30,96	54,38
29,96	30,97	54,40
29,97	30,98	54,41
29,98	30,99	54,43
29,99	31,00	54,44
30,00	31,01	54,46
30,01	31,02	54,47
30,02	31,03	54,49
30,03	31,04	54,51
30,04	31,05	54,52
30,05	31,06	54,54
30,06	31,07	54,55
30,07	31,08	54,57
30,08	31,09	54,58



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,09	31,10	54,60
30,10	31,11	54,62
30,11	31,12	54,63
30,12	31,13	54,65
30,13	31,14	54,66
30,14	31,15	54,68
30,15	31,16	54,69
30,16	31,17	54,71
30,17	31,18	54,73
30,18	31,19	54,74
30,19	31,20	54,76
30,20	31,21	54,77
30,21	31,22	54,79
30,22	31,23	54,80
30,23	31,24	54,82
30,24	31,25	54,84
30,25	31,26	54,85
30,26	31,27	54,87
30,27	31,28	54,88
30,28	31,29	54,90
30,29	31,30	54,91
30,30	31,31	54,93
30,31	31,32	54,94
30,32	31,33	54,96
30,33	31,34	54,98
30,34	31,35	54,99
30,35	31,36	55,01
30,36	31,37	55,02
30,37	31,38	55,04
30,38	31,39	55,05
30,39	31,40	55,07
30,40	31,41	55,09
30,41	31,42	55,10
30,42	31,43	55,12
30,43	31,44	55,13
30,44	31,45	55,15
30,45	31,46	55,16
30,46	31,47	55,18
30,47	31,48	55,19
30,48	31,49	55,21
30,49	31,50	55,23
30,50	31,51	55,24
30,51	31,52	55,26
30,52	31,53	55,27



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	55,29
30,54	31,55	55,30
30,55	31,56	55,32
30,56	31,57	55,33
30,57	31,58	55,35
30,58	31,59	55,37
30,59	31,60	55,38
30,60	31,61	55,40
30,61	31,62	55,41
30,62	31,63	55,43
30,63	31,64	55,44
30,64	31,65	55,46
30,65	31,66	55,47
30,66	31,67	55,49
30,67	31,68	55,50
30,68	31,69	55,52
30,69	31,70	55,54
30,70	31,71	55,55
30,71	31,72	55,57
30,72	31,73	55,58
30,73	31,74	55,60
30,74	31,75	55,61
30,75	31,76	55,63
30,76	31,77	55,64
30,77	31,78	55,66
30,78	31,79	55,67
30,79	31,80	55,69
30,80	31,81	55,71
30,81	31,82	55,72
30,82	31,83	55,74
30,83	31,84	55,75
30,84	31,85	55,77
30,85	31,86	55,78
30,86	31,87	55,80
30,87	31,88	55,81
30,88	31,89	55,83
30,89	31,90	55,84
30,90	31,91	55,86
30,91	31,92	55,87
30,92	31,93	55,89
30,93	31,94	55,91
30,94	31,95	55,92
30,95	31,96	55,94
30,96	31,97	55,95



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,97	31,98	55,97
30,98	31,99	55,98
30,99	32,00	56,00
31,00	32,01	56,01
31,01	32,02	56,03
31,02	32,03	56,04
31,03	32,04	56,06
31,04	32,05	56,07
31,05	32,06	56,09
31,06	32,07	56,11
31,07	32,08	56,12
31,08	32,09	56,14
31,09	32,10	56,15
31,10	32,11	56,17
31,11	32,12	56,18
31,12	32,13	56,20
31,13	32,14	56,21
31,14	32,15	56,23
31,15	32,16	56,24
31,16	32,17	56,26
31,17	32,18	56,27
31,18	32,19	56,29
31,19	32,20	56,30
31,20	32,21	56,32
31,21	32,22	56,33
31,22	32,23	56,35
31,23	32,24	56,37
31,24	32,25	56,38
31,25	32,26	56,40
31,26	32,27	56,41
31,27	32,28	56,43
31,28	32,29	56,44
31,29	32,30	56,46
31,30	32,31	56,47
31,31	32,32	56,49
31,32	32,33	56,50
31,33	32,34	56,52
31,34	32,35	56,53
31,35	32,36	56,55
31,36	32,37	56,56
31,37	32,38	56,58
31,38	32,39	56,59
31,39	32,40	56,61
31,40	32,41	56,62



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	56,64
31,42	32,43	56,65
31,43	32,44	56,67
31,44	32,45	56,68
31,45	32,46	56,70
31,46	32,47	56,72
31,47	32,48	56,73
31,48	32,49	56,75
31,49	32,50	56,76
31,50	32,51	56,78
31,51	32,52	56,79
31,52	32,53	56,81
31,53	32,54	56,82
31,54	32,55	56,84
31,55	32,56	56,85
31,56	32,57	56,87
31,57	32,58	56,88
31,58	32,59	56,90
31,59	32,60	56,91
31,60	32,61	56,93
31,61	32,62	56,94
31,62	32,63	56,96
31,63	32,64	56,97
31,64	32,65	56,99
31,65	32,66	57,00
31,66	32,67	57,02
31,67	32,68	57,03
31,68	32,69	57,05
31,69	32,70	57,06
31,70	32,71	57,08
31,71	32,72	57,09
31,72	32,73	57,11
31,73	32,74	57,12
31,74	32,75	57,14
31,75	32,76	57,15
31,76	32,77	57,17
31,77	32,78	57,18
31,78	32,79	57,20
31,79	32,80	57,21
31,80	32,81	57,23
31,81	32,82	57,24
31,82	32,83	57,26
31,83	32,84	57,27
31,84	32,85	57,29



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	57,30
31,86	32,87	57,32
31,87	32,88	57,33
31,88	32,89	57,35
31,89	32,90	57,36
31,90	32,91	57,38
31,91	32,92	57,39
31,92	32,93	57,41
31,93	32,94	57,42
31,94	32,95	57,44
31,95	32,96	57,45
31,96	32,97	57,47
31,97	32,98	57,48
31,98	32,99	57,50
31,99	33,00	57,51
32,00	33,01	57,53
32,01	33,02	57,54
32,02	33,03	57,56
32,03	33,04	57,57
32,04	33,05	57,59
32,05	33,06	57,60
32,06	33,07	57,62
32,07	33,08	57,63
32,08	33,09	57,65
32,09	33,10	57,66
32,10	33,11	57,68
32,11	33,12	57,69
32,12	33,13	57,71
32,13	33,14	57,72
32,14	33,15	57,74
32,15	33,16	57,75
32,16	33,17	57,77
32,17	33,18	57,78
32,18	33,19	57,80
32,19	33,20	57,81
32,20	33,21	57,83
32,21	33,22	57,84
32,22	33,23	57,86
32,23	33,24	57,87
32,24	33,25	57,89
32,25	33,26	57,90
32,26	33,27	57,92
32,27	33,28	57,93
32,28	33,29	57,95



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	57,96
32,30	33,31	57,98
32,31	33,32	57,99
32,32	33,33	58,01
32,33	33,34	58,02
32,34	33,35	58,04
32,35	33,36	58,05
32,36	33,37	58,07
32,37	33,38	58,08
32,38	33,39	58,10
32,39	33,40	58,11
32,40	33,41	58,13
32,41	33,42	58,14
32,42	33,43	58,16
32,43	33,44	58,17
32,44	33,45	58,18
32,45	33,46	58,20
32,46	33,47	58,21
32,47	33,48	58,23
32,48	33,49	58,24
32,49	33,50	58,26
32,50	33,51	58,27
32,51	33,52	58,29
32,52	33,53	58,30
32,53	33,54	58,32
32,54	33,55	58,33
32,55	33,56	58,35
32,56	33,57	58,36
32,57	33,58	58,38
32,58	33,59	58,39
32,59	33,60	58,41
32,60	33,61	58,42
32,61	33,62	58,44
32,62	33,63	58,45
32,63	33,64	58,47
32,64	33,65	58,48
32,65	33,66	58,50
32,66	33,67	58,51
32,67	33,68	58,52
32,68	33,69	58,54
32,69	33,70	58,55
32,70	33,71	58,57
32,71	33,72	58,58
32,72	33,73	58,60



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
32,73	33,74	58,61
32,74	33,75	58,63
32,75	33,76	58,64
32,76	33,77	58,66
32,77	33,78	58,67
32,78	33,79	58,69
32,79	33,80	58,70
32,80	33,81	58,72
32,81	33,82	58,73
32,82	33,83	58,75
32,83	33,84	58,76
32,84	33,85	58,77
32,85	33,86	58,79
32,86	33,87	58,80
32,87	33,88	58,82
32,88	33,89	58,83
32,89	33,90	58,85
32,90	33,91	58,86
32,91	33,92	58,88
32,92	33,93	58,89
32,93	33,94	58,91
32,94	33,95	58,92
32,95	33,96	58,94
32,96	33,97	58,95
32,97	33,98	58,96
32,98	33,99	58,98
32,99	34,00	58,99
33,00	34,01	59,01
33,01	34,02	59,02
33,02	34,03	59,04
33,03	34,04	59,05
33,04	34,05	59,07
33,05	34,06	59,08
33,06	34,07	59,10
33,07	34,08	59,11
33,08	34,09	59,13
33,09	34,10	59,14
33,10	34,11	59,15
33,11	34,12	59,17
33,12	34,13	59,18
33,13	34,14	59,20
33,14	34,15	59,21
33,15	34,16	59,23
33,16	34,17	59,24



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
33,17	34,18	59,26
33,18	34,19	59,27
33,19	34,20	59,29
33,20	34,21	59,30
33,21	34,22	59,32
33,22	34,23	59,33
33,23	34,24	59,34
33,24	34,25	59,36
33,25	34,26	59,37
33,26	34,27	59,39
33,27	34,28	59,40
33,28	34,29	59,42
33,29	34,30	59,43
33,30	34,31	59,45
33,31	34,32	59,46
33,32	34,33	59,47
33,33	34,34	59,49
33,34	34,35	59,50
33,35	34,36	59,52
33,36	34,37	59,53
33,37	34,38	59,55
33,38	34,39	59,56
33,39	34,40	59,58
33,40	34,41	59,59
33,41	34,42	59,61
33,42	34,43	59,62
33,43	34,44	59,63
33,44	34,45	59,65
33,45	34,46	59,66
33,46	34,47	59,68
33,47	34,48	59,69
33,48	34,49	59,71
33,49	34,50	59,72
33,50	34,51	59,74
33,51	34,52	59,75
33,52	34,53	59,76
33,53	34,54	59,78
33,54	34,55	59,79
33,55	34,56	59,81
33,56	34,57	59,82
33,57	34,58	59,84
33,58	34,59	59,85
33,59	34,60	59,87
33,60	34,61	59,88



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,61	34,62	59,89
33,62	34,63	59,91
33,63	34,64	59,92
33,64	34,65	59,94
33,65	34,66	59,95
33,66	34,67	59,97
33,67	34,68	59,98
33,68	34,69	60,00
33,69	34,70	60,01
33,70	34,71	60,02
33,71	34,72	60,04
33,72	34,73	60,05
33,73	34,74	60,07
33,74	34,75	60,08
33,75	34,76	60,10
33,76	34,77	60,11
33,77	34,78	60,12
33,78	34,79	60,14
33,79	34,80	60,15
33,80	34,81	60,17
33,81	34,82	60,18
33,82	34,83	60,20
33,83	34,84	60,21
33,84	34,85	60,22
33,85	34,86	60,24
33,86	34,87	60,25
33,87	34,88	60,27
33,88	34,89	60,28
33,89	34,90	60,30
33,90	34,91	60,31
33,91	34,92	60,33
33,92	34,93	60,34
33,93	34,94	60,35
33,94	34,95	60,37
33,95	34,96	60,38
33,96	34,97	60,40
33,97	34,98	60,41
33,98	34,99	60,43
33,99	35,00	60,44
34,00	35,01	60,45
34,01	35,02	60,47
34,02	35,03	60,48
34,03	35,04	60,50
34,04	35,05	60,51



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,05	35,06	60,53
34,06	35,07	60,54
34,07	35,08	60,55
34,08	35,09	60,57
34,09	35,10	60,58
34,10	35,11	60,60
34,11	35,12	60,61
34,12	35,13	60,62
34,13	35,14	60,64
34,14	35,15	60,65
34,15	35,16	60,67
34,16	35,17	60,68
34,17	35,18	60,70
34,18	35,19	60,71
34,19	35,20	60,72
34,20	35,21	60,74
34,21	35,22	60,75
34,22	35,23	60,77
34,23	35,24	60,78
34,24	35,25	60,80
34,25	35,26	60,81
34,26	35,27	60,82
34,27	35,28	60,84
34,28	35,29	60,85
34,29	35,30	60,87
34,30	35,31	60,88
34,31	35,32	60,89
34,32	35,33	60,91
34,33	35,34	60,92
34,34	35,35	60,94
34,35	35,36	60,95
34,36	35,37	60,97
34,37	35,38	60,98
34,38	35,39	60,99
34,39	35,40	61,01
34,40	35,41	61,02
34,41	35,42	61,04
34,42	35,43	61,05
34,43	35,44	61,06
34,44	35,45	61,08
34,45	35,46	61,09
34,46	35,47	61,11
34,47	35,48	61,12
34,48	35,49	61,14



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,49	35,50	61,15
34,50	35,51	61,16
34,51	35,52	61,18
34,52	35,53	61,19
34,53	35,54	61,21
34,54	35,55	61,22
34,55	35,56	61,23
34,56	35,57	61,25
34,57	35,58	61,26
34,58	35,59	61,28
34,59	35,60	61,29
34,60	35,61	61,30
34,61	35,62	61,32
34,62	35,63	61,33
34,63	35,64	61,35
34,64	35,65	61,36
34,65	35,66	61,38
34,66	35,67	61,39
34,67	35,68	61,40
34,68	35,69	61,42
34,69	35,70	61,43
34,70	35,71	61,45
34,71	35,72	61,46
34,72	35,73	61,47
34,73	35,74	61,49
34,74	35,75	61,50
34,75	35,76	61,52
34,76	35,77	61,53
34,77	35,78	61,54
34,78	35,79	61,56
34,79	35,80	61,57
34,80	35,81	61,59
34,81	35,82	61,60
34,82	35,83	61,61
34,83	35,84	61,63
34,84	35,85	61,64
34,85	35,86	61,66
34,86	35,87	61,67
34,87	35,88	61,68
34,88	35,89	61,70
34,89	35,90	61,71
34,90	35,91	61,73
34,91	35,92	61,74
34,92	35,93	61,75



R13B1		
V1.0_R13B1		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,93	35,94	61,77
34,94	35,95	61,78
34,95	35,96	61,80
34,96	35,97	61,81
34,97	35,98	61,82
34,98	35,99	61,84
34,99	36,00	61,85
35,00	36,01	61,87
35,01	36,02	61,88
35,02	36,03	61,89
35,03	36,04	61,91
35,04	36,05	61,92
35,05	36,06	61,94
35,06	36,07	61,95
35,07	36,08	61,96
35,08	36,09	61,98
35,09	36,10	61,99
35,10	36,11	62,00