



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-69,01
-0,70	0,31	-68,48
-0,69	0,32	-67,96
-0,68	0,33	-67,46
-0,67	0,34	-66,96
-0,66	0,35	-66,48
-0,65	0,36	-66,01
-0,64	0,37	-65,55
-0,63	0,38	-65,10
-0,62	0,39	-64,66
-0,61	0,40	-64,23
-0,60	0,41	-63,81
-0,59	0,42	-63,40
-0,58	0,43	-62,99
-0,57	0,44	-62,59
-0,56	0,45	-62,20
-0,55	0,46	-61,81
-0,54	0,47	-61,43
-0,53	0,48	-61,06
-0,52	0,49	-60,70
-0,51	0,50	-60,34
-0,50	0,51	-59,98
-0,49	0,52	-59,63
-0,48	0,53	-59,29
-0,47	0,54	-58,95
-0,46	0,55	-58,62
-0,45	0,56	-58,29
-0,44	0,57	-57,97
-0,43	0,58	-57,65
-0,42	0,59	-57,33
-0,41	0,60	-57,02
-0,40	0,61	-56,71
-0,39	0,62	-56,41
-0,38	0,63	-56,11
-0,37	0,64	-55,82
-0,36	0,65	-55,52
-0,35	0,66	-55,24
-0,34	0,67	-54,95
-0,33	0,68	-54,67
-0,32	0,69	-54,39
-0,31	0,70	-54,12
-0,30	0,71	-53,85
-0,29	0,72	-53,58
-0,28	0,73	-53,31



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-53,05
-0,26	0,75	-52,79
-0,25	0,76	-52,53
-0,24	0,77	-52,28
-0,23	0,78	-52,02
-0,22	0,79	-51,77
-0,21	0,80	-51,53
-0,20	0,81	-51,28
-0,19	0,82	-51,04
-0,18	0,83	-50,80
-0,17	0,84	-50,56
-0,16	0,85	-50,32
-0,15	0,86	-50,09
-0,14	0,87	-49,86
-0,13	0,88	-49,63
-0,12	0,89	-49,40
-0,11	0,90	-49,18
-0,10	0,91	-48,95
-0,09	0,92	-48,73
-0,08	0,93	-48,51
-0,07	0,94	-48,30
-0,06	0,95	-48,08
-0,05	0,96	-47,87
-0,04	0,97	-47,65
-0,03	0,98	-47,44
-0,02	0,99	-47,23
-0,01	1,00	-47,03
0,00	1,01	-46,82
0,01	1,02	-46,62
0,02	1,03	-46,41
0,03	1,04	-46,21
0,04	1,05	-46,01
0,05	1,06	-45,81
0,06	1,07	-45,62
0,07	1,08	-45,42
0,08	1,09	-45,23
0,09	1,10	-45,04
0,10	1,11	-44,85
0,11	1,12	-44,66
0,12	1,13	-44,47
0,13	1,14	-44,28
0,14	1,15	-44,09
0,15	1,16	-43,91
0,16	1,17	-43,73



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,17	1,18	-43,54
0,18	1,19	-43,36
0,19	1,20	-43,18
0,20	1,21	-43,00
0,21	1,22	-42,83
0,22	1,23	-42,65
0,23	1,24	-42,48
0,24	1,25	-42,30
0,25	1,26	-42,13
0,26	1,27	-41,96
0,27	1,28	-41,79
0,28	1,29	-41,62
0,29	1,30	-41,45
0,30	1,31	-41,28
0,31	1,32	-41,11
0,32	1,33	-40,95
0,33	1,34	-40,78
0,34	1,35	-40,62
0,35	1,36	-40,45
0,36	1,37	-40,29
0,37	1,38	-40,13
0,38	1,39	-39,97
0,39	1,40	-39,81
0,40	1,41	-39,65
0,41	1,42	-39,49
0,42	1,43	-39,34
0,43	1,44	-39,18
0,44	1,45	-39,03
0,45	1,46	-38,87
0,46	1,47	-38,72
0,47	1,48	-38,57
0,48	1,49	-38,41
0,49	1,50	-38,26
0,50	1,51	-38,11
0,51	1,52	-37,96
0,52	1,53	-37,81
0,53	1,54	-37,67
0,54	1,55	-37,52
0,55	1,56	-37,37
0,56	1,57	-37,23
0,57	1,58	-37,08
0,58	1,59	-36,94
0,59	1,60	-36,79
0,60	1,61	-36,65



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
0,61	1,62	-36,51
0,62	1,63	-36,36
0,63	1,64	-36,22
0,64	1,65	-36,08
0,65	1,66	-35,94
0,66	1,67	-35,80
0,67	1,68	-35,67
0,68	1,69	-35,53
0,69	1,70	-35,39
0,70	1,71	-35,25
0,71	1,72	-35,12
0,72	1,73	-34,98
0,73	1,74	-34,85
0,74	1,75	-34,71
0,75	1,76	-34,58
0,76	1,77	-34,45
0,77	1,78	-34,31
0,78	1,79	-34,18
0,79	1,80	-34,05
0,80	1,81	-33,92
0,81	1,82	-33,79
0,82	1,83	-33,66
0,83	1,84	-33,53
0,84	1,85	-33,40
0,85	1,86	-33,27
0,86	1,87	-33,15
0,87	1,88	-33,02
0,88	1,89	-32,89
0,89	1,90	-32,77
0,90	1,91	-32,64
0,91	1,92	-32,52
0,92	1,93	-32,39
0,93	1,94	-32,27
0,94	1,95	-32,15
0,95	1,96	-32,02
0,96	1,97	-31,90
0,97	1,98	-31,78
0,98	1,99	-31,66
0,99	2,00	-31,54
1,00	2,01	-31,41
1,01	2,02	-31,29
1,02	2,03	-31,17
1,03	2,04	-31,06
1,04	2,05	-30,94



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	-30,82
1,06	2,07	-30,70
1,07	2,08	-30,58
1,08	2,09	-30,47
1,09	2,10	-30,35
1,10	2,11	-30,23
1,11	2,12	-30,12
1,12	2,13	-30,00
1,13	2,14	-29,89
1,14	2,15	-29,77
1,15	2,16	-29,66
1,16	2,17	-29,54
1,17	2,18	-29,43
1,18	2,19	-29,32
1,19	2,20	-29,21
1,20	2,21	-29,09
1,21	2,22	-28,98
1,22	2,23	-28,87
1,23	2,24	-28,76
1,24	2,25	-28,65
1,25	2,26	-28,54
1,26	2,27	-28,43
1,27	2,28	-28,32
1,28	2,29	-28,21
1,29	2,30	-28,10
1,30	2,31	-27,99
1,31	2,32	-27,88
1,32	2,33	-27,78
1,33	2,34	-27,67
1,34	2,35	-27,56
1,35	2,36	-27,45
1,36	2,37	-27,35
1,37	2,38	-27,24
1,38	2,39	-27,14
1,39	2,40	-27,03
1,40	2,41	-26,93
1,41	2,42	-26,82
1,42	2,43	-26,72
1,43	2,44	-26,61
1,44	2,45	-26,51
1,45	2,46	-26,41
1,46	2,47	-26,30
1,47	2,48	-26,20
1,48	2,49	-26,10



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,49	2,50	-26,00
1,50	2,51	-25,89
1,51	2,52	-25,79
1,52	2,53	-25,69
1,53	2,54	-25,59
1,54	2,55	-25,49
1,55	2,56	-25,39
1,56	2,57	-25,29
1,57	2,58	-25,19
1,58	2,59	-25,09
1,59	2,60	-24,99
1,60	2,61	-24,89
1,61	2,62	-24,79
1,62	2,63	-24,70
1,63	2,64	-24,60
1,64	2,65	-24,50
1,65	2,66	-24,40
1,66	2,67	-24,31
1,67	2,68	-24,21
1,68	2,69	-24,11
1,69	2,70	-24,02
1,70	2,71	-23,92
1,71	2,72	-23,82
1,72	2,73	-23,73
1,73	2,74	-23,63
1,74	2,75	-23,54
1,75	2,76	-23,44
1,76	2,77	-23,35
1,77	2,78	-23,25
1,78	2,79	-23,16
1,79	2,80	-23,07
1,80	2,81	-22,97
1,81	2,82	-22,88
1,82	2,83	-22,79
1,83	2,84	-22,69
1,84	2,85	-22,60
1,85	2,86	-22,51
1,86	2,87	-22,42
1,87	2,88	-22,33
1,88	2,89	-22,23
1,89	2,90	-22,14
1,90	2,91	-22,05
1,91	2,92	-21,96
1,92	2,93	-21,87



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
1,93	2,94	-21,78
1,94	2,95	-21,69
1,95	2,96	-21,60
1,96	2,97	-21,51
1,97	2,98	-21,42
1,98	2,99	-21,33
1,99	3,00	-21,24
2,00	3,01	-21,16
2,01	3,02	-21,07
2,02	3,03	-20,98
2,03	3,04	-20,89
2,04	3,05	-20,80
2,05	3,06	-20,72
2,06	3,07	-20,63
2,07	3,08	-20,54
2,08	3,09	-20,45
2,09	3,10	-20,37
2,10	3,11	-20,28
2,11	3,12	-20,19
2,12	3,13	-20,11
2,13	3,14	-20,02
2,14	3,15	-19,94
2,15	3,16	-19,85
2,16	3,17	-19,77
2,17	3,18	-19,68
2,18	3,19	-19,60
2,19	3,20	-19,51
2,20	3,21	-19,43
2,21	3,22	-19,34
2,22	3,23	-19,26
2,23	3,24	-19,17
2,24	3,25	-19,09
2,25	3,26	-19,01
2,26	3,27	-18,92
2,27	3,28	-18,84
2,28	3,29	-18,76
2,29	3,30	-18,67
2,30	3,31	-18,59
2,31	3,32	-18,51
2,32	3,33	-18,43
2,33	3,34	-18,35
2,34	3,35	-18,26
2,35	3,36	-18,18
2,36	3,37	-18,10



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	-18,02
2,38	3,39	-17,94
2,39	3,40	-17,86
2,40	3,41	-17,78
2,41	3,42	-17,70
2,42	3,43	-17,62
2,43	3,44	-17,54
2,44	3,45	-17,46
2,45	3,46	-17,38
2,46	3,47	-17,30
2,47	3,48	-17,22
2,48	3,49	-17,14
2,49	3,50	-17,06
2,50	3,51	-16,98
2,51	3,52	-16,90
2,52	3,53	-16,82
2,53	3,54	-16,74
2,54	3,55	-16,66
2,55	3,56	-16,59
2,56	3,57	-16,51
2,57	3,58	-16,43
2,58	3,59	-16,35
2,59	3,60	-16,28
2,60	3,61	-16,20
2,61	3,62	-16,12
2,62	3,63	-16,04
2,63	3,64	-15,97
2,64	3,65	-15,89
2,65	3,66	-15,81
2,66	3,67	-15,74
2,67	3,68	-15,66
2,68	3,69	-15,59
2,69	3,70	-15,51
2,70	3,71	-15,43
2,71	3,72	-15,36
2,72	3,73	-15,28
2,73	3,74	-15,21
2,74	3,75	-15,13
2,75	3,76	-15,06
2,76	3,77	-14,98
2,77	3,78	-14,91
2,78	3,79	-14,83
2,79	3,80	-14,76
2,80	3,81	-14,68



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,81	3,82	-14,61
2,82	3,83	-14,54
2,83	3,84	-14,46
2,84	3,85	-14,39
2,85	3,86	-14,31
2,86	3,87	-14,24
2,87	3,88	-14,17
2,88	3,89	-14,10
2,89	3,90	-14,02
2,90	3,91	-13,95
2,91	3,92	-13,88
2,92	3,93	-13,80
2,93	3,94	-13,73
2,94	3,95	-13,66
2,95	3,96	-13,59
2,96	3,97	-13,52
2,97	3,98	-13,44
2,98	3,99	-13,37
2,99	4,00	-13,30
3,00	4,01	-13,23
3,01	4,02	-13,16
3,02	4,03	-13,09
3,03	4,04	-13,01
3,04	4,05	-12,94
3,05	4,06	-12,87
3,06	4,07	-12,80
3,07	4,08	-12,73
3,08	4,09	-12,66
3,09	4,10	-12,59
3,10	4,11	-12,52
3,11	4,12	-12,45
3,12	4,13	-12,38
3,13	4,14	-12,31
3,14	4,15	-12,24
3,15	4,16	-12,17
3,16	4,17	-12,10
3,17	4,18	-12,03
3,18	4,19	-11,96
3,19	4,20	-11,90
3,20	4,21	-11,83
3,21	4,22	-11,76
3,22	4,23	-11,69
3,23	4,24	-11,62
3,24	4,25	-11,55



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,25	4,26	-11,48
3,26	4,27	-11,42
3,27	4,28	-11,35
3,28	4,29	-11,28
3,29	4,30	-11,21
3,30	4,31	-11,14
3,31	4,32	-11,08
3,32	4,33	-11,01
3,33	4,34	-10,94
3,34	4,35	-10,87
3,35	4,36	-10,81
3,36	4,37	-10,74
3,37	4,38	-10,67
3,38	4,39	-10,61
3,39	4,40	-10,54
3,40	4,41	-10,47
3,41	4,42	-10,41
3,42	4,43	-10,34
3,43	4,44	-10,27
3,44	4,45	-10,21
3,45	4,46	-10,14
3,46	4,47	-10,08
3,47	4,48	-10,01
3,48	4,49	-9,94
3,49	4,50	-9,88
3,50	4,51	-9,81
3,51	4,52	-9,75
3,52	4,53	-9,68
3,53	4,54	-9,62
3,54	4,55	-9,55
3,55	4,56	-9,49
3,56	4,57	-9,42
3,57	4,58	-9,36
3,58	4,59	-9,29
3,59	4,60	-9,23
3,60	4,61	-9,16
3,61	4,62	-9,10
3,62	4,63	-9,04
3,63	4,64	-8,97
3,64	4,65	-8,91
3,65	4,66	-8,84
3,66	4,67	-8,78
3,67	4,68	-8,72
3,68	4,69	-8,65



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
3,69	4,70	-8,59
3,70	4,71	-8,53
3,71	4,72	-8,46
3,72	4,73	-8,40
3,73	4,74	-8,34
3,74	4,75	-8,27
3,75	4,76	-8,21
3,76	4,77	-8,15
3,77	4,78	-8,09
3,78	4,79	-8,02
3,79	4,80	-7,96
3,80	4,81	-7,90
3,81	4,82	-7,84
3,82	4,83	-7,77
3,83	4,84	-7,71
3,84	4,85	-7,65
3,85	4,86	-7,59
3,86	4,87	-7,53
3,87	4,88	-7,46
3,88	4,89	-7,40
3,89	4,90	-7,34
3,90	4,91	-7,28
3,91	4,92	-7,22
3,92	4,93	-7,16
3,93	4,94	-7,10
3,94	4,95	-7,03
3,95	4,96	-6,97
3,96	4,97	-6,91
3,97	4,98	-6,85
3,98	4,99	-6,79
3,99	5,00	-6,73
4,00	5,01	-6,67
4,01	5,02	-6,61
4,02	5,03	-6,55
4,03	5,04	-6,49
4,04	5,05	-6,43
4,05	5,06	-6,37
4,06	5,07	-6,31
4,07	5,08	-6,25
4,08	5,09	-6,19
4,09	5,10	-6,13
4,10	5,11	-6,07
4,11	5,12	-6,01
4,12	5,13	-5,95



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	-5,89
4,14	5,15	-5,83
4,15	5,16	-5,77
4,16	5,17	-5,71
4,17	5,18	-5,65
4,18	5,19	-5,60
4,19	5,20	-5,54
4,20	5,21	-5,48
4,21	5,22	-5,42
4,22	5,23	-5,36
4,23	5,24	-5,30
4,24	5,25	-5,24
4,25	5,26	-5,19
4,26	5,27	-5,13
4,27	5,28	-5,07
4,28	5,29	-5,01
4,29	5,30	-4,95
4,30	5,31	-4,90
4,31	5,32	-4,84
4,32	5,33	-4,78
4,33	5,34	-4,72
4,34	5,35	-4,66
4,35	5,36	-4,61
4,36	5,37	-4,55
4,37	5,38	-4,49
4,38	5,39	-4,43
4,39	5,40	-4,38
4,40	5,41	-4,32
4,41	5,42	-4,26
4,42	5,43	-4,21
4,43	5,44	-4,15
4,44	5,45	-4,09
4,45	5,46	-4,04
4,46	5,47	-3,98
4,47	5,48	-3,92
4,48	5,49	-3,87
4,49	5,50	-3,81
4,50	5,51	-3,75
4,51	5,52	-3,70
4,52	5,53	-3,64
4,53	5,54	-3,58
4,54	5,55	-3,53
4,55	5,56	-3,47
4,56	5,57	-3,42



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	-3,36
4,58	5,59	-3,30
4,59	5,60	-3,25
4,60	5,61	-3,19
4,61	5,62	-3,14
4,62	5,63	-3,08
4,63	5,64	-3,03
4,64	5,65	-2,97
4,65	5,66	-2,92
4,66	5,67	-2,86
4,67	5,68	-2,81
4,68	5,69	-2,75
4,69	5,70	-2,70
4,70	5,71	-2,64
4,71	5,72	-2,59
4,72	5,73	-2,53
4,73	5,74	-2,48
4,74	5,75	-2,42
4,75	5,76	-2,37
4,76	5,77	-2,31
4,77	5,78	-2,26
4,78	5,79	-2,20
4,79	5,80	-2,15
4,80	5,81	-2,10
4,81	5,82	-2,04
4,82	5,83	-1,99
4,83	5,84	-1,93
4,84	5,85	-1,88
4,85	5,86	-1,83
4,86	5,87	-1,77
4,87	5,88	-1,72
4,88	5,89	-1,66
4,89	5,90	-1,61
4,90	5,91	-1,56
4,91	5,92	-1,50
4,92	5,93	-1,45
4,93	5,94	-1,40
4,94	5,95	-1,34
4,95	5,96	-1,29
4,96	5,97	-1,24
4,97	5,98	-1,18
4,98	5,99	-1,13
4,99	6,00	-1,08
5,00	6,01	-1,03



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	-0,97
5,02	6,03	-0,92
5,03	6,04	-0,87
5,04	6,05	-0,81
5,05	6,06	-0,76
5,06	6,07	-0,71
5,07	6,08	-0,66
5,08	6,09	-0,61
5,09	6,10	-0,55
5,10	6,11	-0,50
5,11	6,12	-0,45
5,12	6,13	-0,40
5,13	6,14	-0,34
5,14	6,15	-0,29
5,15	6,16	-0,24
5,16	6,17	-0,19
5,17	6,18	-0,14
5,18	6,19	-0,09
5,19	6,20	-0,03
5,20	6,21	0,02
5,21	6,22	0,07
5,22	6,23	0,12
5,23	6,24	0,17
5,24	6,25	0,22
5,25	6,26	0,28
5,26	6,27	0,33
5,27	6,28	0,38
5,28	6,29	0,43
5,29	6,30	0,48
5,30	6,31	0,53
5,31	6,32	0,58
5,32	6,33	0,63
5,33	6,34	0,68
5,34	6,35	0,73
5,35	6,36	0,78
5,36	6,37	0,84
5,37	6,38	0,89
5,38	6,39	0,94
5,39	6,40	0,99
5,40	6,41	1,04
5,41	6,42	1,09
5,42	6,43	1,14
5,43	6,44	1,19
5,44	6,45	1,24



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,45	6,46	1,29
5,46	6,47	1,34
5,47	6,48	1,39
5,48	6,49	1,44
5,49	6,50	1,49
5,50	6,51	1,54
5,51	6,52	1,59
5,52	6,53	1,64
5,53	6,54	1,69
5,54	6,55	1,74
5,55	6,56	1,79
5,56	6,57	1,84
5,57	6,58	1,89
5,58	6,59	1,93
5,59	6,60	1,98
5,60	6,61	2,03
5,61	6,62	2,08
5,62	6,63	2,13
5,63	6,64	2,18
5,64	6,65	2,23
5,65	6,66	2,28
5,66	6,67	2,33
5,67	6,68	2,38
5,68	6,69	2,43
5,69	6,70	2,47
5,70	6,71	2,52
5,71	6,72	2,57
5,72	6,73	2,62
5,73	6,74	2,67
5,74	6,75	2,72
5,75	6,76	2,77
5,76	6,77	2,81
5,77	6,78	2,86
5,78	6,79	2,91
5,79	6,80	2,96
5,80	6,81	3,01
5,81	6,82	3,06
5,82	6,83	3,10
5,83	6,84	3,15
5,84	6,85	3,20
5,85	6,86	3,25
5,86	6,87	3,30
5,87	6,88	3,34
5,88	6,89	3,39



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	3,44
5,90	6,91	3,49
5,91	6,92	3,53
5,92	6,93	3,58
5,93	6,94	3,63
5,94	6,95	3,68
5,95	6,96	3,72
5,96	6,97	3,77
5,97	6,98	3,82
5,98	6,99	3,87
5,99	7,00	3,91
6,00	7,01	3,96
6,01	7,02	4,01
6,02	7,03	4,05
6,03	7,04	4,10
6,04	7,05	4,15
6,05	7,06	4,20
6,06	7,07	4,24
6,07	7,08	4,29
6,08	7,09	4,34
6,09	7,10	4,38
6,10	7,11	4,43
6,11	7,12	4,48
6,12	7,13	4,52
6,13	7,14	4,57
6,14	7,15	4,62
6,15	7,16	4,66
6,16	7,17	4,71
6,17	7,18	4,75
6,18	7,19	4,80
6,19	7,20	4,85
6,20	7,21	4,89
6,21	7,22	4,94
6,22	7,23	4,99
6,23	7,24	5,03
6,24	7,25	5,08
6,25	7,26	5,12
6,26	7,27	5,17
6,27	7,28	5,22
6,28	7,29	5,26
6,29	7,30	5,31
6,30	7,31	5,35
6,31	7,32	5,40
6,32	7,33	5,44



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,33	7,34	5,49
6,34	7,35	5,54
6,35	7,36	5,58
6,36	7,37	5,63
6,37	7,38	5,67
6,38	7,39	5,72
6,39	7,40	5,76
6,40	7,41	5,81
6,41	7,42	5,85
6,42	7,43	5,90
6,43	7,44	5,94
6,44	7,45	5,99
6,45	7,46	6,03
6,46	7,47	6,08
6,47	7,48	6,12
6,48	7,49	6,17
6,49	7,50	6,21
6,50	7,51	6,26
6,51	7,52	6,30
6,52	7,53	6,35
6,53	7,54	6,39
6,54	7,55	6,44
6,55	7,56	6,48
6,56	7,57	6,53
6,57	7,58	6,57
6,58	7,59	6,62
6,59	7,60	6,66
6,60	7,61	6,70
6,61	7,62	6,75
6,62	7,63	6,79
6,63	7,64	6,84
6,64	7,65	6,88
6,65	7,66	6,93
6,66	7,67	6,97
6,67	7,68	7,01
6,68	7,69	7,06
6,69	7,70	7,10
6,70	7,71	7,15
6,71	7,72	7,19
6,72	7,73	7,23
6,73	7,74	7,28
6,74	7,75	7,32
6,75	7,76	7,36
6,76	7,77	7,41



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,77	7,78	7,45
6,78	7,79	7,50
6,79	7,80	7,54
6,80	7,81	7,58
6,81	7,82	7,63
6,82	7,83	7,67
6,83	7,84	7,71
6,84	7,85	7,76
6,85	7,86	7,80
6,86	7,87	7,84
6,87	7,88	7,89
6,88	7,89	7,93
6,89	7,90	7,97
6,90	7,91	8,02
6,91	7,92	8,06
6,92	7,93	8,10
6,93	7,94	8,15
6,94	7,95	8,19
6,95	7,96	8,23
6,96	7,97	8,27
6,97	7,98	8,32
6,98	7,99	8,36
6,99	8,00	8,40
7,00	8,01	8,45
7,01	8,02	8,49
7,02	8,03	8,53
7,03	8,04	8,57
7,04	8,05	8,62
7,05	8,06	8,66
7,06	8,07	8,70
7,07	8,08	8,74
7,08	8,09	8,79
7,09	8,10	8,83
7,10	8,11	8,87
7,11	8,12	8,91
7,12	8,13	8,96
7,13	8,14	9,00
7,14	8,15	9,04
7,15	8,16	9,08
7,16	8,17	9,12
7,17	8,18	9,17
7,18	8,19	9,21
7,19	8,20	9,25
7,20	8,21	9,29



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	9,33
7,22	8,23	9,38
7,23	8,24	9,42
7,24	8,25	9,46
7,25	8,26	9,50
7,26	8,27	9,54
7,27	8,28	9,59
7,28	8,29	9,63
7,29	8,30	9,67
7,30	8,31	9,71
7,31	8,32	9,75
7,32	8,33	9,79
7,33	8,34	9,83
7,34	8,35	9,88
7,35	8,36	9,92
7,36	8,37	9,96
7,37	8,38	10,00
7,38	8,39	10,04
7,39	8,40	10,08
7,40	8,41	10,12
7,41	8,42	10,17
7,42	8,43	10,21
7,43	8,44	10,25
7,44	8,45	10,29
7,45	8,46	10,33
7,46	8,47	10,37
7,47	8,48	10,41
7,48	8,49	10,45
7,49	8,50	10,49
7,50	8,51	10,53
7,51	8,52	10,58
7,52	8,53	10,62
7,53	8,54	10,66
7,54	8,55	10,70
7,55	8,56	10,74
7,56	8,57	10,78
7,57	8,58	10,82
7,58	8,59	10,86
7,59	8,60	10,90
7,60	8,61	10,94
7,61	8,62	10,98
7,62	8,63	11,02
7,63	8,64	11,06
7,64	8,65	11,10



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
7,65	8,66	11,14
7,66	8,67	11,18
7,67	8,68	11,22
7,68	8,69	11,26
7,69	8,70	11,30
7,70	8,71	11,34
7,71	8,72	11,39
7,72	8,73	11,43
7,73	8,74	11,47
7,74	8,75	11,51
7,75	8,76	11,55
7,76	8,77	11,59
7,77	8,78	11,63
7,78	8,79	11,67
7,79	8,80	11,71
7,80	8,81	11,74
7,81	8,82	11,78
7,82	8,83	11,82
7,83	8,84	11,86
7,84	8,85	11,90
7,85	8,86	11,94
7,86	8,87	11,98
7,87	8,88	12,02
7,88	8,89	12,06
7,89	8,90	12,10
7,90	8,91	12,14
7,91	8,92	12,18
7,92	8,93	12,22
7,93	8,94	12,26
7,94	8,95	12,30
7,95	8,96	12,34
7,96	8,97	12,38
7,97	8,98	12,42
7,98	8,99	12,46
7,99	9,00	12,50
8,00	9,01	12,54
8,01	9,02	12,57
8,02	9,03	12,61
8,03	9,04	12,65
8,04	9,05	12,69
8,05	9,06	12,73
8,06	9,07	12,77
8,07	9,08	12,81
8,08	9,09	12,85



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,09	9,10	12,89
8,10	9,11	12,93
8,11	9,12	12,96
8,12	9,13	13,00
8,13	9,14	13,04
8,14	9,15	13,08
8,15	9,16	13,12
8,16	9,17	13,16
8,17	9,18	13,20
8,18	9,19	13,24
8,19	9,20	13,27
8,20	9,21	13,31
8,21	9,22	13,35
8,22	9,23	13,39
8,23	9,24	13,43
8,24	9,25	13,47
8,25	9,26	13,50
8,26	9,27	13,54
8,27	9,28	13,58
8,28	9,29	13,62
8,29	9,30	13,66
8,30	9,31	13,70
8,31	9,32	13,73
8,32	9,33	13,77
8,33	9,34	13,81
8,34	9,35	13,85
8,35	9,36	13,89
8,36	9,37	13,93
8,37	9,38	13,96
8,38	9,39	14,00
8,39	9,40	14,04
8,40	9,41	14,08
8,41	9,42	14,12
8,42	9,43	14,15
8,43	9,44	14,19
8,44	9,45	14,23
8,45	9,46	14,27
8,46	9,47	14,30
8,47	9,48	14,34
8,48	9,49	14,38
8,49	9,50	14,42
8,50	9,51	14,46
8,51	9,52	14,49
8,52	9,53	14,53



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,53	9,54	14,57
8,54	9,55	14,61
8,55	9,56	14,64
8,56	9,57	14,68
8,57	9,58	14,72
8,58	9,59	14,76
8,59	9,60	14,79
8,60	9,61	14,83
8,61	9,62	14,87
8,62	9,63	14,91
8,63	9,64	14,94
8,64	9,65	14,98
8,65	9,66	15,02
8,66	9,67	15,05
8,67	9,68	15,09
8,68	9,69	15,13
8,69	9,70	15,17
8,70	9,71	15,20
8,71	9,72	15,24
8,72	9,73	15,28
8,73	9,74	15,31
8,74	9,75	15,35
8,75	9,76	15,39
8,76	9,77	15,43
8,77	9,78	15,46
8,78	9,79	15,50
8,79	9,80	15,54
8,80	9,81	15,57
8,81	9,82	15,61
8,82	9,83	15,65
8,83	9,84	15,68
8,84	9,85	15,72
8,85	9,86	15,76
8,86	9,87	15,79
8,87	9,88	15,83
8,88	9,89	15,87
8,89	9,90	15,90
8,90	9,91	15,94
8,91	9,92	15,98
8,92	9,93	16,01
8,93	9,94	16,05
8,94	9,95	16,09
8,95	9,96	16,12
8,96	9,97	16,16



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,97	9,98	16,19
8,98	9,99	16,23
8,99	10,00	16,27
9,00	10,01	16,30
9,01	10,02	16,34
9,02	10,03	16,38
9,03	10,04	16,41
9,04	10,05	16,45
9,05	10,06	16,48
9,06	10,07	16,52
9,07	10,08	16,56
9,08	10,09	16,59
9,09	10,10	16,63
9,10	10,11	16,66
9,11	10,12	16,70
9,12	10,13	16,74
9,13	10,14	16,77
9,14	10,15	16,81
9,15	10,16	16,84
9,16	10,17	16,88
9,17	10,18	16,92
9,18	10,19	16,95
9,19	10,20	16,99
9,20	10,21	17,02
9,21	10,22	17,06
9,22	10,23	17,09
9,23	10,24	17,13
9,24	10,25	17,17
9,25	10,26	17,20
9,26	10,27	17,24
9,27	10,28	17,27
9,28	10,29	17,31
9,29	10,30	17,34
9,30	10,31	17,38
9,31	10,32	17,42
9,32	10,33	17,45
9,33	10,34	17,49
9,34	10,35	17,52
9,35	10,36	17,56
9,36	10,37	17,59
9,37	10,38	17,63
9,38	10,39	17,66
9,39	10,40	17,70
9,40	10,41	17,73



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,41	10,42	17,77
9,42	10,43	17,80
9,43	10,44	17,84
9,44	10,45	17,87
9,45	10,46	17,91
9,46	10,47	17,94
9,47	10,48	17,98
9,48	10,49	18,01
9,49	10,50	18,05
9,50	10,51	18,08
9,51	10,52	18,12
9,52	10,53	18,15
9,53	10,54	18,19
9,54	10,55	18,22
9,55	10,56	18,26
9,56	10,57	18,29
9,57	10,58	18,33
9,58	10,59	18,36
9,59	10,60	18,40
9,60	10,61	18,43
9,61	10,62	18,47
9,62	10,63	18,50
9,63	10,64	18,54
9,64	10,65	18,57
9,65	10,66	18,61
9,66	10,67	18,64
9,67	10,68	18,68
9,68	10,69	18,71
9,69	10,70	18,74
9,70	10,71	18,78
9,71	10,72	18,81
9,72	10,73	18,85
9,73	10,74	18,88
9,74	10,75	18,92
9,75	10,76	18,95
9,76	10,77	18,99
9,77	10,78	19,02
9,78	10,79	19,05
9,79	10,80	19,09
9,80	10,81	19,12
9,81	10,82	19,16
9,82	10,83	19,19
9,83	10,84	19,23
9,84	10,85	19,26



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,85	10,86	19,29
9,86	10,87	19,33
9,87	10,88	19,36
9,88	10,89	19,40
9,89	10,90	19,43
9,90	10,91	19,46
9,91	10,92	19,50
9,92	10,93	19,53
9,93	10,94	19,57
9,94	10,95	19,60
9,95	10,96	19,63
9,96	10,97	19,67
9,97	10,98	19,70
9,98	10,99	19,74
9,99	11,00	19,77
10,00	11,01	19,80
10,01	11,02	19,84
10,02	11,03	19,87
10,03	11,04	19,91
10,04	11,05	19,94
10,05	11,06	19,97
10,06	11,07	20,01
10,07	11,08	20,04
10,08	11,09	20,07
10,09	11,10	20,11
10,10	11,11	20,14
10,11	11,12	20,17
10,12	11,13	20,21
10,13	11,14	20,24
10,14	11,15	20,28
10,15	11,16	20,31
10,16	11,17	20,34
10,17	11,18	20,38
10,18	11,19	20,41
10,19	11,20	20,44
10,20	11,21	20,48
10,21	11,22	20,51
10,22	11,23	20,54
10,23	11,24	20,58
10,24	11,25	20,61
10,25	11,26	20,64
10,26	11,27	20,68
10,27	11,28	20,71
10,28	11,29	20,74



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,29	11,30	20,78
10,30	11,31	20,81
10,31	11,32	20,84
10,32	11,33	20,88
10,33	11,34	20,91
10,34	11,35	20,94
10,35	11,36	20,97
10,36	11,37	21,01
10,37	11,38	21,04
10,38	11,39	21,07
10,39	11,40	21,11
10,40	11,41	21,14
10,41	11,42	21,17
10,42	11,43	21,21
10,43	11,44	21,24
10,44	11,45	21,27
10,45	11,46	21,30
10,46	11,47	21,34
10,47	11,48	21,37
10,48	11,49	21,40
10,49	11,50	21,43
10,50	11,51	21,47
10,51	11,52	21,50
10,52	11,53	21,53
10,53	11,54	21,57
10,54	11,55	21,60
10,55	11,56	21,63
10,56	11,57	21,66
10,57	11,58	21,70
10,58	11,59	21,73
10,59	11,60	21,76
10,60	11,61	21,79
10,61	11,62	21,83
10,62	11,63	21,86
10,63	11,64	21,89
10,64	11,65	21,92
10,65	11,66	21,96
10,66	11,67	21,99
10,67	11,68	22,02
10,68	11,69	22,05
10,69	11,70	22,09
10,70	11,71	22,12
10,71	11,72	22,15
10,72	11,73	22,18



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	22,22
10,74	11,75	22,25
10,75	11,76	22,28
10,76	11,77	22,31
10,77	11,78	22,34
10,78	11,79	22,38
10,79	11,80	22,41
10,80	11,81	22,44
10,81	11,82	22,47
10,82	11,83	22,50
10,83	11,84	22,54
10,84	11,85	22,57
10,85	11,86	22,60
10,86	11,87	22,63
10,87	11,88	22,66
10,88	11,89	22,70
10,89	11,90	22,73
10,90	11,91	22,76
10,91	11,92	22,79
10,92	11,93	22,82
10,93	11,94	22,86
10,94	11,95	22,89
10,95	11,96	22,92
10,96	11,97	22,95
10,97	11,98	22,98
10,98	11,99	23,02
10,99	12,00	23,05
11,00	12,01	23,08
11,01	12,02	23,11
11,02	12,03	23,14
11,03	12,04	23,17
11,04	12,05	23,21
11,05	12,06	23,24
11,06	12,07	23,27
11,07	12,08	23,30
11,08	12,09	23,33
11,09	12,10	23,36
11,10	12,11	23,40
11,11	12,12	23,43
11,12	12,13	23,46
11,13	12,14	23,49
11,14	12,15	23,52
11,15	12,16	23,55
11,16	12,17	23,58



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,17	12,18	23,62
11,18	12,19	23,65
11,19	12,20	23,68
11,20	12,21	23,71
11,21	12,22	23,74
11,22	12,23	23,77
11,23	12,24	23,80
11,24	12,25	23,83
11,25	12,26	23,87
11,26	12,27	23,90
11,27	12,28	23,93
11,28	12,29	23,96
11,29	12,30	23,99
11,30	12,31	24,02
11,31	12,32	24,05
11,32	12,33	24,08
11,33	12,34	24,12
11,34	12,35	24,15
11,35	12,36	24,18
11,36	12,37	24,21
11,37	12,38	24,24
11,38	12,39	24,27
11,39	12,40	24,30
11,40	12,41	24,33
11,41	12,42	24,36
11,42	12,43	24,39
11,43	12,44	24,43
11,44	12,45	24,46
11,45	12,46	24,49
11,46	12,47	24,52
11,47	12,48	24,55
11,48	12,49	24,58
11,49	12,50	24,61
11,50	12,51	24,64
11,51	12,52	24,67
11,52	12,53	24,70
11,53	12,54	24,73
11,54	12,55	24,76
11,55	12,56	24,80
11,56	12,57	24,83
11,57	12,58	24,86
11,58	12,59	24,89
11,59	12,60	24,92
11,60	12,61	24,95



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	24,98
11,62	12,63	25,01
11,63	12,64	25,04
11,64	12,65	25,07
11,65	12,66	25,10
11,66	12,67	25,13
11,67	12,68	25,16
11,68	12,69	25,19
11,69	12,70	25,22
11,70	12,71	25,25
11,71	12,72	25,28
11,72	12,73	25,31
11,73	12,74	25,34
11,74	12,75	25,38
11,75	12,76	25,41
11,76	12,77	25,44
11,77	12,78	25,47
11,78	12,79	25,50
11,79	12,80	25,53
11,80	12,81	25,56
11,81	12,82	25,59
11,82	12,83	25,62
11,83	12,84	25,65
11,84	12,85	25,68
11,85	12,86	25,71
11,86	12,87	25,74
11,87	12,88	25,77
11,88	12,89	25,80
11,89	12,90	25,83
11,90	12,91	25,86
11,91	12,92	25,89
11,92	12,93	25,92
11,93	12,94	25,95
11,94	12,95	25,98
11,95	12,96	26,01
11,96	12,97	26,04
11,97	12,98	26,07
11,98	12,99	26,10
11,99	13,00	26,13
12,00	13,01	26,16
12,01	13,02	26,19
12,02	13,03	26,22
12,03	13,04	26,25
12,04	13,05	26,28



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,05	13,06	26,31
12,06	13,07	26,34
12,07	13,08	26,37
12,08	13,09	26,40
12,09	13,10	26,43
12,10	13,11	26,46
12,11	13,12	26,49
12,12	13,13	26,52
12,13	13,14	26,55
12,14	13,15	26,58
12,15	13,16	26,61
12,16	13,17	26,64
12,17	13,18	26,66
12,18	13,19	26,69
12,19	13,20	26,72
12,20	13,21	26,75
12,21	13,22	26,78
12,22	13,23	26,81
12,23	13,24	26,84
12,24	13,25	26,87
12,25	13,26	26,90
12,26	13,27	26,93
12,27	13,28	26,96
12,28	13,29	26,99
12,29	13,30	27,02
12,30	13,31	27,05
12,31	13,32	27,08
12,32	13,33	27,11
12,33	13,34	27,14
12,34	13,35	27,17
12,35	13,36	27,20
12,36	13,37	27,22
12,37	13,38	27,25
12,38	13,39	27,28
12,39	13,40	27,31
12,40	13,41	27,34
12,41	13,42	27,37
12,42	13,43	27,40
12,43	13,44	27,43
12,44	13,45	27,46
12,45	13,46	27,49
12,46	13,47	27,52
12,47	13,48	27,55
12,48	13,49	27,58



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
12,49	13,50	27,60
12,50	13,51	27,63
12,51	13,52	27,66
12,52	13,53	27,69
12,53	13,54	27,72
12,54	13,55	27,75
12,55	13,56	27,78
12,56	13,57	27,81
12,57	13,58	27,84
12,58	13,59	27,87
12,59	13,60	27,90
12,60	13,61	27,92
12,61	13,62	27,95
12,62	13,63	27,98
12,63	13,64	28,01
12,64	13,65	28,04
12,65	13,66	28,07
12,66	13,67	28,10
12,67	13,68	28,13
12,68	13,69	28,16
12,69	13,70	28,18
12,70	13,71	28,21
12,71	13,72	28,24
12,72	13,73	28,27
12,73	13,74	28,30
12,74	13,75	28,33
12,75	13,76	28,36
12,76	13,77	28,39
12,77	13,78	28,41
12,78	13,79	28,44
12,79	13,80	28,47
12,80	13,81	28,50
12,81	13,82	28,53
12,82	13,83	28,56
12,83	13,84	28,59
12,84	13,85	28,61
12,85	13,86	28,64
12,86	13,87	28,67
12,87	13,88	28,70
12,88	13,89	28,73
12,89	13,90	28,76
12,90	13,91	28,79
12,91	13,92	28,81
12,92	13,93	28,84



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	28,87
12,94	13,95	28,90
12,95	13,96	28,93
12,96	13,97	28,96
12,97	13,98	28,98
12,98	13,99	29,01
12,99	14,00	29,04
13,00	14,01	29,07
13,01	14,02	29,10
13,02	14,03	29,13
13,03	14,04	29,15
13,04	14,05	29,18
13,05	14,06	29,21
13,06	14,07	29,24
13,07	14,08	29,27
13,08	14,09	29,30
13,09	14,10	29,32
13,10	14,11	29,35
13,11	14,12	29,38
13,12	14,13	29,41
13,13	14,14	29,44
13,14	14,15	29,46
13,15	14,16	29,49
13,16	14,17	29,52
13,17	14,18	29,55
13,18	14,19	29,58
13,19	14,20	29,60
13,20	14,21	29,63
13,21	14,22	29,66
13,22	14,23	29,69
13,23	14,24	29,72
13,24	14,25	29,74
13,25	14,26	29,77
13,26	14,27	29,80
13,27	14,28	29,83
13,28	14,29	29,86
13,29	14,30	29,88
13,30	14,31	29,91
13,31	14,32	29,94
13,32	14,33	29,97
13,33	14,34	30,00
13,34	14,35	30,02
13,35	14,36	30,05
13,36	14,37	30,08



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,37	14,38	30,11
13,38	14,39	30,14
13,39	14,40	30,16
13,40	14,41	30,19
13,41	14,42	30,22
13,42	14,43	30,25
13,43	14,44	30,27
13,44	14,45	30,30
13,45	14,46	30,33
13,46	14,47	30,36
13,47	14,48	30,38
13,48	14,49	30,41
13,49	14,50	30,44
13,50	14,51	30,47
13,51	14,52	30,50
13,52	14,53	30,52
13,53	14,54	30,55
13,54	14,55	30,58
13,55	14,56	30,61
13,56	14,57	30,63
13,57	14,58	30,66
13,58	14,59	30,69
13,59	14,60	30,72
13,60	14,61	30,74
13,61	14,62	30,77
13,62	14,63	30,80
13,63	14,64	30,83
13,64	14,65	30,85
13,65	14,66	30,88
13,66	14,67	30,91
13,67	14,68	30,93
13,68	14,69	30,96
13,69	14,70	30,99
13,70	14,71	31,02
13,71	14,72	31,04
13,72	14,73	31,07
13,73	14,74	31,10
13,74	14,75	31,13
13,75	14,76	31,15
13,76	14,77	31,18
13,77	14,78	31,21
13,78	14,79	31,24
13,79	14,80	31,26
13,80	14,81	31,29



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,81	14,82	31,32
13,82	14,83	31,34
13,83	14,84	31,37
13,84	14,85	31,40
13,85	14,86	31,43
13,86	14,87	31,45
13,87	14,88	31,48
13,88	14,89	31,51
13,89	14,90	31,53
13,90	14,91	31,56
13,91	14,92	31,59
13,92	14,93	31,61
13,93	14,94	31,64
13,94	14,95	31,67
13,95	14,96	31,70
13,96	14,97	31,72
13,97	14,98	31,75
13,98	14,99	31,78
13,99	15,00	31,80
14,00	15,01	31,83
14,01	15,02	31,86
14,02	15,03	31,88
14,03	15,04	31,91
14,04	15,05	31,94
14,05	15,06	31,97
14,06	15,07	31,99
14,07	15,08	32,02
14,08	15,09	32,05
14,09	15,10	32,07
14,10	15,11	32,10
14,11	15,12	32,13
14,12	15,13	32,15
14,13	15,14	32,18
14,14	15,15	32,21
14,15	15,16	32,23
14,16	15,17	32,26
14,17	15,18	32,29
14,18	15,19	32,31
14,19	15,20	32,34
14,20	15,21	32,37
14,21	15,22	32,39
14,22	15,23	32,42
14,23	15,24	32,45
14,24	15,25	32,47



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
14,25	15,26	32,50
14,26	15,27	32,53
14,27	15,28	32,55
14,28	15,29	32,58
14,29	15,30	32,61
14,30	15,31	32,63
14,31	15,32	32,66
14,32	15,33	32,69
14,33	15,34	32,71
14,34	15,35	32,74
14,35	15,36	32,77
14,36	15,37	32,79
14,37	15,38	32,82
14,38	15,39	32,84
14,39	15,40	32,87
14,40	15,41	32,90
14,41	15,42	32,92
14,42	15,43	32,95
14,43	15,44	32,98
14,44	15,45	33,00
14,45	15,46	33,03
14,46	15,47	33,06
14,47	15,48	33,08
14,48	15,49	33,11
14,49	15,50	33,13
14,50	15,51	33,16
14,51	15,52	33,19
14,52	15,53	33,21
14,53	15,54	33,24
14,54	15,55	33,27
14,55	15,56	33,29
14,56	15,57	33,32
14,57	15,58	33,34
14,58	15,59	33,37
14,59	15,60	33,40
14,60	15,61	33,42
14,61	15,62	33,45
14,62	15,63	33,48
14,63	15,64	33,50
14,64	15,65	33,53
14,65	15,66	33,55
14,66	15,67	33,58
14,67	15,68	33,61
14,68	15,69	33,63



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	33,66
14,70	15,71	33,68
14,71	15,72	33,71
14,72	15,73	33,74
14,73	15,74	33,76
14,74	15,75	33,79
14,75	15,76	33,81
14,76	15,77	33,84
14,77	15,78	33,87
14,78	15,79	33,89
14,79	15,80	33,92
14,80	15,81	33,94
14,81	15,82	33,97
14,82	15,83	34,00
14,83	15,84	34,02
14,84	15,85	34,05
14,85	15,86	34,07
14,86	15,87	34,10
14,87	15,88	34,12
14,88	15,89	34,15
14,89	15,90	34,18
14,90	15,91	34,20
14,91	15,92	34,23
14,92	15,93	34,25
14,93	15,94	34,28
14,94	15,95	34,31
14,95	15,96	34,33
14,96	15,97	34,36
14,97	15,98	34,38
14,98	15,99	34,41
14,99	16,00	34,43
15,00	16,01	34,46
15,01	16,02	34,49
15,02	16,03	34,51
15,03	16,04	34,54
15,04	16,05	34,56
15,05	16,06	34,59
15,06	16,07	34,61
15,07	16,08	34,64
15,08	16,09	34,66
15,09	16,10	34,69
15,10	16,11	34,72
15,11	16,12	34,74
15,12	16,13	34,77



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	34,79
15,14	16,15	34,82
15,15	16,16	34,84
15,16	16,17	34,87
15,17	16,18	34,89
15,18	16,19	34,92
15,19	16,20	34,95
15,20	16,21	34,97
15,21	16,22	35,00
15,22	16,23	35,02
15,23	16,24	35,05
15,24	16,25	35,07
15,25	16,26	35,10
15,26	16,27	35,12
15,27	16,28	35,15
15,28	16,29	35,17
15,29	16,30	35,20
15,30	16,31	35,22
15,31	16,32	35,25
15,32	16,33	35,28
15,33	16,34	35,30
15,34	16,35	35,33
15,35	16,36	35,35
15,36	16,37	35,38
15,37	16,38	35,40
15,38	16,39	35,43
15,39	16,40	35,45
15,40	16,41	35,48
15,41	16,42	35,50
15,42	16,43	35,53
15,43	16,44	35,55
15,44	16,45	35,58
15,45	16,46	35,60
15,46	16,47	35,63
15,47	16,48	35,65
15,48	16,49	35,68
15,49	16,50	35,70
15,50	16,51	35,73
15,51	16,52	35,75
15,52	16,53	35,78
15,53	16,54	35,80
15,54	16,55	35,83
15,55	16,56	35,85
15,56	16,57	35,88



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
15,57	16,58	35,90
15,58	16,59	35,93
15,59	16,60	35,95
15,60	16,61	35,98
15,61	16,62	36,00
15,62	16,63	36,03
15,63	16,64	36,05
15,64	16,65	36,08
15,65	16,66	36,10
15,66	16,67	36,13
15,67	16,68	36,15
15,68	16,69	36,18
15,69	16,70	36,20
15,70	16,71	36,23
15,71	16,72	36,25
15,72	16,73	36,28
15,73	16,74	36,30
15,74	16,75	36,33
15,75	16,76	36,35
15,76	16,77	36,38
15,77	16,78	36,40
15,78	16,79	36,43
15,79	16,80	36,45
15,80	16,81	36,48
15,81	16,82	36,50
15,82	16,83	36,53
15,83	16,84	36,55
15,84	16,85	36,58
15,85	16,86	36,60
15,86	16,87	36,63
15,87	16,88	36,65
15,88	16,89	36,67
15,89	16,90	36,70
15,90	16,91	36,72
15,91	16,92	36,75
15,92	16,93	36,77
15,93	16,94	36,80
15,94	16,95	36,82
15,95	16,96	36,85
15,96	16,97	36,87
15,97	16,98	36,90
15,98	16,99	36,92
15,99	17,00	36,95
16,00	17,01	36,97



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	36,99
16,02	17,03	37,02
16,03	17,04	37,04
16,04	17,05	37,07
16,05	17,06	37,09
16,06	17,07	37,12
16,07	17,08	37,14
16,08	17,09	37,17
16,09	17,10	37,19
16,10	17,11	37,21
16,11	17,12	37,24
16,12	17,13	37,26
16,13	17,14	37,29
16,14	17,15	37,31
16,15	17,16	37,34
16,16	17,17	37,36
16,17	17,18	37,39
16,18	17,19	37,41
16,19	17,20	37,43
16,20	17,21	37,46
16,21	17,22	37,48
16,22	17,23	37,51
16,23	17,24	37,53
16,24	17,25	37,56
16,25	17,26	37,58
16,26	17,27	37,60
16,27	17,28	37,63
16,28	17,29	37,65
16,29	17,30	37,68
16,30	17,31	37,70
16,31	17,32	37,73
16,32	17,33	37,75
16,33	17,34	37,77
16,34	17,35	37,80
16,35	17,36	37,82
16,36	17,37	37,85
16,37	17,38	37,87
16,38	17,39	37,90
16,39	17,40	37,92
16,40	17,41	37,94
16,41	17,42	37,97
16,42	17,43	37,99
16,43	17,44	38,02
16,44	17,45	38,04



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
16,45	17,46	38,06
16,46	17,47	38,09
16,47	17,48	38,11
16,48	17,49	38,14
16,49	17,50	38,16
16,50	17,51	38,18
16,51	17,52	38,21
16,52	17,53	38,23
16,53	17,54	38,26
16,54	17,55	38,28
16,55	17,56	38,30
16,56	17,57	38,33
16,57	17,58	38,35
16,58	17,59	38,38
16,59	17,60	38,40
16,60	17,61	38,42
16,61	17,62	38,45
16,62	17,63	38,47
16,63	17,64	38,50
16,64	17,65	38,52
16,65	17,66	38,54
16,66	17,67	38,57
16,67	17,68	38,59
16,68	17,69	38,62
16,69	17,70	38,64
16,70	17,71	38,66
16,71	17,72	38,69
16,72	17,73	38,71
16,73	17,74	38,73
16,74	17,75	38,76
16,75	17,76	38,78
16,76	17,77	38,81
16,77	17,78	38,83
16,78	17,79	38,85
16,79	17,80	38,88
16,80	17,81	38,90
16,81	17,82	38,92
16,82	17,83	38,95
16,83	17,84	38,97
16,84	17,85	39,00
16,85	17,86	39,02
16,86	17,87	39,04
16,87	17,88	39,07
16,88	17,89	39,09



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
16,89	17,90	39,11
16,90	17,91	39,14
16,91	17,92	39,16
16,92	17,93	39,18
16,93	17,94	39,21
16,94	17,95	39,23
16,95	17,96	39,26
16,96	17,97	39,28
16,97	17,98	39,30
16,98	17,99	39,33
16,99	18,00	39,35
17,00	18,01	39,37
17,01	18,02	39,40
17,02	18,03	39,42
17,03	18,04	39,44
17,04	18,05	39,47
17,05	18,06	39,49
17,06	18,07	39,51
17,07	18,08	39,54
17,08	18,09	39,56
17,09	18,10	39,58
17,10	18,11	39,61
17,11	18,12	39,63
17,12	18,13	39,65
17,13	18,14	39,68
17,14	18,15	39,70
17,15	18,16	39,72
17,16	18,17	39,75
17,17	18,18	39,77
17,18	18,19	39,80
17,19	18,20	39,82
17,20	18,21	39,84
17,21	18,22	39,87
17,22	18,23	39,89
17,23	18,24	39,91
17,24	18,25	39,94
17,25	18,26	39,96
17,26	18,27	39,98
17,27	18,28	40,00
17,28	18,29	40,03
17,29	18,30	40,05
17,30	18,31	40,07
17,31	18,32	40,10
17,32	18,33	40,12



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
17,33	18,34	40,14
17,34	18,35	40,17
17,35	18,36	40,19
17,36	18,37	40,21
17,37	18,38	40,24
17,38	18,39	40,26
17,39	18,40	40,28
17,40	18,41	40,31
17,41	18,42	40,33
17,42	18,43	40,35
17,43	18,44	40,38
17,44	18,45	40,40
17,45	18,46	40,42
17,46	18,47	40,45
17,47	18,48	40,47
17,48	18,49	40,49
17,49	18,50	40,51
17,50	18,51	40,54
17,51	18,52	40,56
17,52	18,53	40,58
17,53	18,54	40,61
17,54	18,55	40,63
17,55	18,56	40,65
17,56	18,57	40,68
17,57	18,58	40,70
17,58	18,59	40,72
17,59	18,60	40,74
17,60	18,61	40,77
17,61	18,62	40,79
17,62	18,63	40,81
17,63	18,64	40,84
17,64	18,65	40,86
17,65	18,66	40,88
17,66	18,67	40,91
17,67	18,68	40,93
17,68	18,69	40,95
17,69	18,70	40,97
17,70	18,71	41,00
17,71	18,72	41,02
17,72	18,73	41,04
17,73	18,74	41,07
17,74	18,75	41,09
17,75	18,76	41,11
17,76	18,77	41,13



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
17,77	18,78	41,16
17,78	18,79	41,18
17,79	18,80	41,20
17,80	18,81	41,23
17,81	18,82	41,25
17,82	18,83	41,27
17,83	18,84	41,29
17,84	18,85	41,32
17,85	18,86	41,34
17,86	18,87	41,36
17,87	18,88	41,38
17,88	18,89	41,41
17,89	18,90	41,43
17,90	18,91	41,45
17,91	18,92	41,48
17,92	18,93	41,50
17,93	18,94	41,52
17,94	18,95	41,54
17,95	18,96	41,57
17,96	18,97	41,59
17,97	18,98	41,61
17,98	18,99	41,63
17,99	19,00	41,66
18,00	19,01	41,68
18,01	19,02	41,70
18,02	19,03	41,72
18,03	19,04	41,75
18,04	19,05	41,77
18,05	19,06	41,79
18,06	19,07	41,81
18,07	19,08	41,84
18,08	19,09	41,86
18,09	19,10	41,88
18,10	19,11	41,90
18,11	19,12	41,93
18,12	19,13	41,95
18,13	19,14	41,97
18,14	19,15	41,99
18,15	19,16	42,02
18,16	19,17	42,04
18,17	19,18	42,06
18,18	19,19	42,08
18,19	19,20	42,11
18,20	19,21	42,13



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
18,21	19,22	42,15
18,22	19,23	42,17
18,23	19,24	42,20
18,24	19,25	42,22
18,25	19,26	42,24
18,26	19,27	42,26
18,27	19,28	42,29
18,28	19,29	42,31
18,29	19,30	42,33
18,30	19,31	42,35
18,31	19,32	42,38
18,32	19,33	42,40
18,33	19,34	42,42
18,34	19,35	42,44
18,35	19,36	42,46
18,36	19,37	42,49
18,37	19,38	42,51
18,38	19,39	42,53
18,39	19,40	42,55
18,40	19,41	42,58
18,41	19,42	42,60
18,42	19,43	42,62
18,43	19,44	42,64
18,44	19,45	42,67
18,45	19,46	42,69
18,46	19,47	42,71
18,47	19,48	42,73
18,48	19,49	42,75
18,49	19,50	42,78
18,50	19,51	42,80
18,51	19,52	42,82
18,52	19,53	42,84
18,53	19,54	42,86
18,54	19,55	42,89
18,55	19,56	42,91
18,56	19,57	42,93
18,57	19,58	42,95
18,58	19,59	42,98
18,59	19,60	43,00
18,60	19,61	43,02
18,61	19,62	43,04
18,62	19,63	43,06
18,63	19,64	43,09
18,64	19,65	43,11



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,65	19,66	43,13
18,66	19,67	43,15
18,67	19,68	43,17
18,68	19,69	43,20
18,69	19,70	43,22
18,70	19,71	43,24
18,71	19,72	43,26
18,72	19,73	43,28
18,73	19,74	43,31
18,74	19,75	43,33
18,75	19,76	43,35
18,76	19,77	43,37
18,77	19,78	43,39
18,78	19,79	43,42
18,79	19,80	43,44
18,80	19,81	43,46
18,81	19,82	43,48
18,82	19,83	43,50
18,83	19,84	43,53
18,84	19,85	43,55
18,85	19,86	43,57
18,86	19,87	43,59
18,87	19,88	43,61
18,88	19,89	43,63
18,89	19,90	43,66
18,90	19,91	43,68
18,91	19,92	43,70
18,92	19,93	43,72
18,93	19,94	43,74
18,94	19,95	43,77
18,95	19,96	43,79
18,96	19,97	43,81
18,97	19,98	43,83
18,98	19,99	43,85
18,99	20,00	43,87
19,00	20,01	43,90
19,01	20,02	43,92
19,02	20,03	43,94
19,03	20,04	43,96
19,04	20,05	43,98
19,05	20,06	44,01
19,06	20,07	44,03
19,07	20,08	44,05
19,08	20,09	44,07



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	44,09
19,10	20,11	44,11
19,11	20,12	44,14
19,12	20,13	44,16
19,13	20,14	44,18
19,14	20,15	44,20
19,15	20,16	44,22
19,16	20,17	44,24
19,17	20,18	44,27
19,18	20,19	44,29
19,19	20,20	44,31
19,20	20,21	44,33
19,21	20,22	44,35
19,22	20,23	44,37
19,23	20,24	44,39
19,24	20,25	44,42
19,25	20,26	44,44
19,26	20,27	44,46
19,27	20,28	44,48
19,28	20,29	44,50
19,29	20,30	44,52
19,30	20,31	44,55
19,31	20,32	44,57
19,32	20,33	44,59
19,33	20,34	44,61
19,34	20,35	44,63
19,35	20,36	44,65
19,36	20,37	44,67
19,37	20,38	44,70
19,38	20,39	44,72
19,39	20,40	44,74
19,40	20,41	44,76
19,41	20,42	44,78
19,42	20,43	44,80
19,43	20,44	44,82
19,44	20,45	44,85
19,45	20,46	44,87
19,46	20,47	44,89
19,47	20,48	44,91
19,48	20,49	44,93
19,49	20,50	44,95
19,50	20,51	44,97
19,51	20,52	45,00
19,52	20,53	45,02



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	45,04
19,54	20,55	45,06
19,55	20,56	45,08
19,56	20,57	45,10
19,57	20,58	45,12
19,58	20,59	45,14
19,59	20,60	45,17
19,60	20,61	45,19
19,61	20,62	45,21
19,62	20,63	45,23
19,63	20,64	45,25
19,64	20,65	45,27
19,65	20,66	45,29
19,66	20,67	45,31
19,67	20,68	45,34
19,68	20,69	45,36
19,69	20,70	45,38
19,70	20,71	45,40
19,71	20,72	45,42
19,72	20,73	45,44
19,73	20,74	45,46
19,74	20,75	45,48
19,75	20,76	45,51
19,76	20,77	45,53
19,77	20,78	45,55
19,78	20,79	45,57
19,79	20,80	45,59
19,80	20,81	45,61
19,81	20,82	45,63
19,82	20,83	45,65
19,83	20,84	45,67
19,84	20,85	45,70
19,85	20,86	45,72
19,86	20,87	45,74
19,87	20,88	45,76
19,88	20,89	45,78
19,89	20,90	45,80
19,90	20,91	45,82
19,91	20,92	45,84
19,92	20,93	45,86
19,93	20,94	45,89
19,94	20,95	45,91
19,95	20,96	45,93
19,96	20,97	45,95



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,97	20,98	45,97
19,98	20,99	45,99
19,99	21,00	46,01
20,00	21,01	46,03
20,01	21,02	46,05
20,02	21,03	46,07
20,03	21,04	46,10
20,04	21,05	46,12
20,05	21,06	46,14
20,06	21,07	46,16
20,07	21,08	46,18
20,08	21,09	46,20
20,09	21,10	46,22
20,10	21,11	46,24
20,11	21,12	46,26
20,12	21,13	46,28
20,13	21,14	46,30
20,14	21,15	46,33
20,15	21,16	46,35
20,16	21,17	46,37
20,17	21,18	46,39
20,18	21,19	46,41
20,19	21,20	46,43
20,20	21,21	46,45
20,21	21,22	46,47
20,22	21,23	46,49
20,23	21,24	46,51
20,24	21,25	46,53
20,25	21,26	46,55
20,26	21,27	46,58
20,27	21,28	46,60
20,28	21,29	46,62
20,29	21,30	46,64
20,30	21,31	46,66
20,31	21,32	46,68
20,32	21,33	46,70
20,33	21,34	46,72
20,34	21,35	46,74
20,35	21,36	46,76
20,36	21,37	46,78
20,37	21,38	46,80
20,38	21,39	46,82
20,39	21,40	46,84
20,40	21,41	46,87



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
20,41	21,42	46,89
20,42	21,43	46,91
20,43	21,44	46,93
20,44	21,45	46,95
20,45	21,46	46,97
20,46	21,47	46,99
20,47	21,48	47,01
20,48	21,49	47,03
20,49	21,50	47,05
20,50	21,51	47,07
20,51	21,52	47,09
20,52	21,53	47,11
20,53	21,54	47,13
20,54	21,55	47,15
20,55	21,56	47,17
20,56	21,57	47,20
20,57	21,58	47,22
20,58	21,59	47,24
20,59	21,60	47,26
20,60	21,61	47,28
20,61	21,62	47,30
20,62	21,63	47,32
20,63	21,64	47,34
20,64	21,65	47,36
20,65	21,66	47,38
20,66	21,67	47,40
20,67	21,68	47,42
20,68	21,69	47,44
20,69	21,70	47,46
20,70	21,71	47,48
20,71	21,72	47,50
20,72	21,73	47,52
20,73	21,74	47,54
20,74	21,75	47,56
20,75	21,76	47,58
20,76	21,77	47,61
20,77	21,78	47,63
20,78	21,79	47,65
20,79	21,80	47,67
20,80	21,81	47,69
20,81	21,82	47,71
20,82	21,83	47,73
20,83	21,84	47,75
20,84	21,85	47,77



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	47,79
20,86	21,87	47,81
20,87	21,88	47,83
20,88	21,89	47,85
20,89	21,90	47,87
20,90	21,91	47,89
20,91	21,92	47,91
20,92	21,93	47,93
20,93	21,94	47,95
20,94	21,95	47,97
20,95	21,96	47,99
20,96	21,97	48,01
20,97	21,98	48,03
20,98	21,99	48,05
20,99	22,00	48,07
21,00	22,01	48,09
21,01	22,02	48,11
21,02	22,03	48,13
21,03	22,04	48,15
21,04	22,05	48,17
21,05	22,06	48,19
21,06	22,07	48,21
21,07	22,08	48,23
21,08	22,09	48,25
21,09	22,10	48,28
21,10	22,11	48,30
21,11	22,12	48,32
21,12	22,13	48,34
21,13	22,14	48,36
21,14	22,15	48,38
21,15	22,16	48,40
21,16	22,17	48,42
21,17	22,18	48,44
21,18	22,19	48,46
21,19	22,20	48,48
21,20	22,21	48,50
21,21	22,22	48,52
21,22	22,23	48,54
21,23	22,24	48,56
21,24	22,25	48,58
21,25	22,26	48,60
21,26	22,27	48,62
21,27	22,28	48,64
21,28	22,29	48,66



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,29	22,30	48,68
21,30	22,31	48,70
21,31	22,32	48,72
21,32	22,33	48,74
21,33	22,34	48,76
21,34	22,35	48,78
21,35	22,36	48,80
21,36	22,37	48,82
21,37	22,38	48,84
21,38	22,39	48,86
21,39	22,40	48,88
21,40	22,41	48,90
21,41	22,42	48,92
21,42	22,43	48,94
21,43	22,44	48,96
21,44	22,45	48,98
21,45	22,46	49,00
21,46	22,47	49,02
21,47	22,48	49,04
21,48	22,49	49,06
21,49	22,50	49,08
21,50	22,51	49,10
21,51	22,52	49,12
21,52	22,53	49,14
21,53	22,54	49,16
21,54	22,55	49,18
21,55	22,56	49,20
21,56	22,57	49,22
21,57	22,58	49,24
21,58	22,59	49,26
21,59	22,60	49,28
21,60	22,61	49,30
21,61	22,62	49,32
21,62	22,63	49,34
21,63	22,64	49,36
21,64	22,65	49,38
21,65	22,66	49,39
21,66	22,67	49,41
21,67	22,68	49,43
21,68	22,69	49,45
21,69	22,70	49,47
21,70	22,71	49,49
21,71	22,72	49,51
21,72	22,73	49,53



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	49,55
21,74	22,75	49,57
21,75	22,76	49,59
21,76	22,77	49,61
21,77	22,78	49,63
21,78	22,79	49,65
21,79	22,80	49,67
21,80	22,81	49,69
21,81	22,82	49,71
21,82	22,83	49,73
21,83	22,84	49,75
21,84	22,85	49,77
21,85	22,86	49,79
21,86	22,87	49,81
21,87	22,88	49,83
21,88	22,89	49,85
21,89	22,90	49,87
21,90	22,91	49,89
21,91	22,92	49,91
21,92	22,93	49,93
21,93	22,94	49,95
21,94	22,95	49,97
21,95	22,96	49,99
21,96	22,97	50,01
21,97	22,98	50,03
21,98	22,99	50,05
21,99	23,00	50,06
22,00	23,01	50,08
22,01	23,02	50,10
22,02	23,03	50,12
22,03	23,04	50,14
22,04	23,05	50,16
22,05	23,06	50,18
22,06	23,07	50,20
22,07	23,08	50,22
22,08	23,09	50,24
22,09	23,10	50,26
22,10	23,11	50,28
22,11	23,12	50,30
22,12	23,13	50,32
22,13	23,14	50,34
22,14	23,15	50,36
22,15	23,16	50,38
22,16	23,17	50,40



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
22,17	23,18	50,42
22,18	23,19	50,44
22,19	23,20	50,46
22,20	23,21	50,47
22,21	23,22	50,49
22,22	23,23	50,51
22,23	23,24	50,53
22,24	23,25	50,55
22,25	23,26	50,57
22,26	23,27	50,59
22,27	23,28	50,61
22,28	23,29	50,63
22,29	23,30	50,65
22,30	23,31	50,67
22,31	23,32	50,69
22,32	23,33	50,71
22,33	23,34	50,73
22,34	23,35	50,75
22,35	23,36	50,77
22,36	23,37	50,79
22,37	23,38	50,80
22,38	23,39	50,82
22,39	23,40	50,84
22,40	23,41	50,86
22,41	23,42	50,88
22,42	23,43	50,90
22,43	23,44	50,92
22,44	23,45	50,94
22,45	23,46	50,96
22,46	23,47	50,98
22,47	23,48	51,00
22,48	23,49	51,02
22,49	23,50	51,04
22,50	23,51	51,06
22,51	23,52	51,07
22,52	23,53	51,09
22,53	23,54	51,11
22,54	23,55	51,13
22,55	23,56	51,15
22,56	23,57	51,17
22,57	23,58	51,19
22,58	23,59	51,21
22,59	23,60	51,23
22,60	23,61	51,25



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	51,27
22,62	23,63	51,29
22,63	23,64	51,31
22,64	23,65	51,32
22,65	23,66	51,34
22,66	23,67	51,36
22,67	23,68	51,38
22,68	23,69	51,40
22,69	23,70	51,42
22,70	23,71	51,44
22,71	23,72	51,46
22,72	23,73	51,48
22,73	23,74	51,50
22,74	23,75	51,52
22,75	23,76	51,53
22,76	23,77	51,55
22,77	23,78	51,57
22,78	23,79	51,59
22,79	23,80	51,61
22,80	23,81	51,63
22,81	23,82	51,65
22,82	23,83	51,67
22,83	23,84	51,69
22,84	23,85	51,71
22,85	23,86	51,73
22,86	23,87	51,74
22,87	23,88	51,76
22,88	23,89	51,78
22,89	23,90	51,80
22,90	23,91	51,82
22,91	23,92	51,84
22,92	23,93	51,86
22,93	23,94	51,88
22,94	23,95	51,90
22,95	23,96	51,92
22,96	23,97	51,93
22,97	23,98	51,95
22,98	23,99	51,97
22,99	24,00	51,99
23,00	24,01	52,01
23,01	24,02	52,03
23,02	24,03	52,05
23,03	24,04	52,07
23,04	24,05	52,09



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,05	24,06	52,11
23,06	24,07	52,12
23,07	24,08	52,14
23,08	24,09	52,16
23,09	24,10	52,18
23,10	24,11	52,20
23,11	24,12	52,22
23,12	24,13	52,24
23,13	24,14	52,26
23,14	24,15	52,28
23,15	24,16	52,29
23,16	24,17	52,31
23,17	24,18	52,33
23,18	24,19	52,35
23,19	24,20	52,37
23,20	24,21	52,39
23,21	24,22	52,41
23,22	24,23	52,43
23,23	24,24	52,45
23,24	24,25	52,46
23,25	24,26	52,48
23,26	24,27	52,50
23,27	24,28	52,52
23,28	24,29	52,54
23,29	24,30	52,56
23,30	24,31	52,58
23,31	24,32	52,60
23,32	24,33	52,61
23,33	24,34	52,63
23,34	24,35	52,65
23,35	24,36	52,67
23,36	24,37	52,69
23,37	24,38	52,71
23,38	24,39	52,73
23,39	24,40	52,75
23,40	24,41	52,76
23,41	24,42	52,78
23,42	24,43	52,80
23,43	24,44	52,82
23,44	24,45	52,84
23,45	24,46	52,86
23,46	24,47	52,88
23,47	24,48	52,90
23,48	24,49	52,91



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,49	24,50	52,93
23,50	24,51	52,95
23,51	24,52	52,97
23,52	24,53	52,99
23,53	24,54	53,01
23,54	24,55	53,03
23,55	24,56	53,04
23,56	24,57	53,06
23,57	24,58	53,08
23,58	24,59	53,10
23,59	24,60	53,12
23,60	24,61	53,14
23,61	24,62	53,16
23,62	24,63	53,17
23,63	24,64	53,19
23,64	24,65	53,21
23,65	24,66	53,23
23,66	24,67	53,25
23,67	24,68	53,27
23,68	24,69	53,29
23,69	24,70	53,30
23,70	24,71	53,32
23,71	24,72	53,34
23,72	24,73	53,36
23,73	24,74	53,38
23,74	24,75	53,40
23,75	24,76	53,42
23,76	24,77	53,43
23,77	24,78	53,45
23,78	24,79	53,47
23,79	24,80	53,49
23,80	24,81	53,51
23,81	24,82	53,53
23,82	24,83	53,55
23,83	24,84	53,56
23,84	24,85	53,58
23,85	24,86	53,60
23,86	24,87	53,62
23,87	24,88	53,64
23,88	24,89	53,66
23,89	24,90	53,67
23,90	24,91	53,69
23,91	24,92	53,71
23,92	24,93	53,73



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,93	24,94	53,75
23,94	24,95	53,77
23,95	24,96	53,78
23,96	24,97	53,80
23,97	24,98	53,82
23,98	24,99	53,84
23,99	25,00	53,86
24,00	25,01	53,88
24,01	25,02	53,90
24,02	25,03	53,91
24,03	25,04	53,93
24,04	25,05	53,95
24,05	25,06	53,97
24,06	25,07	53,99
24,07	25,08	54,01
24,08	25,09	54,02
24,09	25,10	54,04
24,10	25,11	54,06
24,11	25,12	54,08
24,12	25,13	54,10
24,13	25,14	54,12
24,14	25,15	54,13
24,15	25,16	54,15
24,16	25,17	54,17
24,17	25,18	54,19
24,18	25,19	54,21
24,19	25,20	54,22
24,20	25,21	54,24
24,21	25,22	54,26
24,22	25,23	54,28
24,23	25,24	54,30
24,24	25,25	54,32
24,25	25,26	54,33
24,26	25,27	54,35
24,27	25,28	54,37
24,28	25,29	54,39
24,29	25,30	54,41
24,30	25,31	54,43
24,31	25,32	54,44
24,32	25,33	54,46
24,33	25,34	54,48
24,34	25,35	54,50
24,35	25,36	54,52
24,36	25,37	54,53



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,37	25,38	54,55
24,38	25,39	54,57
24,39	25,40	54,59
24,40	25,41	54,61
24,41	25,42	54,63
24,42	25,43	54,64
24,43	25,44	54,66
24,44	25,45	54,68
24,45	25,46	54,70
24,46	25,47	54,72
24,47	25,48	54,73
24,48	25,49	54,75
24,49	25,50	54,77
24,50	25,51	54,79
24,51	25,52	54,81
24,52	25,53	54,82
24,53	25,54	54,84
24,54	25,55	54,86
24,55	25,56	54,88
24,56	25,57	54,90
24,57	25,58	54,91
24,58	25,59	54,93
24,59	25,60	54,95
24,60	25,61	54,97
24,61	25,62	54,99
24,62	25,63	55,01
24,63	25,64	55,02
24,64	25,65	55,04
24,65	25,66	55,06
24,66	25,67	55,08
24,67	25,68	55,10
24,68	25,69	55,11
24,69	25,70	55,13
24,70	25,71	55,15
24,71	25,72	55,17
24,72	25,73	55,19
24,73	25,74	55,20
24,74	25,75	55,22
24,75	25,76	55,24
24,76	25,77	55,26
24,77	25,78	55,28
24,78	25,79	55,29
24,79	25,80	55,31
24,80	25,81	55,33



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	55,35
24,82	25,83	55,36
24,83	25,84	55,38
24,84	25,85	55,40
24,85	25,86	55,42
24,86	25,87	55,44
24,87	25,88	55,45
24,88	25,89	55,47
24,89	25,90	55,49
24,90	25,91	55,51
24,91	25,92	55,53
24,92	25,93	55,54
24,93	25,94	55,56
24,94	25,95	55,58
24,95	25,96	55,60
24,96	25,97	55,62
24,97	25,98	55,63
24,98	25,99	55,65
24,99	26,00	55,67
25,00	26,01	55,69
25,01	26,02	55,70
25,02	26,03	55,72
25,03	26,04	55,74
25,04	26,05	55,76
25,05	26,06	55,78
25,06	26,07	55,79
25,07	26,08	55,81
25,08	26,09	55,83
25,09	26,10	55,85
25,10	26,11	55,86
25,11	26,12	55,88
25,12	26,13	55,90
25,13	26,14	55,92
25,14	26,15	55,94
25,15	26,16	55,95
25,16	26,17	55,97
25,17	26,18	55,99
25,18	26,19	56,01
25,19	26,20	56,02
25,20	26,21	56,04
25,21	26,22	56,06
25,22	26,23	56,08
25,23	26,24	56,09
25,24	26,25	56,11



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	56,13
25,26	26,27	56,15
25,27	26,28	56,17
25,28	26,29	56,18
25,29	26,30	56,20
25,30	26,31	56,22
25,31	26,32	56,24
25,32	26,33	56,25
25,33	26,34	56,27
25,34	26,35	56,29
25,35	26,36	56,31
25,36	26,37	56,32
25,37	26,38	56,34
25,38	26,39	56,36
25,39	26,40	56,38
25,40	26,41	56,40
25,41	26,42	56,41
25,42	26,43	56,43
25,43	26,44	56,45
25,44	26,45	56,47
25,45	26,46	56,48
25,46	26,47	56,50
25,47	26,48	56,52
25,48	26,49	56,54
25,49	26,50	56,55
25,50	26,51	56,57
25,51	26,52	56,59
25,52	26,53	56,61
25,53	26,54	56,62
25,54	26,55	56,64
25,55	26,56	56,66
25,56	26,57	56,68
25,57	26,58	56,69
25,58	26,59	56,71
25,59	26,60	56,73
25,60	26,61	56,75
25,61	26,62	56,76
25,62	26,63	56,78
25,63	26,64	56,80
25,64	26,65	56,82
25,65	26,66	56,83
25,66	26,67	56,85
25,67	26,68	56,87
25,68	26,69	56,89



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,69	26,70	56,90
25,70	26,71	56,92
25,71	26,72	56,94
25,72	26,73	56,96
25,73	26,74	56,97
25,74	26,75	56,99
25,75	26,76	57,01
25,76	26,77	57,03
25,77	26,78	57,04
25,78	26,79	57,06
25,79	26,80	57,08
25,80	26,81	57,10
25,81	26,82	57,11
25,82	26,83	57,13
25,83	26,84	57,15
25,84	26,85	57,17
25,85	26,86	57,18
25,86	26,87	57,20
25,87	26,88	57,22
25,88	26,89	57,23
25,89	26,90	57,25
25,90	26,91	57,27
25,91	26,92	57,29
25,92	26,93	57,30
25,93	26,94	57,32
25,94	26,95	57,34
25,95	26,96	57,36
25,96	26,97	57,37
25,97	26,98	57,39
25,98	26,99	57,41
25,99	27,00	57,43
26,00	27,01	57,44
26,01	27,02	57,46
26,02	27,03	57,48
26,03	27,04	57,49
26,04	27,05	57,51
26,05	27,06	57,53
26,06	27,07	57,55
26,07	27,08	57,56
26,08	27,09	57,58
26,09	27,10	57,60
26,10	27,11	57,62
26,11	27,12	57,63
26,12	27,13	57,65



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	57,67
26,14	27,15	57,68
26,15	27,16	57,70
26,16	27,17	57,72
26,17	27,18	57,74
26,18	27,19	57,75
26,19	27,20	57,77
26,20	27,21	57,79
26,21	27,22	57,80
26,22	27,23	57,82
26,23	27,24	57,84
26,24	27,25	57,86
26,25	27,26	57,87
26,26	27,27	57,89
26,27	27,28	57,91
26,28	27,29	57,93
26,29	27,30	57,94
26,30	27,31	57,96
26,31	27,32	57,98
26,32	27,33	57,99
26,33	27,34	58,01
26,34	27,35	58,03
26,35	27,36	58,05
26,36	27,37	58,06
26,37	27,38	58,08
26,38	27,39	58,10
26,39	27,40	58,11
26,40	27,41	58,13
26,41	27,42	58,15
26,42	27,43	58,17
26,43	27,44	58,18
26,44	27,45	58,20
26,45	27,46	58,22
26,46	27,47	58,23
26,47	27,48	58,25
26,48	27,49	58,27
26,49	27,50	58,28
26,50	27,51	58,30
26,51	27,52	58,32
26,52	27,53	58,34
26,53	27,54	58,35
26,54	27,55	58,37
26,55	27,56	58,39
26,56	27,57	58,40



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,57	27,58	58,42
26,58	27,59	58,44
26,59	27,60	58,46
26,60	27,61	58,47
26,61	27,62	58,49
26,62	27,63	58,51
26,63	27,64	58,52
26,64	27,65	58,54
26,65	27,66	58,56
26,66	27,67	58,57
26,67	27,68	58,59
26,68	27,69	58,61
26,69	27,70	58,62
26,70	27,71	58,64
26,71	27,72	58,66
26,72	27,73	58,68
26,73	27,74	58,69
26,74	27,75	58,71
26,75	27,76	58,73
26,76	27,77	58,74
26,77	27,78	58,76
26,78	27,79	58,78
26,79	27,80	58,79
26,80	27,81	58,81
26,81	27,82	58,83
26,82	27,83	58,85
26,83	27,84	58,86
26,84	27,85	58,88
26,85	27,86	58,90
26,86	27,87	58,91
26,87	27,88	58,93
26,88	27,89	58,95
26,89	27,90	58,96
26,90	27,91	58,98
26,91	27,92	59,00
26,92	27,93	59,01
26,93	27,94	59,03
26,94	27,95	59,05
26,95	27,96	59,06
26,96	27,97	59,08
26,97	27,98	59,10
26,98	27,99	59,11
26,99	28,00	59,13
27,00	28,01	59,15



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	59,17
27,02	28,03	59,18
27,03	28,04	59,20
27,04	28,05	59,22
27,05	28,06	59,23
27,06	28,07	59,25
27,07	28,08	59,27
27,08	28,09	59,28
27,09	28,10	59,30
27,10	28,11	59,32
27,11	28,12	59,33
27,12	28,13	59,35
27,13	28,14	59,37
27,14	28,15	59,38
27,15	28,16	59,40
27,16	28,17	59,42
27,17	28,18	59,43
27,18	28,19	59,45
27,19	28,20	59,47
27,20	28,21	59,48
27,21	28,22	59,50
27,22	28,23	59,52
27,23	28,24	59,53
27,24	28,25	59,55
27,25	28,26	59,57
27,26	28,27	59,58
27,27	28,28	59,60
27,28	28,29	59,62
27,29	28,30	59,63
27,30	28,31	59,65
27,31	28,32	59,67
27,32	28,33	59,68
27,33	28,34	59,70
27,34	28,35	59,72
27,35	28,36	59,73
27,36	28,37	59,75
27,37	28,38	59,77
27,38	28,39	59,78
27,39	28,40	59,80
27,40	28,41	59,82
27,41	28,42	59,83
27,42	28,43	59,85
27,43	28,44	59,87
27,44	28,45	59,88



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
27,45	28,46	59,90
27,46	28,47	59,92
27,47	28,48	59,93
27,48	28,49	59,95
27,49	28,50	59,97
27,50	28,51	59,98
27,51	28,52	60,00
27,52	28,53	60,02
27,53	28,54	60,03
27,54	28,55	60,05
27,55	28,56	60,07
27,56	28,57	60,08
27,57	28,58	60,10
27,58	28,59	60,12
27,59	28,60	60,13
27,60	28,61	60,15
27,61	28,62	60,17
27,62	28,63	60,18
27,63	28,64	60,20
27,64	28,65	60,22
27,65	28,66	60,23
27,66	28,67	60,25
27,67	28,68	60,26
27,68	28,69	60,28
27,69	28,70	60,30
27,70	28,71	60,31
27,71	28,72	60,33
27,72	28,73	60,35
27,73	28,74	60,36
27,74	28,75	60,38
27,75	28,76	60,40
27,76	28,77	60,41
27,77	28,78	60,43
27,78	28,79	60,45
27,79	28,80	60,46
27,80	28,81	60,48
27,81	28,82	60,50
27,82	28,83	60,51
27,83	28,84	60,53
27,84	28,85	60,54
27,85	28,86	60,56
27,86	28,87	60,58
27,87	28,88	60,59
27,88	28,89	60,61



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
27,89	28,90	60,63
27,90	28,91	60,64
27,91	28,92	60,66
27,92	28,93	60,68
27,93	28,94	60,69
27,94	28,95	60,71
27,95	28,96	60,73
27,96	28,97	60,74
27,97	28,98	60,76
27,98	28,99	60,77
27,99	29,00	60,79
28,00	29,01	60,81
28,01	29,02	60,82
28,02	29,03	60,84
28,03	29,04	60,86
28,04	29,05	60,87
28,05	29,06	60,89
28,06	29,07	60,91
28,07	29,08	60,92
28,08	29,09	60,94
28,09	29,10	60,95
28,10	29,11	60,97
28,11	29,12	60,99
28,12	29,13	61,00
28,13	29,14	61,02
28,14	29,15	61,04
28,15	29,16	61,05
28,16	29,17	61,07
28,17	29,18	61,08
28,18	29,19	61,10
28,19	29,20	61,12
28,20	29,21	61,13
28,21	29,22	61,15
28,22	29,23	61,17
28,23	29,24	61,18
28,24	29,25	61,20
28,25	29,26	61,21
28,26	29,27	61,23
28,27	29,28	61,25
28,28	29,29	61,26
28,29	29,30	61,28
28,30	29,31	61,30
28,31	29,32	61,31
28,32	29,33	61,33



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	61,34
28,34	29,35	61,36
28,35	29,36	61,38
28,36	29,37	61,39
28,37	29,38	61,41
28,38	29,39	61,43
28,39	29,40	61,44
28,40	29,41	61,46
28,41	29,42	61,47
28,42	29,43	61,49
28,43	29,44	61,51
28,44	29,45	61,52
28,45	29,46	61,54
28,46	29,47	61,55
28,47	29,48	61,57
28,48	29,49	61,59
28,49	29,50	61,60
28,50	29,51	61,62
28,51	29,52	61,64
28,52	29,53	61,65
28,53	29,54	61,67
28,54	29,55	61,68
28,55	29,56	61,70
28,56	29,57	61,72
28,57	29,58	61,73
28,58	29,59	61,75
28,59	29,60	61,76
28,60	29,61	61,78
28,61	29,62	61,80
28,62	29,63	61,81
28,63	29,64	61,83
28,64	29,65	61,84
28,65	29,66	61,86
28,66	29,67	61,88
28,67	29,68	61,89
28,68	29,69	61,91
28,69	29,70	61,93
28,70	29,71	61,94
28,71	29,72	61,96
28,72	29,73	61,97
28,73	29,74	61,99
28,74	29,75	62,01
28,75	29,76	62,02
28,76	29,77	62,04



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	62,05
28,78	29,79	62,07
28,79	29,80	62,09
28,80	29,81	62,10
28,81	29,82	62,12
28,82	29,83	62,13
28,83	29,84	62,15
28,84	29,85	62,17
28,85	29,86	62,18
28,86	29,87	62,20
28,87	29,88	62,21
28,88	29,89	62,23
28,89	29,90	62,25
28,90	29,91	62,26
28,91	29,92	62,28
28,92	29,93	62,29
28,93	29,94	62,31
28,94	29,95	62,32
28,95	29,96	62,34
28,96	29,97	62,36
28,97	29,98	62,37
28,98	29,99	62,39
28,99	30,00	62,40
29,00	30,01	62,42
29,01	30,02	62,44
29,02	30,03	62,45
29,03	30,04	62,47
29,04	30,05	62,48
29,05	30,06	62,50
29,06	30,07	62,52
29,07	30,08	62,53
29,08	30,09	62,55
29,09	30,10	62,56
29,10	30,11	62,58
29,11	30,12	62,60
29,12	30,13	62,61
29,13	30,14	62,63
29,14	30,15	62,64
29,15	30,16	62,66
29,16	30,17	62,67
29,17	30,18	62,69
29,18	30,19	62,71
29,19	30,20	62,72
29,20	30,21	62,74



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	62,75
29,22	30,23	62,77
29,23	30,24	62,79
29,24	30,25	62,80
29,25	30,26	62,82
29,26	30,27	62,83
29,27	30,28	62,85
29,28	30,29	62,86
29,29	30,30	62,88
29,30	30,31	62,90
29,31	30,32	62,91
29,32	30,33	62,93
29,33	30,34	62,94
29,34	30,35	62,96
29,35	30,36	62,97
29,36	30,37	62,99
29,37	30,38	63,01
29,38	30,39	63,02
29,39	30,40	63,04
29,40	30,41	63,05
29,41	30,42	63,07
29,42	30,43	63,09
29,43	30,44	63,10
29,44	30,45	63,12
29,45	30,46	63,13
29,46	30,47	63,15
29,47	30,48	63,16
29,48	30,49	63,18
29,49	30,50	63,20
29,50	30,51	63,21
29,51	30,52	63,23
29,52	30,53	63,24
29,53	30,54	63,26
29,54	30,55	63,27
29,55	30,56	63,29
29,56	30,57	63,31
29,57	30,58	63,32
29,58	30,59	63,34
29,59	30,60	63,35
29,60	30,61	63,37
29,61	30,62	63,38
29,62	30,63	63,40
29,63	30,64	63,41
29,64	30,65	63,43



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,65	30,66	63,45
29,66	30,67	63,46
29,67	30,68	63,48
29,68	30,69	63,49
29,69	30,70	63,51
29,70	30,71	63,52
29,71	30,72	63,54
29,72	30,73	63,56
29,73	30,74	63,57
29,74	30,75	63,59
29,75	30,76	63,60
29,76	30,77	63,62
29,77	30,78	63,63
29,78	30,79	63,65
29,79	30,80	63,66
29,80	30,81	63,68
29,81	30,82	63,70
29,82	30,83	63,71
29,83	30,84	63,73
29,84	30,85	63,74
29,85	30,86	63,76
29,86	30,87	63,77
29,87	30,88	63,79
29,88	30,89	63,80
29,89	30,90	63,82
29,90	30,91	63,84
29,91	30,92	63,85
29,92	30,93	63,87
29,93	30,94	63,88
29,94	30,95	63,90
29,95	30,96	63,91
29,96	30,97	63,93
29,97	30,98	63,94
29,98	30,99	63,96
29,99	31,00	63,98
30,00	31,01	63,99
30,01	31,02	64,01
30,02	31,03	64,02
30,03	31,04	64,04
30,04	31,05	64,05
30,05	31,06	64,07
30,06	31,07	64,08
30,07	31,08	64,10
30,08	31,09	64,11



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
30,09	31,10	64,13
30,10	31,11	64,15
30,11	31,12	64,16
30,12	31,13	64,18
30,13	31,14	64,19
30,14	31,15	64,21
30,15	31,16	64,22
30,16	31,17	64,24
30,17	31,18	64,25
30,18	31,19	64,27
30,19	31,20	64,28
30,20	31,21	64,30
30,21	31,22	64,32
30,22	31,23	64,33
30,23	31,24	64,35
30,24	31,25	64,36
30,25	31,26	64,38
30,26	31,27	64,39
30,27	31,28	64,41
30,28	31,29	64,42
30,29	31,30	64,44
30,30	31,31	64,45
30,31	31,32	64,47
30,32	31,33	64,48
30,33	31,34	64,50
30,34	31,35	64,52
30,35	31,36	64,53
30,36	31,37	64,55
30,37	31,38	64,56
30,38	31,39	64,58
30,39	31,40	64,59
30,40	31,41	64,61
30,41	31,42	64,62
30,42	31,43	64,64
30,43	31,44	64,65
30,44	31,45	64,67
30,45	31,46	64,68
30,46	31,47	64,70
30,47	31,48	64,71
30,48	31,49	64,73
30,49	31,50	64,75
30,50	31,51	64,76
30,51	31,52	64,78
30,52	31,53	64,79



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
30,53	31,54	64,81
30,54	31,55	64,82
30,55	31,56	64,84
30,56	31,57	64,85
30,57	31,58	64,87
30,58	31,59	64,88
30,59	31,60	64,90
30,60	31,61	64,91
30,61	31,62	64,93
30,62	31,63	64,94
30,63	31,64	64,96
30,64	31,65	64,97
30,65	31,66	64,99
30,66	31,67	65,00
30,67	31,68	65,02
30,68	31,69	65,03
30,69	31,70	65,05
30,70	31,71	65,07
30,71	31,72	65,08
30,72	31,73	65,10
30,73	31,74	65,11
30,74	31,75	65,13
30,75	31,76	65,14
30,76	31,77	65,16
30,77	31,78	65,17
30,78	31,79	65,19
30,79	31,80	65,20
30,80	31,81	65,22
30,81	31,82	65,23
30,82	31,83	65,25
30,83	31,84	65,26
30,84	31,85	65,28
30,85	31,86	65,29
30,86	31,87	65,31
30,87	31,88	65,32
30,88	31,89	65,34
30,89	31,90	65,35
30,90	31,91	65,37
30,91	31,92	65,38
30,92	31,93	65,40
30,93	31,94	65,41
30,94	31,95	65,43
30,95	31,96	65,44
30,96	31,97	65,46



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,97	31,98	65,47
30,98	31,99	65,49
30,99	32,00	65,50
31,00	32,01	65,52
31,01	32,02	65,53
31,02	32,03	65,55
31,03	32,04	65,57
31,04	32,05	65,58
31,05	32,06	65,60
31,06	32,07	65,61
31,07	32,08	65,63
31,08	32,09	65,64
31,09	32,10	65,66
31,10	32,11	65,67
31,11	32,12	65,69
31,12	32,13	65,70
31,13	32,14	65,72
31,14	32,15	65,73
31,15	32,16	65,75
31,16	32,17	65,76
31,17	32,18	65,78
31,18	32,19	65,79
31,19	32,20	65,81
31,20	32,21	65,82
31,21	32,22	65,84
31,22	32,23	65,85
31,23	32,24	65,87
31,24	32,25	65,88
31,25	32,26	65,90
31,26	32,27	65,91
31,27	32,28	65,93
31,28	32,29	65,94
31,29	32,30	65,96
31,30	32,31	65,97
31,31	32,32	65,99
31,32	32,33	66,00
31,33	32,34	66,02
31,34	32,35	66,03
31,35	32,36	66,05
31,36	32,37	66,06
31,37	32,38	66,08
31,38	32,39	66,09
31,39	32,40	66,11
31,40	32,41	66,12



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	66,14
31,42	32,43	66,15
31,43	32,44	66,17
31,44	32,45	66,18
31,45	32,46	66,19
31,46	32,47	66,21
31,47	32,48	66,22
31,48	32,49	66,24
31,49	32,50	66,25
31,50	32,51	66,27
31,51	32,52	66,28
31,52	32,53	66,30
31,53	32,54	66,31
31,54	32,55	66,33
31,55	32,56	66,34
31,56	32,57	66,36
31,57	32,58	66,37
31,58	32,59	66,39
31,59	32,60	66,40
31,60	32,61	66,42
31,61	32,62	66,43
31,62	32,63	66,45
31,63	32,64	66,46
31,64	32,65	66,48
31,65	32,66	66,49
31,66	32,67	66,51
31,67	32,68	66,52
31,68	32,69	66,54
31,69	32,70	66,55
31,70	32,71	66,57
31,71	32,72	66,58
31,72	32,73	66,60
31,73	32,74	66,61
31,74	32,75	66,63
31,75	32,76	66,64
31,76	32,77	66,66
31,77	32,78	66,67
31,78	32,79	66,68
31,79	32,80	66,70
31,80	32,81	66,71
31,81	32,82	66,73
31,82	32,83	66,74
31,83	32,84	66,76
31,84	32,85	66,77



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
31,85	32,86	66,79
31,86	32,87	66,80
31,87	32,88	66,82
31,88	32,89	66,83
31,89	32,90	66,85
31,90	32,91	66,86
31,91	32,92	66,88
31,92	32,93	66,89
31,93	32,94	66,91
31,94	32,95	66,92
31,95	32,96	66,94
31,96	32,97	66,95
31,97	32,98	66,97
31,98	32,99	66,98
31,99	33,00	66,99
32,00	33,01	67,01
32,01	33,02	67,02
32,02	33,03	67,04
32,03	33,04	67,05
32,04	33,05	67,07
32,05	33,06	67,08
32,06	33,07	67,10
32,07	33,08	67,11
32,08	33,09	67,13
32,09	33,10	67,14
32,10	33,11	67,16
32,11	33,12	67,17
32,12	33,13	67,19
32,13	33,14	67,20
32,14	33,15	67,21
32,15	33,16	67,23
32,16	33,17	67,24
32,17	33,18	67,26
32,18	33,19	67,27
32,19	33,20	67,29
32,20	33,21	67,30
32,21	33,22	67,32
32,22	33,23	67,33
32,23	33,24	67,35
32,24	33,25	67,36
32,25	33,26	67,38
32,26	33,27	67,39
32,27	33,28	67,40
32,28	33,29	67,42



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	67,43
32,30	33,31	67,45
32,31	33,32	67,46
32,32	33,33	67,48
32,33	33,34	67,49
32,34	33,35	67,51
32,35	33,36	67,52
32,36	33,37	67,54
32,37	33,38	67,55
32,38	33,39	67,57
32,39	33,40	67,58
32,40	33,41	67,59
32,41	33,42	67,61
32,42	33,43	67,62
32,43	33,44	67,64
32,44	33,45	67,65
32,45	33,46	67,67
32,46	33,47	67,68
32,47	33,48	67,70
32,48	33,49	67,71
32,49	33,50	67,73
32,50	33,51	67,74
32,51	33,52	67,75
32,52	33,53	67,77
32,53	33,54	67,78
32,54	33,55	67,80
32,55	33,56	67,81
32,56	33,57	67,83
32,57	33,58	67,84
32,58	33,59	67,86
32,59	33,60	67,87
32,60	33,61	67,88
32,61	33,62	67,90
32,62	33,63	67,91
32,63	33,64	67,93
32,64	33,65	67,94
32,65	33,66	67,96
32,66	33,67	67,97
32,67	33,68	67,99
32,68	33,69	68,00
32,69	33,70	68,01
32,70	33,71	68,03
32,71	33,72	68,04
32,72	33,73	68,06



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,73	33,74	68,07
32,74	33,75	68,09
32,75	33,76	68,10
32,76	33,77	68,12
32,77	33,78	68,13
32,78	33,79	68,14
32,79	33,80	68,16
32,80	33,81	68,17
32,81	33,82	68,19
32,82	33,83	68,20
32,83	33,84	68,22
32,84	33,85	68,23
32,85	33,86	68,25
32,86	33,87	68,26
32,87	33,88	68,27
32,88	33,89	68,29
32,89	33,90	68,30
32,90	33,91	68,32
32,91	33,92	68,33
32,92	33,93	68,35
32,93	33,94	68,36
32,94	33,95	68,37
32,95	33,96	68,39
32,96	33,97	68,40
32,97	33,98	68,42
32,98	33,99	68,43
32,99	34,00	68,45
33,00	34,01	68,46
33,01	34,02	68,47
33,02	34,03	68,49
33,03	34,04	68,50
33,04	34,05	68,52
33,05	34,06	68,53
33,06	34,07	68,55
33,07	34,08	68,56
33,08	34,09	68,58
33,09	34,10	68,59
33,10	34,11	68,60
33,11	34,12	68,62
33,12	34,13	68,63
33,13	34,14	68,65
33,14	34,15	68,66
33,15	34,16	68,68
33,16	34,17	68,69



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,17	34,18	68,70
33,18	34,19	68,72
33,19	34,20	68,73
33,20	34,21	68,75
33,21	34,22	68,76
33,22	34,23	68,77
33,23	34,24	68,79
33,24	34,25	68,80
33,25	34,26	68,82
33,26	34,27	68,83
33,27	34,28	68,85
33,28	34,29	68,86
33,29	34,30	68,87
33,30	34,31	68,89
33,31	34,32	68,90
33,32	34,33	68,92
33,33	34,34	68,93
33,34	34,35	68,95
33,35	34,36	68,96
33,36	34,37	68,97
33,37	34,38	68,99
33,38	34,39	69,00
33,39	34,40	69,02
33,40	34,41	69,03
33,41	34,42	69,04
33,42	34,43	69,06
33,43	34,44	69,07
33,44	34,45	69,09
33,45	34,46	69,10
33,46	34,47	69,12
33,47	34,48	69,13
33,48	34,49	69,14
33,49	34,50	69,16
33,50	34,51	69,17
33,51	34,52	69,19
33,52	34,53	69,20
33,53	34,54	69,21
33,54	34,55	69,23
33,55	34,56	69,24
33,56	34,57	69,26
33,57	34,58	69,27
33,58	34,59	69,29
33,59	34,60	69,30
33,60	34,61	69,31



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,61	34,62	69,33
33,62	34,63	69,34
33,63	34,64	69,36
33,64	34,65	69,37
33,65	34,66	69,38
33,66	34,67	69,40
33,67	34,68	69,41
33,68	34,69	69,43
33,69	34,70	69,44
33,70	34,71	69,45
33,71	34,72	69,47
33,72	34,73	69,48
33,73	34,74	69,50
33,74	34,75	69,51
33,75	34,76	69,52
33,76	34,77	69,54
33,77	34,78	69,55
33,78	34,79	69,57
33,79	34,80	69,58
33,80	34,81	69,59
33,81	34,82	69,61
33,82	34,83	69,62
33,83	34,84	69,64
33,84	34,85	69,65
33,85	34,86	69,66
33,86	34,87	69,68
33,87	34,88	69,69
33,88	34,89	69,71
33,89	34,90	69,72
33,90	34,91	69,74
33,91	34,92	69,75
33,92	34,93	69,76
33,93	34,94	69,78
33,94	34,95	69,79
33,95	34,96	69,80
33,96	34,97	69,82
33,97	34,98	69,83
33,98	34,99	69,85
33,99	35,00	69,86
34,00	35,01	69,87
34,01	35,02	69,89
34,02	35,03	69,90
34,03	35,04	69,92
34,04	35,05	69,93



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,05	35,06	69,94
34,06	35,07	69,96
34,07	35,08	69,97
34,08	35,09	69,99
34,09	35,10	70,00
34,10	35,11	70,01
34,11	35,12	70,03
34,12	35,13	70,04
34,13	35,14	70,06
34,14	35,15	70,07
34,15	35,16	70,08
34,16	35,17	70,10
34,17	35,18	70,11
34,18	35,19	70,13
34,19	35,20	70,14
34,20	35,21	70,15
34,21	35,22	70,17
34,22	35,23	70,18
34,23	35,24	70,19
34,24	35,25	70,21
34,25	35,26	70,22
34,26	35,27	70,24
34,27	35,28	70,25
34,28	35,29	70,26
34,29	35,30	70,28
34,30	35,31	70,29
34,31	35,32	70,31
34,32	35,33	70,32
34,33	35,34	70,33
34,34	35,35	70,35
34,35	35,36	70,36
34,36	35,37	70,37
34,37	35,38	70,39
34,38	35,39	70,40
34,39	35,40	70,42
34,40	35,41	70,43
34,41	35,42	70,44
34,42	35,43	70,46
34,43	35,44	70,47
34,44	35,45	70,49
34,45	35,46	70,50
34,46	35,47	70,51
34,47	35,48	70,53
34,48	35,49	70,54



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,49	35,50	70,55
34,50	35,51	70,57
34,51	35,52	70,58
34,52	35,53	70,60
34,53	35,54	70,61
34,54	35,55	70,62
34,55	35,56	70,64
34,56	35,57	70,65
34,57	35,58	70,66
34,58	35,59	70,68
34,59	35,60	70,69
34,60	35,61	70,71
34,61	35,62	70,72
34,62	35,63	70,73
34,63	35,64	70,75
34,64	35,65	70,76
34,65	35,66	70,77
34,66	35,67	70,79
34,67	35,68	70,80
34,68	35,69	70,82
34,69	35,70	70,83
34,70	35,71	70,84
34,71	35,72	70,86
34,72	35,73	70,87
34,73	35,74	70,88
34,74	35,75	70,90
34,75	35,76	70,91
34,76	35,77	70,93
34,77	35,78	70,94
34,78	35,79	70,95
34,79	35,80	70,97
34,80	35,81	70,98
34,81	35,82	70,99
34,82	35,83	71,01
34,83	35,84	71,02
34,84	35,85	71,03
34,85	35,86	71,05
34,86	35,87	71,06
34,87	35,88	71,08
34,88	35,89	71,09
34,89	35,90	71,10
34,90	35,91	71,12
34,91	35,92	71,13
34,92	35,93	71,14



R403B		
V1.0_R403B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,93	35,94	71,16
34,94	35,95	71,17
34,95	35,96	71,18
34,96	35,97	71,20
34,97	35,98	71,21
34,98	35,99	71,23
34,99	36,00	71,24
35,00	36,01	71,25
35,01	36,02	71,27