



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-63,93
-0,70	0,31	-63,41
-0,69	0,32	-62,90
-0,68	0,33	-62,41
-0,67	0,34	-61,93
-0,66	0,35	-61,46
-0,65	0,36	-61,00
-0,64	0,37	-60,55
-0,63	0,38	-60,11
-0,62	0,39	-59,68
-0,61	0,40	-59,26
-0,60	0,41	-58,85
-0,59	0,42	-58,44
-0,58	0,43	-58,05
-0,57	0,44	-57,66
-0,56	0,45	-57,28
-0,55	0,46	-56,90
-0,54	0,47	-56,53
-0,53	0,48	-56,17
-0,52	0,49	-55,81
-0,51	0,50	-55,46
-0,50	0,51	-55,12
-0,49	0,52	-54,78
-0,48	0,53	-54,44
-0,47	0,54	-54,11
-0,46	0,55	-53,79
-0,45	0,56	-53,47
-0,44	0,57	-53,15
-0,43	0,58	-52,84
-0,42	0,59	-52,53
-0,41	0,60	-52,23
-0,40	0,61	-51,93
-0,39	0,62	-51,64
-0,38	0,63	-51,34
-0,37	0,64	-51,06
-0,36	0,65	-50,77
-0,35	0,66	-50,49
-0,34	0,67	-50,22
-0,33	0,68	-49,94
-0,32	0,69	-49,67
-0,31	0,70	-49,40
-0,30	0,71	-49,14
-0,29	0,72	-48,88
-0,28	0,73	-48,62



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-48,36
-0,26	0,75	-48,11
-0,25	0,76	-47,86
-0,24	0,77	-47,61
-0,23	0,78	-47,37
-0,22	0,79	-47,12
-0,21	0,80	-46,88
-0,20	0,81	-46,65
-0,19	0,82	-46,41
-0,18	0,83	-46,18
-0,17	0,84	-45,94
-0,16	0,85	-45,72
-0,15	0,86	-45,49
-0,14	0,87	-45,26
-0,13	0,88	-45,04
-0,12	0,89	-44,82
-0,11	0,90	-44,60
-0,10	0,91	-44,38
-0,09	0,92	-44,17
-0,08	0,93	-43,96
-0,07	0,94	-43,75
-0,06	0,95	-43,54
-0,05	0,96	-43,33
-0,04	0,97	-43,12
-0,03	0,98	-42,92
-0,02	0,99	-42,71
-0,01	1,00	-42,51
0,00	1,01	-42,31
0,01	1,02	-42,12
0,02	1,03	-41,92
0,03	1,04	-41,72
0,04	1,05	-41,53
0,05	1,06	-41,34
0,06	1,07	-41,15
0,07	1,08	-40,96
0,08	1,09	-40,77
0,09	1,10	-40,58
0,10	1,11	-40,40
0,11	1,12	-40,21
0,12	1,13	-40,03
0,13	1,14	-39,85
0,14	1,15	-39,67
0,15	1,16	-39,49
0,16	1,17	-39,31



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,17	1,18	-39,14
0,18	1,19	-38,96
0,19	1,20	-38,79
0,20	1,21	-38,61
0,21	1,22	-38,44
0,22	1,23	-38,27
0,23	1,24	-38,10
0,24	1,25	-37,93
0,25	1,26	-37,76
0,26	1,27	-37,60
0,27	1,28	-37,43
0,28	1,29	-37,27
0,29	1,30	-37,10
0,30	1,31	-36,94
0,31	1,32	-36,78
0,32	1,33	-36,62
0,33	1,34	-36,46
0,34	1,35	-36,30
0,35	1,36	-36,14
0,36	1,37	-35,99
0,37	1,38	-35,83
0,38	1,39	-35,67
0,39	1,40	-35,52
0,40	1,41	-35,37
0,41	1,42	-35,21
0,42	1,43	-35,06
0,43	1,44	-34,91
0,44	1,45	-34,76
0,45	1,46	-34,61
0,46	1,47	-34,46
0,47	1,48	-34,32
0,48	1,49	-34,17
0,49	1,50	-34,02
0,50	1,51	-33,88
0,51	1,52	-33,73
0,52	1,53	-33,59
0,53	1,54	-33,44
0,54	1,55	-33,30
0,55	1,56	-33,16
0,56	1,57	-33,02
0,57	1,58	-32,88
0,58	1,59	-32,74
0,59	1,60	-32,60
0,60	1,61	-32,46



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,61	1,62	-32,32
0,62	1,63	-32,19
0,63	1,64	-32,05
0,64	1,65	-31,92
0,65	1,66	-31,78
0,66	1,67	-31,65
0,67	1,68	-31,51
0,68	1,69	-31,38
0,69	1,70	-31,25
0,70	1,71	-31,11
0,71	1,72	-30,98
0,72	1,73	-30,85
0,73	1,74	-30,72
0,74	1,75	-30,59
0,75	1,76	-30,46
0,76	1,77	-30,34
0,77	1,78	-30,21
0,78	1,79	-30,08
0,79	1,80	-29,95
0,80	1,81	-29,83
0,81	1,82	-29,70
0,82	1,83	-29,58
0,83	1,84	-29,45
0,84	1,85	-29,33
0,85	1,86	-29,20
0,86	1,87	-29,08
0,87	1,88	-28,96
0,88	1,89	-28,84
0,89	1,90	-28,71
0,90	1,91	-28,59
0,91	1,92	-28,47
0,92	1,93	-28,35
0,93	1,94	-28,23
0,94	1,95	-28,11
0,95	1,96	-28,00
0,96	1,97	-27,88
0,97	1,98	-27,76
0,98	1,99	-27,64
0,99	2,00	-27,53
1,00	2,01	-27,41
1,01	2,02	-27,29
1,02	2,03	-27,18
1,03	2,04	-27,06
1,04	2,05	-26,95



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	-26,83
1,06	2,07	-26,72
1,07	2,08	-26,61
1,08	2,09	-26,49
1,09	2,10	-26,38
1,10	2,11	-26,27
1,11	2,12	-26,16
1,12	2,13	-26,05
1,13	2,14	-25,94
1,14	2,15	-25,83
1,15	2,16	-25,72
1,16	2,17	-25,61
1,17	2,18	-25,50
1,18	2,19	-25,39
1,19	2,20	-25,28
1,20	2,21	-25,17
1,21	2,22	-25,06
1,22	2,23	-24,96
1,23	2,24	-24,85
1,24	2,25	-24,74
1,25	2,26	-24,64
1,26	2,27	-24,53
1,27	2,28	-24,42
1,28	2,29	-24,32
1,29	2,30	-24,21
1,30	2,31	-24,11
1,31	2,32	-24,01
1,32	2,33	-23,90
1,33	2,34	-23,80
1,34	2,35	-23,70
1,35	2,36	-23,59
1,36	2,37	-23,49
1,37	2,38	-23,39
1,38	2,39	-23,29
1,39	2,40	-23,19
1,40	2,41	-23,08
1,41	2,42	-22,98
1,42	2,43	-22,88
1,43	2,44	-22,78
1,44	2,45	-22,68
1,45	2,46	-22,58
1,46	2,47	-22,48
1,47	2,48	-22,39
1,48	2,49	-22,29



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,49	2,50	-22,19
1,50	2,51	-22,09
1,51	2,52	-21,99
1,52	2,53	-21,90
1,53	2,54	-21,80
1,54	2,55	-21,70
1,55	2,56	-21,61
1,56	2,57	-21,51
1,57	2,58	-21,41
1,58	2,59	-21,32
1,59	2,60	-21,22
1,60	2,61	-21,13
1,61	2,62	-21,03
1,62	2,63	-20,94
1,63	2,64	-20,84
1,64	2,65	-20,75
1,65	2,66	-20,66
1,66	2,67	-20,56
1,67	2,68	-20,47
1,68	2,69	-20,38
1,69	2,70	-20,28
1,70	2,71	-20,19
1,71	2,72	-20,10
1,72	2,73	-20,01
1,73	2,74	-19,92
1,74	2,75	-19,82
1,75	2,76	-19,73
1,76	2,77	-19,64
1,77	2,78	-19,55
1,78	2,79	-19,46
1,79	2,80	-19,37
1,80	2,81	-19,28
1,81	2,82	-19,19
1,82	2,83	-19,10
1,83	2,84	-19,01
1,84	2,85	-18,93
1,85	2,86	-18,84
1,86	2,87	-18,75
1,87	2,88	-18,66
1,88	2,89	-18,57
1,89	2,90	-18,48
1,90	2,91	-18,40
1,91	2,92	-18,31
1,92	2,93	-18,22



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,93	2,94	-18,14
1,94	2,95	-18,05
1,95	2,96	-17,96
1,96	2,97	-17,88
1,97	2,98	-17,79
1,98	2,99	-17,71
1,99	3,00	-17,62
2,00	3,01	-17,54
2,01	3,02	-17,45
2,02	3,03	-17,37
2,03	3,04	-17,28
2,04	3,05	-17,20
2,05	3,06	-17,11
2,06	3,07	-17,03
2,07	3,08	-16,95
2,08	3,09	-16,86
2,09	3,10	-16,78
2,10	3,11	-16,70
2,11	3,12	-16,61
2,12	3,13	-16,53
2,13	3,14	-16,45
2,14	3,15	-16,36
2,15	3,16	-16,28
2,16	3,17	-16,20
2,17	3,18	-16,12
2,18	3,19	-16,04
2,19	3,20	-15,96
2,20	3,21	-15,88
2,21	3,22	-15,79
2,22	3,23	-15,71
2,23	3,24	-15,63
2,24	3,25	-15,55
2,25	3,26	-15,47
2,26	3,27	-15,39
2,27	3,28	-15,31
2,28	3,29	-15,23
2,29	3,30	-15,15
2,30	3,31	-15,08
2,31	3,32	-15,00
2,32	3,33	-14,92
2,33	3,34	-14,84
2,34	3,35	-14,76
2,35	3,36	-14,68
2,36	3,37	-14,60



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	-14,53
2,38	3,39	-14,45
2,39	3,40	-14,37
2,40	3,41	-14,29
2,41	3,42	-14,22
2,42	3,43	-14,14
2,43	3,44	-14,06
2,44	3,45	-13,99
2,45	3,46	-13,91
2,46	3,47	-13,83
2,47	3,48	-13,76
2,48	3,49	-13,68
2,49	3,50	-13,60
2,50	3,51	-13,53
2,51	3,52	-13,45
2,52	3,53	-13,38
2,53	3,54	-13,30
2,54	3,55	-13,23
2,55	3,56	-13,15
2,56	3,57	-13,08
2,57	3,58	-13,00
2,58	3,59	-12,93
2,59	3,60	-12,85
2,60	3,61	-12,78
2,61	3,62	-12,71
2,62	3,63	-12,63
2,63	3,64	-12,56
2,64	3,65	-12,49
2,65	3,66	-12,41
2,66	3,67	-12,34
2,67	3,68	-12,27
2,68	3,69	-12,19
2,69	3,70	-12,12
2,70	3,71	-12,05
2,71	3,72	-11,98
2,72	3,73	-11,90
2,73	3,74	-11,83
2,74	3,75	-11,76
2,75	3,76	-11,69
2,76	3,77	-11,62
2,77	3,78	-11,54
2,78	3,79	-11,47
2,79	3,80	-11,40
2,80	3,81	-11,33



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
2,81	3,82	-11,26
2,82	3,83	-11,19
2,83	3,84	-11,12
2,84	3,85	-11,05
2,85	3,86	-10,98
2,86	3,87	-10,91
2,87	3,88	-10,84
2,88	3,89	-10,77
2,89	3,90	-10,70
2,90	3,91	-10,63
2,91	3,92	-10,56
2,92	3,93	-10,49
2,93	3,94	-10,42
2,94	3,95	-10,35
2,95	3,96	-10,28
2,96	3,97	-10,21
2,97	3,98	-10,14
2,98	3,99	-10,07
2,99	4,00	-10,00
3,00	4,01	-9,94
3,01	4,02	-9,87
3,02	4,03	-9,80
3,03	4,04	-9,73
3,04	4,05	-9,66
3,05	4,06	-9,60
3,06	4,07	-9,53
3,07	4,08	-9,46
3,08	4,09	-9,39
3,09	4,10	-9,33
3,10	4,11	-9,26
3,11	4,12	-9,19
3,12	4,13	-9,13
3,13	4,14	-9,06
3,14	4,15	-8,99
3,15	4,16	-8,93
3,16	4,17	-8,86
3,17	4,18	-8,79
3,18	4,19	-8,73
3,19	4,20	-8,66
3,20	4,21	-8,59
3,21	4,22	-8,53
3,22	4,23	-8,46
3,23	4,24	-8,40
3,24	4,25	-8,33



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,25	4,26	-8,27
3,26	4,27	-8,20
3,27	4,28	-8,14
3,28	4,29	-8,07
3,29	4,30	-8,01
3,30	4,31	-7,94
3,31	4,32	-7,88
3,32	4,33	-7,81
3,33	4,34	-7,75
3,34	4,35	-7,68
3,35	4,36	-7,62
3,36	4,37	-7,56
3,37	4,38	-7,49
3,38	4,39	-7,43
3,39	4,40	-7,36
3,40	4,41	-7,30
3,41	4,42	-7,24
3,42	4,43	-7,17
3,43	4,44	-7,11
3,44	4,45	-7,05
3,45	4,46	-6,98
3,46	4,47	-6,92
3,47	4,48	-6,86
3,48	4,49	-6,80
3,49	4,50	-6,73
3,50	4,51	-6,67
3,51	4,52	-6,61
3,52	4,53	-6,55
3,53	4,54	-6,48
3,54	4,55	-6,42
3,55	4,56	-6,36
3,56	4,57	-6,30
3,57	4,58	-6,24
3,58	4,59	-6,17
3,59	4,60	-6,11
3,60	4,61	-6,05
3,61	4,62	-5,99
3,62	4,63	-5,93
3,63	4,64	-5,87
3,64	4,65	-5,81
3,65	4,66	-5,75
3,66	4,67	-5,68
3,67	4,68	-5,62
3,68	4,69	-5,56



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
3,69	4,70	-5,50
3,70	4,71	-5,44
3,71	4,72	-5,38
3,72	4,73	-5,32
3,73	4,74	-5,26
3,74	4,75	-5,20
3,75	4,76	-5,14
3,76	4,77	-5,08
3,77	4,78	-5,02
3,78	4,79	-4,96
3,79	4,80	-4,90
3,80	4,81	-4,84
3,81	4,82	-4,78
3,82	4,83	-4,72
3,83	4,84	-4,66
3,84	4,85	-4,60
3,85	4,86	-4,55
3,86	4,87	-4,49
3,87	4,88	-4,43
3,88	4,89	-4,37
3,89	4,90	-4,31
3,90	4,91	-4,25
3,91	4,92	-4,19
3,92	4,93	-4,13
3,93	4,94	-4,08
3,94	4,95	-4,02
3,95	4,96	-3,96
3,96	4,97	-3,90
3,97	4,98	-3,84
3,98	4,99	-3,79
3,99	5,00	-3,73
4,00	5,01	-3,67
4,01	5,02	-3,61
4,02	5,03	-3,55
4,03	5,04	-3,50
4,04	5,05	-3,44
4,05	5,06	-3,38
4,06	5,07	-3,33
4,07	5,08	-3,27
4,08	5,09	-3,21
4,09	5,10	-3,15
4,10	5,11	-3,10
4,11	5,12	-3,04
4,12	5,13	-2,98



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	-2,93
4,14	5,15	-2,87
4,15	5,16	-2,81
4,16	5,17	-2,76
4,17	5,18	-2,70
4,18	5,19	-2,65
4,19	5,20	-2,59
4,20	5,21	-2,53
4,21	5,22	-2,48
4,22	5,23	-2,42
4,23	5,24	-2,37
4,24	5,25	-2,31
4,25	5,26	-2,25
4,26	5,27	-2,20
4,27	5,28	-2,14
4,28	5,29	-2,09
4,29	5,30	-2,03
4,30	5,31	-1,98
4,31	5,32	-1,92
4,32	5,33	-1,87
4,33	5,34	-1,81
4,34	5,35	-1,76
4,35	5,36	-1,70
4,36	5,37	-1,65
4,37	5,38	-1,59
4,38	5,39	-1,54
4,39	5,40	-1,48
4,40	5,41	-1,43
4,41	5,42	-1,37
4,42	5,43	-1,32
4,43	5,44	-1,27
4,44	5,45	-1,21
4,45	5,46	-1,16
4,46	5,47	-1,10
4,47	5,48	-1,05
4,48	5,49	-1,00
4,49	5,50	-0,94
4,50	5,51	-0,89
4,51	5,52	-0,83
4,52	5,53	-0,78
4,53	5,54	-0,73
4,54	5,55	-0,67
4,55	5,56	-0,62
4,56	5,57	-0,57



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	-0,51
4,58	5,59	-0,46
4,59	5,60	-0,41
4,60	5,61	-0,35
4,61	5,62	-0,30
4,62	5,63	-0,25
4,63	5,64	-0,20
4,64	5,65	-0,14
4,65	5,66	-0,09
4,66	5,67	-0,04
4,67	5,68	0,01
4,68	5,69	0,07
4,69	5,70	0,12
4,70	5,71	0,17
4,71	5,72	0,22
4,72	5,73	0,28
4,73	5,74	0,33
4,74	5,75	0,38
4,75	5,76	0,43
4,76	5,77	0,48
4,77	5,78	0,54
4,78	5,79	0,59
4,79	5,80	0,64
4,80	5,81	0,69
4,81	5,82	0,74
4,82	5,83	0,79
4,83	5,84	0,85
4,84	5,85	0,90
4,85	5,86	0,95
4,86	5,87	1,00
4,87	5,88	1,05
4,88	5,89	1,10
4,89	5,90	1,15
4,90	5,91	1,20
4,91	5,92	1,25
4,92	5,93	1,30
4,93	5,94	1,36
4,94	5,95	1,41
4,95	5,96	1,46
4,96	5,97	1,51
4,97	5,98	1,56
4,98	5,99	1,61
4,99	6,00	1,66
5,00	6,01	1,71



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	1,76
5,02	6,03	1,81
5,03	6,04	1,86
5,04	6,05	1,91
5,05	6,06	1,96
5,06	6,07	2,01
5,07	6,08	2,06
5,08	6,09	2,11
5,09	6,10	2,16
5,10	6,11	2,21
5,11	6,12	2,26
5,12	6,13	2,31
5,13	6,14	2,36
5,14	6,15	2,41
5,15	6,16	2,46
5,16	6,17	2,51
5,17	6,18	2,55
5,18	6,19	2,60
5,19	6,20	2,65
5,20	6,21	2,70
5,21	6,22	2,75
5,22	6,23	2,80
5,23	6,24	2,85
5,24	6,25	2,90
5,25	6,26	2,95
5,26	6,27	3,00
5,27	6,28	3,04
5,28	6,29	3,09
5,29	6,30	3,14
5,30	6,31	3,19
5,31	6,32	3,24
5,32	6,33	3,29
5,33	6,34	3,34
5,34	6,35	3,38
5,35	6,36	3,43
5,36	6,37	3,48
5,37	6,38	3,53
5,38	6,39	3,58
5,39	6,40	3,62
5,40	6,41	3,67
5,41	6,42	3,72
5,42	6,43	3,77
5,43	6,44	3,82
5,44	6,45	3,86



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,45	6,46	3,91
5,46	6,47	3,96
5,47	6,48	4,01
5,48	6,49	4,05
5,49	6,50	4,10
5,50	6,51	4,15
5,51	6,52	4,20
5,52	6,53	4,24
5,53	6,54	4,29
5,54	6,55	4,34
5,55	6,56	4,38
5,56	6,57	4,43
5,57	6,58	4,48
5,58	6,59	4,52
5,59	6,60	4,57
5,60	6,61	4,62
5,61	6,62	4,67
5,62	6,63	4,71
5,63	6,64	4,76
5,64	6,65	4,81
5,65	6,66	4,85
5,66	6,67	4,90
5,67	6,68	4,94
5,68	6,69	4,99
5,69	6,70	5,04
5,70	6,71	5,08
5,71	6,72	5,13
5,72	6,73	5,18
5,73	6,74	5,22
5,74	6,75	5,27
5,75	6,76	5,31
5,76	6,77	5,36
5,77	6,78	5,41
5,78	6,79	5,45
5,79	6,80	5,50
5,80	6,81	5,54
5,81	6,82	5,59
5,82	6,83	5,64
5,83	6,84	5,68
5,84	6,85	5,73
5,85	6,86	5,77
5,86	6,87	5,82
5,87	6,88	5,86
5,88	6,89	5,91



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	5,95
5,90	6,91	6,00
5,91	6,92	6,04
5,92	6,93	6,09
5,93	6,94	6,13
5,94	6,95	6,18
5,95	6,96	6,22
5,96	6,97	6,27
5,97	6,98	6,31
5,98	6,99	6,36
5,99	7,00	6,40
6,00	7,01	6,45
6,01	7,02	6,49
6,02	7,03	6,54
6,03	7,04	6,58
6,04	7,05	6,63
6,05	7,06	6,67
6,06	7,07	6,72
6,07	7,08	6,76
6,08	7,09	6,81
6,09	7,10	6,85
6,10	7,11	6,89
6,11	7,12	6,94
6,12	7,13	6,98
6,13	7,14	7,03
6,14	7,15	7,07
6,15	7,16	7,12
6,16	7,17	7,16
6,17	7,18	7,20
6,18	7,19	7,25
6,19	7,20	7,29
6,20	7,21	7,33
6,21	7,22	7,38
6,22	7,23	7,42
6,23	7,24	7,47
6,24	7,25	7,51
6,25	7,26	7,55
6,26	7,27	7,60
6,27	7,28	7,64
6,28	7,29	7,68
6,29	7,30	7,73
6,30	7,31	7,77
6,31	7,32	7,81
6,32	7,33	7,86



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,33	7,34	7,90
6,34	7,35	7,94
6,35	7,36	7,99
6,36	7,37	8,03
6,37	7,38	8,07
6,38	7,39	8,12
6,39	7,40	8,16
6,40	7,41	8,20
6,41	7,42	8,25
6,42	7,43	8,29
6,43	7,44	8,33
6,44	7,45	8,37
6,45	7,46	8,42
6,46	7,47	8,46
6,47	7,48	8,50
6,48	7,49	8,54
6,49	7,50	8,59
6,50	7,51	8,63
6,51	7,52	8,67
6,52	7,53	8,71
6,53	7,54	8,76
6,54	7,55	8,80
6,55	7,56	8,84
6,56	7,57	8,88
6,57	7,58	8,93
6,58	7,59	8,97
6,59	7,60	9,01
6,60	7,61	9,05
6,61	7,62	9,09
6,62	7,63	9,14
6,63	7,64	9,18
6,64	7,65	9,22
6,65	7,66	9,26
6,66	7,67	9,30
6,67	7,68	9,35
6,68	7,69	9,39
6,69	7,70	9,43
6,70	7,71	9,47
6,71	7,72	9,51
6,72	7,73	9,55
6,73	7,74	9,60
6,74	7,75	9,64
6,75	7,76	9,68
6,76	7,77	9,72



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,77	7,78	9,76
6,78	7,79	9,80
6,79	7,80	9,84
6,80	7,81	9,89
6,81	7,82	9,93
6,82	7,83	9,97
6,83	7,84	10,01
6,84	7,85	10,05
6,85	7,86	10,09
6,86	7,87	10,13
6,87	7,88	10,17
6,88	7,89	10,21
6,89	7,90	10,26
6,90	7,91	10,30
6,91	7,92	10,34
6,92	7,93	10,38
6,93	7,94	10,42
6,94	7,95	10,46
6,95	7,96	10,50
6,96	7,97	10,54
6,97	7,98	10,58
6,98	7,99	10,62
6,99	8,00	10,66
7,00	8,01	10,70
7,01	8,02	10,74
7,02	8,03	10,78
7,03	8,04	10,82
7,04	8,05	10,86
7,05	8,06	10,91
7,06	8,07	10,95
7,07	8,08	10,99
7,08	8,09	11,03
7,09	8,10	11,07
7,10	8,11	11,11
7,11	8,12	11,15
7,12	8,13	11,19
7,13	8,14	11,23
7,14	8,15	11,27
7,15	8,16	11,31
7,16	8,17	11,35
7,17	8,18	11,39
7,18	8,19	11,43
7,19	8,20	11,47
7,20	8,21	11,51



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	11,55
7,22	8,23	11,58
7,23	8,24	11,62
7,24	8,25	11,66
7,25	8,26	11,70
7,26	8,27	11,74
7,27	8,28	11,78
7,28	8,29	11,82
7,29	8,30	11,86
7,30	8,31	11,90
7,31	8,32	11,94
7,32	8,33	11,98
7,33	8,34	12,02
7,34	8,35	12,06
7,35	8,36	12,10
7,36	8,37	12,14
7,37	8,38	12,18
7,38	8,39	12,22
7,39	8,40	12,25
7,40	8,41	12,29
7,41	8,42	12,33
7,42	8,43	12,37
7,43	8,44	12,41
7,44	8,45	12,45
7,45	8,46	12,49
7,46	8,47	12,53
7,47	8,48	12,57
7,48	8,49	12,60
7,49	8,50	12,64
7,50	8,51	12,68
7,51	8,52	12,72
7,52	8,53	12,76
7,53	8,54	12,80
7,54	8,55	12,84
7,55	8,56	12,87
7,56	8,57	12,91
7,57	8,58	12,95
7,58	8,59	12,99
7,59	8,60	13,03
7,60	8,61	13,07
7,61	8,62	13,11
7,62	8,63	13,14
7,63	8,64	13,18
7,64	8,65	13,22



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,65	8,66	13,26
7,66	8,67	13,30
7,67	8,68	13,33
7,68	8,69	13,37
7,69	8,70	13,41
7,70	8,71	13,45
7,71	8,72	13,49
7,72	8,73	13,52
7,73	8,74	13,56
7,74	8,75	13,60
7,75	8,76	13,64
7,76	8,77	13,68
7,77	8,78	13,71
7,78	8,79	13,75
7,79	8,80	13,79
7,80	8,81	13,83
7,81	8,82	13,86
7,82	8,83	13,90
7,83	8,84	13,94
7,84	8,85	13,98
7,85	8,86	14,02
7,86	8,87	14,05
7,87	8,88	14,09
7,88	8,89	14,13
7,89	8,90	14,17
7,90	8,91	14,20
7,91	8,92	14,24
7,92	8,93	14,28
7,93	8,94	14,31
7,94	8,95	14,35
7,95	8,96	14,39
7,96	8,97	14,43
7,97	8,98	14,46
7,98	8,99	14,50
7,99	9,00	14,54
8,00	9,01	14,57
8,01	9,02	14,61
8,02	9,03	14,65
8,03	9,04	14,69
8,04	9,05	14,72
8,05	9,06	14,76
8,06	9,07	14,80
8,07	9,08	14,83
8,08	9,09	14,87



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,09	9,10	14,91
8,10	9,11	14,94
8,11	9,12	14,98
8,12	9,13	15,02
8,13	9,14	15,05
8,14	9,15	15,09
8,15	9,16	15,13
8,16	9,17	15,16
8,17	9,18	15,20
8,18	9,19	15,24
8,19	9,20	15,27
8,20	9,21	15,31
8,21	9,22	15,35
8,22	9,23	15,38
8,23	9,24	15,42
8,24	9,25	15,46
8,25	9,26	15,49
8,26	9,27	15,53
8,27	9,28	15,56
8,28	9,29	15,60
8,29	9,30	15,64
8,30	9,31	15,67
8,31	9,32	15,71
8,32	9,33	15,74
8,33	9,34	15,78
8,34	9,35	15,82
8,35	9,36	15,85
8,36	9,37	15,89
8,37	9,38	15,93
8,38	9,39	15,96
8,39	9,40	16,00
8,40	9,41	16,03
8,41	9,42	16,07
8,42	9,43	16,10
8,43	9,44	16,14
8,44	9,45	16,18
8,45	9,46	16,21
8,46	9,47	16,25
8,47	9,48	16,28
8,48	9,49	16,32
8,49	9,50	16,35
8,50	9,51	16,39
8,51	9,52	16,43
8,52	9,53	16,46



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,53	9,54	16,50
8,54	9,55	16,53
8,55	9,56	16,57
8,56	9,57	16,60
8,57	9,58	16,64
8,58	9,59	16,67
8,59	9,60	16,71
8,60	9,61	16,74
8,61	9,62	16,78
8,62	9,63	16,82
8,63	9,64	16,85
8,64	9,65	16,89
8,65	9,66	16,92
8,66	9,67	16,96
8,67	9,68	16,99
8,68	9,69	17,03
8,69	9,70	17,06
8,70	9,71	17,10
8,71	9,72	17,13
8,72	9,73	17,17
8,73	9,74	17,20
8,74	9,75	17,24
8,75	9,76	17,27
8,76	9,77	17,31
8,77	9,78	17,34
8,78	9,79	17,38
8,79	9,80	17,41
8,80	9,81	17,45
8,81	9,82	17,48
8,82	9,83	17,51
8,83	9,84	17,55
8,84	9,85	17,58
8,85	9,86	17,62
8,86	9,87	17,65
8,87	9,88	17,69
8,88	9,89	17,72
8,89	9,90	17,76
8,90	9,91	17,79
8,91	9,92	17,83
8,92	9,93	17,86
8,93	9,94	17,89
8,94	9,95	17,93
8,95	9,96	17,96
8,96	9,97	18,00



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,97	9,98	18,03
8,98	9,99	18,07
8,99	10,00	18,10
9,00	10,01	18,14
9,01	10,02	18,17
9,02	10,03	18,20
9,03	10,04	18,24
9,04	10,05	18,27
9,05	10,06	18,31
9,06	10,07	18,34
9,07	10,08	18,37
9,08	10,09	18,41
9,09	10,10	18,44
9,10	10,11	18,48
9,11	10,12	18,51
9,12	10,13	18,54
9,13	10,14	18,58
9,14	10,15	18,61
9,15	10,16	18,65
9,16	10,17	18,68
9,17	10,18	18,71
9,18	10,19	18,75
9,19	10,20	18,78
9,20	10,21	18,81
9,21	10,22	18,85
9,22	10,23	18,88
9,23	10,24	18,92
9,24	10,25	18,95
9,25	10,26	18,98
9,26	10,27	19,02
9,27	10,28	19,05
9,28	10,29	19,08
9,29	10,30	19,12
9,30	10,31	19,15
9,31	10,32	19,18
9,32	10,33	19,22
9,33	10,34	19,25
9,34	10,35	19,28
9,35	10,36	19,32
9,36	10,37	19,35
9,37	10,38	19,38
9,38	10,39	19,42
9,39	10,40	19,45
9,40	10,41	19,48



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,41	10,42	19,52
9,42	10,43	19,55
9,43	10,44	19,58
9,44	10,45	19,62
9,45	10,46	19,65
9,46	10,47	19,68
9,47	10,48	19,72
9,48	10,49	19,75
9,49	10,50	19,78
9,50	10,51	19,82
9,51	10,52	19,85
9,52	10,53	19,88
9,53	10,54	19,91
9,54	10,55	19,95
9,55	10,56	19,98
9,56	10,57	20,01
9,57	10,58	20,05
9,58	10,59	20,08
9,59	10,60	20,11
9,60	10,61	20,14
9,61	10,62	20,18
9,62	10,63	20,21
9,63	10,64	20,24
9,64	10,65	20,28
9,65	10,66	20,31
9,66	10,67	20,34
9,67	10,68	20,37
9,68	10,69	20,41
9,69	10,70	20,44
9,70	10,71	20,47
9,71	10,72	20,50
9,72	10,73	20,54
9,73	10,74	20,57
9,74	10,75	20,60
9,75	10,76	20,63
9,76	10,77	20,67
9,77	10,78	20,70
9,78	10,79	20,73
9,79	10,80	20,76
9,80	10,81	20,80
9,81	10,82	20,83
9,82	10,83	20,86
9,83	10,84	20,89
9,84	10,85	20,92



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
9,85	10,86	20,96
9,86	10,87	20,99
9,87	10,88	21,02
9,88	10,89	21,05
9,89	10,90	21,09
9,90	10,91	21,12
9,91	10,92	21,15
9,92	10,93	21,18
9,93	10,94	21,21
9,94	10,95	21,25
9,95	10,96	21,28
9,96	10,97	21,31
9,97	10,98	21,34
9,98	10,99	21,37
9,99	11,00	21,41
10,00	11,01	21,44
10,01	11,02	21,47
10,02	11,03	21,50
10,03	11,04	21,53
10,04	11,05	21,56
10,05	11,06	21,60
10,06	11,07	21,63
10,07	11,08	21,66
10,08	11,09	21,69
10,09	11,10	21,72
10,10	11,11	21,75
10,11	11,12	21,79
10,12	11,13	21,82
10,13	11,14	21,85
10,14	11,15	21,88
10,15	11,16	21,91
10,16	11,17	21,94
10,17	11,18	21,98
10,18	11,19	22,01
10,19	11,20	22,04
10,20	11,21	22,07
10,21	11,22	22,10
10,22	11,23	22,13
10,23	11,24	22,16
10,24	11,25	22,20
10,25	11,26	22,23
10,26	11,27	22,26
10,27	11,28	22,29
10,28	11,29	22,32



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
10,29	11,30	22,35
10,30	11,31	22,38
10,31	11,32	22,41
10,32	11,33	22,45
10,33	11,34	22,48
10,34	11,35	22,51
10,35	11,36	22,54
10,36	11,37	22,57
10,37	11,38	22,60
10,38	11,39	22,63
10,39	11,40	22,66
10,40	11,41	22,69
10,41	11,42	22,73
10,42	11,43	22,76
10,43	11,44	22,79
10,44	11,45	22,82
10,45	11,46	22,85
10,46	11,47	22,88
10,47	11,48	22,91
10,48	11,49	22,94
10,49	11,50	22,97
10,50	11,51	23,00
10,51	11,52	23,03
10,52	11,53	23,07
10,53	11,54	23,10
10,54	11,55	23,13
10,55	11,56	23,16
10,56	11,57	23,19
10,57	11,58	23,22
10,58	11,59	23,25
10,59	11,60	23,28
10,60	11,61	23,31
10,61	11,62	23,34
10,62	11,63	23,37
10,63	11,64	23,40
10,64	11,65	23,43
10,65	11,66	23,46
10,66	11,67	23,49
10,67	11,68	23,53
10,68	11,69	23,56
10,69	11,70	23,59
10,70	11,71	23,62
10,71	11,72	23,65
10,72	11,73	23,68



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	23,71
10,74	11,75	23,74
10,75	11,76	23,77
10,76	11,77	23,80
10,77	11,78	23,83
10,78	11,79	23,86
10,79	11,80	23,89
10,80	11,81	23,92
10,81	11,82	23,95
10,82	11,83	23,98
10,83	11,84	24,01
10,84	11,85	24,04
10,85	11,86	24,07
10,86	11,87	24,10
10,87	11,88	24,13
10,88	11,89	24,16
10,89	11,90	24,19
10,90	11,91	24,22
10,91	11,92	24,25
10,92	11,93	24,28
10,93	11,94	24,31
10,94	11,95	24,34
10,95	11,96	24,37
10,96	11,97	24,40
10,97	11,98	24,43
10,98	11,99	24,46
10,99	12,00	24,49
11,00	12,01	24,52
11,01	12,02	24,55
11,02	12,03	24,58
11,03	12,04	24,61
11,04	12,05	24,64
11,05	12,06	24,67
11,06	12,07	24,70
11,07	12,08	24,73
11,08	12,09	24,76
11,09	12,10	24,79
11,10	12,11	24,82
11,11	12,12	24,85
11,12	12,13	24,88
11,13	12,14	24,91
11,14	12,15	24,94
11,15	12,16	24,97
11,16	12,17	25,00



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,17	12,18	25,03
11,18	12,19	25,06
11,19	12,20	25,08
11,20	12,21	25,11
11,21	12,22	25,14
11,22	12,23	25,17
11,23	12,24	25,20
11,24	12,25	25,23
11,25	12,26	25,26
11,26	12,27	25,29
11,27	12,28	25,32
11,28	12,29	25,35
11,29	12,30	25,38
11,30	12,31	25,41
11,31	12,32	25,44
11,32	12,33	25,47
11,33	12,34	25,50
11,34	12,35	25,53
11,35	12,36	25,55
11,36	12,37	25,58
11,37	12,38	25,61
11,38	12,39	25,64
11,39	12,40	25,67
11,40	12,41	25,70
11,41	12,42	25,73
11,42	12,43	25,76
11,43	12,44	25,79
11,44	12,45	25,82
11,45	12,46	25,85
11,46	12,47	25,87
11,47	12,48	25,90
11,48	12,49	25,93
11,49	12,50	25,96
11,50	12,51	25,99
11,51	12,52	26,02
11,52	12,53	26,05
11,53	12,54	26,08
11,54	12,55	26,11
11,55	12,56	26,14
11,56	12,57	26,16
11,57	12,58	26,19
11,58	12,59	26,22
11,59	12,60	26,25
11,60	12,61	26,28



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	26,31
11,62	12,63	26,34
11,63	12,64	26,37
11,64	12,65	26,39
11,65	12,66	26,42
11,66	12,67	26,45
11,67	12,68	26,48
11,68	12,69	26,51
11,69	12,70	26,54
11,70	12,71	26,57
11,71	12,72	26,59
11,72	12,73	26,62
11,73	12,74	26,65
11,74	12,75	26,68
11,75	12,76	26,71
11,76	12,77	26,74
11,77	12,78	26,77
11,78	12,79	26,79
11,79	12,80	26,82
11,80	12,81	26,85
11,81	12,82	26,88
11,82	12,83	26,91
11,83	12,84	26,94
11,84	12,85	26,96
11,85	12,86	26,99
11,86	12,87	27,02
11,87	12,88	27,05
11,88	12,89	27,08
11,89	12,90	27,11
11,90	12,91	27,13
11,91	12,92	27,16
11,92	12,93	27,19
11,93	12,94	27,22
11,94	12,95	27,25
11,95	12,96	27,28
11,96	12,97	27,30
11,97	12,98	27,33
11,98	12,99	27,36
11,99	13,00	27,39
12,00	13,01	27,42
12,01	13,02	27,44
12,02	13,03	27,47
12,03	13,04	27,50
12,04	13,05	27,53



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
12,05	13,06	27,56
12,06	13,07	27,58
12,07	13,08	27,61
12,08	13,09	27,64
12,09	13,10	27,67
12,10	13,11	27,70
12,11	13,12	27,72
12,12	13,13	27,75
12,13	13,14	27,78
12,14	13,15	27,81
12,15	13,16	27,84
12,16	13,17	27,86
12,17	13,18	27,89
12,18	13,19	27,92
12,19	13,20	27,95
12,20	13,21	27,98
12,21	13,22	28,00
12,22	13,23	28,03
12,23	13,24	28,06
12,24	13,25	28,09
12,25	13,26	28,11
12,26	13,27	28,14
12,27	13,28	28,17
12,28	13,29	28,20
12,29	13,30	28,22
12,30	13,31	28,25
12,31	13,32	28,28
12,32	13,33	28,31
12,33	13,34	28,34
12,34	13,35	28,36
12,35	13,36	28,39
12,36	13,37	28,42
12,37	13,38	28,45
12,38	13,39	28,47
12,39	13,40	28,50
12,40	13,41	28,53
12,41	13,42	28,56
12,42	13,43	28,58
12,43	13,44	28,61
12,44	13,45	28,64
12,45	13,46	28,67
12,46	13,47	28,69
12,47	13,48	28,72
12,48	13,49	28,75



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	28,77
12,50	13,51	28,80
12,51	13,52	28,83
12,52	13,53	28,86
12,53	13,54	28,88
12,54	13,55	28,91
12,55	13,56	28,94
12,56	13,57	28,97
12,57	13,58	28,99
12,58	13,59	29,02
12,59	13,60	29,05
12,60	13,61	29,07
12,61	13,62	29,10
12,62	13,63	29,13
12,63	13,64	29,16
12,64	13,65	29,18
12,65	13,66	29,21
12,66	13,67	29,24
12,67	13,68	29,26
12,68	13,69	29,29
12,69	13,70	29,32
12,70	13,71	29,35
12,71	13,72	29,37
12,72	13,73	29,40
12,73	13,74	29,43
12,74	13,75	29,45
12,75	13,76	29,48
12,76	13,77	29,51
12,77	13,78	29,53
12,78	13,79	29,56
12,79	13,80	29,59
12,80	13,81	29,61
12,81	13,82	29,64
12,82	13,83	29,67
12,83	13,84	29,70
12,84	13,85	29,72
12,85	13,86	29,75
12,86	13,87	29,78
12,87	13,88	29,80
12,88	13,89	29,83
12,89	13,90	29,86
12,90	13,91	29,88
12,91	13,92	29,91
12,92	13,93	29,94



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	29,96
12,94	13,95	29,99
12,95	13,96	30,02
12,96	13,97	30,04
12,97	13,98	30,07
12,98	13,99	30,10
12,99	14,00	30,12
13,00	14,01	30,15
13,01	14,02	30,18
13,02	14,03	30,20
13,03	14,04	30,23
13,04	14,05	30,26
13,05	14,06	30,28
13,06	14,07	30,31
13,07	14,08	30,33
13,08	14,09	30,36
13,09	14,10	30,39
13,10	14,11	30,41
13,11	14,12	30,44
13,12	14,13	30,47
13,13	14,14	30,49
13,14	14,15	30,52
13,15	14,16	30,55
13,16	14,17	30,57
13,17	14,18	30,60
13,18	14,19	30,63
13,19	14,20	30,65
13,20	14,21	30,68
13,21	14,22	30,70
13,22	14,23	30,73
13,23	14,24	30,76
13,24	14,25	30,78
13,25	14,26	30,81
13,26	14,27	30,84
13,27	14,28	30,86
13,28	14,29	30,89
13,29	14,30	30,91
13,30	14,31	30,94
13,31	14,32	30,97
13,32	14,33	30,99
13,33	14,34	31,02
13,34	14,35	31,04
13,35	14,36	31,07
13,36	14,37	31,10



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,37	14,38	31,12
13,38	14,39	31,15
13,39	14,40	31,18
13,40	14,41	31,20
13,41	14,42	31,23
13,42	14,43	31,25
13,43	14,44	31,28
13,44	14,45	31,31
13,45	14,46	31,33
13,46	14,47	31,36
13,47	14,48	31,38
13,48	14,49	31,41
13,49	14,50	31,43
13,50	14,51	31,46
13,51	14,52	31,49
13,52	14,53	31,51
13,53	14,54	31,54
13,54	14,55	31,56
13,55	14,56	31,59
13,56	14,57	31,62
13,57	14,58	31,64
13,58	14,59	31,67
13,59	14,60	31,69
13,60	14,61	31,72
13,61	14,62	31,74
13,62	14,63	31,77
13,63	14,64	31,80
13,64	14,65	31,82
13,65	14,66	31,85
13,66	14,67	31,87
13,67	14,68	31,90
13,68	14,69	31,92
13,69	14,70	31,95
13,70	14,71	31,98
13,71	14,72	32,00
13,72	14,73	32,03
13,73	14,74	32,05
13,74	14,75	32,08
13,75	14,76	32,10
13,76	14,77	32,13
13,77	14,78	32,15
13,78	14,79	32,18
13,79	14,80	32,21
13,80	14,81	32,23



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,81	14,82	32,26
13,82	14,83	32,28
13,83	14,84	32,31
13,84	14,85	32,33
13,85	14,86	32,36
13,86	14,87	32,38
13,87	14,88	32,41
13,88	14,89	32,43
13,89	14,90	32,46
13,90	14,91	32,49
13,91	14,92	32,51
13,92	14,93	32,54
13,93	14,94	32,56
13,94	14,95	32,59
13,95	14,96	32,61
13,96	14,97	32,64
13,97	14,98	32,66
13,98	14,99	32,69
13,99	15,00	32,71
14,00	15,01	32,74
14,01	15,02	32,76
14,02	15,03	32,79
14,03	15,04	32,81
14,04	15,05	32,84
14,05	15,06	32,86
14,06	15,07	32,89
14,07	15,08	32,91
14,08	15,09	32,94
14,09	15,10	32,96
14,10	15,11	32,99
14,11	15,12	33,02
14,12	15,13	33,04
14,13	15,14	33,07
14,14	15,15	33,09
14,15	15,16	33,12
14,16	15,17	33,14
14,17	15,18	33,17
14,18	15,19	33,19
14,19	15,20	33,22
14,20	15,21	33,24
14,21	15,22	33,27
14,22	15,23	33,29
14,23	15,24	33,32
14,24	15,25	33,34



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,25	15,26	33,37
14,26	15,27	33,39
14,27	15,28	33,41
14,28	15,29	33,44
14,29	15,30	33,46
14,30	15,31	33,49
14,31	15,32	33,51
14,32	15,33	33,54
14,33	15,34	33,56
14,34	15,35	33,59
14,35	15,36	33,61
14,36	15,37	33,64
14,37	15,38	33,66
14,38	15,39	33,69
14,39	15,40	33,71
14,40	15,41	33,74
14,41	15,42	33,76
14,42	15,43	33,79
14,43	15,44	33,81
14,44	15,45	33,84
14,45	15,46	33,86
14,46	15,47	33,89
14,47	15,48	33,91
14,48	15,49	33,93
14,49	15,50	33,96
14,50	15,51	33,98
14,51	15,52	34,01
14,52	15,53	34,03
14,53	15,54	34,06
14,54	15,55	34,08
14,55	15,56	34,11
14,56	15,57	34,13
14,57	15,58	34,16
14,58	15,59	34,18
14,59	15,60	34,21
14,60	15,61	34,23
14,61	15,62	34,25
14,62	15,63	34,28
14,63	15,64	34,30
14,64	15,65	34,33
14,65	15,66	34,35
14,66	15,67	34,38
14,67	15,68	34,40
14,68	15,69	34,43



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	34,45
14,70	15,71	34,47
14,71	15,72	34,50
14,72	15,73	34,52
14,73	15,74	34,55
14,74	15,75	34,57
14,75	15,76	34,60
14,76	15,77	34,62
14,77	15,78	34,64
14,78	15,79	34,67
14,79	15,80	34,69
14,80	15,81	34,72
14,81	15,82	34,74
14,82	15,83	34,77
14,83	15,84	34,79
14,84	15,85	34,81
14,85	15,86	34,84
14,86	15,87	34,86
14,87	15,88	34,89
14,88	15,89	34,91
14,89	15,90	34,93
14,90	15,91	34,96
14,91	15,92	34,98
14,92	15,93	35,01
14,93	15,94	35,03
14,94	15,95	35,06
14,95	15,96	35,08
14,96	15,97	35,10
14,97	15,98	35,13
14,98	15,99	35,15
14,99	16,00	35,18
15,00	16,01	35,20
15,01	16,02	35,22
15,02	16,03	35,25
15,03	16,04	35,27
15,04	16,05	35,30
15,05	16,06	35,32
15,06	16,07	35,34
15,07	16,08	35,37
15,08	16,09	35,39
15,09	16,10	35,42
15,10	16,11	35,44
15,11	16,12	35,46
15,12	16,13	35,49



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	35,51
15,14	16,15	35,54
15,15	16,16	35,56
15,16	16,17	35,58
15,17	16,18	35,61
15,18	16,19	35,63
15,19	16,20	35,65
15,20	16,21	35,68
15,21	16,22	35,70
15,22	16,23	35,73
15,23	16,24	35,75
15,24	16,25	35,77
15,25	16,26	35,80
15,26	16,27	35,82
15,27	16,28	35,84
15,28	16,29	35,87
15,29	16,30	35,89
15,30	16,31	35,92
15,31	16,32	35,94
15,32	16,33	35,96
15,33	16,34	35,99
15,34	16,35	36,01
15,35	16,36	36,03
15,36	16,37	36,06
15,37	16,38	36,08
15,38	16,39	36,10
15,39	16,40	36,13
15,40	16,41	36,15
15,41	16,42	36,18
15,42	16,43	36,20
15,43	16,44	36,22
15,44	16,45	36,25
15,45	16,46	36,27
15,46	16,47	36,29
15,47	16,48	36,32
15,48	16,49	36,34
15,49	16,50	36,36
15,50	16,51	36,39
15,51	16,52	36,41
15,52	16,53	36,43
15,53	16,54	36,46
15,54	16,55	36,48
15,55	16,56	36,50
15,56	16,57	36,53



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
15,57	16,58	36,55
15,58	16,59	36,57
15,59	16,60	36,60
15,60	16,61	36,62
15,61	16,62	36,64
15,62	16,63	36,67
15,63	16,64	36,69
15,64	16,65	36,71
15,65	16,66	36,74
15,66	16,67	36,76
15,67	16,68	36,78
15,68	16,69	36,81
15,69	16,70	36,83
15,70	16,71	36,85
15,71	16,72	36,88
15,72	16,73	36,90
15,73	16,74	36,92
15,74	16,75	36,95
15,75	16,76	36,97
15,76	16,77	36,99
15,77	16,78	37,02
15,78	16,79	37,04
15,79	16,80	37,06
15,80	16,81	37,09
15,81	16,82	37,11
15,82	16,83	37,13
15,83	16,84	37,16
15,84	16,85	37,18
15,85	16,86	37,20
15,86	16,87	37,23
15,87	16,88	37,25
15,88	16,89	37,27
15,89	16,90	37,29
15,90	16,91	37,32
15,91	16,92	37,34
15,92	16,93	37,36
15,93	16,94	37,39
15,94	16,95	37,41
15,95	16,96	37,43
15,96	16,97	37,46
15,97	16,98	37,48
15,98	16,99	37,50
15,99	17,00	37,52
16,00	17,01	37,55



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
16,01	17,02	37,57
16,02	17,03	37,59
16,03	17,04	37,62
16,04	17,05	37,64
16,05	17,06	37,66
16,06	17,07	37,68
16,07	17,08	37,71
16,08	17,09	37,73
16,09	17,10	37,75
16,10	17,11	37,78
16,11	17,12	37,80
16,12	17,13	37,82
16,13	17,14	37,84
16,14	17,15	37,87
16,15	17,16	37,89
16,16	17,17	37,91
16,17	17,18	37,94
16,18	17,19	37,96
16,19	17,20	37,98
16,20	17,21	38,00
16,21	17,22	38,03
16,22	17,23	38,05
16,23	17,24	38,07
16,24	17,25	38,10
16,25	17,26	38,12
16,26	17,27	38,14
16,27	17,28	38,16
16,28	17,29	38,19
16,29	17,30	38,21
16,30	17,31	38,23
16,31	17,32	38,25
16,32	17,33	38,28
16,33	17,34	38,30
16,34	17,35	38,32
16,35	17,36	38,34
16,36	17,37	38,37
16,37	17,38	38,39
16,38	17,39	38,41
16,39	17,40	38,43
16,40	17,41	38,46
16,41	17,42	38,48
16,42	17,43	38,50
16,43	17,44	38,52
16,44	17,45	38,55



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,45	17,46	38,57
16,46	17,47	38,59
16,47	17,48	38,61
16,48	17,49	38,64
16,49	17,50	38,66
16,50	17,51	38,68
16,51	17,52	38,70
16,52	17,53	38,73
16,53	17,54	38,75
16,54	17,55	38,77
16,55	17,56	38,79
16,56	17,57	38,82
16,57	17,58	38,84
16,58	17,59	38,86
16,59	17,60	38,88
16,60	17,61	38,91
16,61	17,62	38,93
16,62	17,63	38,95
16,63	17,64	38,97
16,64	17,65	39,00
16,65	17,66	39,02
16,66	17,67	39,04
16,67	17,68	39,06
16,68	17,69	39,08
16,69	17,70	39,11
16,70	17,71	39,13
16,71	17,72	39,15
16,72	17,73	39,17
16,73	17,74	39,20
16,74	17,75	39,22
16,75	17,76	39,24
16,76	17,77	39,26
16,77	17,78	39,28
16,78	17,79	39,31
16,79	17,80	39,33
16,80	17,81	39,35
16,81	17,82	39,37
16,82	17,83	39,40
16,83	17,84	39,42
16,84	17,85	39,44
16,85	17,86	39,46
16,86	17,87	39,48
16,87	17,88	39,51
16,88	17,89	39,53



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	39,55
16,90	17,91	39,57
16,91	17,92	39,59
16,92	17,93	39,62
16,93	17,94	39,64
16,94	17,95	39,66
16,95	17,96	39,68
16,96	17,97	39,70
16,97	17,98	39,73
16,98	17,99	39,75
16,99	18,00	39,77
17,00	18,01	39,79
17,01	18,02	39,81
17,02	18,03	39,84
17,03	18,04	39,86
17,04	18,05	39,88
17,05	18,06	39,90
17,06	18,07	39,92
17,07	18,08	39,95
17,08	18,09	39,97
17,09	18,10	39,99
17,10	18,11	40,01
17,11	18,12	40,03
17,12	18,13	40,06
17,13	18,14	40,08
17,14	18,15	40,10
17,15	18,16	40,12
17,16	18,17	40,14
17,17	18,18	40,16
17,18	18,19	40,19
17,19	18,20	40,21
17,20	18,21	40,23
17,21	18,22	40,25
17,22	18,23	40,27
17,23	18,24	40,30
17,24	18,25	40,32
17,25	18,26	40,34
17,26	18,27	40,36
17,27	18,28	40,38
17,28	18,29	40,40
17,29	18,30	40,43
17,30	18,31	40,45
17,31	18,32	40,47
17,32	18,33	40,49



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	40,51
17,34	18,35	40,53
17,35	18,36	40,56
17,36	18,37	40,58
17,37	18,38	40,60
17,38	18,39	40,62
17,39	18,40	40,64
17,40	18,41	40,66
17,41	18,42	40,69
17,42	18,43	40,71
17,43	18,44	40,73
17,44	18,45	40,75
17,45	18,46	40,77
17,46	18,47	40,79
17,47	18,48	40,81
17,48	18,49	40,84
17,49	18,50	40,86
17,50	18,51	40,88
17,51	18,52	40,90
17,52	18,53	40,92
17,53	18,54	40,94
17,54	18,55	40,97
17,55	18,56	40,99
17,56	18,57	41,01
17,57	18,58	41,03
17,58	18,59	41,05
17,59	18,60	41,07
17,60	18,61	41,09
17,61	18,62	41,12
17,62	18,63	41,14
17,63	18,64	41,16
17,64	18,65	41,18
17,65	18,66	41,20
17,66	18,67	41,22
17,67	18,68	41,24
17,68	18,69	41,26
17,69	18,70	41,29
17,70	18,71	41,31
17,71	18,72	41,33
17,72	18,73	41,35
17,73	18,74	41,37
17,74	18,75	41,39
17,75	18,76	41,41
17,76	18,77	41,44



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,77	18,78	41,46
17,78	18,79	41,48
17,79	18,80	41,50
17,80	18,81	41,52
17,81	18,82	41,54
17,82	18,83	41,56
17,83	18,84	41,58
17,84	18,85	41,61
17,85	18,86	41,63
17,86	18,87	41,65
17,87	18,88	41,67
17,88	18,89	41,69
17,89	18,90	41,71
17,90	18,91	41,73
17,91	18,92	41,75
17,92	18,93	41,77
17,93	18,94	41,80
17,94	18,95	41,82
17,95	18,96	41,84
17,96	18,97	41,86
17,97	18,98	41,88
17,98	18,99	41,90
17,99	19,00	41,92
18,00	19,01	41,94
18,01	19,02	41,96
18,02	19,03	41,99
18,03	19,04	42,01
18,04	19,05	42,03
18,05	19,06	42,05
18,06	19,07	42,07
18,07	19,08	42,09
18,08	19,09	42,11
18,09	19,10	42,13
18,10	19,11	42,15
18,11	19,12	42,18
18,12	19,13	42,20
18,13	19,14	42,22
18,14	19,15	42,24
18,15	19,16	42,26
18,16	19,17	42,28
18,17	19,18	42,30
18,18	19,19	42,32
18,19	19,20	42,34
18,20	19,21	42,36



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,21	19,22	42,38
18,22	19,23	42,41
18,23	19,24	42,43
18,24	19,25	42,45
18,25	19,26	42,47
18,26	19,27	42,49
18,27	19,28	42,51
18,28	19,29	42,53
18,29	19,30	42,55
18,30	19,31	42,57
18,31	19,32	42,59
18,32	19,33	42,61
18,33	19,34	42,63
18,34	19,35	42,66
18,35	19,36	42,68
18,36	19,37	42,70
18,37	19,38	42,72
18,38	19,39	42,74
18,39	19,40	42,76
18,40	19,41	42,78
18,41	19,42	42,80
18,42	19,43	42,82
18,43	19,44	42,84
18,44	19,45	42,86
18,45	19,46	42,88
18,46	19,47	42,90
18,47	19,48	42,93
18,48	19,49	42,95
18,49	19,50	42,97
18,50	19,51	42,99
18,51	19,52	43,01
18,52	19,53	43,03
18,53	19,54	43,05
18,54	19,55	43,07
18,55	19,56	43,09
18,56	19,57	43,11
18,57	19,58	43,13
18,58	19,59	43,15
18,59	19,60	43,17
18,60	19,61	43,19
18,61	19,62	43,21
18,62	19,63	43,23
18,63	19,64	43,26
18,64	19,65	43,28



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,65	19,66	43,30
18,66	19,67	43,32
18,67	19,68	43,34
18,68	19,69	43,36
18,69	19,70	43,38
18,70	19,71	43,40
18,71	19,72	43,42
18,72	19,73	43,44
18,73	19,74	43,46
18,74	19,75	43,48
18,75	19,76	43,50
18,76	19,77	43,52
18,77	19,78	43,54
18,78	19,79	43,56
18,79	19,80	43,58
18,80	19,81	43,60
18,81	19,82	43,62
18,82	19,83	43,64
18,83	19,84	43,66
18,84	19,85	43,69
18,85	19,86	43,71
18,86	19,87	43,73
18,87	19,88	43,75
18,88	19,89	43,77
18,89	19,90	43,79
18,90	19,91	43,81
18,91	19,92	43,83
18,92	19,93	43,85
18,93	19,94	43,87
18,94	19,95	43,89
18,95	19,96	43,91
18,96	19,97	43,93
18,97	19,98	43,95
18,98	19,99	43,97
18,99	20,00	43,99
19,00	20,01	44,01
19,01	20,02	44,03
19,02	20,03	44,05
19,03	20,04	44,07
19,04	20,05	44,09
19,05	20,06	44,11
19,06	20,07	44,13
19,07	20,08	44,15
19,08	20,09	44,17



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	44,19
19,10	20,11	44,21
19,11	20,12	44,23
19,12	20,13	44,25
19,13	20,14	44,27
19,14	20,15	44,29
19,15	20,16	44,31
19,16	20,17	44,33
19,17	20,18	44,35
19,18	20,19	44,37
19,19	20,20	44,39
19,20	20,21	44,41
19,21	20,22	44,43
19,22	20,23	44,45
19,23	20,24	44,47
19,24	20,25	44,49
19,25	20,26	44,51
19,26	20,27	44,53
19,27	20,28	44,55
19,28	20,29	44,57
19,29	20,30	44,59
19,30	20,31	44,61
19,31	20,32	44,63
19,32	20,33	44,65
19,33	20,34	44,67
19,34	20,35	44,69
19,35	20,36	44,71
19,36	20,37	44,73
19,37	20,38	44,75
19,38	20,39	44,77
19,39	20,40	44,79
19,40	20,41	44,81
19,41	20,42	44,83
19,42	20,43	44,85
19,43	20,44	44,87
19,44	20,45	44,89
19,45	20,46	44,91
19,46	20,47	44,93
19,47	20,48	44,95
19,48	20,49	44,97
19,49	20,50	44,99
19,50	20,51	45,01
19,51	20,52	45,03
19,52	20,53	45,05



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	45,07
19,54	20,55	45,09
19,55	20,56	45,11
19,56	20,57	45,13
19,57	20,58	45,15
19,58	20,59	45,17
19,59	20,60	45,19
19,60	20,61	45,21
19,61	20,62	45,23
19,62	20,63	45,25
19,63	20,64	45,27
19,64	20,65	45,29
19,65	20,66	45,31
19,66	20,67	45,33
19,67	20,68	45,35
19,68	20,69	45,37
19,69	20,70	45,39
19,70	20,71	45,41
19,71	20,72	45,43
19,72	20,73	45,45
19,73	20,74	45,47
19,74	20,75	45,49
19,75	20,76	45,51
19,76	20,77	45,53
19,77	20,78	45,55
19,78	20,79	45,57
19,79	20,80	45,59
19,80	20,81	45,61
19,81	20,82	45,63
19,82	20,83	45,65
19,83	20,84	45,67
19,84	20,85	45,69
19,85	20,86	45,71
19,86	20,87	45,72
19,87	20,88	45,74
19,88	20,89	45,76
19,89	20,90	45,78
19,90	20,91	45,80
19,91	20,92	45,82
19,92	20,93	45,84
19,93	20,94	45,86
19,94	20,95	45,88
19,95	20,96	45,90
19,96	20,97	45,92



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,97	20,98	45,94
19,98	20,99	45,96
19,99	21,00	45,98
20,00	21,01	46,00
20,01	21,02	46,02
20,02	21,03	46,04
20,03	21,04	46,06
20,04	21,05	46,08
20,05	21,06	46,10
20,06	21,07	46,12
20,07	21,08	46,13
20,08	21,09	46,15
20,09	21,10	46,17
20,10	21,11	46,19
20,11	21,12	46,21
20,12	21,13	46,23
20,13	21,14	46,25
20,14	21,15	46,27
20,15	21,16	46,29
20,16	21,17	46,31
20,17	21,18	46,33
20,18	21,19	46,35
20,19	21,20	46,37
20,20	21,21	46,39
20,21	21,22	46,41
20,22	21,23	46,43
20,23	21,24	46,45
20,24	21,25	46,46
20,25	21,26	46,48
20,26	21,27	46,50
20,27	21,28	46,52
20,28	21,29	46,54
20,29	21,30	46,56
20,30	21,31	46,58
20,31	21,32	46,60
20,32	21,33	46,62
20,33	21,34	46,64
20,34	21,35	46,66
20,35	21,36	46,68
20,36	21,37	46,70
20,37	21,38	46,72
20,38	21,39	46,73
20,39	21,40	46,75
20,40	21,41	46,77



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,41	21,42	46,79
20,42	21,43	46,81
20,43	21,44	46,83
20,44	21,45	46,85
20,45	21,46	46,87
20,46	21,47	46,89
20,47	21,48	46,91
20,48	21,49	46,93
20,49	21,50	46,95
20,50	21,51	46,97
20,51	21,52	46,98
20,52	21,53	47,00
20,53	21,54	47,02
20,54	21,55	47,04
20,55	21,56	47,06
20,56	21,57	47,08
20,57	21,58	47,10
20,58	21,59	47,12
20,59	21,60	47,14
20,60	21,61	47,16
20,61	21,62	47,18
20,62	21,63	47,19
20,63	21,64	47,21
20,64	21,65	47,23
20,65	21,66	47,25
20,66	21,67	47,27
20,67	21,68	47,29
20,68	21,69	47,31
20,69	21,70	47,33
20,70	21,71	47,35
20,71	21,72	47,37
20,72	21,73	47,39
20,73	21,74	47,40
20,74	21,75	47,42
20,75	21,76	47,44
20,76	21,77	47,46
20,77	21,78	47,48
20,78	21,79	47,50
20,79	21,80	47,52
20,80	21,81	47,54
20,81	21,82	47,56
20,82	21,83	47,57
20,83	21,84	47,59
20,84	21,85	47,61



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	47,63
20,86	21,87	47,65
20,87	21,88	47,67
20,88	21,89	47,69
20,89	21,90	47,71
20,90	21,91	47,73
20,91	21,92	47,75
20,92	21,93	47,76
20,93	21,94	47,78
20,94	21,95	47,80
20,95	21,96	47,82
20,96	21,97	47,84
20,97	21,98	47,86
20,98	21,99	47,88
20,99	22,00	47,90
21,00	22,01	47,91
21,01	22,02	47,93
21,02	22,03	47,95
21,03	22,04	47,97
21,04	22,05	47,99
21,05	22,06	48,01
21,06	22,07	48,03
21,07	22,08	48,05
21,08	22,09	48,07
21,09	22,10	48,08
21,10	22,11	48,10
21,11	22,12	48,12
21,12	22,13	48,14
21,13	22,14	48,16
21,14	22,15	48,18
21,15	22,16	48,20
21,16	22,17	48,22
21,17	22,18	48,23
21,18	22,19	48,25
21,19	22,20	48,27
21,20	22,21	48,29
21,21	22,22	48,31
21,22	22,23	48,33
21,23	22,24	48,35
21,24	22,25	48,36
21,25	22,26	48,38
21,26	22,27	48,40
21,27	22,28	48,42
21,28	22,29	48,44



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
21,29	22,30	48,46
21,30	22,31	48,48
21,31	22,32	48,50
21,32	22,33	48,51
21,33	22,34	48,53
21,34	22,35	48,55
21,35	22,36	48,57
21,36	22,37	48,59
21,37	22,38	48,61
21,38	22,39	48,63
21,39	22,40	48,64
21,40	22,41	48,66
21,41	22,42	48,68
21,42	22,43	48,70
21,43	22,44	48,72
21,44	22,45	48,74
21,45	22,46	48,76
21,46	22,47	48,77
21,47	22,48	48,79
21,48	22,49	48,81
21,49	22,50	48,83
21,50	22,51	48,85
21,51	22,52	48,87
21,52	22,53	48,88
21,53	22,54	48,90
21,54	22,55	48,92
21,55	22,56	48,94
21,56	22,57	48,96
21,57	22,58	48,98
21,58	22,59	49,00
21,59	22,60	49,01
21,60	22,61	49,03
21,61	22,62	49,05
21,62	22,63	49,07
21,63	22,64	49,09
21,64	22,65	49,11
21,65	22,66	49,12
21,66	22,67	49,14
21,67	22,68	49,16
21,68	22,69	49,18
21,69	22,70	49,20
21,70	22,71	49,22
21,71	22,72	49,23
21,72	22,73	49,25



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	49,27
21,74	22,75	49,29
21,75	22,76	49,31
21,76	22,77	49,33
21,77	22,78	49,34
21,78	22,79	49,36
21,79	22,80	49,38
21,80	22,81	49,40
21,81	22,82	49,42
21,82	22,83	49,44
21,83	22,84	49,45
21,84	22,85	49,47
21,85	22,86	49,49
21,86	22,87	49,51
21,87	22,88	49,53
21,88	22,89	49,55
21,89	22,90	49,56
21,90	22,91	49,58
21,91	22,92	49,60
21,92	22,93	49,62
21,93	22,94	49,64
21,94	22,95	49,66
21,95	22,96	49,67
21,96	22,97	49,69
21,97	22,98	49,71
21,98	22,99	49,73
21,99	23,00	49,75
22,00	23,01	49,76
22,01	23,02	49,78
22,02	23,03	49,80
22,03	23,04	49,82
22,04	23,05	49,84
22,05	23,06	49,86
22,06	23,07	49,87
22,07	23,08	49,89
22,08	23,09	49,91
22,09	23,10	49,93
22,10	23,11	49,95
22,11	23,12	49,96
22,12	23,13	49,98
22,13	23,14	50,00
22,14	23,15	50,02
22,15	23,16	50,04
22,16	23,17	50,05



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,17	23,18	50,07
22,18	23,19	50,09
22,19	23,20	50,11
22,20	23,21	50,13
22,21	23,22	50,14
22,22	23,23	50,16
22,23	23,24	50,18
22,24	23,25	50,20
22,25	23,26	50,22
22,26	23,27	50,23
22,27	23,28	50,25
22,28	23,29	50,27
22,29	23,30	50,29
22,30	23,31	50,31
22,31	23,32	50,32
22,32	23,33	50,34
22,33	23,34	50,36
22,34	23,35	50,38
22,35	23,36	50,40
22,36	23,37	50,41
22,37	23,38	50,43
22,38	23,39	50,45
22,39	23,40	50,47
22,40	23,41	50,49
22,41	23,42	50,50
22,42	23,43	50,52
22,43	23,44	50,54
22,44	23,45	50,56
22,45	23,46	50,58
22,46	23,47	50,59
22,47	23,48	50,61
22,48	23,49	50,63
22,49	23,50	50,65
22,50	23,51	50,67
22,51	23,52	50,68
22,52	23,53	50,70
22,53	23,54	50,72
22,54	23,55	50,74
22,55	23,56	50,75
22,56	23,57	50,77
22,57	23,58	50,79
22,58	23,59	50,81
22,59	23,60	50,83
22,60	23,61	50,84



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	50,86
22,62	23,63	50,88
22,63	23,64	50,90
22,64	23,65	50,92
22,65	23,66	50,93
22,66	23,67	50,95
22,67	23,68	50,97
22,68	23,69	50,99
22,69	23,70	51,00
22,70	23,71	51,02
22,71	23,72	51,04
22,72	23,73	51,06
22,73	23,74	51,08
22,74	23,75	51,09
22,75	23,76	51,11
22,76	23,77	51,13
22,77	23,78	51,15
22,78	23,79	51,16
22,79	23,80	51,18
22,80	23,81	51,20
22,81	23,82	51,22
22,82	23,83	51,23
22,83	23,84	51,25
22,84	23,85	51,27
22,85	23,86	51,29
22,86	23,87	51,31
22,87	23,88	51,32
22,88	23,89	51,34
22,89	23,90	51,36
22,90	23,91	51,38
22,91	23,92	51,39
22,92	23,93	51,41
22,93	23,94	51,43
22,94	23,95	51,45
22,95	23,96	51,46
22,96	23,97	51,48
22,97	23,98	51,50
22,98	23,99	51,52
22,99	24,00	51,53
23,00	24,01	51,55
23,01	24,02	51,57
23,02	24,03	51,59
23,03	24,04	51,60
23,04	24,05	51,62



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,05	24,06	51,64
23,06	24,07	51,66
23,07	24,08	51,67
23,08	24,09	51,69
23,09	24,10	51,71
23,10	24,11	51,73
23,11	24,12	51,74
23,12	24,13	51,76
23,13	24,14	51,78
23,14	24,15	51,80
23,15	24,16	51,81
23,16	24,17	51,83
23,17	24,18	51,85
23,18	24,19	51,87
23,19	24,20	51,88
23,20	24,21	51,90
23,21	24,22	51,92
23,22	24,23	51,94
23,23	24,24	51,95
23,24	24,25	51,97
23,25	24,26	51,99
23,26	24,27	52,01
23,27	24,28	52,02
23,28	24,29	52,04
23,29	24,30	52,06
23,30	24,31	52,08
23,31	24,32	52,09
23,32	24,33	52,11
23,33	24,34	52,13
23,34	24,35	52,15
23,35	24,36	52,16
23,36	24,37	52,18
23,37	24,38	52,20
23,38	24,39	52,22
23,39	24,40	52,23
23,40	24,41	52,25
23,41	24,42	52,27
23,42	24,43	52,29
23,43	24,44	52,30
23,44	24,45	52,32
23,45	24,46	52,34
23,46	24,47	52,35
23,47	24,48	52,37
23,48	24,49	52,39



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,49	24,50	52,41
23,50	24,51	52,42
23,51	24,52	52,44
23,52	24,53	52,46
23,53	24,54	52,48
23,54	24,55	52,49
23,55	24,56	52,51
23,56	24,57	52,53
23,57	24,58	52,54
23,58	24,59	52,56
23,59	24,60	52,58
23,60	24,61	52,60
23,61	24,62	52,61
23,62	24,63	52,63
23,63	24,64	52,65
23,64	24,65	52,67
23,65	24,66	52,68
23,66	24,67	52,70
23,67	24,68	52,72
23,68	24,69	52,73
23,69	24,70	52,75
23,70	24,71	52,77
23,71	24,72	52,79
23,72	24,73	52,80
23,73	24,74	52,82
23,74	24,75	52,84
23,75	24,76	52,85
23,76	24,77	52,87
23,77	24,78	52,89
23,78	24,79	52,91
23,79	24,80	52,92
23,80	24,81	52,94
23,81	24,82	52,96
23,82	24,83	52,97
23,83	24,84	52,99
23,84	24,85	53,01
23,85	24,86	53,03
23,86	24,87	53,04
23,87	24,88	53,06
23,88	24,89	53,08
23,89	24,90	53,09
23,90	24,91	53,11
23,91	24,92	53,13
23,92	24,93	53,14



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,93	24,94	53,16
23,94	24,95	53,18
23,95	24,96	53,20
23,96	24,97	53,21
23,97	24,98	53,23
23,98	24,99	53,25
23,99	25,00	53,26
24,00	25,01	53,28
24,01	25,02	53,30
24,02	25,03	53,32
24,03	25,04	53,33
24,04	25,05	53,35
24,05	25,06	53,37
24,06	25,07	53,38
24,07	25,08	53,40
24,08	25,09	53,42
24,09	25,10	53,43
24,10	25,11	53,45
24,11	25,12	53,47
24,12	25,13	53,49
24,13	25,14	53,50
24,14	25,15	53,52
24,15	25,16	53,54
24,16	25,17	53,55
24,17	25,18	53,57
24,18	25,19	53,59
24,19	25,20	53,60
24,20	25,21	53,62
24,21	25,22	53,64
24,22	25,23	53,65
24,23	25,24	53,67
24,24	25,25	53,69
24,25	25,26	53,70
24,26	25,27	53,72
24,27	25,28	53,74
24,28	25,29	53,76
24,29	25,30	53,77
24,30	25,31	53,79
24,31	25,32	53,81
24,32	25,33	53,82
24,33	25,34	53,84
24,34	25,35	53,86
24,35	25,36	53,87
24,36	25,37	53,89



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,37	25,38	53,91
24,38	25,39	53,92
24,39	25,40	53,94
24,40	25,41	53,96
24,41	25,42	53,97
24,42	25,43	53,99
24,43	25,44	54,01
24,44	25,45	54,02
24,45	25,46	54,04
24,46	25,47	54,06
24,47	25,48	54,08
24,48	25,49	54,09
24,49	25,50	54,11
24,50	25,51	54,13
24,51	25,52	54,14
24,52	25,53	54,16
24,53	25,54	54,18
24,54	25,55	54,19
24,55	25,56	54,21
24,56	25,57	54,23
24,57	25,58	54,24
24,58	25,59	54,26
24,59	25,60	54,28
24,60	25,61	54,29
24,61	25,62	54,31
24,62	25,63	54,33
24,63	25,64	54,34
24,64	25,65	54,36
24,65	25,66	54,38
24,66	25,67	54,39
24,67	25,68	54,41
24,68	25,69	54,43
24,69	25,70	54,44
24,70	25,71	54,46
24,71	25,72	54,48
24,72	25,73	54,49
24,73	25,74	54,51
24,74	25,75	54,53
24,75	25,76	54,54
24,76	25,77	54,56
24,77	25,78	54,58
24,78	25,79	54,59
24,79	25,80	54,61
24,80	25,81	54,63



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
24,81	25,82	54,64
24,82	25,83	54,66
24,83	25,84	54,68
24,84	25,85	54,69
24,85	25,86	54,71
24,86	25,87	54,72
24,87	25,88	54,74
24,88	25,89	54,76
24,89	25,90	54,77
24,90	25,91	54,79
24,91	25,92	54,81
24,92	25,93	54,82
24,93	25,94	54,84
24,94	25,95	54,86
24,95	25,96	54,87
24,96	25,97	54,89
24,97	25,98	54,91
24,98	25,99	54,92
24,99	26,00	54,94
25,00	26,01	54,96
25,01	26,02	54,97
25,02	26,03	54,99
25,03	26,04	55,01
25,04	26,05	55,02
25,05	26,06	55,04
25,06	26,07	55,06
25,07	26,08	55,07
25,08	26,09	55,09
25,09	26,10	55,10
25,10	26,11	55,12
25,11	26,12	55,14
25,12	26,13	55,15
25,13	26,14	55,17
25,14	26,15	55,19
25,15	26,16	55,20
25,16	26,17	55,22
25,17	26,18	55,24
25,18	26,19	55,25
25,19	26,20	55,27
25,20	26,21	55,29
25,21	26,22	55,30
25,22	26,23	55,32
25,23	26,24	55,33
25,24	26,25	55,35



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	55,37
25,26	26,27	55,38
25,27	26,28	55,40
25,28	26,29	55,42
25,29	26,30	55,43
25,30	26,31	55,45
25,31	26,32	55,47
25,32	26,33	55,48
25,33	26,34	55,50
25,34	26,35	55,51
25,35	26,36	55,53
25,36	26,37	55,55
25,37	26,38	55,56
25,38	26,39	55,58
25,39	26,40	55,60
25,40	26,41	55,61
25,41	26,42	55,63
25,42	26,43	55,64
25,43	26,44	55,66
25,44	26,45	55,68
25,45	26,46	55,69
25,46	26,47	55,71
25,47	26,48	55,73
25,48	26,49	55,74
25,49	26,50	55,76
25,50	26,51	55,77
25,51	26,52	55,79
25,52	26,53	55,81
25,53	26,54	55,82
25,54	26,55	55,84
25,55	26,56	55,86
25,56	26,57	55,87
25,57	26,58	55,89
25,58	26,59	55,90
25,59	26,60	55,92
25,60	26,61	55,94
25,61	26,62	55,95
25,62	26,63	55,97
25,63	26,64	55,99
25,64	26,65	56,00
25,65	26,66	56,02
25,66	26,67	56,03
25,67	26,68	56,05
25,68	26,69	56,07



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
25,69	26,70	56,08
25,70	26,71	56,10
25,71	26,72	56,11
25,72	26,73	56,13
25,73	26,74	56,15
25,74	26,75	56,16
25,75	26,76	56,18
25,76	26,77	56,19
25,77	26,78	56,21
25,78	26,79	56,23
25,79	26,80	56,24
25,80	26,81	56,26
25,81	26,82	56,28
25,82	26,83	56,29
25,83	26,84	56,31
25,84	26,85	56,32
25,85	26,86	56,34
25,86	26,87	56,36
25,87	26,88	56,37
25,88	26,89	56,39
25,89	26,90	56,40
25,90	26,91	56,42
25,91	26,92	56,44
25,92	26,93	56,45
25,93	26,94	56,47
25,94	26,95	56,48
25,95	26,96	56,50
25,96	26,97	56,52
25,97	26,98	56,53
25,98	26,99	56,55
25,99	27,00	56,56
26,00	27,01	56,58
26,01	27,02	56,60
26,02	27,03	56,61
26,03	27,04	56,63
26,04	27,05	56,64
26,05	27,06	56,66
26,06	27,07	56,68
26,07	27,08	56,69
26,08	27,09	56,71
26,09	27,10	56,72
26,10	27,11	56,74
26,11	27,12	56,76
26,12	27,13	56,77



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	56,79
26,14	27,15	56,80
26,15	27,16	56,82
26,16	27,17	56,84
26,17	27,18	56,85
26,18	27,19	56,87
26,19	27,20	56,88
26,20	27,21	56,90
26,21	27,22	56,91
26,22	27,23	56,93
26,23	27,24	56,95
26,24	27,25	56,96
26,25	27,26	56,98
26,26	27,27	56,99
26,27	27,28	57,01
26,28	27,29	57,03
26,29	27,30	57,04
26,30	27,31	57,06
26,31	27,32	57,07
26,32	27,33	57,09
26,33	27,34	57,11
26,34	27,35	57,12
26,35	27,36	57,14
26,36	27,37	57,15
26,37	27,38	57,17
26,38	27,39	57,18
26,39	27,40	57,20
26,40	27,41	57,22
26,41	27,42	57,23
26,42	27,43	57,25
26,43	27,44	57,26
26,44	27,45	57,28
26,45	27,46	57,29
26,46	27,47	57,31
26,47	27,48	57,33
26,48	27,49	57,34
26,49	27,50	57,36
26,50	27,51	57,37
26,51	27,52	57,39
26,52	27,53	57,41
26,53	27,54	57,42
26,54	27,55	57,44
26,55	27,56	57,45
26,56	27,57	57,47



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
26,57	27,58	57,48
26,58	27,59	57,50
26,59	27,60	57,52
26,60	27,61	57,53
26,61	27,62	57,55
26,62	27,63	57,56
26,63	27,64	57,58
26,64	27,65	57,59
26,65	27,66	57,61
26,66	27,67	57,63
26,67	27,68	57,64
26,68	27,69	57,66
26,69	27,70	57,67
26,70	27,71	57,69
26,71	27,72	57,70
26,72	27,73	57,72
26,73	27,74	57,73
26,74	27,75	57,75
26,75	27,76	57,77
26,76	27,77	57,78
26,77	27,78	57,80
26,78	27,79	57,81
26,79	27,80	57,83
26,80	27,81	57,84
26,81	27,82	57,86
26,82	27,83	57,88
26,83	27,84	57,89
26,84	27,85	57,91
26,85	27,86	57,92
26,86	27,87	57,94
26,87	27,88	57,95
26,88	27,89	57,97
26,89	27,90	57,98
26,90	27,91	58,00
26,91	27,92	58,02
26,92	27,93	58,03
26,93	27,94	58,05
26,94	27,95	58,06
26,95	27,96	58,08
26,96	27,97	58,09
26,97	27,98	58,11
26,98	27,99	58,12
26,99	28,00	58,14
27,00	28,01	58,16



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	58,17
27,02	28,03	58,19
27,03	28,04	58,20
27,04	28,05	58,22
27,05	28,06	58,23
27,06	28,07	58,25
27,07	28,08	58,26
27,08	28,09	58,28
27,09	28,10	58,29
27,10	28,11	58,31
27,11	28,12	58,33
27,12	28,13	58,34
27,13	28,14	58,36
27,14	28,15	58,37
27,15	28,16	58,39
27,16	28,17	58,40
27,17	28,18	58,42
27,18	28,19	58,43
27,19	28,20	58,45
27,20	28,21	58,46
27,21	28,22	58,48
27,22	28,23	58,50
27,23	28,24	58,51
27,24	28,25	58,53
27,25	28,26	58,54
27,26	28,27	58,56
27,27	28,28	58,57
27,28	28,29	58,59
27,29	28,30	58,60
27,30	28,31	58,62
27,31	28,32	58,63
27,32	28,33	58,65
27,33	28,34	58,67
27,34	28,35	58,68
27,35	28,36	58,70
27,36	28,37	58,71
27,37	28,38	58,73
27,38	28,39	58,74
27,39	28,40	58,76
27,40	28,41	58,77
27,41	28,42	58,79
27,42	28,43	58,80
27,43	28,44	58,82
27,44	28,45	58,83



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	58,85
27,46	28,47	58,86
27,47	28,48	58,88
27,48	28,49	58,90
27,49	28,50	58,91
27,50	28,51	58,93
27,51	28,52	58,94
27,52	28,53	58,96
27,53	28,54	58,97
27,54	28,55	58,99
27,55	28,56	59,00
27,56	28,57	59,02
27,57	28,58	59,03
27,58	28,59	59,05
27,59	28,60	59,06
27,60	28,61	59,08
27,61	28,62	59,09
27,62	28,63	59,11
27,63	28,64	59,12
27,64	28,65	59,14
27,65	28,66	59,15
27,66	28,67	59,17
27,67	28,68	59,19
27,68	28,69	59,20
27,69	28,70	59,22
27,70	28,71	59,23
27,71	28,72	59,25
27,72	28,73	59,26
27,73	28,74	59,28
27,74	28,75	59,29
27,75	28,76	59,31
27,76	28,77	59,32
27,77	28,78	59,34
27,78	28,79	59,35
27,79	28,80	59,37
27,80	28,81	59,38
27,81	28,82	59,40
27,82	28,83	59,41
27,83	28,84	59,43
27,84	28,85	59,44
27,85	28,86	59,46
27,86	28,87	59,47
27,87	28,88	59,49
27,88	28,89	59,50



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	59,52
27,90	28,91	59,53
27,91	28,92	59,55
27,92	28,93	59,56
27,93	28,94	59,58
27,94	28,95	59,59
27,95	28,96	59,61
27,96	28,97	59,62
27,97	28,98	59,64
27,98	28,99	59,65
27,99	29,00	59,67
28,00	29,01	59,68
28,01	29,02	59,70
28,02	29,03	59,72
28,03	29,04	59,73
28,04	29,05	59,75
28,05	29,06	59,76
28,06	29,07	59,78
28,07	29,08	59,79
28,08	29,09	59,81
28,09	29,10	59,82
28,10	29,11	59,84
28,11	29,12	59,85
28,12	29,13	59,87
28,13	29,14	59,88
28,14	29,15	59,90
28,15	29,16	59,91
28,16	29,17	59,93
28,17	29,18	59,94
28,18	29,19	59,96
28,19	29,20	59,97
28,20	29,21	59,99
28,21	29,22	60,00
28,22	29,23	60,02
28,23	29,24	60,03
28,24	29,25	60,05
28,25	29,26	60,06
28,26	29,27	60,08
28,27	29,28	60,09
28,28	29,29	60,11
28,29	29,30	60,12
28,30	29,31	60,14
28,31	29,32	60,15
28,32	29,33	60,16



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	60,18
28,34	29,35	60,19
28,35	29,36	60,21
28,36	29,37	60,22
28,37	29,38	60,24
28,38	29,39	60,25
28,39	29,40	60,27
28,40	29,41	60,28
28,41	29,42	60,30
28,42	29,43	60,31
28,43	29,44	60,33
28,44	29,45	60,34
28,45	29,46	60,36
28,46	29,47	60,37
28,47	29,48	60,39
28,48	29,49	60,40
28,49	29,50	60,42
28,50	29,51	60,43
28,51	29,52	60,45
28,52	29,53	60,46
28,53	29,54	60,48
28,54	29,55	60,49
28,55	29,56	60,51
28,56	29,57	60,52
28,57	29,58	60,54
28,58	29,59	60,55
28,59	29,60	60,57
28,60	29,61	60,58
28,61	29,62	60,60
28,62	29,63	60,61
28,63	29,64	60,63
28,64	29,65	60,64
28,65	29,66	60,66
28,66	29,67	60,67
28,67	29,68	60,68
28,68	29,69	60,70
28,69	29,70	60,71
28,70	29,71	60,73
28,71	29,72	60,74
28,72	29,73	60,76
28,73	29,74	60,77
28,74	29,75	60,79
28,75	29,76	60,80
28,76	29,77	60,82



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	60,83
28,78	29,79	60,85
28,79	29,80	60,86
28,80	29,81	60,88
28,81	29,82	60,89
28,82	29,83	60,91
28,83	29,84	60,92
28,84	29,85	60,94
28,85	29,86	60,95
28,86	29,87	60,97
28,87	29,88	60,98
28,88	29,89	60,99
28,89	29,90	61,01
28,90	29,91	61,02
28,91	29,92	61,04
28,92	29,93	61,05
28,93	29,94	61,07
28,94	29,95	61,08
28,95	29,96	61,10
28,96	29,97	61,11
28,97	29,98	61,13
28,98	29,99	61,14
28,99	30,00	61,16
29,00	30,01	61,17
29,01	30,02	61,19
29,02	30,03	61,20
29,03	30,04	61,21
29,04	30,05	61,23
29,05	30,06	61,24
29,06	30,07	61,26
29,07	30,08	61,27
29,08	30,09	61,29
29,09	30,10	61,30
29,10	30,11	61,32
29,11	30,12	61,33
29,12	30,13	61,35
29,13	30,14	61,36
29,14	30,15	61,38
29,15	30,16	61,39
29,16	30,17	61,40
29,17	30,18	61,42
29,18	30,19	61,43
29,19	30,20	61,45
29,20	30,21	61,46



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	61,48
29,22	30,23	61,49
29,23	30,24	61,51
29,24	30,25	61,52
29,25	30,26	61,54
29,26	30,27	61,55
29,27	30,28	61,56
29,28	30,29	61,58
29,29	30,30	61,59
29,30	30,31	61,61
29,31	30,32	61,62
29,32	30,33	61,64
29,33	30,34	61,65
29,34	30,35	61,67
29,35	30,36	61,68
29,36	30,37	61,69
29,37	30,38	61,71
29,38	30,39	61,72
29,39	30,40	61,74
29,40	30,41	61,75
29,41	30,42	61,77
29,42	30,43	61,78
29,43	30,44	61,80
29,44	30,45	61,81
29,45	30,46	61,83
29,46	30,47	61,84
29,47	30,48	61,85
29,48	30,49	61,87
29,49	30,50	61,88
29,50	30,51	61,90
29,51	30,52	61,91
29,52	30,53	61,93
29,53	30,54	61,94
29,54	30,55	61,96
29,55	30,56	61,97
29,56	30,57	61,98
29,57	30,58	62,00
29,58	30,59	62,01
29,59	30,60	62,03
29,60	30,61	62,04
29,61	30,62	62,06
29,62	30,63	62,07
29,63	30,64	62,08
29,64	30,65	62,10



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
29,65	30,66	62,11
29,66	30,67	62,13
29,67	30,68	62,14
29,68	30,69	62,16
29,69	30,70	62,17
29,70	30,71	62,19
29,71	30,72	62,20
29,72	30,73	62,21
29,73	30,74	62,23
29,74	30,75	62,24
29,75	30,76	62,26
29,76	30,77	62,27
29,77	30,78	62,29
29,78	30,79	62,30
29,79	30,80	62,31
29,80	30,81	62,33
29,81	30,82	62,34
29,82	30,83	62,36
29,83	30,84	62,37
29,84	30,85	62,39
29,85	30,86	62,40
29,86	30,87	62,41
29,87	30,88	62,43
29,88	30,89	62,44
29,89	30,90	62,46
29,90	30,91	62,47
29,91	30,92	62,49
29,92	30,93	62,50
29,93	30,94	62,51
29,94	30,95	62,53
29,95	30,96	62,54
29,96	30,97	62,56
29,97	30,98	62,57
29,98	30,99	62,59
29,99	31,00	62,60
30,00	31,01	62,61
30,01	31,02	62,63
30,02	31,03	62,64
30,03	31,04	62,66
30,04	31,05	62,67
30,05	31,06	62,69
30,06	31,07	62,70
30,07	31,08	62,71
30,08	31,09	62,73



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,09	31,10	62,74
30,10	31,11	62,76
30,11	31,12	62,77
30,12	31,13	62,78
30,13	31,14	62,80
30,14	31,15	62,81
30,15	31,16	62,83
30,16	31,17	62,84
30,17	31,18	62,86
30,18	31,19	62,87
30,19	31,20	62,88
30,20	31,21	62,90
30,21	31,22	62,91
30,22	31,23	62,93
30,23	31,24	62,94
30,24	31,25	62,95
30,25	31,26	62,97
30,26	31,27	62,98
30,27	31,28	63,00
30,28	31,29	63,01
30,29	31,30	63,03
30,30	31,31	63,04
30,31	31,32	63,05
30,32	31,33	63,07
30,33	31,34	63,08
30,34	31,35	63,10
30,35	31,36	63,11
30,36	31,37	63,12
30,37	31,38	63,14
30,38	31,39	63,15
30,39	31,40	63,17
30,40	31,41	63,18
30,41	31,42	63,19
30,42	31,43	63,21
30,43	31,44	63,22
30,44	31,45	63,24
30,45	31,46	63,25
30,46	31,47	63,26
30,47	31,48	63,28
30,48	31,49	63,29
30,49	31,50	63,31
30,50	31,51	63,32
30,51	31,52	63,33
30,52	31,53	63,35



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	63,36
30,54	31,55	63,38
30,55	31,56	63,39
30,56	31,57	63,40
30,57	31,58	63,42
30,58	31,59	63,43
30,59	31,60	63,45
30,60	31,61	63,46
30,61	31,62	63,47
30,62	31,63	63,49
30,63	31,64	63,50
30,64	31,65	63,52
30,65	31,66	63,53
30,66	31,67	63,54
30,67	31,68	63,56
30,68	31,69	63,57
30,69	31,70	63,59
30,70	31,71	63,60
30,71	31,72	63,61
30,72	31,73	63,63
30,73	31,74	63,64
30,74	31,75	63,66
30,75	31,76	63,67
30,76	31,77	63,68
30,77	31,78	63,70
30,78	31,79	63,71
30,79	31,80	63,73
30,80	31,81	63,74
30,81	31,82	63,75
30,82	31,83	63,77
30,83	31,84	63,78
30,84	31,85	63,80
30,85	31,86	63,81
30,86	31,87	63,82
30,87	31,88	63,84
30,88	31,89	63,85
30,89	31,90	63,87
30,90	31,91	63,88
30,91	31,92	63,89
30,92	31,93	63,91
30,93	31,94	63,92
30,94	31,95	63,93
30,95	31,96	63,95
30,96	31,97	63,96



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,97	31,98	63,98
30,98	31,99	63,99
30,99	32,00	64,00
31,00	32,01	64,02
31,01	32,02	64,03
31,02	32,03	64,05
31,03	32,04	64,06
31,04	32,05	64,07
31,05	32,06	64,09
31,06	32,07	64,10
31,07	32,08	64,11
31,08	32,09	64,13
31,09	32,10	64,14
31,10	32,11	64,16
31,11	32,12	64,17
31,12	32,13	64,18
31,13	32,14	64,20
31,14	32,15	64,21
31,15	32,16	64,22
31,16	32,17	64,24
31,17	32,18	64,25
31,18	32,19	64,27
31,19	32,20	64,28
31,20	32,21	64,29
31,21	32,22	64,31
31,22	32,23	64,32
31,23	32,24	64,33
31,24	32,25	64,35
31,25	32,26	64,36
31,26	32,27	64,38
31,27	32,28	64,39
31,28	32,29	64,40
31,29	32,30	64,42
31,30	32,31	64,43
31,31	32,32	64,44
31,32	32,33	64,46
31,33	32,34	64,47
31,34	32,35	64,49
31,35	32,36	64,50
31,36	32,37	64,51
31,37	32,38	64,53
31,38	32,39	64,54
31,39	32,40	64,55
31,40	32,41	64,57



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	64,58
31,42	32,43	64,60
31,43	32,44	64,61
31,44	32,45	64,62
31,45	32,46	64,64
31,46	32,47	64,65
31,47	32,48	64,66
31,48	32,49	64,68
31,49	32,50	64,69
31,50	32,51	64,70
31,51	32,52	64,72
31,52	32,53	64,73
31,53	32,54	64,75
31,54	32,55	64,76
31,55	32,56	64,77
31,56	32,57	64,79
31,57	32,58	64,80
31,58	32,59	64,81
31,59	32,60	64,83
31,60	32,61	64,84
31,61	32,62	64,85
31,62	32,63	64,87
31,63	32,64	64,88
31,64	32,65	64,90
31,65	32,66	64,91
31,66	32,67	64,92
31,67	32,68	64,94
31,68	32,69	64,95
31,69	32,70	64,96
31,70	32,71	64,98
31,71	32,72	64,99
31,72	32,73	65,00
31,73	32,74	65,02
31,74	32,75	65,03
31,75	32,76	65,04
31,76	32,77	65,06
31,77	32,78	65,07
31,78	32,79	65,08
31,79	32,80	65,10
31,80	32,81	65,11
31,81	32,82	65,13
31,82	32,83	65,14
31,83	32,84	65,15
31,84	32,85	65,17



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	65,18
31,86	32,87	65,19
31,87	32,88	65,21
31,88	32,89	65,22
31,89	32,90	65,23
31,90	32,91	65,25
31,91	32,92	65,26
31,92	32,93	65,27
31,93	32,94	65,29
31,94	32,95	65,30
31,95	32,96	65,31
31,96	32,97	65,33
31,97	32,98	65,34
31,98	32,99	65,35
31,99	33,00	65,37
32,00	33,01	65,38
32,01	33,02	65,40
32,02	33,03	65,41
32,03	33,04	65,42
32,04	33,05	65,44
32,05	33,06	65,45
32,06	33,07	65,46
32,07	33,08	65,48
32,08	33,09	65,49
32,09	33,10	65,50
32,10	33,11	65,52
32,11	33,12	65,53
32,12	33,13	65,54
32,13	33,14	65,56
32,14	33,15	65,57
32,15	33,16	65,58
32,16	33,17	65,60
32,17	33,18	65,61
32,18	33,19	65,62
32,19	33,20	65,64
32,20	33,21	65,65
32,21	33,22	65,66
32,22	33,23	65,68
32,23	33,24	65,69
32,24	33,25	65,70
32,25	33,26	65,72
32,26	33,27	65,73
32,27	33,28	65,74
32,28	33,29	65,76



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	65,77
32,30	33,31	65,78
32,31	33,32	65,80
32,32	33,33	65,81
32,33	33,34	65,82
32,34	33,35	65,84
32,35	33,36	65,85
32,36	33,37	65,86
32,37	33,38	65,88
32,38	33,39	65,89
32,39	33,40	65,90
32,40	33,41	65,92
32,41	33,42	65,93
32,42	33,43	65,94
32,43	33,44	65,96
32,44	33,45	65,97
32,45	33,46	65,98
32,46	33,47	66,00
32,47	33,48	66,01
32,48	33,49	66,02
32,49	33,50	66,04
32,50	33,51	66,05
32,51	33,52	66,06
32,52	33,53	66,08
32,53	33,54	66,09
32,54	33,55	66,10
32,55	33,56	66,12
32,56	33,57	66,13
32,57	33,58	66,14
32,58	33,59	66,16
32,59	33,60	66,17
32,60	33,61	66,18
32,61	33,62	66,20
32,62	33,63	66,21
32,63	33,64	66,22
32,64	33,65	66,23
32,65	33,66	66,25
32,66	33,67	66,26
32,67	33,68	66,27
32,68	33,69	66,29
32,69	33,70	66,30
32,70	33,71	66,31
32,71	33,72	66,33
32,72	33,73	66,34



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,73	33,74	66,35
32,74	33,75	66,37
32,75	33,76	66,38
32,76	33,77	66,39
32,77	33,78	66,41
32,78	33,79	66,42
32,79	33,80	66,43
32,80	33,81	66,45
32,81	33,82	66,46
32,82	33,83	66,47
32,83	33,84	66,49
32,84	33,85	66,50
32,85	33,86	66,51
32,86	33,87	66,52
32,87	33,88	66,54
32,88	33,89	66,55
32,89	33,90	66,56
32,90	33,91	66,58
32,91	33,92	66,59
32,92	33,93	66,60
32,93	33,94	66,62
32,94	33,95	66,63
32,95	33,96	66,64
32,96	33,97	66,66
32,97	33,98	66,67
32,98	33,99	66,68
32,99	34,00	66,69
33,00	34,01	66,71
33,01	34,02	66,72
33,02	34,03	66,73
33,03	34,04	66,75
33,04	34,05	66,76
33,05	34,06	66,77
33,06	34,07	66,79
33,07	34,08	66,80
33,08	34,09	66,81
33,09	34,10	66,83
33,10	34,11	66,84
33,11	34,12	66,85
33,12	34,13	66,86
33,13	34,14	66,88
33,14	34,15	66,89
33,15	34,16	66,90
33,16	34,17	66,92



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,17	34,18	66,93
33,18	34,19	66,94
33,19	34,20	66,96
33,20	34,21	66,97
33,21	34,22	66,98
33,22	34,23	66,99
33,23	34,24	67,01
33,24	34,25	67,02
33,25	34,26	67,03
33,26	34,27	67,05
33,27	34,28	67,06
33,28	34,29	67,07
33,29	34,30	67,09
33,30	34,31	67,10
33,31	34,32	67,11
33,32	34,33	67,12
33,33	34,34	67,14
33,34	34,35	67,15
33,35	34,36	67,16
33,36	34,37	67,18
33,37	34,38	67,19
33,38	34,39	67,20
33,39	34,40	67,22
33,40	34,41	67,23
33,41	34,42	67,24
33,42	34,43	67,25
33,43	34,44	67,27
33,44	34,45	67,28
33,45	34,46	67,29
33,46	34,47	67,31
33,47	34,48	67,32
33,48	34,49	67,33
33,49	34,50	67,34
33,50	34,51	67,36
33,51	34,52	67,37
33,52	34,53	67,38
33,53	34,54	67,40
33,54	34,55	67,41
33,55	34,56	67,42
33,56	34,57	67,43
33,57	34,58	67,45
33,58	34,59	67,46
33,59	34,60	67,47
33,60	34,61	67,49



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,61	34,62	67,50
33,62	34,63	67,51
33,63	34,64	67,52
33,64	34,65	67,54
33,65	34,66	67,55
33,66	34,67	67,56
33,67	34,68	67,58
33,68	34,69	67,59
33,69	34,70	67,60
33,70	34,71	67,61
33,71	34,72	67,63
33,72	34,73	67,64
33,73	34,74	67,65
33,74	34,75	67,67
33,75	34,76	67,68
33,76	34,77	67,69
33,77	34,78	67,70
33,78	34,79	67,72
33,79	34,80	67,73
33,80	34,81	67,74
33,81	34,82	67,76
33,82	34,83	67,77
33,83	34,84	67,78
33,84	34,85	67,79
33,85	34,86	67,81
33,86	34,87	67,82
33,87	34,88	67,83
33,88	34,89	67,84
33,89	34,90	67,86
33,90	34,91	67,87
33,91	34,92	67,88
33,92	34,93	67,90
33,93	34,94	67,91
33,94	34,95	67,92
33,95	34,96	67,93
33,96	34,97	67,95
33,97	34,98	67,96
33,98	34,99	67,97
33,99	35,00	67,98
34,00	35,01	68,00
34,01	35,02	68,01
34,02	35,03	68,02
34,03	35,04	68,04
34,04	35,05	68,05



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,05	35,06	68,06
34,06	35,07	68,07
34,07	35,08	68,09
34,08	35,09	68,10
34,09	35,10	68,11
34,10	35,11	68,12
34,11	35,12	68,14
34,12	35,13	68,15
34,13	35,14	68,16
34,14	35,15	68,17
34,15	35,16	68,19
34,16	35,17	68,20
34,17	35,18	68,21
34,18	35,19	68,23
34,19	35,20	68,24
34,20	35,21	68,25
34,21	35,22	68,26
34,22	35,23	68,28
34,23	35,24	68,29
34,24	35,25	68,30
34,25	35,26	68,31
34,26	35,27	68,33
34,27	35,28	68,34
34,28	35,29	68,35
34,29	35,30	68,36
34,30	35,31	68,38
34,31	35,32	68,39
34,32	35,33	68,40
34,33	35,34	68,41
34,34	35,35	68,43
34,35	35,36	68,44
34,36	35,37	68,45
34,37	35,38	68,47
34,38	35,39	68,48
34,39	35,40	68,49
34,40	35,41	68,50
34,41	35,42	68,52
34,42	35,43	68,53
34,43	35,44	68,54
34,44	35,45	68,55
34,45	35,46	68,57
34,46	35,47	68,58
34,47	35,48	68,59
34,48	35,49	68,60



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,49	35,50	68,62
34,50	35,51	68,63
34,51	35,52	68,64
34,52	35,53	68,65
34,53	35,54	68,67
34,54	35,55	68,68
34,55	35,56	68,69
34,56	35,57	68,70
34,57	35,58	68,72
34,58	35,59	68,73
34,59	35,60	68,74
34,60	35,61	68,75
34,61	35,62	68,77
34,62	35,63	68,78
34,63	35,64	68,79
34,64	35,65	68,80
34,65	35,66	68,82
34,66	35,67	68,83
34,67	35,68	68,84
34,68	35,69	68,85
34,69	35,70	68,87
34,70	35,71	68,88
34,71	35,72	68,89
34,72	35,73	68,90
34,73	35,74	68,92
34,74	35,75	68,93
34,75	35,76	68,94
34,76	35,77	68,95
34,77	35,78	68,97
34,78	35,79	68,98
34,79	35,80	68,99
34,80	35,81	69,00
34,81	35,82	69,02
34,82	35,83	69,03
34,83	35,84	69,04
34,84	35,85	69,05
34,85	35,86	69,06
34,86	35,87	69,08
34,87	35,88	69,09
34,88	35,89	69,10
34,89	35,90	69,11
34,90	35,91	69,13
34,91	35,92	69,14
34,92	35,93	69,15



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,93	35,94	69,16
34,94	35,95	69,18
34,95	35,96	69,19
34,96	35,97	69,20
34,97	35,98	69,21
34,98	35,99	69,23
34,99	36,00	69,24
35,00	36,01	69,25
35,01	36,02	69,26
35,02	36,03	69,28
35,03	36,04	69,29
35,04	36,05	69,30
35,05	36,06	69,31
35,06	36,07	69,32
35,07	36,08	69,34
35,08	36,09	69,35
35,09	36,10	69,36
35,10	36,11	69,37
35,11	36,12	69,39
35,12	36,13	69,40
35,13	36,14	69,41
35,14	36,15	69,42
35,15	36,16	69,44
35,16	36,17	69,45
35,17	36,18	69,46
35,18	36,19	69,47
35,19	36,20	69,48
35,20	36,21	69,50
35,21	36,22	69,51
35,22	36,23	69,52
35,23	36,24	69,53
35,24	36,25	69,55
35,25	36,26	69,56
35,26	36,27	69,57
35,27	36,28	69,58
35,28	36,29	69,60
35,29	36,30	69,61
35,30	36,31	69,62
35,31	36,32	69,63
35,32	36,33	69,64
35,33	36,34	69,66
35,34	36,35	69,67
35,35	36,36	69,68
35,36	36,37	69,69



R407B		
V1.0_R407B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
35,37	36,38	69,71
35,38	36,39	69,72
35,39	36,40	69,73
35,40	36,41	69,74
35,41	36,42	69,75