



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
-0,71	0,30	-51,34
-0,70	0,31	-50,78
-0,69	0,32	-50,24
-0,68	0,33	-49,71
-0,67	0,34	-49,19
-0,66	0,35	-48,69
-0,65	0,36	-48,19
-0,64	0,37	-47,71
-0,63	0,38	-47,24
-0,62	0,39	-46,78
-0,61	0,40	-46,33
-0,60	0,41	-45,88
-0,59	0,42	-45,45
-0,58	0,43	-45,02
-0,57	0,44	-44,60
-0,56	0,45	-44,19
-0,55	0,46	-43,79
-0,54	0,47	-43,39
-0,53	0,48	-43,00
-0,52	0,49	-42,62
-0,51	0,50	-42,24
-0,50	0,51	-41,87
-0,49	0,52	-41,51
-0,48	0,53	-41,15
-0,47	0,54	-40,79
-0,46	0,55	-40,44
-0,45	0,56	-40,10
-0,44	0,57	-39,76
-0,43	0,58	-39,43
-0,42	0,59	-39,10
-0,41	0,60	-38,77
-0,40	0,61	-38,45
-0,39	0,62	-38,14
-0,38	0,63	-37,82
-0,37	0,64	-37,51
-0,36	0,65	-37,21
-0,35	0,66	-36,91
-0,34	0,67	-36,61
-0,33	0,68	-36,32
-0,32	0,69	-36,03
-0,31	0,70	-35,74
-0,30	0,71	-35,46
-0,29	0,72	-35,18
-0,28	0,73	-34,90



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
-0,27	0,74	-34,62
-0,26	0,75	-34,35
-0,25	0,76	-34,08
-0,24	0,77	-33,82
-0,23	0,78	-33,55
-0,22	0,79	-33,29
-0,21	0,80	-33,04
-0,20	0,81	-32,78
-0,19	0,82	-32,53
-0,18	0,83	-32,28
-0,17	0,84	-32,03
-0,16	0,85	-31,78
-0,15	0,86	-31,54
-0,14	0,87	-31,30
-0,13	0,88	-31,06
-0,12	0,89	-30,82
-0,11	0,90	-30,59
-0,10	0,91	-30,35
-0,09	0,92	-30,12
-0,08	0,93	-29,90
-0,07	0,94	-29,67
-0,06	0,95	-29,44
-0,05	0,96	-29,22
-0,04	0,97	-29,00
-0,03	0,98	-28,78
-0,02	0,99	-28,56
-0,01	1,00	-28,35
0,00	1,01	-28,13
0,01	1,02	-27,92
0,02	1,03	-27,71
0,03	1,04	-27,50
0,04	1,05	-27,29
0,05	1,06	-27,09
0,06	1,07	-26,88
0,07	1,08	-26,68
0,08	1,09	-26,48
0,09	1,10	-26,28
0,10	1,11	-26,08
0,11	1,12	-25,88
0,12	1,13	-25,69
0,13	1,14	-25,49
0,14	1,15	-25,30
0,15	1,16	-25,11
0,16	1,17	-24,92



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,17	1,18	-24,73
0,18	1,19	-24,54
0,19	1,20	-24,35
0,20	1,21	-24,17
0,21	1,22	-23,98
0,22	1,23	-23,80
0,23	1,24	-23,62
0,24	1,25	-23,44
0,25	1,26	-23,26
0,26	1,27	-23,08
0,27	1,28	-22,90
0,28	1,29	-22,72
0,29	1,30	-22,55
0,30	1,31	-22,37
0,31	1,32	-22,20
0,32	1,33	-22,03
0,33	1,34	-21,86
0,34	1,35	-21,69
0,35	1,36	-21,52
0,36	1,37	-21,35
0,37	1,38	-21,18
0,38	1,39	-21,02
0,39	1,40	-20,85
0,40	1,41	-20,69
0,41	1,42	-20,52
0,42	1,43	-20,36
0,43	1,44	-20,20
0,44	1,45	-20,04
0,45	1,46	-19,88
0,46	1,47	-19,72
0,47	1,48	-19,56
0,48	1,49	-19,40
0,49	1,50	-19,24
0,50	1,51	-19,09
0,51	1,52	-18,93
0,52	1,53	-18,78
0,53	1,54	-18,63
0,54	1,55	-18,47
0,55	1,56	-18,32
0,56	1,57	-18,17
0,57	1,58	-18,02
0,58	1,59	-17,87
0,59	1,60	-17,72
0,60	1,61	-17,57



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
0,61	1,62	-17,43
0,62	1,63	-17,28
0,63	1,64	-17,13
0,64	1,65	-16,99
0,65	1,66	-16,84
0,66	1,67	-16,70
0,67	1,68	-16,55
0,68	1,69	-16,41
0,69	1,70	-16,27
0,70	1,71	-16,13
0,71	1,72	-15,99
0,72	1,73	-15,85
0,73	1,74	-15,71
0,74	1,75	-15,57
0,75	1,76	-15,43
0,76	1,77	-15,29
0,77	1,78	-15,16
0,78	1,79	-15,02
0,79	1,80	-14,88
0,80	1,81	-14,75
0,81	1,82	-14,61
0,82	1,83	-14,48
0,83	1,84	-14,35
0,84	1,85	-14,21
0,85	1,86	-14,08
0,86	1,87	-13,95
0,87	1,88	-13,82
0,88	1,89	-13,69
0,89	1,90	-13,56
0,90	1,91	-13,43
0,91	1,92	-13,30
0,92	1,93	-13,17
0,93	1,94	-13,04
0,94	1,95	-12,91
0,95	1,96	-12,79
0,96	1,97	-12,66
0,97	1,98	-12,53
0,98	1,99	-12,41
0,99	2,00	-12,28
1,00	2,01	-12,16
1,01	2,02	-12,03
1,02	2,03	-11,91
1,03	2,04	-11,79
1,04	2,05	-11,67



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	-11,54
1,06	2,07	-11,42
1,07	2,08	-11,30
1,08	2,09	-11,18
1,09	2,10	-11,06
1,10	2,11	-10,94
1,11	2,12	-10,82
1,12	2,13	-10,70
1,13	2,14	-10,58
1,14	2,15	-10,46
1,15	2,16	-10,34
1,16	2,17	-10,23
1,17	2,18	-10,11
1,18	2,19	-9,99
1,19	2,20	-9,88
1,20	2,21	-9,76
1,21	2,22	-9,65
1,22	2,23	-9,53
1,23	2,24	-9,42
1,24	2,25	-9,30
1,25	2,26	-9,19
1,26	2,27	-9,08
1,27	2,28	-8,96
1,28	2,29	-8,85
1,29	2,30	-8,74
1,30	2,31	-8,63
1,31	2,32	-8,51
1,32	2,33	-8,40
1,33	2,34	-8,29
1,34	2,35	-8,18
1,35	2,36	-8,07
1,36	2,37	-7,96
1,37	2,38	-7,85
1,38	2,39	-7,74
1,39	2,40	-7,64
1,40	2,41	-7,53
1,41	2,42	-7,42
1,42	2,43	-7,31
1,43	2,44	-7,20
1,44	2,45	-7,10
1,45	2,46	-6,99
1,46	2,47	-6,88
1,47	2,48	-6,78
1,48	2,49	-6,67



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,49	2,50	-6,57
1,50	2,51	-6,46
1,51	2,52	-6,36
1,52	2,53	-6,25
1,53	2,54	-6,15
1,54	2,55	-6,05
1,55	2,56	-5,94
1,56	2,57	-5,84
1,57	2,58	-5,74
1,58	2,59	-5,63
1,59	2,60	-5,53
1,60	2,61	-5,43
1,61	2,62	-5,33
1,62	2,63	-5,23
1,63	2,64	-5,13
1,64	2,65	-5,03
1,65	2,66	-4,93
1,66	2,67	-4,83
1,67	2,68	-4,73
1,68	2,69	-4,63
1,69	2,70	-4,53
1,70	2,71	-4,43
1,71	2,72	-4,33
1,72	2,73	-4,23
1,73	2,74	-4,13
1,74	2,75	-4,04
1,75	2,76	-3,94
1,76	2,77	-3,84
1,77	2,78	-3,74
1,78	2,79	-3,65
1,79	2,80	-3,55
1,80	2,81	-3,46
1,81	2,82	-3,36
1,82	2,83	-3,26
1,83	2,84	-3,17
1,84	2,85	-3,07
1,85	2,86	-2,98
1,86	2,87	-2,88
1,87	2,88	-2,79
1,88	2,89	-2,70
1,89	2,90	-2,60
1,90	2,91	-2,51
1,91	2,92	-2,41
1,92	2,93	-2,32



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,93	2,94	-2,23
1,94	2,95	-2,14
1,95	2,96	-2,04
1,96	2,97	-1,95
1,97	2,98	-1,86
1,98	2,99	-1,77
1,99	3,00	-1,68
2,00	3,01	-1,59
2,01	3,02	-1,49
2,02	3,03	-1,40
2,03	3,04	-1,31
2,04	3,05	-1,22
2,05	3,06	-1,13
2,06	3,07	-1,04
2,07	3,08	-0,95
2,08	3,09	-0,86
2,09	3,10	-0,77
2,10	3,11	-0,69
2,11	3,12	-0,60
2,12	3,13	-0,51
2,13	3,14	-0,42
2,14	3,15	-0,33
2,15	3,16	-0,24
2,16	3,17	-0,16
2,17	3,18	-0,07
2,18	3,19	0,02
2,19	3,20	0,10
2,20	3,21	0,19
2,21	3,22	0,28
2,22	3,23	0,36
2,23	3,24	0,45
2,24	3,25	0,54
2,25	3,26	0,62
2,26	3,27	0,71
2,27	3,28	0,79
2,28	3,29	0,88
2,29	3,30	0,96
2,30	3,31	1,05
2,31	3,32	1,13
2,32	3,33	1,22
2,33	3,34	1,30
2,34	3,35	1,39
2,35	3,36	1,47
2,36	3,37	1,55



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	1,64
2,38	3,39	1,72
2,39	3,40	1,80
2,40	3,41	1,89
2,41	3,42	1,97
2,42	3,43	2,05
2,43	3,44	2,13
2,44	3,45	2,22
2,45	3,46	2,30
2,46	3,47	2,38
2,47	3,48	2,46
2,48	3,49	2,54
2,49	3,50	2,62
2,50	3,51	2,70
2,51	3,52	2,79
2,52	3,53	2,87
2,53	3,54	2,95
2,54	3,55	3,03
2,55	3,56	3,11
2,56	3,57	3,19
2,57	3,58	3,27
2,58	3,59	3,35
2,59	3,60	3,43
2,60	3,61	3,51
2,61	3,62	3,58
2,62	3,63	3,66
2,63	3,64	3,74
2,64	3,65	3,82
2,65	3,66	3,90
2,66	3,67	3,98
2,67	3,68	4,06
2,68	3,69	4,13
2,69	3,70	4,21
2,70	3,71	4,29
2,71	3,72	4,37
2,72	3,73	4,44
2,73	3,74	4,52
2,74	3,75	4,60
2,75	3,76	4,68
2,76	3,77	4,75
2,77	3,78	4,83
2,78	3,79	4,91
2,79	3,80	4,98
2,80	3,81	5,06



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
2,81	3,82	5,13
2,82	3,83	5,21
2,83	3,84	5,29
2,84	3,85	5,36
2,85	3,86	5,44
2,86	3,87	5,51
2,87	3,88	5,59
2,88	3,89	5,66
2,89	3,90	5,74
2,90	3,91	5,81
2,91	3,92	5,89
2,92	3,93	5,96
2,93	3,94	6,03
2,94	3,95	6,11
2,95	3,96	6,18
2,96	3,97	6,26
2,97	3,98	6,33
2,98	3,99	6,40
2,99	4,00	6,48
3,00	4,01	6,55
3,01	4,02	6,62
3,02	4,03	6,70
3,03	4,04	6,77
3,04	4,05	6,84
3,05	4,06	6,91
3,06	4,07	6,99
3,07	4,08	7,06
3,08	4,09	7,13
3,09	4,10	7,20
3,10	4,11	7,27
3,11	4,12	7,35
3,12	4,13	7,42
3,13	4,14	7,49
3,14	4,15	7,56
3,15	4,16	7,63
3,16	4,17	7,70
3,17	4,18	7,77
3,18	4,19	7,84
3,19	4,20	7,92
3,20	4,21	7,99
3,21	4,22	8,06
3,22	4,23	8,13
3,23	4,24	8,20
3,24	4,25	8,27



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
3,25	4,26	8,34
3,26	4,27	8,41
3,27	4,28	8,48
3,28	4,29	8,55
3,29	4,30	8,62
3,30	4,31	8,68
3,31	4,32	8,75
3,32	4,33	8,82
3,33	4,34	8,89
3,34	4,35	8,96
3,35	4,36	9,03
3,36	4,37	9,10
3,37	4,38	9,17
3,38	4,39	9,23
3,39	4,40	9,30
3,40	4,41	9,37
3,41	4,42	9,44
3,42	4,43	9,51
3,43	4,44	9,57
3,44	4,45	9,64
3,45	4,46	9,71
3,46	4,47	9,78
3,47	4,48	9,84
3,48	4,49	9,91
3,49	4,50	9,98
3,50	4,51	10,05
3,51	4,52	10,11
3,52	4,53	10,18
3,53	4,54	10,25
3,54	4,55	10,31
3,55	4,56	10,38
3,56	4,57	10,44
3,57	4,58	10,51
3,58	4,59	10,58
3,59	4,60	10,64
3,60	4,61	10,71
3,61	4,62	10,77
3,62	4,63	10,84
3,63	4,64	10,91
3,64	4,65	10,97
3,65	4,66	11,04
3,66	4,67	11,10
3,67	4,68	11,17
3,68	4,69	11,23



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
3,69	4,70	11,30
3,70	4,71	11,36
3,71	4,72	11,43
3,72	4,73	11,49
3,73	4,74	11,56
3,74	4,75	11,62
3,75	4,76	11,68
3,76	4,77	11,75
3,77	4,78	11,81
3,78	4,79	11,88
3,79	4,80	11,94
3,80	4,81	12,00
3,81	4,82	12,07
3,82	4,83	12,13
3,83	4,84	12,19
3,84	4,85	12,26
3,85	4,86	12,32
3,86	4,87	12,38
3,87	4,88	12,45
3,88	4,89	12,51
3,89	4,90	12,57
3,90	4,91	12,64
3,91	4,92	12,70
3,92	4,93	12,76
3,93	4,94	12,82
3,94	4,95	12,89
3,95	4,96	12,95
3,96	4,97	13,01
3,97	4,98	13,07
3,98	4,99	13,13
3,99	5,00	13,20
4,00	5,01	13,26
4,01	5,02	13,32
4,02	5,03	13,38
4,03	5,04	13,44
4,04	5,05	13,50
4,05	5,06	13,57
4,06	5,07	13,63
4,07	5,08	13,69
4,08	5,09	13,75
4,09	5,10	13,81
4,10	5,11	13,87
4,11	5,12	13,93
4,12	5,13	13,99



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	14,05
4,14	5,15	14,11
4,15	5,16	14,17
4,16	5,17	14,23
4,17	5,18	14,29
4,18	5,19	14,35
4,19	5,20	14,42
4,20	5,21	14,48
4,21	5,22	14,54
4,22	5,23	14,59
4,23	5,24	14,65
4,24	5,25	14,71
4,25	5,26	14,77
4,26	5,27	14,83
4,27	5,28	14,89
4,28	5,29	14,95
4,29	5,30	15,01
4,30	5,31	15,07
4,31	5,32	15,13
4,32	5,33	15,19
4,33	5,34	15,25
4,34	5,35	15,31
4,35	5,36	15,36
4,36	5,37	15,42
4,37	5,38	15,48
4,38	5,39	15,54
4,39	5,40	15,60
4,40	5,41	15,66
4,41	5,42	15,72
4,42	5,43	15,77
4,43	5,44	15,83
4,44	5,45	15,89
4,45	5,46	15,95
4,46	5,47	16,01
4,47	5,48	16,06
4,48	5,49	16,12
4,49	5,50	16,18
4,50	5,51	16,24
4,51	5,52	16,29
4,52	5,53	16,35
4,53	5,54	16,41
4,54	5,55	16,47
4,55	5,56	16,52
4,56	5,57	16,58



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	16,64
4,58	5,59	16,69
4,59	5,60	16,75
4,60	5,61	16,81
4,61	5,62	16,86
4,62	5,63	16,92
4,63	5,64	16,98
4,64	5,65	17,03
4,65	5,66	17,09
4,66	5,67	17,15
4,67	5,68	17,20
4,68	5,69	17,26
4,69	5,70	17,31
4,70	5,71	17,37
4,71	5,72	17,43
4,72	5,73	17,48
4,73	5,74	17,54
4,74	5,75	17,59
4,75	5,76	17,65
4,76	5,77	17,70
4,77	5,78	17,76
4,78	5,79	17,82
4,79	5,80	17,87
4,80	5,81	17,93
4,81	5,82	17,98
4,82	5,83	18,04
4,83	5,84	18,09
4,84	5,85	18,15
4,85	5,86	18,20
4,86	5,87	18,26
4,87	5,88	18,31
4,88	5,89	18,37
4,89	5,90	18,42
4,90	5,91	18,47
4,91	5,92	18,53
4,92	5,93	18,58
4,93	5,94	18,64
4,94	5,95	18,69
4,95	5,96	18,75
4,96	5,97	18,80
4,97	5,98	18,85
4,98	5,99	18,91
4,99	6,00	18,96
5,00	6,01	19,02



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	19,07
5,02	6,03	19,12
5,03	6,04	19,18
5,04	6,05	19,23
5,05	6,06	19,28
5,06	6,07	19,34
5,07	6,08	19,39
5,08	6,09	19,44
5,09	6,10	19,50
5,10	6,11	19,55
5,11	6,12	19,60
5,12	6,13	19,66
5,13	6,14	19,71
5,14	6,15	19,76
5,15	6,16	19,82
5,16	6,17	19,87
5,17	6,18	19,92
5,18	6,19	19,97
5,19	6,20	20,03
5,20	6,21	20,08
5,21	6,22	20,13
5,22	6,23	20,18
5,23	6,24	20,24
5,24	6,25	20,29
5,25	6,26	20,34
5,26	6,27	20,39
5,27	6,28	20,45
5,28	6,29	20,50
5,29	6,30	20,55
5,30	6,31	20,60
5,31	6,32	20,65
5,32	6,33	20,71
5,33	6,34	20,76
5,34	6,35	20,81
5,35	6,36	20,86
5,36	6,37	20,91
5,37	6,38	20,96
5,38	6,39	21,01
5,39	6,40	21,07
5,40	6,41	21,12
5,41	6,42	21,17
5,42	6,43	21,22
5,43	6,44	21,27
5,44	6,45	21,32



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,45	6,46	21,37
5,46	6,47	21,42
5,47	6,48	21,47
5,48	6,49	21,53
5,49	6,50	21,58
5,50	6,51	21,63
5,51	6,52	21,68
5,52	6,53	21,73
5,53	6,54	21,78
5,54	6,55	21,83
5,55	6,56	21,88
5,56	6,57	21,93
5,57	6,58	21,98
5,58	6,59	22,03
5,59	6,60	22,08
5,60	6,61	22,13
5,61	6,62	22,18
5,62	6,63	22,23
5,63	6,64	22,28
5,64	6,65	22,33
5,65	6,66	22,38
5,66	6,67	22,43
5,67	6,68	22,48
5,68	6,69	22,53
5,69	6,70	22,58
5,70	6,71	22,63
5,71	6,72	22,68
5,72	6,73	22,73
5,73	6,74	22,78
5,74	6,75	22,83
5,75	6,76	22,88
5,76	6,77	22,93
5,77	6,78	22,97
5,78	6,79	23,02
5,79	6,80	23,07
5,80	6,81	23,12
5,81	6,82	23,17
5,82	6,83	23,22
5,83	6,84	23,27
5,84	6,85	23,32
5,85	6,86	23,37
5,86	6,87	23,41
5,87	6,88	23,46
5,88	6,89	23,51



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	23,56
5,90	6,91	23,61
5,91	6,92	23,66
5,92	6,93	23,71
5,93	6,94	23,75
5,94	6,95	23,80
5,95	6,96	23,85
5,96	6,97	23,90
5,97	6,98	23,95
5,98	6,99	24,00
5,99	7,00	24,04
6,00	7,01	24,09
6,01	7,02	24,14
6,02	7,03	24,19
6,03	7,04	24,23
6,04	7,05	24,28
6,05	7,06	24,33
6,06	7,07	24,38
6,07	7,08	24,43
6,08	7,09	24,47
6,09	7,10	24,52
6,10	7,11	24,57
6,11	7,12	24,62
6,12	7,13	24,66
6,13	7,14	24,71
6,14	7,15	24,76
6,15	7,16	24,80
6,16	7,17	24,85
6,17	7,18	24,90
6,18	7,19	24,95
6,19	7,20	24,99
6,20	7,21	25,04
6,21	7,22	25,09
6,22	7,23	25,13
6,23	7,24	25,18
6,24	7,25	25,23
6,25	7,26	25,27
6,26	7,27	25,32
6,27	7,28	25,37
6,28	7,29	25,41
6,29	7,30	25,46
6,30	7,31	25,51
6,31	7,32	25,55
6,32	7,33	25,60



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,33	7,34	25,65
6,34	7,35	25,69
6,35	7,36	25,74
6,36	7,37	25,78
6,37	7,38	25,83
6,38	7,39	25,88
6,39	7,40	25,92
6,40	7,41	25,97
6,41	7,42	26,01
6,42	7,43	26,06
6,43	7,44	26,11
6,44	7,45	26,15
6,45	7,46	26,20
6,46	7,47	26,24
6,47	7,48	26,29
6,48	7,49	26,33
6,49	7,50	26,38
6,50	7,51	26,43
6,51	7,52	26,47
6,52	7,53	26,52
6,53	7,54	26,56
6,54	7,55	26,61
6,55	7,56	26,65
6,56	7,57	26,70
6,57	7,58	26,74
6,58	7,59	26,79
6,59	7,60	26,83
6,60	7,61	26,88
6,61	7,62	26,92
6,62	7,63	26,97
6,63	7,64	27,01
6,64	7,65	27,06
6,65	7,66	27,10
6,66	7,67	27,15
6,67	7,68	27,19
6,68	7,69	27,24
6,69	7,70	27,28
6,70	7,71	27,33
6,71	7,72	27,37
6,72	7,73	27,42
6,73	7,74	27,46
6,74	7,75	27,51
6,75	7,76	27,55
6,76	7,77	27,59



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,77	7,78	27,64
6,78	7,79	27,68
6,79	7,80	27,73
6,80	7,81	27,77
6,81	7,82	27,82
6,82	7,83	27,86
6,83	7,84	27,90
6,84	7,85	27,95
6,85	7,86	27,99
6,86	7,87	28,04
6,87	7,88	28,08
6,88	7,89	28,12
6,89	7,90	28,17
6,90	7,91	28,21
6,91	7,92	28,25
6,92	7,93	28,30
6,93	7,94	28,34
6,94	7,95	28,39
6,95	7,96	28,43
6,96	7,97	28,47
6,97	7,98	28,52
6,98	7,99	28,56
6,99	8,00	28,60
7,00	8,01	28,65
7,01	8,02	28,69
7,02	8,03	28,73
7,03	8,04	28,78
7,04	8,05	28,82
7,05	8,06	28,86
7,06	8,07	28,91
7,07	8,08	28,95
7,08	8,09	28,99
7,09	8,10	29,04
7,10	8,11	29,08
7,11	8,12	29,12
7,12	8,13	29,16
7,13	8,14	29,21
7,14	8,15	29,25
7,15	8,16	29,29
7,16	8,17	29,34
7,17	8,18	29,38
7,18	8,19	29,42
7,19	8,20	29,46
7,20	8,21	29,51



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	29,55
7,22	8,23	29,59
7,23	8,24	29,63
7,24	8,25	29,68
7,25	8,26	29,72
7,26	8,27	29,76
7,27	8,28	29,80
7,28	8,29	29,85
7,29	8,30	29,89
7,30	8,31	29,93
7,31	8,32	29,97
7,32	8,33	30,01
7,33	8,34	30,06
7,34	8,35	30,10
7,35	8,36	30,14
7,36	8,37	30,18
7,37	8,38	30,22
7,38	8,39	30,27
7,39	8,40	30,31
7,40	8,41	30,35
7,41	8,42	30,39
7,42	8,43	30,43
7,43	8,44	30,48
7,44	8,45	30,52
7,45	8,46	30,56
7,46	8,47	30,60
7,47	8,48	30,64
7,48	8,49	30,68
7,49	8,50	30,72
7,50	8,51	30,77
7,51	8,52	30,81
7,52	8,53	30,85
7,53	8,54	30,89
7,54	8,55	30,93
7,55	8,56	30,97
7,56	8,57	31,01
7,57	8,58	31,06
7,58	8,59	31,10
7,59	8,60	31,14
7,60	8,61	31,18
7,61	8,62	31,22
7,62	8,63	31,26
7,63	8,64	31,30
7,64	8,65	31,34



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
7,65	8,66	31,38
7,66	8,67	31,42
7,67	8,68	31,47
7,68	8,69	31,51
7,69	8,70	31,55
7,70	8,71	31,59
7,71	8,72	31,63
7,72	8,73	31,67
7,73	8,74	31,71
7,74	8,75	31,75
7,75	8,76	31,79
7,76	8,77	31,83
7,77	8,78	31,87
7,78	8,79	31,91
7,79	8,80	31,95
7,80	8,81	31,99
7,81	8,82	32,03
7,82	8,83	32,07
7,83	8,84	32,11
7,84	8,85	32,15
7,85	8,86	32,19
7,86	8,87	32,23
7,87	8,88	32,27
7,88	8,89	32,31
7,89	8,90	32,35
7,90	8,91	32,40
7,91	8,92	32,44
7,92	8,93	32,48
7,93	8,94	32,51
7,94	8,95	32,55
7,95	8,96	32,59
7,96	8,97	32,63
7,97	8,98	32,67
7,98	8,99	32,71
7,99	9,00	32,75
8,00	9,01	32,79
8,01	9,02	32,83
8,02	9,03	32,87
8,03	9,04	32,91
8,04	9,05	32,95
8,05	9,06	32,99
8,06	9,07	33,03
8,07	9,08	33,07
8,08	9,09	33,11



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,09	9,10	33,15
8,10	9,11	33,19
8,11	9,12	33,23
8,12	9,13	33,27
8,13	9,14	33,31
8,14	9,15	33,35
8,15	9,16	33,39
8,16	9,17	33,42
8,17	9,18	33,46
8,18	9,19	33,50
8,19	9,20	33,54
8,20	9,21	33,58
8,21	9,22	33,62
8,22	9,23	33,66
8,23	9,24	33,70
8,24	9,25	33,74
8,25	9,26	33,78
8,26	9,27	33,81
8,27	9,28	33,85
8,28	9,29	33,89
8,29	9,30	33,93
8,30	9,31	33,97
8,31	9,32	34,01
8,32	9,33	34,05
8,33	9,34	34,09
8,34	9,35	34,12
8,35	9,36	34,16
8,36	9,37	34,20
8,37	9,38	34,24
8,38	9,39	34,28
8,39	9,40	34,32
8,40	9,41	34,36
8,41	9,42	34,39
8,42	9,43	34,43
8,43	9,44	34,47
8,44	9,45	34,51
8,45	9,46	34,55
8,46	9,47	34,59
8,47	9,48	34,62
8,48	9,49	34,66
8,49	9,50	34,70
8,50	9,51	34,74
8,51	9,52	34,78
8,52	9,53	34,81



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,53	9,54	34,85
8,54	9,55	34,89
8,55	9,56	34,93
8,56	9,57	34,97
8,57	9,58	35,00
8,58	9,59	35,04
8,59	9,60	35,08
8,60	9,61	35,12
8,61	9,62	35,16
8,62	9,63	35,19
8,63	9,64	35,23
8,64	9,65	35,27
8,65	9,66	35,31
8,66	9,67	35,34
8,67	9,68	35,38
8,68	9,69	35,42
8,69	9,70	35,46
8,70	9,71	35,50
8,71	9,72	35,53
8,72	9,73	35,57
8,73	9,74	35,61
8,74	9,75	35,65
8,75	9,76	35,68
8,76	9,77	35,72
8,77	9,78	35,76
8,78	9,79	35,79
8,79	9,80	35,83
8,80	9,81	35,87
8,81	9,82	35,91
8,82	9,83	35,94
8,83	9,84	35,98
8,84	9,85	36,02
8,85	9,86	36,06
8,86	9,87	36,09
8,87	9,88	36,13
8,88	9,89	36,17
8,89	9,90	36,20
8,90	9,91	36,24
8,91	9,92	36,28
8,92	9,93	36,31
8,93	9,94	36,35
8,94	9,95	36,39
8,95	9,96	36,42
8,96	9,97	36,46



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,97	9,98	36,50
8,98	9,99	36,54
8,99	10,00	36,57
9,00	10,01	36,61
9,01	10,02	36,65
9,02	10,03	36,68
9,03	10,04	36,72
9,04	10,05	36,75
9,05	10,06	36,79
9,06	10,07	36,83
9,07	10,08	36,86
9,08	10,09	36,90
9,09	10,10	36,94
9,10	10,11	36,97
9,11	10,12	37,01
9,12	10,13	37,05
9,13	10,14	37,08
9,14	10,15	37,12
9,15	10,16	37,16
9,16	10,17	37,19
9,17	10,18	37,23
9,18	10,19	37,26
9,19	10,20	37,30
9,20	10,21	37,34
9,21	10,22	37,37
9,22	10,23	37,41
9,23	10,24	37,45
9,24	10,25	37,48
9,25	10,26	37,52
9,26	10,27	37,55
9,27	10,28	37,59
9,28	10,29	37,63
9,29	10,30	37,66
9,30	10,31	37,70
9,31	10,32	37,73
9,32	10,33	37,77
9,33	10,34	37,80
9,34	10,35	37,84
9,35	10,36	37,88
9,36	10,37	37,91
9,37	10,38	37,95
9,38	10,39	37,98
9,39	10,40	38,02
9,40	10,41	38,05



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,41	10,42	38,09
9,42	10,43	38,13
9,43	10,44	38,16
9,44	10,45	38,20
9,45	10,46	38,23
9,46	10,47	38,27
9,47	10,48	38,30
9,48	10,49	38,34
9,49	10,50	38,37
9,50	10,51	38,41
9,51	10,52	38,44
9,52	10,53	38,48
9,53	10,54	38,52
9,54	10,55	38,55
9,55	10,56	38,59
9,56	10,57	38,62
9,57	10,58	38,66
9,58	10,59	38,69
9,59	10,60	38,73
9,60	10,61	38,76
9,61	10,62	38,80
9,62	10,63	38,83
9,63	10,64	38,87
9,64	10,65	38,90
9,65	10,66	38,94
9,66	10,67	38,97
9,67	10,68	39,01
9,68	10,69	39,04
9,69	10,70	39,08
9,70	10,71	39,11
9,71	10,72	39,15
9,72	10,73	39,18
9,73	10,74	39,22
9,74	10,75	39,25
9,75	10,76	39,29
9,76	10,77	39,32
9,77	10,78	39,36
9,78	10,79	39,39
9,79	10,80	39,42
9,80	10,81	39,46
9,81	10,82	39,49
9,82	10,83	39,53
9,83	10,84	39,56
9,84	10,85	39,60



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
9,85	10,86	39,63
9,86	10,87	39,67
9,87	10,88	39,70
9,88	10,89	39,74
9,89	10,90	39,77
9,90	10,91	39,80
9,91	10,92	39,84
9,92	10,93	39,87
9,93	10,94	39,91
9,94	10,95	39,94
9,95	10,96	39,98
9,96	10,97	40,01
9,97	10,98	40,04
9,98	10,99	40,08
9,99	11,00	40,11
10,00	11,01	40,15
10,01	11,02	40,18
10,02	11,03	40,22
10,03	11,04	40,25
10,04	11,05	40,28
10,05	11,06	40,32
10,06	11,07	40,35
10,07	11,08	40,39
10,08	11,09	40,42
10,09	11,10	40,45
10,10	11,11	40,49
10,11	11,12	40,52
10,12	11,13	40,56
10,13	11,14	40,59
10,14	11,15	40,62
10,15	11,16	40,66
10,16	11,17	40,69
10,17	11,18	40,72
10,18	11,19	40,76
10,19	11,20	40,79
10,20	11,21	40,83
10,21	11,22	40,86
10,22	11,23	40,89
10,23	11,24	40,93
10,24	11,25	40,96
10,25	11,26	40,99
10,26	11,27	41,03
10,27	11,28	41,06
10,28	11,29	41,10



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
10,29	11,30	41,13
10,30	11,31	41,16
10,31	11,32	41,20
10,32	11,33	41,23
10,33	11,34	41,26
10,34	11,35	41,30
10,35	11,36	41,33
10,36	11,37	41,36
10,37	11,38	41,40
10,38	11,39	41,43
10,39	11,40	41,46
10,40	11,41	41,50
10,41	11,42	41,53
10,42	11,43	41,56
10,43	11,44	41,60
10,44	11,45	41,63
10,45	11,46	41,66
10,46	11,47	41,69
10,47	11,48	41,73
10,48	11,49	41,76
10,49	11,50	41,79
10,50	11,51	41,83
10,51	11,52	41,86
10,52	11,53	41,89
10,53	11,54	41,93
10,54	11,55	41,96
10,55	11,56	41,99
10,56	11,57	42,03
10,57	11,58	42,06
10,58	11,59	42,09
10,59	11,60	42,12
10,60	11,61	42,16
10,61	11,62	42,19
10,62	11,63	42,22
10,63	11,64	42,26
10,64	11,65	42,29
10,65	11,66	42,32
10,66	11,67	42,35
10,67	11,68	42,39
10,68	11,69	42,42
10,69	11,70	42,45
10,70	11,71	42,48
10,71	11,72	42,52
10,72	11,73	42,55



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	42,58
10,74	11,75	42,61
10,75	11,76	42,65
10,76	11,77	42,68
10,77	11,78	42,71
10,78	11,79	42,74
10,79	11,80	42,78
10,80	11,81	42,81
10,81	11,82	42,84
10,82	11,83	42,87
10,83	11,84	42,91
10,84	11,85	42,94
10,85	11,86	42,97
10,86	11,87	43,00
10,87	11,88	43,04
10,88	11,89	43,07
10,89	11,90	43,10
10,90	11,91	43,13
10,91	11,92	43,16
10,92	11,93	43,20
10,93	11,94	43,23
10,94	11,95	43,26
10,95	11,96	43,29
10,96	11,97	43,33
10,97	11,98	43,36
10,98	11,99	43,39
10,99	12,00	43,42
11,00	12,01	43,45
11,01	12,02	43,49
11,02	12,03	43,52
11,03	12,04	43,55
11,04	12,05	43,58
11,05	12,06	43,61
11,06	12,07	43,64
11,07	12,08	43,68
11,08	12,09	43,71
11,09	12,10	43,74
11,10	12,11	43,77
11,11	12,12	43,80
11,12	12,13	43,84
11,13	12,14	43,87
11,14	12,15	43,90
11,15	12,16	43,93
11,16	12,17	43,96



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,17	12,18	43,99
11,18	12,19	44,03
11,19	12,20	44,06
11,20	12,21	44,09
11,21	12,22	44,12
11,22	12,23	44,15
11,23	12,24	44,18
11,24	12,25	44,22
11,25	12,26	44,25
11,26	12,27	44,28
11,27	12,28	44,31
11,28	12,29	44,34
11,29	12,30	44,37
11,30	12,31	44,40
11,31	12,32	44,44
11,32	12,33	44,47
11,33	12,34	44,50
11,34	12,35	44,53
11,35	12,36	44,56
11,36	12,37	44,59
11,37	12,38	44,62
11,38	12,39	44,66
11,39	12,40	44,69
11,40	12,41	44,72
11,41	12,42	44,75
11,42	12,43	44,78
11,43	12,44	44,81
11,44	12,45	44,84
11,45	12,46	44,87
11,46	12,47	44,90
11,47	12,48	44,94
11,48	12,49	44,97
11,49	12,50	45,00
11,50	12,51	45,03
11,51	12,52	45,06
11,52	12,53	45,09
11,53	12,54	45,12
11,54	12,55	45,15
11,55	12,56	45,18
11,56	12,57	45,22
11,57	12,58	45,25
11,58	12,59	45,28
11,59	12,60	45,31
11,60	12,61	45,34



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	45,37
11,62	12,63	45,40
11,63	12,64	45,43
11,64	12,65	45,46
11,65	12,66	45,49
11,66	12,67	45,52
11,67	12,68	45,55
11,68	12,69	45,59
11,69	12,70	45,62
11,70	12,71	45,65
11,71	12,72	45,68
11,72	12,73	45,71
11,73	12,74	45,74
11,74	12,75	45,77
11,75	12,76	45,80
11,76	12,77	45,83
11,77	12,78	45,86
11,78	12,79	45,89
11,79	12,80	45,92
11,80	12,81	45,95
11,81	12,82	45,98
11,82	12,83	46,01
11,83	12,84	46,04
11,84	12,85	46,07
11,85	12,86	46,10
11,86	12,87	46,13
11,87	12,88	46,17
11,88	12,89	46,20
11,89	12,90	46,23
11,90	12,91	46,26
11,91	12,92	46,29
11,92	12,93	46,32
11,93	12,94	46,35
11,94	12,95	46,38
11,95	12,96	46,41
11,96	12,97	46,44
11,97	12,98	46,47
11,98	12,99	46,50
11,99	13,00	46,53
12,00	13,01	46,56
12,01	13,02	46,59
12,02	13,03	46,62
12,03	13,04	46,65
12,04	13,05	46,68



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,05	13,06	46,71
12,06	13,07	46,74
12,07	13,08	46,77
12,08	13,09	46,80
12,09	13,10	46,83
12,10	13,11	46,86
12,11	13,12	46,89
12,12	13,13	46,92
12,13	13,14	46,95
12,14	13,15	46,98
12,15	13,16	47,01
12,16	13,17	47,04
12,17	13,18	47,07
12,18	13,19	47,10
12,19	13,20	47,13
12,20	13,21	47,16
12,21	13,22	47,19
12,22	13,23	47,22
12,23	13,24	47,25
12,24	13,25	47,28
12,25	13,26	47,31
12,26	13,27	47,34
12,27	13,28	47,37
12,28	13,29	47,40
12,29	13,30	47,43
12,30	13,31	47,46
12,31	13,32	47,48
12,32	13,33	47,51
12,33	13,34	47,54
12,34	13,35	47,57
12,35	13,36	47,60
12,36	13,37	47,63
12,37	13,38	47,66
12,38	13,39	47,69
12,39	13,40	47,72
12,40	13,41	47,75
12,41	13,42	47,78
12,42	13,43	47,81
12,43	13,44	47,84
12,44	13,45	47,87
12,45	13,46	47,90
12,46	13,47	47,93
12,47	13,48	47,96
12,48	13,49	47,99



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	48,02
12,50	13,51	48,04
12,51	13,52	48,07
12,52	13,53	48,10
12,53	13,54	48,13
12,54	13,55	48,16
12,55	13,56	48,19
12,56	13,57	48,22
12,57	13,58	48,25
12,58	13,59	48,28
12,59	13,60	48,31
12,60	13,61	48,34
12,61	13,62	48,37
12,62	13,63	48,40
12,63	13,64	48,42
12,64	13,65	48,45
12,65	13,66	48,48
12,66	13,67	48,51
12,67	13,68	48,54
12,68	13,69	48,57
12,69	13,70	48,60
12,70	13,71	48,63
12,71	13,72	48,66
12,72	13,73	48,69
12,73	13,74	48,71
12,74	13,75	48,74
12,75	13,76	48,77
12,76	13,77	48,80
12,77	13,78	48,83
12,78	13,79	48,86
12,79	13,80	48,89
12,80	13,81	48,92
12,81	13,82	48,95
12,82	13,83	48,97
12,83	13,84	49,00
12,84	13,85	49,03
12,85	13,86	49,06
12,86	13,87	49,09
12,87	13,88	49,12
12,88	13,89	49,15
12,89	13,90	49,18
12,90	13,91	49,20
12,91	13,92	49,23
12,92	13,93	49,26



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	49,29
12,94	13,95	49,32
12,95	13,96	49,35
12,96	13,97	49,38
12,97	13,98	49,40
12,98	13,99	49,43
12,99	14,00	49,46
13,00	14,01	49,49
13,01	14,02	49,52
13,02	14,03	49,55
13,03	14,04	49,58
13,04	14,05	49,60
13,05	14,06	49,63
13,06	14,07	49,66
13,07	14,08	49,69
13,08	14,09	49,72
13,09	14,10	49,75
13,10	14,11	49,77
13,11	14,12	49,80
13,12	14,13	49,83
13,13	14,14	49,86
13,14	14,15	49,89
13,15	14,16	49,92
13,16	14,17	49,94
13,17	14,18	49,97
13,18	14,19	50,00
13,19	14,20	50,03
13,20	14,21	50,06
13,21	14,22	50,09
13,22	14,23	50,11
13,23	14,24	50,14
13,24	14,25	50,17
13,25	14,26	50,20
13,26	14,27	50,23
13,27	14,28	50,25
13,28	14,29	50,28
13,29	14,30	50,31
13,30	14,31	50,34
13,31	14,32	50,37
13,32	14,33	50,39
13,33	14,34	50,42
13,34	14,35	50,45
13,35	14,36	50,48
13,36	14,37	50,51



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
13,37	14,38	50,53
13,38	14,39	50,56
13,39	14,40	50,59
13,40	14,41	50,62
13,41	14,42	50,65
13,42	14,43	50,67
13,43	14,44	50,70
13,44	14,45	50,73
13,45	14,46	50,76
13,46	14,47	50,79
13,47	14,48	50,81
13,48	14,49	50,84
13,49	14,50	50,87
13,50	14,51	50,90
13,51	14,52	50,92
13,52	14,53	50,95
13,53	14,54	50,98
13,54	14,55	51,01
13,55	14,56	51,04
13,56	14,57	51,06
13,57	14,58	51,09
13,58	14,59	51,12
13,59	14,60	51,15
13,60	14,61	51,17
13,61	14,62	51,20
13,62	14,63	51,23
13,63	14,64	51,26
13,64	14,65	51,28
13,65	14,66	51,31
13,66	14,67	51,34
13,67	14,68	51,37
13,68	14,69	51,39
13,69	14,70	51,42
13,70	14,71	51,45
13,71	14,72	51,48
13,72	14,73	51,50
13,73	14,74	51,53
13,74	14,75	51,56
13,75	14,76	51,59
13,76	14,77	51,61
13,77	14,78	51,64
13,78	14,79	51,67
13,79	14,80	51,70
13,80	14,81	51,72



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,81	14,82	51,75
13,82	14,83	51,78
13,83	14,84	51,81
13,84	14,85	51,83
13,85	14,86	51,86
13,86	14,87	51,89
13,87	14,88	51,91
13,88	14,89	51,94
13,89	14,90	51,97
13,90	14,91	52,00
13,91	14,92	52,02
13,92	14,93	52,05
13,93	14,94	52,08
13,94	14,95	52,11
13,95	14,96	52,13
13,96	14,97	52,16
13,97	14,98	52,19
13,98	14,99	52,21
13,99	15,00	52,24
14,00	15,01	52,27
14,01	15,02	52,30
14,02	15,03	52,32
14,03	15,04	52,35
14,04	15,05	52,38
14,05	15,06	52,40
14,06	15,07	52,43
14,07	15,08	52,46
14,08	15,09	52,48
14,09	15,10	52,51
14,10	15,11	52,54
14,11	15,12	52,56
14,12	15,13	52,59
14,13	15,14	52,62
14,14	15,15	52,65
14,15	15,16	52,67
14,16	15,17	52,70
14,17	15,18	52,73
14,18	15,19	52,75
14,19	15,20	52,78
14,20	15,21	52,81
14,21	15,22	52,83
14,22	15,23	52,86
14,23	15,24	52,89
14,24	15,25	52,91



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
14,25	15,26	52,94
14,26	15,27	52,97
14,27	15,28	52,99
14,28	15,29	53,02
14,29	15,30	53,05
14,30	15,31	53,07
14,31	15,32	53,10
14,32	15,33	53,13
14,33	15,34	53,15
14,34	15,35	53,18
14,35	15,36	53,21
14,36	15,37	53,23
14,37	15,38	53,26
14,38	15,39	53,29
14,39	15,40	53,31
14,40	15,41	53,34
14,41	15,42	53,37
14,42	15,43	53,39
14,43	15,44	53,42
14,44	15,45	53,45
14,45	15,46	53,47
14,46	15,47	53,50
14,47	15,48	53,53
14,48	15,49	53,55
14,49	15,50	53,58
14,50	15,51	53,61
14,51	15,52	53,63
14,52	15,53	53,66
14,53	15,54	53,68
14,54	15,55	53,71
14,55	15,56	53,74
14,56	15,57	53,76
14,57	15,58	53,79
14,58	15,59	53,82
14,59	15,60	53,84
14,60	15,61	53,87
14,61	15,62	53,89
14,62	15,63	53,92
14,63	15,64	53,95
14,64	15,65	53,97
14,65	15,66	54,00
14,66	15,67	54,03
14,67	15,68	54,05
14,68	15,69	54,08



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
14,69	15,70	54,10
14,70	15,71	54,13
14,71	15,72	54,16
14,72	15,73	54,18
14,73	15,74	54,21
14,74	15,75	54,24
14,75	15,76	54,26
14,76	15,77	54,29
14,77	15,78	54,31
14,78	15,79	54,34
14,79	15,80	54,37
14,80	15,81	54,39
14,81	15,82	54,42
14,82	15,83	54,44
14,83	15,84	54,47
14,84	15,85	54,50
14,85	15,86	54,52
14,86	15,87	54,55
14,87	15,88	54,57
14,88	15,89	54,60
14,89	15,90	54,63
14,90	15,91	54,65
14,91	15,92	54,68
14,92	15,93	54,70
14,93	15,94	54,73
14,94	15,95	54,76
14,95	15,96	54,78
14,96	15,97	54,81
14,97	15,98	54,83
14,98	15,99	54,86
14,99	16,00	54,88
15,00	16,01	54,91
15,01	16,02	54,94
15,02	16,03	54,96
15,03	16,04	54,99
15,04	16,05	55,01
15,05	16,06	55,04
15,06	16,07	55,06
15,07	16,08	55,09
15,08	16,09	55,12
15,09	16,10	55,14
15,10	16,11	55,17
15,11	16,12	55,19
15,12	16,13	55,22



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	55,24
15,14	16,15	55,27
15,15	16,16	55,30
15,16	16,17	55,32
15,17	16,18	55,35
15,18	16,19	55,37
15,19	16,20	55,40
15,20	16,21	55,42
15,21	16,22	55,45
15,22	16,23	55,47
15,23	16,24	55,50
15,24	16,25	55,53
15,25	16,26	55,55
15,26	16,27	55,58
15,27	16,28	55,60
15,28	16,29	55,63
15,29	16,30	55,65
15,30	16,31	55,68
15,31	16,32	55,70
15,32	16,33	55,73
15,33	16,34	55,75
15,34	16,35	55,78
15,35	16,36	55,81
15,36	16,37	55,83
15,37	16,38	55,86
15,38	16,39	55,88
15,39	16,40	55,91
15,40	16,41	55,93
15,41	16,42	55,96
15,42	16,43	55,98
15,43	16,44	56,01
15,44	16,45	56,03
15,45	16,46	56,06
15,46	16,47	56,08
15,47	16,48	56,11
15,48	16,49	56,13
15,49	16,50	56,16
15,50	16,51	56,18
15,51	16,52	56,21
15,52	16,53	56,23
15,53	16,54	56,26
15,54	16,55	56,29
15,55	16,56	56,31
15,56	16,57	56,34



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,57	16,58	56,36
15,58	16,59	56,39
15,59	16,60	56,41
15,60	16,61	56,44
15,61	16,62	56,46
15,62	16,63	56,49
15,63	16,64	56,51
15,64	16,65	56,54
15,65	16,66	56,56
15,66	16,67	56,59
15,67	16,68	56,61
15,68	16,69	56,64
15,69	16,70	56,66
15,70	16,71	56,69
15,71	16,72	56,71
15,72	16,73	56,74
15,73	16,74	56,76
15,74	16,75	56,79
15,75	16,76	56,81
15,76	16,77	56,84
15,77	16,78	56,86
15,78	16,79	56,89
15,79	16,80	56,91
15,80	16,81	56,94
15,81	16,82	56,96
15,82	16,83	56,99
15,83	16,84	57,01
15,84	16,85	57,03
15,85	16,86	57,06
15,86	16,87	57,08
15,87	16,88	57,11
15,88	16,89	57,13
15,89	16,90	57,16
15,90	16,91	57,18
15,91	16,92	57,21
15,92	16,93	57,23
15,93	16,94	57,26
15,94	16,95	57,28
15,95	16,96	57,31
15,96	16,97	57,33
15,97	16,98	57,36
15,98	16,99	57,38
15,99	17,00	57,41
16,00	17,01	57,43



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	57,45
16,02	17,03	57,48
16,03	17,04	57,50
16,04	17,05	57,53
16,05	17,06	57,55
16,06	17,07	57,58
16,07	17,08	57,60
16,08	17,09	57,63
16,09	17,10	57,65
16,10	17,11	57,68
16,11	17,12	57,70
16,12	17,13	57,73
16,13	17,14	57,75
16,14	17,15	57,77
16,15	17,16	57,80
16,16	17,17	57,82
16,17	17,18	57,85
16,18	17,19	57,87
16,19	17,20	57,90
16,20	17,21	57,92
16,21	17,22	57,95
16,22	17,23	57,97
16,23	17,24	57,99
16,24	17,25	58,02
16,25	17,26	58,04
16,26	17,27	58,07
16,27	17,28	58,09
16,28	17,29	58,12
16,29	17,30	58,14
16,30	17,31	58,16
16,31	17,32	58,19
16,32	17,33	58,21
16,33	17,34	58,24
16,34	17,35	58,26
16,35	17,36	58,29
16,36	17,37	58,31
16,37	17,38	58,33
16,38	17,39	58,36
16,39	17,40	58,38
16,40	17,41	58,41
16,41	17,42	58,43
16,42	17,43	58,46
16,43	17,44	58,48
16,44	17,45	58,50



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,45	17,46	58,53
16,46	17,47	58,55
16,47	17,48	58,58
16,48	17,49	58,60
16,49	17,50	58,62
16,50	17,51	58,65
16,51	17,52	58,67
16,52	17,53	58,70
16,53	17,54	58,72
16,54	17,55	58,74
16,55	17,56	58,77
16,56	17,57	58,79
16,57	17,58	58,82
16,58	17,59	58,84
16,59	17,60	58,87
16,60	17,61	58,89
16,61	17,62	58,91
16,62	17,63	58,94
16,63	17,64	58,96
16,64	17,65	58,99
16,65	17,66	59,01
16,66	17,67	59,03
16,67	17,68	59,06
16,68	17,69	59,08
16,69	17,70	59,10
16,70	17,71	59,13
16,71	17,72	59,15
16,72	17,73	59,18
16,73	17,74	59,20
16,74	17,75	59,22
16,75	17,76	59,25
16,76	17,77	59,27
16,77	17,78	59,30
16,78	17,79	59,32
16,79	17,80	59,34
16,80	17,81	59,37
16,81	17,82	59,39
16,82	17,83	59,41
16,83	17,84	59,44
16,84	17,85	59,46
16,85	17,86	59,49
16,86	17,87	59,51
16,87	17,88	59,53
16,88	17,89	59,56



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	59,58
16,90	17,91	59,60
16,91	17,92	59,63
16,92	17,93	59,65
16,93	17,94	59,68
16,94	17,95	59,70
16,95	17,96	59,72
16,96	17,97	59,75
16,97	17,98	59,77
16,98	17,99	59,79
16,99	18,00	59,82
17,00	18,01	59,84
17,01	18,02	59,86
17,02	18,03	59,89
17,03	18,04	59,91
17,04	18,05	59,94
17,05	18,06	59,96
17,06	18,07	59,98
17,07	18,08	60,01
17,08	18,09	60,03
17,09	18,10	60,05
17,10	18,11	60,08
17,11	18,12	60,10
17,12	18,13	60,12
17,13	18,14	60,15
17,14	18,15	60,17
17,15	18,16	60,19
17,16	18,17	60,22
17,17	18,18	60,24
17,18	18,19	60,26
17,19	18,20	60,29
17,20	18,21	60,31
17,21	18,22	60,33
17,22	18,23	60,36
17,23	18,24	60,38
17,24	18,25	60,40
17,25	18,26	60,43
17,26	18,27	60,45
17,27	18,28	60,47
17,28	18,29	60,50
17,29	18,30	60,52
17,30	18,31	60,54
17,31	18,32	60,57
17,32	18,33	60,59



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	60,61
17,34	18,35	60,64
17,35	18,36	60,66
17,36	18,37	60,68
17,37	18,38	60,71
17,38	18,39	60,73
17,39	18,40	60,75
17,40	18,41	60,78
17,41	18,42	60,80
17,42	18,43	60,82
17,43	18,44	60,85
17,44	18,45	60,87
17,45	18,46	60,89
17,46	18,47	60,92
17,47	18,48	60,94
17,48	18,49	60,96
17,49	18,50	60,99
17,50	18,51	61,01
17,51	18,52	61,03
17,52	18,53	61,05
17,53	18,54	61,08
17,54	18,55	61,10
17,55	18,56	61,12
17,56	18,57	61,15
17,57	18,58	61,17
17,58	18,59	61,19
17,59	18,60	61,22
17,60	18,61	61,24
17,61	18,62	61,26
17,62	18,63	61,28
17,63	18,64	61,31
17,64	18,65	61,33
17,65	18,66	61,35
17,66	18,67	61,38
17,67	18,68	61,40
17,68	18,69	61,42
17,69	18,70	61,45
17,70	18,71	61,47
17,71	18,72	61,49
17,72	18,73	61,51
17,73	18,74	61,54
17,74	18,75	61,56
17,75	18,76	61,58
17,76	18,77	61,61



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,77	18,78	61,63
17,78	18,79	61,65
17,79	18,80	61,67
17,80	18,81	61,70
17,81	18,82	61,72
17,82	18,83	61,74
17,83	18,84	61,77
17,84	18,85	61,79
17,85	18,86	61,81
17,86	18,87	61,83
17,87	18,88	61,86
17,88	18,89	61,88
17,89	18,90	61,90
17,90	18,91	61,92
17,91	18,92	61,95
17,92	18,93	61,97
17,93	18,94	61,99
17,94	18,95	62,02
17,95	18,96	62,04
17,96	18,97	62,06
17,97	18,98	62,08
17,98	18,99	62,11
17,99	19,00	62,13
18,00	19,01	62,15
18,01	19,02	62,17
18,02	19,03	62,20
18,03	19,04	62,22
18,04	19,05	62,24
18,05	19,06	62,26
18,06	19,07	62,29
18,07	19,08	62,31
18,08	19,09	62,33
18,09	19,10	62,36
18,10	19,11	62,38
18,11	19,12	62,40
18,12	19,13	62,42
18,13	19,14	62,45
18,14	19,15	62,47
18,15	19,16	62,49
18,16	19,17	62,51
18,17	19,18	62,54
18,18	19,19	62,56
18,19	19,20	62,58
18,20	19,21	62,60



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,21	19,22	62,63
18,22	19,23	62,65
18,23	19,24	62,67
18,24	19,25	62,69
18,25	19,26	62,72
18,26	19,27	62,74
18,27	19,28	62,76
18,28	19,29	62,78
18,29	19,30	62,80
18,30	19,31	62,83
18,31	19,32	62,85
18,32	19,33	62,87
18,33	19,34	62,89
18,34	19,35	62,92
18,35	19,36	62,94
18,36	19,37	62,96
18,37	19,38	62,98
18,38	19,39	63,01
18,39	19,40	63,03
18,40	19,41	63,05
18,41	19,42	63,07
18,42	19,43	63,09
18,43	19,44	63,12
18,44	19,45	63,14
18,45	19,46	63,16
18,46	19,47	63,18
18,47	19,48	63,21
18,48	19,49	63,23
18,49	19,50	63,25
18,50	19,51	63,27
18,51	19,52	63,29
18,52	19,53	63,32
18,53	19,54	63,34
18,54	19,55	63,36
18,55	19,56	63,38
18,56	19,57	63,41
18,57	19,58	63,43
18,58	19,59	63,45
18,59	19,60	63,47
18,60	19,61	63,49
18,61	19,62	63,52
18,62	19,63	63,54
18,63	19,64	63,56
18,64	19,65	63,58



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,65	19,66	63,60
18,66	19,67	63,63
18,67	19,68	63,65
18,68	19,69	63,67
18,69	19,70	63,69
18,70	19,71	63,71
18,71	19,72	63,74
18,72	19,73	63,76
18,73	19,74	63,78
18,74	19,75	63,80
18,75	19,76	63,82
18,76	19,77	63,85
18,77	19,78	63,87
18,78	19,79	63,89
18,79	19,80	63,91
18,80	19,81	63,93
18,81	19,82	63,96
18,82	19,83	63,98
18,83	19,84	64,00
18,84	19,85	64,02
18,85	19,86	64,04
18,86	19,87	64,07
18,87	19,88	64,09
18,88	19,89	64,11
18,89	19,90	64,13
18,90	19,91	64,15
18,91	19,92	64,18
18,92	19,93	64,20
18,93	19,94	64,22
18,94	19,95	64,24
18,95	19,96	64,26
18,96	19,97	64,28
18,97	19,98	64,31
18,98	19,99	64,33
18,99	20,00	64,35
19,00	20,01	64,37
19,01	20,02	64,39
19,02	20,03	64,42
19,03	20,04	64,44
19,04	20,05	64,46
19,05	20,06	64,48
19,06	20,07	64,50
19,07	20,08	64,52
19,08	20,09	64,55



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	64,57
19,10	20,11	64,59
19,11	20,12	64,61
19,12	20,13	64,63
19,13	20,14	64,65
19,14	20,15	64,68
19,15	20,16	64,70
19,16	20,17	64,72
19,17	20,18	64,74
19,18	20,19	64,76
19,19	20,20	64,78
19,20	20,21	64,81
19,21	20,22	64,83
19,22	20,23	64,85
19,23	20,24	64,87
19,24	20,25	64,89
19,25	20,26	64,91
19,26	20,27	64,94
19,27	20,28	64,96
19,28	20,29	64,98
19,29	20,30	65,00
19,30	20,31	65,02
19,31	20,32	65,04
19,32	20,33	65,06
19,33	20,34	65,09
19,34	20,35	65,11
19,35	20,36	65,13
19,36	20,37	65,15
19,37	20,38	65,17
19,38	20,39	65,19
19,39	20,40	65,21
19,40	20,41	65,24
19,41	20,42	65,26
19,42	20,43	65,28
19,43	20,44	65,30
19,44	20,45	65,32
19,45	20,46	65,34
19,46	20,47	65,36
19,47	20,48	65,39
19,48	20,49	65,41
19,49	20,50	65,43
19,50	20,51	65,45
19,51	20,52	65,47
19,52	20,53	65,49



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	65,51
19,54	20,55	65,54
19,55	20,56	65,56
19,56	20,57	65,58
19,57	20,58	65,60
19,58	20,59	65,62
19,59	20,60	65,64
19,60	20,61	65,66
19,61	20,62	65,68
19,62	20,63	65,71
19,63	20,64	65,73
19,64	20,65	65,75
19,65	20,66	65,77
19,66	20,67	65,79
19,67	20,68	65,81
19,68	20,69	65,83
19,69	20,70	65,85
19,70	20,71	65,88
19,71	20,72	65,90
19,72	20,73	65,92
19,73	20,74	65,94
19,74	20,75	65,96
19,75	20,76	65,98
19,76	20,77	66,00
19,77	20,78	66,02
19,78	20,79	66,05
19,79	20,80	66,07
19,80	20,81	66,09
19,81	20,82	66,11
19,82	20,83	66,13
19,83	20,84	66,15
19,84	20,85	66,17
19,85	20,86	66,19
19,86	20,87	66,21
19,87	20,88	66,24
19,88	20,89	66,26
19,89	20,90	66,28
19,90	20,91	66,30
19,91	20,92	66,32
19,92	20,93	66,34
19,93	20,94	66,36
19,94	20,95	66,38
19,95	20,96	66,40
19,96	20,97	66,42



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,97	20,98	66,45
19,98	20,99	66,47
19,99	21,00	66,49
20,00	21,01	66,51
20,01	21,02	66,53
20,02	21,03	66,55
20,03	21,04	66,57
20,04	21,05	66,59
20,05	21,06	66,61
20,06	21,07	66,63
20,07	21,08	66,66
20,08	21,09	66,68
20,09	21,10	66,70
20,10	21,11	66,72
20,11	21,12	66,74
20,12	21,13	66,76
20,13	21,14	66,78
20,14	21,15	66,80
20,15	21,16	66,82
20,16	21,17	66,84
20,17	21,18	66,86
20,18	21,19	66,88
20,19	21,20	66,91
20,20	21,21	66,93
20,21	21,22	66,95
20,22	21,23	66,97
20,23	21,24	66,99
20,24	21,25	67,01
20,25	21,26	67,03
20,26	21,27	67,05
20,27	21,28	67,07
20,28	21,29	67,09
20,29	21,30	67,11
20,30	21,31	67,13
20,31	21,32	67,15
20,32	21,33	67,18
20,33	21,34	67,20
20,34	21,35	67,22
20,35	21,36	67,24
20,36	21,37	67,26
20,37	21,38	67,28
20,38	21,39	67,30
20,39	21,40	67,32
20,40	21,41	67,34



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
20,41	21,42	67,36
20,42	21,43	67,38
20,43	21,44	67,40
20,44	21,45	67,42
20,45	21,46	67,44
20,46	21,47	67,47
20,47	21,48	67,49
20,48	21,49	67,51
20,49	21,50	67,53
20,50	21,51	67,55
20,51	21,52	67,57
20,52	21,53	67,59
20,53	21,54	67,61
20,54	21,55	67,63
20,55	21,56	67,65
20,56	21,57	67,67
20,57	21,58	67,69
20,58	21,59	67,71
20,59	21,60	67,73
20,60	21,61	67,75
20,61	21,62	67,77
20,62	21,63	67,79
20,63	21,64	67,81
20,64	21,65	67,84
20,65	21,66	67,86
20,66	21,67	67,88
20,67	21,68	67,90
20,68	21,69	67,92
20,69	21,70	67,94
20,70	21,71	67,96
20,71	21,72	67,98
20,72	21,73	68,00
20,73	21,74	68,02
20,74	21,75	68,04
20,75	21,76	68,06
20,76	21,77	68,08
20,77	21,78	68,10
20,78	21,79	68,12
20,79	21,80	68,14
20,80	21,81	68,16
20,81	21,82	68,18
20,82	21,83	68,20
20,83	21,84	68,22
20,84	21,85	68,24



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	68,26
20,86	21,87	68,28
20,87	21,88	68,30
20,88	21,89	68,32
20,89	21,90	68,35
20,90	21,91	68,37
20,91	21,92	68,39
20,92	21,93	68,41
20,93	21,94	68,43
20,94	21,95	68,45
20,95	21,96	68,47
20,96	21,97	68,49
20,97	21,98	68,51
20,98	21,99	68,53
20,99	22,00	68,55
21,00	22,01	68,57
21,01	22,02	68,59
21,02	22,03	68,61
21,03	22,04	68,63
21,04	22,05	68,65
21,05	22,06	68,67
21,06	22,07	68,69
21,07	22,08	68,71
21,08	22,09	68,73
21,09	22,10	68,75
21,10	22,11	68,77
21,11	22,12	68,79
21,12	22,13	68,81
21,13	22,14	68,83
21,14	22,15	68,85
21,15	22,16	68,87
21,16	22,17	68,89
21,17	22,18	68,91
21,18	22,19	68,93
21,19	22,20	68,95
21,20	22,21	68,97
21,21	22,22	68,99
21,22	22,23	69,01
21,23	22,24	69,03
21,24	22,25	69,05
21,25	22,26	69,07
21,26	22,27	69,09
21,27	22,28	69,11
21,28	22,29	69,13



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,29	22,30	69,15
21,30	22,31	69,17
21,31	22,32	69,19
21,32	22,33	69,21
21,33	22,34	69,23
21,34	22,35	69,25
21,35	22,36	69,27
21,36	22,37	69,29
21,37	22,38	69,31
21,38	22,39	69,33
21,39	22,40	69,35
21,40	22,41	69,37
21,41	22,42	69,39
21,42	22,43	69,41
21,43	22,44	69,43
21,44	22,45	69,45
21,45	22,46	69,47
21,46	22,47	69,49
21,47	22,48	69,51
21,48	22,49	69,53
21,49	22,50	69,55
21,50	22,51	69,57
21,51	22,52	69,59
21,52	22,53	69,61
21,53	22,54	69,63
21,54	22,55	69,65
21,55	22,56	69,67
21,56	22,57	69,69
21,57	22,58	69,71
21,58	22,59	69,73
21,59	22,60	69,75
21,60	22,61	69,77
21,61	22,62	69,79
21,62	22,63	69,81
21,63	22,64	69,83
21,64	22,65	69,85
21,65	22,66	69,87
21,66	22,67	69,89
21,67	22,68	69,91
21,68	22,69	69,93
21,69	22,70	69,95
21,70	22,71	69,97
21,71	22,72	69,99
21,72	22,73	70,01



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	70,03
21,74	22,75	70,05
21,75	22,76	70,07
21,76	22,77	70,09
21,77	22,78	70,11
21,78	22,79	70,12
21,79	22,80	70,14
21,80	22,81	70,16
21,81	22,82	70,18
21,82	22,83	70,20
21,83	22,84	70,22
21,84	22,85	70,24
21,85	22,86	70,26
21,86	22,87	70,28
21,87	22,88	70,30
21,88	22,89	70,32
21,89	22,90	70,34
21,90	22,91	70,36
21,91	22,92	70,38
21,92	22,93	70,40
21,93	22,94	70,42
21,94	22,95	70,44
21,95	22,96	70,46
21,96	22,97	70,48
21,97	22,98	70,50
21,98	22,99	70,52
21,99	23,00	70,54
22,00	23,01	70,56
22,01	23,02	70,58
22,02	23,03	70,60
22,03	23,04	70,62
22,04	23,05	70,63
22,05	23,06	70,65
22,06	23,07	70,67
22,07	23,08	70,69
22,08	23,09	70,71
22,09	23,10	70,73
22,10	23,11	70,75
22,11	23,12	70,77
22,12	23,13	70,79
22,13	23,14	70,81
22,14	23,15	70,83
22,15	23,16	70,85
22,16	23,17	70,87



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
22,17	23,18	70,89
22,18	23,19	70,91
22,19	23,20	70,93
22,20	23,21	70,95
22,21	23,22	70,97
22,22	23,23	70,98
22,23	23,24	71,00
22,24	23,25	71,02
22,25	23,26	71,04
22,26	23,27	71,06
22,27	23,28	71,08
22,28	23,29	71,10
22,29	23,30	71,12
22,30	23,31	71,14
22,31	23,32	71,16
22,32	23,33	71,18
22,33	23,34	71,20
22,34	23,35	71,22
22,35	23,36	71,24
22,36	23,37	71,26
22,37	23,38	71,28
22,38	23,39	71,29
22,39	23,40	71,31
22,40	23,41	71,33
22,41	23,42	71,35
22,42	23,43	71,37
22,43	23,44	71,39
22,44	23,45	71,41
22,45	23,46	71,43
22,46	23,47	71,45
22,47	23,48	71,47
22,48	23,49	71,49
22,49	23,50	71,51
22,50	23,51	71,53
22,51	23,52	71,54
22,52	23,53	71,56
22,53	23,54	71,58
22,54	23,55	71,60
22,55	23,56	71,62
22,56	23,57	71,64
22,57	23,58	71,66
22,58	23,59	71,68
22,59	23,60	71,70
22,60	23,61	71,72



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
22,61	23,62	71,74
22,62	23,63	71,76
22,63	23,64	71,77
22,64	23,65	71,79
22,65	23,66	71,81
22,66	23,67	71,83
22,67	23,68	71,85
22,68	23,69	71,87
22,69	23,70	71,89
22,70	23,71	71,91
22,71	23,72	71,93
22,72	23,73	71,95
22,73	23,74	71,97
22,74	23,75	71,98
22,75	23,76	72,00
22,76	23,77	72,02
22,77	23,78	72,04
22,78	23,79	72,06
22,79	23,80	72,08
22,80	23,81	72,10
22,81	23,82	72,12
22,82	23,83	72,14
22,83	23,84	72,16
22,84	23,85	72,18
22,85	23,86	72,19
22,86	23,87	72,21
22,87	23,88	72,23
22,88	23,89	72,25
22,89	23,90	72,27
22,90	23,91	72,29
22,91	23,92	72,31
22,92	23,93	72,33
22,93	23,94	72,35
22,94	23,95	72,36
22,95	23,96	72,38
22,96	23,97	72,40
22,97	23,98	72,42
22,98	23,99	72,44
22,99	24,00	72,46
23,00	24,01	72,48
23,01	24,02	72,50
23,02	24,03	72,52
23,03	24,04	72,54
23,04	24,05	72,55



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,05	24,06	72,57
23,06	24,07	72,59
23,07	24,08	72,61
23,08	24,09	72,63
23,09	24,10	72,65
23,10	24,11	72,67
23,11	24,12	72,69
23,12	24,13	72,70
23,13	24,14	72,72
23,14	24,15	72,74
23,15	24,16	72,76
23,16	24,17	72,78
23,17	24,18	72,80
23,18	24,19	72,82
23,19	24,20	72,84
23,20	24,21	72,86
23,21	24,22	72,87
23,22	24,23	72,89
23,23	24,24	72,91
23,24	24,25	72,93
23,25	24,26	72,95
23,26	24,27	72,97
23,27	24,28	72,99
23,28	24,29	73,01
23,29	24,30	73,02
23,30	24,31	73,04
23,31	24,32	73,06
23,32	24,33	73,08
23,33	24,34	73,10
23,34	24,35	73,12
23,35	24,36	73,14
23,36	24,37	73,16
23,37	24,38	73,17
23,38	24,39	73,19
23,39	24,40	73,21
23,40	24,41	73,23
23,41	24,42	73,25
23,42	24,43	73,27
23,43	24,44	73,29
23,44	24,45	73,30
23,45	24,46	73,32
23,46	24,47	73,34
23,47	24,48	73,36
23,48	24,49	73,38



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,49	24,50	73,40
23,50	24,51	73,42
23,51	24,52	73,43
23,52	24,53	73,45
23,53	24,54	73,47
23,54	24,55	73,49
23,55	24,56	73,51
23,56	24,57	73,53
23,57	24,58	73,55
23,58	24,59	73,56
23,59	24,60	73,58
23,60	24,61	73,60
23,61	24,62	73,62
23,62	24,63	73,64
23,63	24,64	73,66
23,64	24,65	73,68
23,65	24,66	73,69
23,66	24,67	73,71
23,67	24,68	73,73
23,68	24,69	73,75
23,69	24,70	73,77
23,70	24,71	73,79
23,71	24,72	73,81
23,72	24,73	73,82
23,73	24,74	73,84
23,74	24,75	73,86
23,75	24,76	73,88
23,76	24,77	73,90
23,77	24,78	73,92
23,78	24,79	73,93
23,79	24,80	73,95
23,80	24,81	73,97
23,81	24,82	73,99
23,82	24,83	74,01
23,83	24,84	74,03
23,84	24,85	74,04
23,85	24,86	74,06
23,86	24,87	74,08
23,87	24,88	74,10
23,88	24,89	74,12
23,89	24,90	74,14
23,90	24,91	74,16
23,91	24,92	74,17
23,92	24,93	74,19



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,93	24,94	74,21
23,94	24,95	74,23
23,95	24,96	74,25
23,96	24,97	74,27
23,97	24,98	74,28
23,98	24,99	74,30
23,99	25,00	74,32
24,00	25,01	74,34
24,01	25,02	74,36
24,02	25,03	74,38
24,03	25,04	74,39
24,04	25,05	74,41
24,05	25,06	74,43
24,06	25,07	74,45
24,07	25,08	74,47
24,08	25,09	74,48
24,09	25,10	74,50
24,10	25,11	74,52
24,11	25,12	74,54
24,12	25,13	74,56
24,13	25,14	74,58
24,14	25,15	74,59
24,15	25,16	74,61
24,16	25,17	74,63
24,17	25,18	74,65
24,18	25,19	74,67
24,19	25,20	74,69
24,20	25,21	74,70
24,21	25,22	74,72
24,22	25,23	74,74
24,23	25,24	74,76
24,24	25,25	74,78
24,25	25,26	74,79
24,26	25,27	74,81
24,27	25,28	74,83
24,28	25,29	74,85
24,29	25,30	74,87
24,30	25,31	74,89
24,31	25,32	74,90
24,32	25,33	74,92
24,33	25,34	74,94
24,34	25,35	74,96
24,35	25,36	74,98
24,36	25,37	74,99



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,37	25,38	75,01
24,38	25,39	75,03
24,39	25,40	75,05
24,40	25,41	75,07
24,41	25,42	75,08
24,42	25,43	75,10
24,43	25,44	75,12
24,44	25,45	75,14
24,45	25,46	75,16
24,46	25,47	75,17
24,47	25,48	75,19
24,48	25,49	75,21
24,49	25,50	75,23
24,50	25,51	75,25
24,51	25,52	75,26
24,52	25,53	75,28
24,53	25,54	75,30
24,54	25,55	75,32
24,55	25,56	75,34
24,56	25,57	75,35
24,57	25,58	75,37
24,58	25,59	75,39
24,59	25,60	75,41
24,60	25,61	75,43
24,61	25,62	75,44
24,62	25,63	75,46
24,63	25,64	75,48
24,64	25,65	75,50
24,65	25,66	75,52
24,66	25,67	75,53
24,67	25,68	75,55
24,68	25,69	75,57
24,69	25,70	75,59
24,70	25,71	75,61
24,71	25,72	75,62
24,72	25,73	75,64
24,73	25,74	75,66
24,74	25,75	75,68
24,75	25,76	75,70
24,76	25,77	75,71
24,77	25,78	75,73
24,78	25,79	75,75
24,79	25,80	75,77
24,80	25,81	75,78



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	75,80
24,82	25,83	75,82
24,83	25,84	75,84
24,84	25,85	75,86
24,85	25,86	75,87
24,86	25,87	75,89
24,87	25,88	75,91
24,88	25,89	75,93
24,89	25,90	75,94
24,90	25,91	75,96
24,91	25,92	75,98
24,92	25,93	76,00
24,93	25,94	76,02
24,94	25,95	76,03
24,95	25,96	76,05
24,96	25,97	76,07
24,97	25,98	76,09
24,98	25,99	76,10
24,99	26,00	76,12
25,00	26,01	76,14
25,01	26,02	76,16
25,02	26,03	76,18
25,03	26,04	76,19
25,04	26,05	76,21
25,05	26,06	76,23
25,06	26,07	76,25
25,07	26,08	76,26
25,08	26,09	76,28
25,09	26,10	76,30
25,10	26,11	76,32
25,11	26,12	76,34
25,12	26,13	76,35
25,13	26,14	76,37
25,14	26,15	76,39
25,15	26,16	76,41
25,16	26,17	76,42
25,17	26,18	76,44
25,18	26,19	76,46
25,19	26,20	76,48
25,20	26,21	76,49
25,21	26,22	76,51
25,22	26,23	76,53
25,23	26,24	76,55
25,24	26,25	76,56



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	76,58
25,26	26,27	76,60
25,27	26,28	76,62
25,28	26,29	76,64
25,29	26,30	76,65
25,30	26,31	76,67
25,31	26,32	76,69
25,32	26,33	76,71
25,33	26,34	76,72
25,34	26,35	76,74
25,35	26,36	76,76
25,36	26,37	76,78
25,37	26,38	76,79
25,38	26,39	76,81
25,39	26,40	76,83
25,40	26,41	76,85
25,41	26,42	76,86
25,42	26,43	76,88
25,43	26,44	76,90
25,44	26,45	76,92
25,45	26,46	76,93
25,46	26,47	76,95
25,47	26,48	76,97
25,48	26,49	76,99
25,49	26,50	77,00
25,50	26,51	77,02
25,51	26,52	77,04
25,52	26,53	77,06
25,53	26,54	77,07
25,54	26,55	77,09
25,55	26,56	77,11
25,56	26,57	77,13
25,57	26,58	77,14
25,58	26,59	77,16
25,59	26,60	77,18
25,60	26,61	77,20
25,61	26,62	77,21
25,62	26,63	77,23
25,63	26,64	77,25
25,64	26,65	77,26
25,65	26,66	77,28
25,66	26,67	77,30
25,67	26,68	77,32
25,68	26,69	77,33



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
25,69	26,70	77,35
25,70	26,71	77,37
25,71	26,72	77,39
25,72	26,73	77,40
25,73	26,74	77,42
25,74	26,75	77,44
25,75	26,76	77,46
25,76	26,77	77,47
25,77	26,78	77,49
25,78	26,79	77,51
25,79	26,80	77,53
25,80	26,81	77,54
25,81	26,82	77,56
25,82	26,83	77,58
25,83	26,84	77,59
25,84	26,85	77,61
25,85	26,86	77,63
25,86	26,87	77,65
25,87	26,88	77,66
25,88	26,89	77,68
25,89	26,90	77,70
25,90	26,91	77,72
25,91	26,92	77,73
25,92	26,93	77,75
25,93	26,94	77,77
25,94	26,95	77,78
25,95	26,96	77,80
25,96	26,97	77,82
25,97	26,98	77,84
25,98	26,99	77,85
25,99	27,00	77,87
26,00	27,01	77,89
26,01	27,02	77,90
26,02	27,03	77,92
26,03	27,04	77,94
26,04	27,05	77,96
26,05	27,06	77,97
26,06	27,07	77,99
26,07	27,08	78,01
26,08	27,09	78,03
26,09	27,10	78,04
26,10	27,11	78,06
26,11	27,12	78,08
26,12	27,13	78,09



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	78,11
26,14	27,15	78,13
26,15	27,16	78,15
26,16	27,17	78,16
26,17	27,18	78,18
26,18	27,19	78,20
26,19	27,20	78,21
26,20	27,21	78,23
26,21	27,22	78,25
26,22	27,23	78,27
26,23	27,24	78,28
26,24	27,25	78,30
26,25	27,26	78,32
26,26	27,27	78,33
26,27	27,28	78,35
26,28	27,29	78,37
26,29	27,30	78,38
26,30	27,31	78,40
26,31	27,32	78,42
26,32	27,33	78,44
26,33	27,34	78,45
26,34	27,35	78,47
26,35	27,36	78,49
26,36	27,37	78,50
26,37	27,38	78,52
26,38	27,39	78,54
26,39	27,40	78,55
26,40	27,41	78,57
26,41	27,42	78,59
26,42	27,43	78,61
26,43	27,44	78,62
26,44	27,45	78,64
26,45	27,46	78,66
26,46	27,47	78,67
26,47	27,48	78,69
26,48	27,49	78,71
26,49	27,50	78,72
26,50	27,51	78,74
26,51	27,52	78,76
26,52	27,53	78,78
26,53	27,54	78,79
26,54	27,55	78,81
26,55	27,56	78,83
26,56	27,57	78,84



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
26,57	27,58	78,86
26,58	27,59	78,88
26,59	27,60	78,89
26,60	27,61	78,91
26,61	27,62	78,93
26,62	27,63	78,94
26,63	27,64	78,96
26,64	27,65	78,98
26,65	27,66	79,00
26,66	27,67	79,01
26,67	27,68	79,03
26,68	27,69	79,05
26,69	27,70	79,06
26,70	27,71	79,08
26,71	27,72	79,10
26,72	27,73	79,11
26,73	27,74	79,13
26,74	27,75	79,15
26,75	27,76	79,16
26,76	27,77	79,18
26,77	27,78	79,20
26,78	27,79	79,21
26,79	27,80	79,23
26,80	27,81	79,25
26,81	27,82	79,26
26,82	27,83	79,28
26,83	27,84	79,30
26,84	27,85	79,32
26,85	27,86	79,33
26,86	27,87	79,35
26,87	27,88	79,37
26,88	27,89	79,38
26,89	27,90	79,40
26,90	27,91	79,42
26,91	27,92	79,43
26,92	27,93	79,45
26,93	27,94	79,47
26,94	27,95	79,48
26,95	27,96	79,50
26,96	27,97	79,52
26,97	27,98	79,53
26,98	27,99	79,55
26,99	28,00	79,57
27,00	28,01	79,58



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	79,60
27,02	28,03	79,62
27,03	28,04	79,63
27,04	28,05	79,65
27,05	28,06	79,67
27,06	28,07	79,68
27,07	28,08	79,70
27,08	28,09	79,72
27,09	28,10	79,73
27,10	28,11	79,75
27,11	28,12	79,77
27,12	28,13	79,78
27,13	28,14	79,80
27,14	28,15	79,82
27,15	28,16	79,83
27,16	28,17	79,85
27,17	28,18	79,87
27,18	28,19	79,88
27,19	28,20	79,90
27,20	28,21	79,92
27,21	28,22	79,93
27,22	28,23	79,95
27,23	28,24	79,97
27,24	28,25	79,98
27,25	28,26	80,00
27,26	28,27	80,02
27,27	28,28	80,03
27,28	28,29	80,05
27,29	28,30	80,07
27,30	28,31	80,08
27,31	28,32	80,10
27,32	28,33	80,12
27,33	28,34	80,13
27,34	28,35	80,15
27,35	28,36	80,16
27,36	28,37	80,18
27,37	28,38	80,20
27,38	28,39	80,21
27,39	28,40	80,23
27,40	28,41	80,25
27,41	28,42	80,26
27,42	28,43	80,28
27,43	28,44	80,30
27,44	28,45	80,31



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	80,33
27,46	28,47	80,35
27,47	28,48	80,36
27,48	28,49	80,38
27,49	28,50	80,40
27,50	28,51	80,41
27,51	28,52	80,43
27,52	28,53	80,45
27,53	28,54	80,46
27,54	28,55	80,48
27,55	28,56	80,49
27,56	28,57	80,51
27,57	28,58	80,53
27,58	28,59	80,54
27,59	28,60	80,56
27,60	28,61	80,58
27,61	28,62	80,59
27,62	28,63	80,61
27,63	28,64	80,63
27,64	28,65	80,64
27,65	28,66	80,66
27,66	28,67	80,68
27,67	28,68	80,69
27,68	28,69	80,71
27,69	28,70	80,72
27,70	28,71	80,74
27,71	28,72	80,76
27,72	28,73	80,77
27,73	28,74	80,79
27,74	28,75	80,81
27,75	28,76	80,82
27,76	28,77	80,84
27,77	28,78	80,86
27,78	28,79	80,87
27,79	28,80	80,89
27,80	28,81	80,90
27,81	28,82	80,92
27,82	28,83	80,94
27,83	28,84	80,95
27,84	28,85	80,97
27,85	28,86	80,99
27,86	28,87	81,00
27,87	28,88	81,02
27,88	28,89	81,03



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	81,05
27,90	28,91	81,07
27,91	28,92	81,08
27,92	28,93	81,10
27,93	28,94	81,12
27,94	28,95	81,13
27,95	28,96	81,15
27,96	28,97	81,16
27,97	28,98	81,18
27,98	28,99	81,20
27,99	29,00	81,21
28,00	29,01	81,23
28,01	29,02	81,25
28,02	29,03	81,26
28,03	29,04	81,28
28,04	29,05	81,29
28,05	29,06	81,31
28,06	29,07	81,33
28,07	29,08	81,34
28,08	29,09	81,36
28,09	29,10	81,38
28,10	29,11	81,39
28,11	29,12	81,41
28,12	29,13	81,42
28,13	29,14	81,44
28,14	29,15	81,46
28,15	29,16	81,47
28,16	29,17	81,49
28,17	29,18	81,50
28,18	29,19	81,52
28,19	29,20	81,54
28,20	29,21	81,55
28,21	29,22	81,57
28,22	29,23	81,59
28,23	29,24	81,60
28,24	29,25	81,62
28,25	29,26	81,63
28,26	29,27	81,65
28,27	29,28	81,67
28,28	29,29	81,68
28,29	29,30	81,70
28,30	29,31	81,71
28,31	29,32	81,73
28,32	29,33	81,75



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	81,76
28,34	29,35	81,78
28,35	29,36	81,79
28,36	29,37	81,81
28,37	29,38	81,83
28,38	29,39	81,84
28,39	29,40	81,86
28,40	29,41	81,87
28,41	29,42	81,89
28,42	29,43	81,91
28,43	29,44	81,92
28,44	29,45	81,94
28,45	29,46	81,96
28,46	29,47	81,97
28,47	29,48	81,99
28,48	29,49	82,00
28,49	29,50	82,02
28,50	29,51	82,04
28,51	29,52	82,05
28,52	29,53	82,07
28,53	29,54	82,08
28,54	29,55	82,10
28,55	29,56	82,11
28,56	29,57	82,13
28,57	29,58	82,15
28,58	29,59	82,16
28,59	29,60	82,18
28,60	29,61	82,19
28,61	29,62	82,21
28,62	29,63	82,23
28,63	29,64	82,24
28,64	29,65	82,26
28,65	29,66	82,27
28,66	29,67	82,29
28,67	29,68	82,31
28,68	29,69	82,32
28,69	29,70	82,34
28,70	29,71	82,35
28,71	29,72	82,37
28,72	29,73	82,39
28,73	29,74	82,40
28,74	29,75	82,42
28,75	29,76	82,43
28,76	29,77	82,45



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	82,47
28,78	29,79	82,48
28,79	29,80	82,50
28,80	29,81	82,51
28,81	29,82	82,53
28,82	29,83	82,54
28,83	29,84	82,56
28,84	29,85	82,58
28,85	29,86	82,59
28,86	29,87	82,61
28,87	29,88	82,62
28,88	29,89	82,64
28,89	29,90	82,66
28,90	29,91	82,67
28,91	29,92	82,69
28,92	29,93	82,70
28,93	29,94	82,72
28,94	29,95	82,73
28,95	29,96	82,75
28,96	29,97	82,77
28,97	29,98	82,78
28,98	29,99	82,80
28,99	30,00	82,81
29,00	30,01	82,83
29,01	30,02	82,84
29,02	30,03	82,86
29,03	30,04	82,88
29,04	30,05	82,89
29,05	30,06	82,91
29,06	30,07	82,92
29,07	30,08	82,94
29,08	30,09	82,96
29,09	30,10	82,97
29,10	30,11	82,99
29,11	30,12	83,00
29,12	30,13	83,02
29,13	30,14	83,03
29,14	30,15	83,05
29,15	30,16	83,07
29,16	30,17	83,08
29,17	30,18	83,10
29,18	30,19	83,11
29,19	30,20	83,13
29,20	30,21	83,14



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	83,16
29,22	30,23	83,17
29,23	30,24	83,19
29,24	30,25	83,21
29,25	30,26	83,22
29,26	30,27	83,24
29,27	30,28	83,25
29,28	30,29	83,27
29,29	30,30	83,28
29,30	30,31	83,30
29,31	30,32	83,32
29,32	30,33	83,33
29,33	30,34	83,35
29,34	30,35	83,36
29,35	30,36	83,38
29,36	30,37	83,39
29,37	30,38	83,41
29,38	30,39	83,43
29,39	30,40	83,44
29,40	30,41	83,46
29,41	30,42	83,47
29,42	30,43	83,49
29,43	30,44	83,50
29,44	30,45	83,52
29,45	30,46	83,53
29,46	30,47	83,55
29,47	30,48	83,57
29,48	30,49	83,58
29,49	30,50	83,60
29,50	30,51	83,61
29,51	30,52	83,63
29,52	30,53	83,64
29,53	30,54	83,66
29,54	30,55	83,67
29,55	30,56	83,69
29,56	30,57	83,71
29,57	30,58	83,72
29,58	30,59	83,74
29,59	30,60	83,75
29,60	30,61	83,77
29,61	30,62	83,78
29,62	30,63	83,80
29,63	30,64	83,81
29,64	30,65	83,83



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,65	30,66	83,84
29,66	30,67	83,86
29,67	30,68	83,88
29,68	30,69	83,89
29,69	30,70	83,91
29,70	30,71	83,92
29,71	30,72	83,94
29,72	30,73	83,95
29,73	30,74	83,97
29,74	30,75	83,98
29,75	30,76	84,00
29,76	30,77	84,01
29,77	30,78	84,03
29,78	30,79	84,05
29,79	30,80	84,06
29,80	30,81	84,08
29,81	30,82	84,09
29,82	30,83	84,11
29,83	30,84	84,12
29,84	30,85	84,14
29,85	30,86	84,15
29,86	30,87	84,17
29,87	30,88	84,18
29,88	30,89	84,20
29,89	30,90	84,21
29,90	30,91	84,23
29,91	30,92	84,25
29,92	30,93	84,26
29,93	30,94	84,28
29,94	30,95	84,29
29,95	30,96	84,31
29,96	30,97	84,32
29,97	30,98	84,34
29,98	30,99	84,35
29,99	31,00	84,37
30,00	31,01	84,38
30,01	31,02	84,40
30,02	31,03	84,41
30,03	31,04	84,43
30,04	31,05	84,45
30,05	31,06	84,46
30,06	31,07	84,48
30,07	31,08	84,49
30,08	31,09	84,51



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,09	31,10	84,52
30,10	31,11	84,54
30,11	31,12	84,55
30,12	31,13	84,57
30,13	31,14	84,58
30,14	31,15	84,60
30,15	31,16	84,61
30,16	31,17	84,63
30,17	31,18	84,64
30,18	31,19	84,66
30,19	31,20	84,67
30,20	31,21	84,69
30,21	31,22	84,70
30,22	31,23	84,72
30,23	31,24	84,74
30,24	31,25	84,75
30,25	31,26	84,77
30,26	31,27	84,78
30,27	31,28	84,80
30,28	31,29	84,81
30,29	31,30	84,83
30,30	31,31	84,84
30,31	31,32	84,86
30,32	31,33	84,87
30,33	31,34	84,89
30,34	31,35	84,90
30,35	31,36	84,92
30,36	31,37	84,93
30,37	31,38	84,95
30,38	31,39	84,96
30,39	31,40	84,98
30,40	31,41	84,99
30,41	31,42	85,01
30,42	31,43	85,02
30,43	31,44	85,04
30,44	31,45	85,05
30,45	31,46	85,07
30,46	31,47	85,08
30,47	31,48	85,10
30,48	31,49	85,11
30,49	31,50	85,13
30,50	31,51	85,14
30,51	31,52	85,16
30,52	31,53	85,18



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	85,19
30,54	31,55	85,21
30,55	31,56	85,22
30,56	31,57	85,24
30,57	31,58	85,25
30,58	31,59	85,27
30,59	31,60	85,28
30,60	31,61	85,30
30,61	31,62	85,31
30,62	31,63	85,33
30,63	31,64	85,34
30,64	31,65	85,36
30,65	31,66	85,37
30,66	31,67	85,39
30,67	31,68	85,40
30,68	31,69	85,42
30,69	31,70	85,43
30,70	31,71	85,45
30,71	31,72	85,46
30,72	31,73	85,48
30,73	31,74	85,49
30,74	31,75	85,51
30,75	31,76	85,52
30,76	31,77	85,54
30,77	31,78	85,55
30,78	31,79	85,57
30,79	31,80	85,58
30,80	31,81	85,60
30,81	31,82	85,61
30,82	31,83	85,63
30,83	31,84	85,64
30,84	31,85	85,66
30,85	31,86	85,67
30,86	31,87	85,69
30,87	31,88	85,70
30,88	31,89	85,72
30,89	31,90	85,73
30,90	31,91	85,75
30,91	31,92	85,76
30,92	31,93	85,78
30,93	31,94	85,79
30,94	31,95	85,81
30,95	31,96	85,82
30,96	31,97	85,84



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,97	31,98	85,85
30,98	31,99	85,87
30,99	32,00	85,88
31,00	32,01	85,90
31,01	32,02	85,91
31,02	32,03	85,93
31,03	32,04	85,94
31,04	32,05	85,95
31,05	32,06	85,97
31,06	32,07	85,98
31,07	32,08	86,00
31,08	32,09	86,01
31,09	32,10	86,03
31,10	32,11	86,04
31,11	32,12	86,06
31,12	32,13	86,07
31,13	32,14	86,09
31,14	32,15	86,10
31,15	32,16	86,12
31,16	32,17	86,13
31,17	32,18	86,15
31,18	32,19	86,16
31,19	32,20	86,18
31,20	32,21	86,19
31,21	32,22	86,21
31,22	32,23	86,22
31,23	32,24	86,24
31,24	32,25	86,25
31,25	32,26	86,27
31,26	32,27	86,28
31,27	32,28	86,30
31,28	32,29	86,31
31,29	32,30	86,33
31,30	32,31	86,34
31,31	32,32	86,36
31,32	32,33	86,37
31,33	32,34	86,38
31,34	32,35	86,40
31,35	32,36	86,41
31,36	32,37	86,43
31,37	32,38	86,44
31,38	32,39	86,46
31,39	32,40	86,47
31,40	32,41	86,49



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	86,50
31,42	32,43	86,52
31,43	32,44	86,53
31,44	32,45	86,55
31,45	32,46	86,56
31,46	32,47	86,58
31,47	32,48	86,59
31,48	32,49	86,61
31,49	32,50	86,62
31,50	32,51	86,64
31,51	32,52	86,65
31,52	32,53	86,66
31,53	32,54	86,68
31,54	32,55	86,69
31,55	32,56	86,71
31,56	32,57	86,72
31,57	32,58	86,74
31,58	32,59	86,75
31,59	32,60	86,77
31,60	32,61	86,78
31,61	32,62	86,80
31,62	32,63	86,81
31,63	32,64	86,83
31,64	32,65	86,84
31,65	32,66	86,86
31,66	32,67	86,87
31,67	32,68	86,88
31,68	32,69	86,90
31,69	32,70	86,91
31,70	32,71	86,93
31,71	32,72	86,94
31,72	32,73	86,96
31,73	32,74	86,97
31,74	32,75	86,99
31,75	32,76	87,00
31,76	32,77	87,02
31,77	32,78	87,03
31,78	32,79	87,05
31,79	32,80	87,06
31,80	32,81	87,07
31,81	32,82	87,09
31,82	32,83	87,10
31,83	32,84	87,12
31,84	32,85	87,13



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	87,15
31,86	32,87	87,16
31,87	32,88	87,18
31,88	32,89	87,19
31,89	32,90	87,21
31,90	32,91	87,22
31,91	32,92	87,23
31,92	32,93	87,25
31,93	32,94	87,26
31,94	32,95	87,28
31,95	32,96	87,29
31,96	32,97	87,31
31,97	32,98	87,32
31,98	32,99	87,34
31,99	33,00	87,35
32,00	33,01	87,36
32,01	33,02	87,38
32,02	33,03	87,39
32,03	33,04	87,41
32,04	33,05	87,42
32,05	33,06	87,44
32,06	33,07	87,45
32,07	33,08	87,47
32,08	33,09	87,48
32,09	33,10	87,49
32,10	33,11	87,51
32,11	33,12	87,52
32,12	33,13	87,54
32,13	33,14	87,55
32,14	33,15	87,57
32,15	33,16	87,58
32,16	33,17	87,60
32,17	33,18	87,61
32,18	33,19	87,62
32,19	33,20	87,64
32,20	33,21	87,65
32,21	33,22	87,67
32,22	33,23	87,68
32,23	33,24	87,70
32,24	33,25	87,71
32,25	33,26	87,73
32,26	33,27	87,74
32,27	33,28	87,75
32,28	33,29	87,77



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	87,78
32,30	33,31	87,80
32,31	33,32	87,81
32,32	33,33	87,83
32,33	33,34	87,84
32,34	33,35	87,85
32,35	33,36	87,87
32,36	33,37	87,88
32,37	33,38	87,90
32,38	33,39	87,91
32,39	33,40	87,93
32,40	33,41	87,94
32,41	33,42	87,96
32,42	33,43	87,97
32,43	33,44	87,98
32,44	33,45	88,00
32,45	33,46	88,01
32,46	33,47	88,03
32,47	33,48	88,04
32,48	33,49	88,06
32,49	33,50	88,07
32,50	33,51	88,08
32,51	33,52	88,10
32,52	33,53	88,11
32,53	33,54	88,13
32,54	33,55	88,14
32,55	33,56	88,16
32,56	33,57	88,17
32,57	33,58	88,18
32,58	33,59	88,20
32,59	33,60	88,21
32,60	33,61	88,23
32,61	33,62	88,24
32,62	33,63	88,26
32,63	33,64	88,27
32,64	33,65	88,28
32,65	33,66	88,30
32,66	33,67	88,31
32,67	33,68	88,33
32,68	33,69	88,34
32,69	33,70	88,35
32,70	33,71	88,37
32,71	33,72	88,38
32,72	33,73	88,40



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,73	33,74	88,41
32,74	33,75	88,43
32,75	33,76	88,44
32,76	33,77	88,45
32,77	33,78	88,47
32,78	33,79	88,48
32,79	33,80	88,50
32,80	33,81	88,51
32,81	33,82	88,52
32,82	33,83	88,54
32,83	33,84	88,55
32,84	33,85	88,57
32,85	33,86	88,58
32,86	33,87	88,60
32,87	33,88	88,61
32,88	33,89	88,62
32,89	33,90	88,64
32,90	33,91	88,65
32,91	33,92	88,67
32,92	33,93	88,68
32,93	33,94	88,69
32,94	33,95	88,71
32,95	33,96	88,72
32,96	33,97	88,74
32,97	33,98	88,75
32,98	33,99	88,76
32,99	34,00	88,78
33,00	34,01	88,79
33,01	34,02	88,81
33,02	34,03	88,82
33,03	34,04	88,84
33,04	34,05	88,85
33,05	34,06	88,86
33,06	34,07	88,88
33,07	34,08	88,89
33,08	34,09	88,91
33,09	34,10	88,92
33,10	34,11	88,93
33,11	34,12	88,95
33,12	34,13	88,96
33,13	34,14	88,98
33,14	34,15	88,99
33,15	34,16	89,00
33,16	34,17	89,02



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
33,17	34,18	89,03
33,18	34,19	89,05
33,19	34,20	89,06
33,20	34,21	89,07
33,21	34,22	89,09
33,22	34,23	89,10
33,23	34,24	89,12
33,24	34,25	89,13
33,25	34,26	89,14
33,26	34,27	89,16
33,27	34,28	89,17
33,28	34,29	89,19
33,29	34,30	89,20
33,30	34,31	89,21
33,31	34,32	89,23
33,32	34,33	89,24
33,33	34,34	89,26
33,34	34,35	89,27
33,35	34,36	89,28
33,36	34,37	89,30
33,37	34,38	89,31
33,38	34,39	89,32
33,39	34,40	89,34
33,40	34,41	89,35
33,41	34,42	89,37
33,42	34,43	89,38
33,43	34,44	89,39
33,44	34,45	89,41
33,45	34,46	89,42
33,46	34,47	89,44
33,47	34,48	89,45
33,48	34,49	89,46
33,49	34,50	89,48
33,50	34,51	89,49
33,51	34,52	89,51
33,52	34,53	89,52
33,53	34,54	89,53
33,54	34,55	89,55
33,55	34,56	89,56
33,56	34,57	89,57
33,57	34,58	89,59
33,58	34,59	89,60
33,59	34,60	89,62
33,60	34,61	89,63



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
33,61	34,62	89,64
33,62	34,63	89,66
33,63	34,64	89,67
33,64	34,65	89,69
33,65	34,66	89,70
33,66	34,67	89,71
33,67	34,68	89,73
33,68	34,69	89,74
33,69	34,70	89,75
33,70	34,71	89,77
33,71	34,72	89,78
33,72	34,73	89,80
33,73	34,74	89,81
33,74	34,75	89,82
33,75	34,76	89,84
33,76	34,77	89,85
33,77	34,78	89,86
33,78	34,79	89,88
33,79	34,80	89,89
33,80	34,81	89,91
33,81	34,82	89,92
33,82	34,83	89,93
33,83	34,84	89,95
33,84	34,85	89,96
33,85	34,86	89,97
33,86	34,87	89,99
33,87	34,88	90,00
33,88	34,89	90,02
33,89	34,90	90,03
33,90	34,91	90,04
33,91	34,92	90,06
33,92	34,93	90,07
33,93	34,94	90,08
33,94	34,95	90,10
33,95	34,96	90,11
33,96	34,97	90,12
33,97	34,98	90,14
33,98	34,99	90,15
33,99	35,00	90,17
34,00	35,01	90,18
34,01	35,02	90,19
34,02	35,03	90,21
34,03	35,04	90,22
34,04	35,05	90,23



R413A		
V1.0_R413A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,05	35,06	90,25
34,06	35,07	90,26
34,07	35,08	90,28
34,08	35,09	90,29
34,09	35,10	90,30
34,10	35,11	90,32
34,11	35,12	90,33