



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-57,72
-0,70	0,31	-57,18
-0,69	0,32	-56,66
-0,68	0,33	-56,15
-0,67	0,34	-55,65
-0,66	0,35	-55,17
-0,65	0,36	-54,70
-0,64	0,37	-54,23
-0,63	0,38	-53,78
-0,62	0,39	-53,34
-0,61	0,40	-52,90
-0,60	0,41	-52,48
-0,59	0,42	-52,06
-0,58	0,43	-51,65
-0,57	0,44	-51,25
-0,56	0,45	-50,86
-0,55	0,46	-50,47
-0,54	0,47	-50,09
-0,53	0,48	-49,71
-0,52	0,49	-49,35
-0,51	0,50	-48,98
-0,50	0,51	-48,63
-0,49	0,52	-48,28
-0,48	0,53	-47,93
-0,47	0,54	-47,59
-0,46	0,55	-47,26
-0,45	0,56	-46,93
-0,44	0,57	-46,60
-0,43	0,58	-46,28
-0,42	0,59	-45,96
-0,41	0,60	-45,65
-0,40	0,61	-45,34
-0,39	0,62	-45,04
-0,38	0,63	-44,74
-0,37	0,64	-44,44
-0,36	0,65	-44,15
-0,35	0,66	-43,86
-0,34	0,67	-43,58
-0,33	0,68	-43,29
-0,32	0,69	-43,01
-0,31	0,70	-42,74
-0,30	0,71	-42,47
-0,29	0,72	-42,20
-0,28	0,73	-41,93



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-41,67
-0,26	0,75	-41,40
-0,25	0,76	-41,15
-0,24	0,77	-40,89
-0,23	0,78	-40,64
-0,22	0,79	-40,39
-0,21	0,80	-40,14
-0,20	0,81	-39,89
-0,19	0,82	-39,65
-0,18	0,83	-39,41
-0,17	0,84	-39,17
-0,16	0,85	-38,94
-0,15	0,86	-38,70
-0,14	0,87	-38,47
-0,13	0,88	-38,24
-0,12	0,89	-38,01
-0,11	0,90	-37,79
-0,10	0,91	-37,56
-0,09	0,92	-37,34
-0,08	0,93	-37,12
-0,07	0,94	-36,91
-0,06	0,95	-36,69
-0,05	0,96	-36,47
-0,04	0,97	-36,26
-0,03	0,98	-36,05
-0,02	0,99	-35,84
-0,01	1,00	-35,63
0,00	1,01	-35,43
0,01	1,02	-35,22
0,02	1,03	-35,02
0,03	1,04	-34,82
0,04	1,05	-34,62
0,05	1,06	-34,42
0,06	1,07	-34,23
0,07	1,08	-34,03
0,08	1,09	-33,84
0,09	1,10	-33,65
0,10	1,11	-33,45
0,11	1,12	-33,27
0,12	1,13	-33,08
0,13	1,14	-32,89
0,14	1,15	-32,70
0,15	1,16	-32,52
0,16	1,17	-32,34



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,17	1,18	-32,15
0,18	1,19	-31,97
0,19	1,20	-31,79
0,20	1,21	-31,62
0,21	1,22	-31,44
0,22	1,23	-31,26
0,23	1,24	-31,09
0,24	1,25	-30,91
0,25	1,26	-30,74
0,26	1,27	-30,57
0,27	1,28	-30,40
0,28	1,29	-30,23
0,29	1,30	-30,06
0,30	1,31	-29,89
0,31	1,32	-29,73
0,32	1,33	-29,56
0,33	1,34	-29,40
0,34	1,35	-29,23
0,35	1,36	-29,07
0,36	1,37	-28,91
0,37	1,38	-28,75
0,38	1,39	-28,59
0,39	1,40	-28,43
0,40	1,41	-28,27
0,41	1,42	-28,11
0,42	1,43	-27,96
0,43	1,44	-27,80
0,44	1,45	-27,65
0,45	1,46	-27,49
0,46	1,47	-27,34
0,47	1,48	-27,19
0,48	1,49	-27,04
0,49	1,50	-26,89
0,50	1,51	-26,74
0,51	1,52	-26,59
0,52	1,53	-26,44
0,53	1,54	-26,29
0,54	1,55	-26,14
0,55	1,56	-26,00
0,56	1,57	-25,85
0,57	1,58	-25,71
0,58	1,59	-25,56
0,59	1,60	-25,42
0,60	1,61	-25,28



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,61	1,62	-25,14
0,62	1,63	-24,99
0,63	1,64	-24,85
0,64	1,65	-24,71
0,65	1,66	-24,58
0,66	1,67	-24,44
0,67	1,68	-24,30
0,68	1,69	-24,16
0,69	1,70	-24,03
0,70	1,71	-23,89
0,71	1,72	-23,75
0,72	1,73	-23,62
0,73	1,74	-23,49
0,74	1,75	-23,35
0,75	1,76	-23,22
0,76	1,77	-23,09
0,77	1,78	-22,95
0,78	1,79	-22,82
0,79	1,80	-22,69
0,80	1,81	-22,56
0,81	1,82	-22,43
0,82	1,83	-22,30
0,83	1,84	-22,18
0,84	1,85	-22,05
0,85	1,86	-21,92
0,86	1,87	-21,79
0,87	1,88	-21,67
0,88	1,89	-21,54
0,89	1,90	-21,42
0,90	1,91	-21,29
0,91	1,92	-21,17
0,92	1,93	-21,04
0,93	1,94	-20,92
0,94	1,95	-20,80
0,95	1,96	-20,68
0,96	1,97	-20,55
0,97	1,98	-20,43
0,98	1,99	-20,31
0,99	2,00	-20,19
1,00	2,01	-20,07
1,01	2,02	-19,95
1,02	2,03	-19,83
1,03	2,04	-19,71
1,04	2,05	-19,60



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,05	2,06	-19,48
1,06	2,07	-19,36
1,07	2,08	-19,25
1,08	2,09	-19,13
1,09	2,10	-19,01
1,10	2,11	-18,90
1,11	2,12	-18,78
1,12	2,13	-18,67
1,13	2,14	-18,55
1,14	2,15	-18,44
1,15	2,16	-18,33
1,16	2,17	-18,21
1,17	2,18	-18,10
1,18	2,19	-17,99
1,19	2,20	-17,88
1,20	2,21	-17,77
1,21	2,22	-17,66
1,22	2,23	-17,54
1,23	2,24	-17,43
1,24	2,25	-17,32
1,25	2,26	-17,21
1,26	2,27	-17,11
1,27	2,28	-17,00
1,28	2,29	-16,89
1,29	2,30	-16,78
1,30	2,31	-16,67
1,31	2,32	-16,57
1,32	2,33	-16,46
1,33	2,34	-16,35
1,34	2,35	-16,25
1,35	2,36	-16,14
1,36	2,37	-16,04
1,37	2,38	-15,93
1,38	2,39	-15,83
1,39	2,40	-15,72
1,40	2,41	-15,62
1,41	2,42	-15,51
1,42	2,43	-15,41
1,43	2,44	-15,31
1,44	2,45	-15,20
1,45	2,46	-15,10
1,46	2,47	-15,00
1,47	2,48	-14,90
1,48	2,49	-14,80



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,49	2,50	-14,69
1,50	2,51	-14,59
1,51	2,52	-14,49
1,52	2,53	-14,39
1,53	2,54	-14,29
1,54	2,55	-14,19
1,55	2,56	-14,09
1,56	2,57	-13,99
1,57	2,58	-13,90
1,58	2,59	-13,80
1,59	2,60	-13,70
1,60	2,61	-13,60
1,61	2,62	-13,50
1,62	2,63	-13,41
1,63	2,64	-13,31
1,64	2,65	-13,21
1,65	2,66	-13,12
1,66	2,67	-13,02
1,67	2,68	-12,92
1,68	2,69	-12,83
1,69	2,70	-12,73
1,70	2,71	-12,64
1,71	2,72	-12,54
1,72	2,73	-12,45
1,73	2,74	-12,35
1,74	2,75	-12,26
1,75	2,76	-12,17
1,76	2,77	-12,07
1,77	2,78	-11,98
1,78	2,79	-11,89
1,79	2,80	-11,79
1,80	2,81	-11,70
1,81	2,82	-11,61
1,82	2,83	-11,52
1,83	2,84	-11,42
1,84	2,85	-11,33
1,85	2,86	-11,24
1,86	2,87	-11,15
1,87	2,88	-11,06
1,88	2,89	-10,97
1,89	2,90	-10,88
1,90	2,91	-10,79
1,91	2,92	-10,70
1,92	2,93	-10,61



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,93	2,94	-10,52
1,94	2,95	-10,43
1,95	2,96	-10,34
1,96	2,97	-10,25
1,97	2,98	-10,16
1,98	2,99	-10,08
1,99	3,00	-9,99
2,00	3,01	-9,90
2,01	3,02	-9,81
2,02	3,03	-9,73
2,03	3,04	-9,64
2,04	3,05	-9,55
2,05	3,06	-9,47
2,06	3,07	-9,38
2,07	3,08	-9,29
2,08	3,09	-9,21
2,09	3,10	-9,12
2,10	3,11	-9,04
2,11	3,12	-8,95
2,12	3,13	-8,86
2,13	3,14	-8,78
2,14	3,15	-8,70
2,15	3,16	-8,61
2,16	3,17	-8,53
2,17	3,18	-8,44
2,18	3,19	-8,36
2,19	3,20	-8,27
2,20	3,21	-8,19
2,21	3,22	-8,11
2,22	3,23	-8,02
2,23	3,24	-7,94
2,24	3,25	-7,86
2,25	3,26	-7,78
2,26	3,27	-7,69
2,27	3,28	-7,61
2,28	3,29	-7,53
2,29	3,30	-7,45
2,30	3,31	-7,37
2,31	3,32	-7,29
2,32	3,33	-7,20
2,33	3,34	-7,12
2,34	3,35	-7,04
2,35	3,36	-6,96
2,36	3,37	-6,88



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	-6,80
2,38	3,39	-6,72
2,39	3,40	-6,64
2,40	3,41	-6,56
2,41	3,42	-6,48
2,42	3,43	-6,40
2,43	3,44	-6,32
2,44	3,45	-6,24
2,45	3,46	-6,17
2,46	3,47	-6,09
2,47	3,48	-6,01
2,48	3,49	-5,93
2,49	3,50	-5,85
2,50	3,51	-5,77
2,51	3,52	-5,70
2,52	3,53	-5,62
2,53	3,54	-5,54
2,54	3,55	-5,46
2,55	3,56	-5,39
2,56	3,57	-5,31
2,57	3,58	-5,23
2,58	3,59	-5,16
2,59	3,60	-5,08
2,60	3,61	-5,00
2,61	3,62	-4,93
2,62	3,63	-4,85
2,63	3,64	-4,77
2,64	3,65	-4,70
2,65	3,66	-4,62
2,66	3,67	-4,55
2,67	3,68	-4,47
2,68	3,69	-4,40
2,69	3,70	-4,32
2,70	3,71	-4,25
2,71	3,72	-4,17
2,72	3,73	-4,10
2,73	3,74	-4,02
2,74	3,75	-3,95
2,75	3,76	-3,88
2,76	3,77	-3,80
2,77	3,78	-3,73
2,78	3,79	-3,66
2,79	3,80	-3,58
2,80	3,81	-3,51



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
2,81	3,82	-3,44
2,82	3,83	-3,36
2,83	3,84	-3,29
2,84	3,85	-3,22
2,85	3,86	-3,14
2,86	3,87	-3,07
2,87	3,88	-3,00
2,88	3,89	-2,93
2,89	3,90	-2,86
2,90	3,91	-2,78
2,91	3,92	-2,71
2,92	3,93	-2,64
2,93	3,94	-2,57
2,94	3,95	-2,50
2,95	3,96	-2,43
2,96	3,97	-2,36
2,97	3,98	-2,29
2,98	3,99	-2,21
2,99	4,00	-2,14
3,00	4,01	-2,07
3,01	4,02	-2,00
3,02	4,03	-1,93
3,03	4,04	-1,86
3,04	4,05	-1,79
3,05	4,06	-1,72
3,06	4,07	-1,65
3,07	4,08	-1,58
3,08	4,09	-1,51
3,09	4,10	-1,45
3,10	4,11	-1,38
3,11	4,12	-1,31
3,12	4,13	-1,24
3,13	4,14	-1,17
3,14	4,15	-1,10
3,15	4,16	-1,03
3,16	4,17	-0,96
3,17	4,18	-0,90
3,18	4,19	-0,83
3,19	4,20	-0,76
3,20	4,21	-0,69
3,21	4,22	-0,62
3,22	4,23	-0,56
3,23	4,24	-0,49
3,24	4,25	-0,42



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
3,25	4,26	-0,35
3,26	4,27	-0,29
3,27	4,28	-0,22
3,28	4,29	-0,15
3,29	4,30	-0,09
3,30	4,31	-0,02
3,31	4,32	0,05
3,32	4,33	0,11
3,33	4,34	0,18
3,34	4,35	0,25
3,35	4,36	0,31
3,36	4,37	0,38
3,37	4,38	0,44
3,38	4,39	0,51
3,39	4,40	0,58
3,40	4,41	0,64
3,41	4,42	0,71
3,42	4,43	0,77
3,43	4,44	0,84
3,44	4,45	0,90
3,45	4,46	0,97
3,46	4,47	1,03
3,47	4,48	1,10
3,48	4,49	1,16
3,49	4,50	1,23
3,50	4,51	1,29
3,51	4,52	1,35
3,52	4,53	1,42
3,53	4,54	1,48
3,54	4,55	1,55
3,55	4,56	1,61
3,56	4,57	1,67
3,57	4,58	1,74
3,58	4,59	1,80
3,59	4,60	1,86
3,60	4,61	1,93
3,61	4,62	1,99
3,62	4,63	2,05
3,63	4,64	2,12
3,64	4,65	2,18
3,65	4,66	2,24
3,66	4,67	2,31
3,67	4,68	2,37
3,68	4,69	2,43



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,69	4,70	2,49
3,70	4,71	2,56
3,71	4,72	2,62
3,72	4,73	2,68
3,73	4,74	2,74
3,74	4,75	2,80
3,75	4,76	2,87
3,76	4,77	2,93
3,77	4,78	2,99
3,78	4,79	3,05
3,79	4,80	3,11
3,80	4,81	3,17
3,81	4,82	3,24
3,82	4,83	3,30
3,83	4,84	3,36
3,84	4,85	3,42
3,85	4,86	3,48
3,86	4,87	3,54
3,87	4,88	3,60
3,88	4,89	3,66
3,89	4,90	3,72
3,90	4,91	3,78
3,91	4,92	3,84
3,92	4,93	3,90
3,93	4,94	3,96
3,94	4,95	4,02
3,95	4,96	4,08
3,96	4,97	4,14
3,97	4,98	4,20
3,98	4,99	4,26
3,99	5,00	4,32
4,00	5,01	4,38
4,01	5,02	4,44
4,02	5,03	4,50
4,03	5,04	4,56
4,04	5,05	4,62
4,05	5,06	4,68
4,06	5,07	4,74
4,07	5,08	4,79
4,08	5,09	4,85
4,09	5,10	4,91
4,10	5,11	4,97
4,11	5,12	5,03
4,12	5,13	5,09



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	5,15
4,14	5,15	5,20
4,15	5,16	5,26
4,16	5,17	5,32
4,17	5,18	5,38
4,18	5,19	5,44
4,19	5,20	5,49
4,20	5,21	5,55
4,21	5,22	5,61
4,22	5,23	5,67
4,23	5,24	5,72
4,24	5,25	5,78
4,25	5,26	5,84
4,26	5,27	5,90
4,27	5,28	5,95
4,28	5,29	6,01
4,29	5,30	6,07
4,30	5,31	6,12
4,31	5,32	6,18
4,32	5,33	6,24
4,33	5,34	6,30
4,34	5,35	6,35
4,35	5,36	6,41
4,36	5,37	6,46
4,37	5,38	6,52
4,38	5,39	6,58
4,39	5,40	6,63
4,40	5,41	6,69
4,41	5,42	6,75
4,42	5,43	6,80
4,43	5,44	6,86
4,44	5,45	6,91
4,45	5,46	6,97
4,46	5,47	7,02
4,47	5,48	7,08
4,48	5,49	7,14
4,49	5,50	7,19
4,50	5,51	7,25
4,51	5,52	7,30
4,52	5,53	7,36
4,53	5,54	7,41
4,54	5,55	7,47
4,55	5,56	7,52
4,56	5,57	7,58



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	7,63
4,58	5,59	7,69
4,59	5,60	7,74
4,60	5,61	7,80
4,61	5,62	7,85
4,62	5,63	7,90
4,63	5,64	7,96
4,64	5,65	8,01
4,65	5,66	8,07
4,66	5,67	8,12
4,67	5,68	8,18
4,68	5,69	8,23
4,69	5,70	8,28
4,70	5,71	8,34
4,71	5,72	8,39
4,72	5,73	8,45
4,73	5,74	8,50
4,74	5,75	8,55
4,75	5,76	8,61
4,76	5,77	8,66
4,77	5,78	8,71
4,78	5,79	8,77
4,79	5,80	8,82
4,80	5,81	8,87
4,81	5,82	8,93
4,82	5,83	8,98
4,83	5,84	9,03
4,84	5,85	9,08
4,85	5,86	9,14
4,86	5,87	9,19
4,87	5,88	9,24
4,88	5,89	9,30
4,89	5,90	9,35
4,90	5,91	9,40
4,91	5,92	9,45
4,92	5,93	9,50
4,93	5,94	9,56
4,94	5,95	9,61
4,95	5,96	9,66
4,96	5,97	9,71
4,97	5,98	9,77
4,98	5,99	9,82
4,99	6,00	9,87
5,00	6,01	9,92



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	9,97
5,02	6,03	10,02
5,03	6,04	10,08
5,04	6,05	10,13
5,05	6,06	10,18
5,06	6,07	10,23
5,07	6,08	10,28
5,08	6,09	10,33
5,09	6,10	10,38
5,10	6,11	10,44
5,11	6,12	10,49
5,12	6,13	10,54
5,13	6,14	10,59
5,14	6,15	10,64
5,15	6,16	10,69
5,16	6,17	10,74
5,17	6,18	10,79
5,18	6,19	10,84
5,19	6,20	10,89
5,20	6,21	10,94
5,21	6,22	10,99
5,22	6,23	11,05
5,23	6,24	11,10
5,24	6,25	11,15
5,25	6,26	11,20
5,26	6,27	11,25
5,27	6,28	11,30
5,28	6,29	11,35
5,29	6,30	11,40
5,30	6,31	11,45
5,31	6,32	11,50
5,32	6,33	11,55
5,33	6,34	11,60
5,34	6,35	11,65
5,35	6,36	11,70
5,36	6,37	11,74
5,37	6,38	11,79
5,38	6,39	11,84
5,39	6,40	11,89
5,40	6,41	11,94
5,41	6,42	11,99
5,42	6,43	12,04
5,43	6,44	12,09
5,44	6,45	12,14



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,45	6,46	12,19
5,46	6,47	12,24
5,47	6,48	12,29
5,48	6,49	12,34
5,49	6,50	12,38
5,50	6,51	12,43
5,51	6,52	12,48
5,52	6,53	12,53
5,53	6,54	12,58
5,54	6,55	12,63
5,55	6,56	12,68
5,56	6,57	12,72
5,57	6,58	12,77
5,58	6,59	12,82
5,59	6,60	12,87
5,60	6,61	12,92
5,61	6,62	12,97
5,62	6,63	13,01
5,63	6,64	13,06
5,64	6,65	13,11
5,65	6,66	13,16
5,66	6,67	13,21
5,67	6,68	13,25
5,68	6,69	13,30
5,69	6,70	13,35
5,70	6,71	13,40
5,71	6,72	13,44
5,72	6,73	13,49
5,73	6,74	13,54
5,74	6,75	13,59
5,75	6,76	13,63
5,76	6,77	13,68
5,77	6,78	13,73
5,78	6,79	13,78
5,79	6,80	13,82
5,80	6,81	13,87
5,81	6,82	13,92
5,82	6,83	13,97
5,83	6,84	14,01
5,84	6,85	14,06
5,85	6,86	14,11
5,86	6,87	14,15
5,87	6,88	14,20
5,88	6,89	14,25



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	14,29
5,90	6,91	14,34
5,91	6,92	14,39
5,92	6,93	14,43
5,93	6,94	14,48
5,94	6,95	14,53
5,95	6,96	14,57
5,96	6,97	14,62
5,97	6,98	14,66
5,98	6,99	14,71
5,99	7,00	14,76
6,00	7,01	14,80
6,01	7,02	14,85
6,02	7,03	14,90
6,03	7,04	14,94
6,04	7,05	14,99
6,05	7,06	15,03
6,06	7,07	15,08
6,07	7,08	15,12
6,08	7,09	15,17
6,09	7,10	15,22
6,10	7,11	15,26
6,11	7,12	15,31
6,12	7,13	15,35
6,13	7,14	15,40
6,14	7,15	15,44
6,15	7,16	15,49
6,16	7,17	15,53
6,17	7,18	15,58
6,18	7,19	15,63
6,19	7,20	15,67
6,20	7,21	15,72
6,21	7,22	15,76
6,22	7,23	15,81
6,23	7,24	15,85
6,24	7,25	15,90
6,25	7,26	15,94
6,26	7,27	15,99
6,27	7,28	16,03
6,28	7,29	16,08
6,29	7,30	16,12
6,30	7,31	16,16
6,31	7,32	16,21
6,32	7,33	16,25



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,33	7,34	16,30
6,34	7,35	16,34
6,35	7,36	16,39
6,36	7,37	16,43
6,37	7,38	16,48
6,38	7,39	16,52
6,39	7,40	16,57
6,40	7,41	16,61
6,41	7,42	16,65
6,42	7,43	16,70
6,43	7,44	16,74
6,44	7,45	16,79
6,45	7,46	16,83
6,46	7,47	16,87
6,47	7,48	16,92
6,48	7,49	16,96
6,49	7,50	17,01
6,50	7,51	17,05
6,51	7,52	17,09
6,52	7,53	17,14
6,53	7,54	17,18
6,54	7,55	17,22
6,55	7,56	17,27
6,56	7,57	17,31
6,57	7,58	17,35
6,58	7,59	17,40
6,59	7,60	17,44
6,60	7,61	17,48
6,61	7,62	17,53
6,62	7,63	17,57
6,63	7,64	17,61
6,64	7,65	17,66
6,65	7,66	17,70
6,66	7,67	17,74
6,67	7,68	17,79
6,68	7,69	17,83
6,69	7,70	17,87
6,70	7,71	17,92
6,71	7,72	17,96
6,72	7,73	18,00
6,73	7,74	18,04
6,74	7,75	18,09
6,75	7,76	18,13
6,76	7,77	18,17



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,77	7,78	18,22
6,78	7,79	18,26
6,79	7,80	18,30
6,80	7,81	18,34
6,81	7,82	18,39
6,82	7,83	18,43
6,83	7,84	18,47
6,84	7,85	18,51
6,85	7,86	18,56
6,86	7,87	18,60
6,87	7,88	18,64
6,88	7,89	18,68
6,89	7,90	18,72
6,90	7,91	18,77
6,91	7,92	18,81
6,92	7,93	18,85
6,93	7,94	18,89
6,94	7,95	18,93
6,95	7,96	18,98
6,96	7,97	19,02
6,97	7,98	19,06
6,98	7,99	19,10
6,99	8,00	19,14
7,00	8,01	19,19
7,01	8,02	19,23
7,02	8,03	19,27
7,03	8,04	19,31
7,04	8,05	19,35
7,05	8,06	19,39
7,06	8,07	19,43
7,07	8,08	19,48
7,08	8,09	19,52
7,09	8,10	19,56
7,10	8,11	19,60
7,11	8,12	19,64
7,12	8,13	19,68
7,13	8,14	19,72
7,14	8,15	19,77
7,15	8,16	19,81
7,16	8,17	19,85
7,17	8,18	19,89
7,18	8,19	19,93
7,19	8,20	19,97
7,20	8,21	20,01



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	20,05
7,22	8,23	20,09
7,23	8,24	20,13
7,24	8,25	20,18
7,25	8,26	20,22
7,26	8,27	20,26
7,27	8,28	20,30
7,28	8,29	20,34
7,29	8,30	20,38
7,30	8,31	20,42
7,31	8,32	20,46
7,32	8,33	20,50
7,33	8,34	20,54
7,34	8,35	20,58
7,35	8,36	20,62
7,36	8,37	20,66
7,37	8,38	20,70
7,38	8,39	20,74
7,39	8,40	20,78
7,40	8,41	20,82
7,41	8,42	20,86
7,42	8,43	20,90
7,43	8,44	20,94
7,44	8,45	20,98
7,45	8,46	21,02
7,46	8,47	21,06
7,47	8,48	21,10
7,48	8,49	21,14
7,49	8,50	21,18
7,50	8,51	21,22
7,51	8,52	21,26
7,52	8,53	21,30
7,53	8,54	21,34
7,54	8,55	21,38
7,55	8,56	21,42
7,56	8,57	21,46
7,57	8,58	21,50
7,58	8,59	21,54
7,59	8,60	21,58
7,60	8,61	21,62
7,61	8,62	21,66
7,62	8,63	21,70
7,63	8,64	21,74
7,64	8,65	21,78



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,65	8,66	21,82
7,66	8,67	21,86
7,67	8,68	21,90
7,68	8,69	21,94
7,69	8,70	21,97
7,70	8,71	22,01
7,71	8,72	22,05
7,72	8,73	22,09
7,73	8,74	22,13
7,74	8,75	22,17
7,75	8,76	22,21
7,76	8,77	22,25
7,77	8,78	22,29
7,78	8,79	22,33
7,79	8,80	22,36
7,80	8,81	22,40
7,81	8,82	22,44
7,82	8,83	22,48
7,83	8,84	22,52
7,84	8,85	22,56
7,85	8,86	22,60
7,86	8,87	22,64
7,87	8,88	22,67
7,88	8,89	22,71
7,89	8,90	22,75
7,90	8,91	22,79
7,91	8,92	22,83
7,92	8,93	22,87
7,93	8,94	22,91
7,94	8,95	22,94
7,95	8,96	22,98
7,96	8,97	23,02
7,97	8,98	23,06
7,98	8,99	23,10
7,99	9,00	23,13
8,00	9,01	23,17
8,01	9,02	23,21
8,02	9,03	23,25
8,03	9,04	23,29
8,04	9,05	23,33
8,05	9,06	23,36
8,06	9,07	23,40
8,07	9,08	23,44
8,08	9,09	23,48



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,09	9,10	23,52
8,10	9,11	23,55
8,11	9,12	23,59
8,12	9,13	23,63
8,13	9,14	23,67
8,14	9,15	23,70
8,15	9,16	23,74
8,16	9,17	23,78
8,17	9,18	23,82
8,18	9,19	23,86
8,19	9,20	23,89
8,20	9,21	23,93
8,21	9,22	23,97
8,22	9,23	24,01
8,23	9,24	24,04
8,24	9,25	24,08
8,25	9,26	24,12
8,26	9,27	24,16
8,27	9,28	24,19
8,28	9,29	24,23
8,29	9,30	24,27
8,30	9,31	24,30
8,31	9,32	24,34
8,32	9,33	24,38
8,33	9,34	24,42
8,34	9,35	24,45
8,35	9,36	24,49
8,36	9,37	24,53
8,37	9,38	24,56
8,38	9,39	24,60
8,39	9,40	24,64
8,40	9,41	24,68
8,41	9,42	24,71
8,42	9,43	24,75
8,43	9,44	24,79
8,44	9,45	24,82
8,45	9,46	24,86
8,46	9,47	24,90
8,47	9,48	24,93
8,48	9,49	24,97
8,49	9,50	25,01
8,50	9,51	25,04
8,51	9,52	25,08
8,52	9,53	25,12



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,53	9,54	25,15
8,54	9,55	25,19
8,55	9,56	25,23
8,56	9,57	25,26
8,57	9,58	25,30
8,58	9,59	25,34
8,59	9,60	25,37
8,60	9,61	25,41
8,61	9,62	25,44
8,62	9,63	25,48
8,63	9,64	25,52
8,64	9,65	25,55
8,65	9,66	25,59
8,66	9,67	25,63
8,67	9,68	25,66
8,68	9,69	25,70
8,69	9,70	25,73
8,70	9,71	25,77
8,71	9,72	25,81
8,72	9,73	25,84
8,73	9,74	25,88
8,74	9,75	25,91
8,75	9,76	25,95
8,76	9,77	25,99
8,77	9,78	26,02
8,78	9,79	26,06
8,79	9,80	26,09
8,80	9,81	26,13
8,81	9,82	26,17
8,82	9,83	26,20
8,83	9,84	26,24
8,84	9,85	26,27
8,85	9,86	26,31
8,86	9,87	26,34
8,87	9,88	26,38
8,88	9,89	26,42
8,89	9,90	26,45
8,90	9,91	26,49
8,91	9,92	26,52
8,92	9,93	26,56
8,93	9,94	26,59
8,94	9,95	26,63
8,95	9,96	26,66
8,96	9,97	26,70



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,97	9,98	26,73
8,98	9,99	26,77
8,99	10,00	26,81
9,00	10,01	26,84
9,01	10,02	26,88
9,02	10,03	26,91
9,03	10,04	26,95
9,04	10,05	26,98
9,05	10,06	27,02
9,06	10,07	27,05
9,07	10,08	27,09
9,08	10,09	27,12
9,09	10,10	27,16
9,10	10,11	27,19
9,11	10,12	27,23
9,12	10,13	27,26
9,13	10,14	27,30
9,14	10,15	27,33
9,15	10,16	27,37
9,16	10,17	27,40
9,17	10,18	27,44
9,18	10,19	27,47
9,19	10,20	27,51
9,20	10,21	27,54
9,21	10,22	27,58
9,22	10,23	27,61
9,23	10,24	27,64
9,24	10,25	27,68
9,25	10,26	27,71
9,26	10,27	27,75
9,27	10,28	27,78
9,28	10,29	27,82
9,29	10,30	27,85
9,30	10,31	27,89
9,31	10,32	27,92
9,32	10,33	27,96
9,33	10,34	27,99
9,34	10,35	28,02
9,35	10,36	28,06
9,36	10,37	28,09
9,37	10,38	28,13
9,38	10,39	28,16
9,39	10,40	28,20
9,40	10,41	28,23



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,41	10,42	28,26
9,42	10,43	28,30
9,43	10,44	28,33
9,44	10,45	28,37
9,45	10,46	28,40
9,46	10,47	28,44
9,47	10,48	28,47
9,48	10,49	28,50
9,49	10,50	28,54
9,50	10,51	28,57
9,51	10,52	28,61
9,52	10,53	28,64
9,53	10,54	28,67
9,54	10,55	28,71
9,55	10,56	28,74
9,56	10,57	28,78
9,57	10,58	28,81
9,58	10,59	28,84
9,59	10,60	28,88
9,60	10,61	28,91
9,61	10,62	28,94
9,62	10,63	28,98
9,63	10,64	29,01
9,64	10,65	29,05
9,65	10,66	29,08
9,66	10,67	29,11
9,67	10,68	29,15
9,68	10,69	29,18
9,69	10,70	29,21
9,70	10,71	29,25
9,71	10,72	29,28
9,72	10,73	29,31
9,73	10,74	29,35
9,74	10,75	29,38
9,75	10,76	29,41
9,76	10,77	29,45
9,77	10,78	29,48
9,78	10,79	29,51
9,79	10,80	29,55
9,80	10,81	29,58
9,81	10,82	29,61
9,82	10,83	29,65
9,83	10,84	29,68
9,84	10,85	29,71



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
9,85	10,86	29,75
9,86	10,87	29,78
9,87	10,88	29,81
9,88	10,89	29,85
9,89	10,90	29,88
9,90	10,91	29,91
9,91	10,92	29,95
9,92	10,93	29,98
9,93	10,94	30,01
9,94	10,95	30,04
9,95	10,96	30,08
9,96	10,97	30,11
9,97	10,98	30,14
9,98	10,99	30,18
9,99	11,00	30,21
10,00	11,01	30,24
10,01	11,02	30,27
10,02	11,03	30,31
10,03	11,04	30,34
10,04	11,05	30,37
10,05	11,06	30,41
10,06	11,07	30,44
10,07	11,08	30,47
10,08	11,09	30,50
10,09	11,10	30,54
10,10	11,11	30,57
10,11	11,12	30,60
10,12	11,13	30,63
10,13	11,14	30,67
10,14	11,15	30,70
10,15	11,16	30,73
10,16	11,17	30,76
10,17	11,18	30,80
10,18	11,19	30,83
10,19	11,20	30,86
10,20	11,21	30,89
10,21	11,22	30,93
10,22	11,23	30,96
10,23	11,24	30,99
10,24	11,25	31,02
10,25	11,26	31,06
10,26	11,27	31,09
10,27	11,28	31,12
10,28	11,29	31,15



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,29	11,30	31,18
10,30	11,31	31,22
10,31	11,32	31,25
10,32	11,33	31,28
10,33	11,34	31,31
10,34	11,35	31,35
10,35	11,36	31,38
10,36	11,37	31,41
10,37	11,38	31,44
10,38	11,39	31,47
10,39	11,40	31,51
10,40	11,41	31,54
10,41	11,42	31,57
10,42	11,43	31,60
10,43	11,44	31,63
10,44	11,45	31,67
10,45	11,46	31,70
10,46	11,47	31,73
10,47	11,48	31,76
10,48	11,49	31,79
10,49	11,50	31,82
10,50	11,51	31,86
10,51	11,52	31,89
10,52	11,53	31,92
10,53	11,54	31,95
10,54	11,55	31,98
10,55	11,56	32,01
10,56	11,57	32,05
10,57	11,58	32,08
10,58	11,59	32,11
10,59	11,60	32,14
10,60	11,61	32,17
10,61	11,62	32,20
10,62	11,63	32,24
10,63	11,64	32,27
10,64	11,65	32,30
10,65	11,66	32,33
10,66	11,67	32,36
10,67	11,68	32,39
10,68	11,69	32,42
10,69	11,70	32,46
10,70	11,71	32,49
10,71	11,72	32,52
10,72	11,73	32,55



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	32,58
10,74	11,75	32,61
10,75	11,76	32,64
10,76	11,77	32,67
10,77	11,78	32,71
10,78	11,79	32,74
10,79	11,80	32,77
10,80	11,81	32,80
10,81	11,82	32,83
10,82	11,83	32,86
10,83	11,84	32,89
10,84	11,85	32,92
10,85	11,86	32,96
10,86	11,87	32,99
10,87	11,88	33,02
10,88	11,89	33,05
10,89	11,90	33,08
10,90	11,91	33,11
10,91	11,92	33,14
10,92	11,93	33,17
10,93	11,94	33,20
10,94	11,95	33,23
10,95	11,96	33,26
10,96	11,97	33,30
10,97	11,98	33,33
10,98	11,99	33,36
10,99	12,00	33,39
11,00	12,01	33,42
11,01	12,02	33,45
11,02	12,03	33,48
11,03	12,04	33,51
11,04	12,05	33,54
11,05	12,06	33,57
11,06	12,07	33,60
11,07	12,08	33,63
11,08	12,09	33,66
11,09	12,10	33,69
11,10	12,11	33,73
11,11	12,12	33,76
11,12	12,13	33,79
11,13	12,14	33,82
11,14	12,15	33,85
11,15	12,16	33,88
11,16	12,17	33,91



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
11,17	12,18	33,94
11,18	12,19	33,97
11,19	12,20	34,00
11,20	12,21	34,03
11,21	12,22	34,06
11,22	12,23	34,09
11,23	12,24	34,12
11,24	12,25	34,15
11,25	12,26	34,18
11,26	12,27	34,21
11,27	12,28	34,24
11,28	12,29	34,27
11,29	12,30	34,30
11,30	12,31	34,33
11,31	12,32	34,36
11,32	12,33	34,39
11,33	12,34	34,42
11,34	12,35	34,45
11,35	12,36	34,48
11,36	12,37	34,51
11,37	12,38	34,54
11,38	12,39	34,57
11,39	12,40	34,60
11,40	12,41	34,63
11,41	12,42	34,66
11,42	12,43	34,69
11,43	12,44	34,72
11,44	12,45	34,75
11,45	12,46	34,78
11,46	12,47	34,81
11,47	12,48	34,84
11,48	12,49	34,87
11,49	12,50	34,90
11,50	12,51	34,93
11,51	12,52	34,96
11,52	12,53	34,99
11,53	12,54	35,02
11,54	12,55	35,05
11,55	12,56	35,08
11,56	12,57	35,11
11,57	12,58	35,14
11,58	12,59	35,17
11,59	12,60	35,20
11,60	12,61	35,23



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	35,26
11,62	12,63	35,29
11,63	12,64	35,32
11,64	12,65	35,35
11,65	12,66	35,38
11,66	12,67	35,41
11,67	12,68	35,44
11,68	12,69	35,47
11,69	12,70	35,50
11,70	12,71	35,53
11,71	12,72	35,55
11,72	12,73	35,58
11,73	12,74	35,61
11,74	12,75	35,64
11,75	12,76	35,67
11,76	12,77	35,70
11,77	12,78	35,73
11,78	12,79	35,76
11,79	12,80	35,79
11,80	12,81	35,82
11,81	12,82	35,85
11,82	12,83	35,88
11,83	12,84	35,91
11,84	12,85	35,94
11,85	12,86	35,97
11,86	12,87	35,99
11,87	12,88	36,02
11,88	12,89	36,05
11,89	12,90	36,08
11,90	12,91	36,11
11,91	12,92	36,14
11,92	12,93	36,17
11,93	12,94	36,20
11,94	12,95	36,23
11,95	12,96	36,26
11,96	12,97	36,29
11,97	12,98	36,31
11,98	12,99	36,34
11,99	13,00	36,37
12,00	13,01	36,40
12,01	13,02	36,43
12,02	13,03	36,46
12,03	13,04	36,49
12,04	13,05	36,52



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,05	13,06	36,55
12,06	13,07	36,57
12,07	13,08	36,60
12,08	13,09	36,63
12,09	13,10	36,66
12,10	13,11	36,69
12,11	13,12	36,72
12,12	13,13	36,75
12,13	13,14	36,78
12,14	13,15	36,81
12,15	13,16	36,83
12,16	13,17	36,86
12,17	13,18	36,89
12,18	13,19	36,92
12,19	13,20	36,95
12,20	13,21	36,98
12,21	13,22	37,01
12,22	13,23	37,03
12,23	13,24	37,06
12,24	13,25	37,09
12,25	13,26	37,12
12,26	13,27	37,15
12,27	13,28	37,18
12,28	13,29	37,21
12,29	13,30	37,23
12,30	13,31	37,26
12,31	13,32	37,29
12,32	13,33	37,32
12,33	13,34	37,35
12,34	13,35	37,38
12,35	13,36	37,40
12,36	13,37	37,43
12,37	13,38	37,46
12,38	13,39	37,49
12,39	13,40	37,52
12,40	13,41	37,55
12,41	13,42	37,57
12,42	13,43	37,60
12,43	13,44	37,63
12,44	13,45	37,66
12,45	13,46	37,69
12,46	13,47	37,72
12,47	13,48	37,74
12,48	13,49	37,77



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	37,80
12,50	13,51	37,83
12,51	13,52	37,86
12,52	13,53	37,88
12,53	13,54	37,91
12,54	13,55	37,94
12,55	13,56	37,97
12,56	13,57	38,00
12,57	13,58	38,03
12,58	13,59	38,05
12,59	13,60	38,08
12,60	13,61	38,11
12,61	13,62	38,14
12,62	13,63	38,16
12,63	13,64	38,19
12,64	13,65	38,22
12,65	13,66	38,25
12,66	13,67	38,28
12,67	13,68	38,30
12,68	13,69	38,33
12,69	13,70	38,36
12,70	13,71	38,39
12,71	13,72	38,42
12,72	13,73	38,44
12,73	13,74	38,47
12,74	13,75	38,50
12,75	13,76	38,53
12,76	13,77	38,55
12,77	13,78	38,58
12,78	13,79	38,61
12,79	13,80	38,64
12,80	13,81	38,67
12,81	13,82	38,69
12,82	13,83	38,72
12,83	13,84	38,75
12,84	13,85	38,78
12,85	13,86	38,80
12,86	13,87	38,83
12,87	13,88	38,86
12,88	13,89	38,89
12,89	13,90	38,91
12,90	13,91	38,94
12,91	13,92	38,97
12,92	13,93	39,00



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	39,02
12,94	13,95	39,05
12,95	13,96	39,08
12,96	13,97	39,11
12,97	13,98	39,13
12,98	13,99	39,16
12,99	14,00	39,19
13,00	14,01	39,22
13,01	14,02	39,24
13,02	14,03	39,27
13,03	14,04	39,30
13,04	14,05	39,33
13,05	14,06	39,35
13,06	14,07	39,38
13,07	14,08	39,41
13,08	14,09	39,43
13,09	14,10	39,46
13,10	14,11	39,49
13,11	14,12	39,52
13,12	14,13	39,54
13,13	14,14	39,57
13,14	14,15	39,60
13,15	14,16	39,63
13,16	14,17	39,65
13,17	14,18	39,68
13,18	14,19	39,71
13,19	14,20	39,73
13,20	14,21	39,76
13,21	14,22	39,79
13,22	14,23	39,81
13,23	14,24	39,84
13,24	14,25	39,87
13,25	14,26	39,90
13,26	14,27	39,92
13,27	14,28	39,95
13,28	14,29	39,98
13,29	14,30	40,00
13,30	14,31	40,03
13,31	14,32	40,06
13,32	14,33	40,08
13,33	14,34	40,11
13,34	14,35	40,14
13,35	14,36	40,17
13,36	14,37	40,19



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,37	14,38	40,22
13,38	14,39	40,25
13,39	14,40	40,27
13,40	14,41	40,30
13,41	14,42	40,33
13,42	14,43	40,35
13,43	14,44	40,38
13,44	14,45	40,41
13,45	14,46	40,43
13,46	14,47	40,46
13,47	14,48	40,49
13,48	14,49	40,51
13,49	14,50	40,54
13,50	14,51	40,57
13,51	14,52	40,59
13,52	14,53	40,62
13,53	14,54	40,65
13,54	14,55	40,67
13,55	14,56	40,70
13,56	14,57	40,73
13,57	14,58	40,75
13,58	14,59	40,78
13,59	14,60	40,81
13,60	14,61	40,83
13,61	14,62	40,86
13,62	14,63	40,89
13,63	14,64	40,91
13,64	14,65	40,94
13,65	14,66	40,97
13,66	14,67	40,99
13,67	14,68	41,02
13,68	14,69	41,04
13,69	14,70	41,07
13,70	14,71	41,10
13,71	14,72	41,12
13,72	14,73	41,15
13,73	14,74	41,18
13,74	14,75	41,20
13,75	14,76	41,23
13,76	14,77	41,26
13,77	14,78	41,28
13,78	14,79	41,31
13,79	14,80	41,33
13,80	14,81	41,36



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,81	14,82	41,39
13,82	14,83	41,41
13,83	14,84	41,44
13,84	14,85	41,47
13,85	14,86	41,49
13,86	14,87	41,52
13,87	14,88	41,54
13,88	14,89	41,57
13,89	14,90	41,60
13,90	14,91	41,62
13,91	14,92	41,65
13,92	14,93	41,67
13,93	14,94	41,70
13,94	14,95	41,73
13,95	14,96	41,75
13,96	14,97	41,78
13,97	14,98	41,80
13,98	14,99	41,83
13,99	15,00	41,86
14,00	15,01	41,88
14,01	15,02	41,91
14,02	15,03	41,93
14,03	15,04	41,96
14,04	15,05	41,99
14,05	15,06	42,01
14,06	15,07	42,04
14,07	15,08	42,06
14,08	15,09	42,09
14,09	15,10	42,12
14,10	15,11	42,14
14,11	15,12	42,17
14,12	15,13	42,19
14,13	15,14	42,22
14,14	15,15	42,25
14,15	15,16	42,27
14,16	15,17	42,30
14,17	15,18	42,32
14,18	15,19	42,35
14,19	15,20	42,37
14,20	15,21	42,40
14,21	15,22	42,43
14,22	15,23	42,45
14,23	15,24	42,48
14,24	15,25	42,50



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
14,25	15,26	42,53
14,26	15,27	42,55
14,27	15,28	42,58
14,28	15,29	42,61
14,29	15,30	42,63
14,30	15,31	42,66
14,31	15,32	42,68
14,32	15,33	42,71
14,33	15,34	42,73
14,34	15,35	42,76
14,35	15,36	42,78
14,36	15,37	42,81
14,37	15,38	42,84
14,38	15,39	42,86
14,39	15,40	42,89
14,40	15,41	42,91
14,41	15,42	42,94
14,42	15,43	42,96
14,43	15,44	42,99
14,44	15,45	43,01
14,45	15,46	43,04
14,46	15,47	43,06
14,47	15,48	43,09
14,48	15,49	43,12
14,49	15,50	43,14
14,50	15,51	43,17
14,51	15,52	43,19
14,52	15,53	43,22
14,53	15,54	43,24
14,54	15,55	43,27
14,55	15,56	43,29
14,56	15,57	43,32
14,57	15,58	43,34
14,58	15,59	43,37
14,59	15,60	43,39
14,60	15,61	43,42
14,61	15,62	43,44
14,62	15,63	43,47
14,63	15,64	43,49
14,64	15,65	43,52
14,65	15,66	43,54
14,66	15,67	43,57
14,67	15,68	43,60
14,68	15,69	43,62



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	43,65
14,70	15,71	43,67
14,71	15,72	43,70
14,72	15,73	43,72
14,73	15,74	43,75
14,74	15,75	43,77
14,75	15,76	43,80
14,76	15,77	43,82
14,77	15,78	43,85
14,78	15,79	43,87
14,79	15,80	43,90
14,80	15,81	43,92
14,81	15,82	43,95
14,82	15,83	43,97
14,83	15,84	44,00
14,84	15,85	44,02
14,85	15,86	44,05
14,86	15,87	44,07
14,87	15,88	44,10
14,88	15,89	44,12
14,89	15,90	44,15
14,90	15,91	44,17
14,91	15,92	44,19
14,92	15,93	44,22
14,93	15,94	44,24
14,94	15,95	44,27
14,95	15,96	44,29
14,96	15,97	44,32
14,97	15,98	44,34
14,98	15,99	44,37
14,99	16,00	44,39
15,00	16,01	44,42
15,01	16,02	44,44
15,02	16,03	44,47
15,03	16,04	44,49
15,04	16,05	44,52
15,05	16,06	44,54
15,06	16,07	44,57
15,07	16,08	44,59
15,08	16,09	44,62
15,09	16,10	44,64
15,10	16,11	44,66
15,11	16,12	44,69
15,12	16,13	44,71



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	44,74
15,14	16,15	44,76
15,15	16,16	44,79
15,16	16,17	44,81
15,17	16,18	44,84
15,18	16,19	44,86
15,19	16,20	44,89
15,20	16,21	44,91
15,21	16,22	44,94
15,22	16,23	44,96
15,23	16,24	44,98
15,24	16,25	45,01
15,25	16,26	45,03
15,26	16,27	45,06
15,27	16,28	45,08
15,28	16,29	45,11
15,29	16,30	45,13
15,30	16,31	45,16
15,31	16,32	45,18
15,32	16,33	45,20
15,33	16,34	45,23
15,34	16,35	45,25
15,35	16,36	45,28
15,36	16,37	45,30
15,37	16,38	45,33
15,38	16,39	45,35
15,39	16,40	45,37
15,40	16,41	45,40
15,41	16,42	45,42
15,42	16,43	45,45
15,43	16,44	45,47
15,44	16,45	45,50
15,45	16,46	45,52
15,46	16,47	45,54
15,47	16,48	45,57
15,48	16,49	45,59
15,49	16,50	45,62
15,50	16,51	45,64
15,51	16,52	45,67
15,52	16,53	45,69
15,53	16,54	45,71
15,54	16,55	45,74
15,55	16,56	45,76
15,56	16,57	45,79



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,57	16,58	45,81
15,58	16,59	45,83
15,59	16,60	45,86
15,60	16,61	45,88
15,61	16,62	45,91
15,62	16,63	45,93
15,63	16,64	45,95
15,64	16,65	45,98
15,65	16,66	46,00
15,66	16,67	46,03
15,67	16,68	46,05
15,68	16,69	46,07
15,69	16,70	46,10
15,70	16,71	46,12
15,71	16,72	46,15
15,72	16,73	46,17
15,73	16,74	46,19
15,74	16,75	46,22
15,75	16,76	46,24
15,76	16,77	46,27
15,77	16,78	46,29
15,78	16,79	46,31
15,79	16,80	46,34
15,80	16,81	46,36
15,81	16,82	46,38
15,82	16,83	46,41
15,83	16,84	46,43
15,84	16,85	46,46
15,85	16,86	46,48
15,86	16,87	46,50
15,87	16,88	46,53
15,88	16,89	46,55
15,89	16,90	46,58
15,90	16,91	46,60
15,91	16,92	46,62
15,92	16,93	46,65
15,93	16,94	46,67
15,94	16,95	46,69
15,95	16,96	46,72
15,96	16,97	46,74
15,97	16,98	46,76
15,98	16,99	46,79
15,99	17,00	46,81
16,00	17,01	46,84



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	46,86
16,02	17,03	46,88
16,03	17,04	46,91
16,04	17,05	46,93
16,05	17,06	46,95
16,06	17,07	46,98
16,07	17,08	47,00
16,08	17,09	47,02
16,09	17,10	47,05
16,10	17,11	47,07
16,11	17,12	47,10
16,12	17,13	47,12
16,13	17,14	47,14
16,14	17,15	47,17
16,15	17,16	47,19
16,16	17,17	47,21
16,17	17,18	47,24
16,18	17,19	47,26
16,19	17,20	47,28
16,20	17,21	47,31
16,21	17,22	47,33
16,22	17,23	47,35
16,23	17,24	47,38
16,24	17,25	47,40
16,25	17,26	47,42
16,26	17,27	47,45
16,27	17,28	47,47
16,28	17,29	47,49
16,29	17,30	47,52
16,30	17,31	47,54
16,31	17,32	47,56
16,32	17,33	47,59
16,33	17,34	47,61
16,34	17,35	47,63
16,35	17,36	47,66
16,36	17,37	47,68
16,37	17,38	47,70
16,38	17,39	47,73
16,39	17,40	47,75
16,40	17,41	47,77
16,41	17,42	47,80
16,42	17,43	47,82
16,43	17,44	47,84
16,44	17,45	47,87



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
16,45	17,46	47,89
16,46	17,47	47,91
16,47	17,48	47,93
16,48	17,49	47,96
16,49	17,50	47,98
16,50	17,51	48,00
16,51	17,52	48,03
16,52	17,53	48,05
16,53	17,54	48,07
16,54	17,55	48,10
16,55	17,56	48,12
16,56	17,57	48,14
16,57	17,58	48,17
16,58	17,59	48,19
16,59	17,60	48,21
16,60	17,61	48,23
16,61	17,62	48,26
16,62	17,63	48,28
16,63	17,64	48,30
16,64	17,65	48,33
16,65	17,66	48,35
16,66	17,67	48,37
16,67	17,68	48,40
16,68	17,69	48,42
16,69	17,70	48,44
16,70	17,71	48,46
16,71	17,72	48,49
16,72	17,73	48,51
16,73	17,74	48,53
16,74	17,75	48,56
16,75	17,76	48,58
16,76	17,77	48,60
16,77	17,78	48,62
16,78	17,79	48,65
16,79	17,80	48,67
16,80	17,81	48,69
16,81	17,82	48,72
16,82	17,83	48,74
16,83	17,84	48,76
16,84	17,85	48,78
16,85	17,86	48,81
16,86	17,87	48,83
16,87	17,88	48,85
16,88	17,89	48,88



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	48,90
16,90	17,91	48,92
16,91	17,92	48,94
16,92	17,93	48,97
16,93	17,94	48,99
16,94	17,95	49,01
16,95	17,96	49,03
16,96	17,97	49,06
16,97	17,98	49,08
16,98	17,99	49,10
16,99	18,00	49,12
17,00	18,01	49,15
17,01	18,02	49,17
17,02	18,03	49,19
17,03	18,04	49,22
17,04	18,05	49,24
17,05	18,06	49,26
17,06	18,07	49,28
17,07	18,08	49,31
17,08	18,09	49,33
17,09	18,10	49,35
17,10	18,11	49,37
17,11	18,12	49,40
17,12	18,13	49,42
17,13	18,14	49,44
17,14	18,15	49,46
17,15	18,16	49,49
17,16	18,17	49,51
17,17	18,18	49,53
17,18	18,19	49,55
17,19	18,20	49,58
17,20	18,21	49,60
17,21	18,22	49,62
17,22	18,23	49,64
17,23	18,24	49,67
17,24	18,25	49,69
17,25	18,26	49,71
17,26	18,27	49,73
17,27	18,28	49,75
17,28	18,29	49,78
17,29	18,30	49,80
17,30	18,31	49,82
17,31	18,32	49,84
17,32	18,33	49,87



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	49,89
17,34	18,35	49,91
17,35	18,36	49,93
17,36	18,37	49,96
17,37	18,38	49,98
17,38	18,39	50,00
17,39	18,40	50,02
17,40	18,41	50,04
17,41	18,42	50,07
17,42	18,43	50,09
17,43	18,44	50,11
17,44	18,45	50,13
17,45	18,46	50,16
17,46	18,47	50,18
17,47	18,48	50,20
17,48	18,49	50,22
17,49	18,50	50,24
17,50	18,51	50,27
17,51	18,52	50,29
17,52	18,53	50,31
17,53	18,54	50,33
17,54	18,55	50,36
17,55	18,56	50,38
17,56	18,57	50,40
17,57	18,58	50,42
17,58	18,59	50,44
17,59	18,60	50,47
17,60	18,61	50,49
17,61	18,62	50,51
17,62	18,63	50,53
17,63	18,64	50,55
17,64	18,65	50,58
17,65	18,66	50,60
17,66	18,67	50,62
17,67	18,68	50,64
17,68	18,69	50,66
17,69	18,70	50,69
17,70	18,71	50,71
17,71	18,72	50,73
17,72	18,73	50,75
17,73	18,74	50,77
17,74	18,75	50,80
17,75	18,76	50,82
17,76	18,77	50,84



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,77	18,78	50,86
17,78	18,79	50,88
17,79	18,80	50,91
17,80	18,81	50,93
17,81	18,82	50,95
17,82	18,83	50,97
17,83	18,84	50,99
17,84	18,85	51,01
17,85	18,86	51,04
17,86	18,87	51,06
17,87	18,88	51,08
17,88	18,89	51,10
17,89	18,90	51,12
17,90	18,91	51,15
17,91	18,92	51,17
17,92	18,93	51,19
17,93	18,94	51,21
17,94	18,95	51,23
17,95	18,96	51,25
17,96	18,97	51,28
17,97	18,98	51,30
17,98	18,99	51,32
17,99	19,00	51,34
18,00	19,01	51,36
18,01	19,02	51,38
18,02	19,03	51,41
18,03	19,04	51,43
18,04	19,05	51,45
18,05	19,06	51,47
18,06	19,07	51,49
18,07	19,08	51,51
18,08	19,09	51,54
18,09	19,10	51,56
18,10	19,11	51,58
18,11	19,12	51,60
18,12	19,13	51,62
18,13	19,14	51,64
18,14	19,15	51,67
18,15	19,16	51,69
18,16	19,17	51,71
18,17	19,18	51,73
18,18	19,19	51,75
18,19	19,20	51,77
18,20	19,21	51,79



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
18,21	19,22	51,82
18,22	19,23	51,84
18,23	19,24	51,86
18,24	19,25	51,88
18,25	19,26	51,90
18,26	19,27	51,92
18,27	19,28	51,95
18,28	19,29	51,97
18,29	19,30	51,99
18,30	19,31	52,01
18,31	19,32	52,03
18,32	19,33	52,05
18,33	19,34	52,07
18,34	19,35	52,10
18,35	19,36	52,12
18,36	19,37	52,14
18,37	19,38	52,16
18,38	19,39	52,18
18,39	19,40	52,20
18,40	19,41	52,22
18,41	19,42	52,25
18,42	19,43	52,27
18,43	19,44	52,29
18,44	19,45	52,31
18,45	19,46	52,33
18,46	19,47	52,35
18,47	19,48	52,37
18,48	19,49	52,39
18,49	19,50	52,42
18,50	19,51	52,44
18,51	19,52	52,46
18,52	19,53	52,48
18,53	19,54	52,50
18,54	19,55	52,52
18,55	19,56	52,54
18,56	19,57	52,56
18,57	19,58	52,59
18,58	19,59	52,61
18,59	19,60	52,63
18,60	19,61	52,65
18,61	19,62	52,67
18,62	19,63	52,69
18,63	19,64	52,71
18,64	19,65	52,73



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,65	19,66	52,75
18,66	19,67	52,78
18,67	19,68	52,80
18,68	19,69	52,82
18,69	19,70	52,84
18,70	19,71	52,86
18,71	19,72	52,88
18,72	19,73	52,90
18,73	19,74	52,92
18,74	19,75	52,94
18,75	19,76	52,97
18,76	19,77	52,99
18,77	19,78	53,01
18,78	19,79	53,03
18,79	19,80	53,05
18,80	19,81	53,07
18,81	19,82	53,09
18,82	19,83	53,11
18,83	19,84	53,13
18,84	19,85	53,16
18,85	19,86	53,18
18,86	19,87	53,20
18,87	19,88	53,22
18,88	19,89	53,24
18,89	19,90	53,26
18,90	19,91	53,28
18,91	19,92	53,30
18,92	19,93	53,32
18,93	19,94	53,34
18,94	19,95	53,36
18,95	19,96	53,39
18,96	19,97	53,41
18,97	19,98	53,43
18,98	19,99	53,45
18,99	20,00	53,47
19,00	20,01	53,49
19,01	20,02	53,51
19,02	20,03	53,53
19,03	20,04	53,55
19,04	20,05	53,57
19,05	20,06	53,59
19,06	20,07	53,62
19,07	20,08	53,64
19,08	20,09	53,66



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	53,68
19,10	20,11	53,70
19,11	20,12	53,72
19,12	20,13	53,74
19,13	20,14	53,76
19,14	20,15	53,78
19,15	20,16	53,80
19,16	20,17	53,82
19,17	20,18	53,84
19,18	20,19	53,86
19,19	20,20	53,88
19,20	20,21	53,91
19,21	20,22	53,93
19,22	20,23	53,95
19,23	20,24	53,97
19,24	20,25	53,99
19,25	20,26	54,01
19,26	20,27	54,03
19,27	20,28	54,05
19,28	20,29	54,07
19,29	20,30	54,09
19,30	20,31	54,11
19,31	20,32	54,13
19,32	20,33	54,15
19,33	20,34	54,17
19,34	20,35	54,19
19,35	20,36	54,22
19,36	20,37	54,24
19,37	20,38	54,26
19,38	20,39	54,28
19,39	20,40	54,30
19,40	20,41	54,32
19,41	20,42	54,34
19,42	20,43	54,36
19,43	20,44	54,38
19,44	20,45	54,40
19,45	20,46	54,42
19,46	20,47	54,44
19,47	20,48	54,46
19,48	20,49	54,48
19,49	20,50	54,50
19,50	20,51	54,52
19,51	20,52	54,54
19,52	20,53	54,56



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	54,58
19,54	20,55	54,60
19,55	20,56	54,63
19,56	20,57	54,65
19,57	20,58	54,67
19,58	20,59	54,69
19,59	20,60	54,71
19,60	20,61	54,73
19,61	20,62	54,75
19,62	20,63	54,77
19,63	20,64	54,79
19,64	20,65	54,81
19,65	20,66	54,83
19,66	20,67	54,85
19,67	20,68	54,87
19,68	20,69	54,89
19,69	20,70	54,91
19,70	20,71	54,93
19,71	20,72	54,95
19,72	20,73	54,97
19,73	20,74	54,99
19,74	20,75	55,01
19,75	20,76	55,03
19,76	20,77	55,05
19,77	20,78	55,07
19,78	20,79	55,09
19,79	20,80	55,11
19,80	20,81	55,13
19,81	20,82	55,15
19,82	20,83	55,17
19,83	20,84	55,19
19,84	20,85	55,21
19,85	20,86	55,23
19,86	20,87	55,25
19,87	20,88	55,27
19,88	20,89	55,30
19,89	20,90	55,32
19,90	20,91	55,34
19,91	20,92	55,36
19,92	20,93	55,38
19,93	20,94	55,40
19,94	20,95	55,42
19,95	20,96	55,44
19,96	20,97	55,46



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,97	20,98	55,48
19,98	20,99	55,50
19,99	21,00	55,52
20,00	21,01	55,54
20,01	21,02	55,56
20,02	21,03	55,58
20,03	21,04	55,60
20,04	21,05	55,62
20,05	21,06	55,64
20,06	21,07	55,66
20,07	21,08	55,68
20,08	21,09	55,70
20,09	21,10	55,72
20,10	21,11	55,74
20,11	21,12	55,76
20,12	21,13	55,78
20,13	21,14	55,80
20,14	21,15	55,82
20,15	21,16	55,84
20,16	21,17	55,86
20,17	21,18	55,88
20,18	21,19	55,90
20,19	21,20	55,92
20,20	21,21	55,94
20,21	21,22	55,96
20,22	21,23	55,98
20,23	21,24	56,00
20,24	21,25	56,02
20,25	21,26	56,04
20,26	21,27	56,06
20,27	21,28	56,08
20,28	21,29	56,10
20,29	21,30	56,12
20,30	21,31	56,14
20,31	21,32	56,16
20,32	21,33	56,18
20,33	21,34	56,20
20,34	21,35	56,22
20,35	21,36	56,23
20,36	21,37	56,25
20,37	21,38	56,27
20,38	21,39	56,29
20,39	21,40	56,31
20,40	21,41	56,33



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
20,41	21,42	56,35
20,42	21,43	56,37
20,43	21,44	56,39
20,44	21,45	56,41
20,45	21,46	56,43
20,46	21,47	56,45
20,47	21,48	56,47
20,48	21,49	56,49
20,49	21,50	56,51
20,50	21,51	56,53
20,51	21,52	56,55
20,52	21,53	56,57
20,53	21,54	56,59
20,54	21,55	56,61
20,55	21,56	56,63
20,56	21,57	56,65
20,57	21,58	56,67
20,58	21,59	56,69
20,59	21,60	56,71
20,60	21,61	56,73
20,61	21,62	56,75
20,62	21,63	56,77
20,63	21,64	56,79
20,64	21,65	56,81
20,65	21,66	56,83
20,66	21,67	56,85
20,67	21,68	56,87
20,68	21,69	56,89
20,69	21,70	56,90
20,70	21,71	56,92
20,71	21,72	56,94
20,72	21,73	56,96
20,73	21,74	56,98
20,74	21,75	57,00
20,75	21,76	57,02
20,76	21,77	57,04
20,77	21,78	57,06
20,78	21,79	57,08
20,79	21,80	57,10
20,80	21,81	57,12
20,81	21,82	57,14
20,82	21,83	57,16
20,83	21,84	57,18
20,84	21,85	57,20



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	57,22
20,86	21,87	57,24
20,87	21,88	57,26
20,88	21,89	57,28
20,89	21,90	57,30
20,90	21,91	57,31
20,91	21,92	57,33
20,92	21,93	57,35
20,93	21,94	57,37
20,94	21,95	57,39
20,95	21,96	57,41
20,96	21,97	57,43
20,97	21,98	57,45
20,98	21,99	57,47
20,99	22,00	57,49
21,00	22,01	57,51
21,01	22,02	57,53
21,02	22,03	57,55
21,03	22,04	57,57
21,04	22,05	57,59
21,05	22,06	57,61
21,06	22,07	57,62
21,07	22,08	57,64
21,08	22,09	57,66
21,09	22,10	57,68
21,10	22,11	57,70
21,11	22,12	57,72
21,12	22,13	57,74
21,13	22,14	57,76
21,14	22,15	57,78
21,15	22,16	57,80
21,16	22,17	57,82
21,17	22,18	57,84
21,18	22,19	57,86
21,19	22,20	57,88
21,20	22,21	57,89
21,21	22,22	57,91
21,22	22,23	57,93
21,23	22,24	57,95
21,24	22,25	57,97
21,25	22,26	57,99
21,26	22,27	58,01
21,27	22,28	58,03
21,28	22,29	58,05



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
21,29	22,30	58,07
21,30	22,31	58,09
21,31	22,32	58,11
21,32	22,33	58,12
21,33	22,34	58,14
21,34	22,35	58,16
21,35	22,36	58,18
21,36	22,37	58,20
21,37	22,38	58,22
21,38	22,39	58,24
21,39	22,40	58,26
21,40	22,41	58,28
21,41	22,42	58,30
21,42	22,43	58,32
21,43	22,44	58,34
21,44	22,45	58,35
21,45	22,46	58,37
21,46	22,47	58,39
21,47	22,48	58,41
21,48	22,49	58,43
21,49	22,50	58,45
21,50	22,51	58,47
21,51	22,52	58,49
21,52	22,53	58,51
21,53	22,54	58,53
21,54	22,55	58,54
21,55	22,56	58,56
21,56	22,57	58,58
21,57	22,58	58,60
21,58	22,59	58,62
21,59	22,60	58,64
21,60	22,61	58,66
21,61	22,62	58,68
21,62	22,63	58,70
21,63	22,64	58,72
21,64	22,65	58,73
21,65	22,66	58,75
21,66	22,67	58,77
21,67	22,68	58,79
21,68	22,69	58,81
21,69	22,70	58,83
21,70	22,71	58,85
21,71	22,72	58,87
21,72	22,73	58,89



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
21,73	22,74	58,90
21,74	22,75	58,92
21,75	22,76	58,94
21,76	22,77	58,96
21,77	22,78	58,98
21,78	22,79	59,00
21,79	22,80	59,02
21,80	22,81	59,04
21,81	22,82	59,06
21,82	22,83	59,07
21,83	22,84	59,09
21,84	22,85	59,11
21,85	22,86	59,13
21,86	22,87	59,15
21,87	22,88	59,17
21,88	22,89	59,19
21,89	22,90	59,21
21,90	22,91	59,22
21,91	22,92	59,24
21,92	22,93	59,26
21,93	22,94	59,28
21,94	22,95	59,30
21,95	22,96	59,32
21,96	22,97	59,34
21,97	22,98	59,36
21,98	22,99	59,37
21,99	23,00	59,39
22,00	23,01	59,41
22,01	23,02	59,43
22,02	23,03	59,45
22,03	23,04	59,47
22,04	23,05	59,49
22,05	23,06	59,50
22,06	23,07	59,52
22,07	23,08	59,54
22,08	23,09	59,56
22,09	23,10	59,58
22,10	23,11	59,60
22,11	23,12	59,62
22,12	23,13	59,64
22,13	23,14	59,65
22,14	23,15	59,67
22,15	23,16	59,69
22,16	23,17	59,71



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,17	23,18	59,73
22,18	23,19	59,75
22,19	23,20	59,77
22,20	23,21	59,78
22,21	23,22	59,80
22,22	23,23	59,82
22,23	23,24	59,84
22,24	23,25	59,86
22,25	23,26	59,88
22,26	23,27	59,90
22,27	23,28	59,91
22,28	23,29	59,93
22,29	23,30	59,95
22,30	23,31	59,97
22,31	23,32	59,99
22,32	23,33	60,01
22,33	23,34	60,03
22,34	23,35	60,04
22,35	23,36	60,06
22,36	23,37	60,08
22,37	23,38	60,10
22,38	23,39	60,12
22,39	23,40	60,14
22,40	23,41	60,15
22,41	23,42	60,17
22,42	23,43	60,19
22,43	23,44	60,21
22,44	23,45	60,23
22,45	23,46	60,25
22,46	23,47	60,27
22,47	23,48	60,28
22,48	23,49	60,30
22,49	23,50	60,32
22,50	23,51	60,34
22,51	23,52	60,36
22,52	23,53	60,38
22,53	23,54	60,39
22,54	23,55	60,41
22,55	23,56	60,43
22,56	23,57	60,45
22,57	23,58	60,47
22,58	23,59	60,49
22,59	23,60	60,50
22,60	23,61	60,52



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	60,54
22,62	23,63	60,56
22,63	23,64	60,58
22,64	23,65	60,60
22,65	23,66	60,61
22,66	23,67	60,63
22,67	23,68	60,65
22,68	23,69	60,67
22,69	23,70	60,69
22,70	23,71	60,71
22,71	23,72	60,72
22,72	23,73	60,74
22,73	23,74	60,76
22,74	23,75	60,78
22,75	23,76	60,80
22,76	23,77	60,81
22,77	23,78	60,83
22,78	23,79	60,85
22,79	23,80	60,87
22,80	23,81	60,89
22,81	23,82	60,91
22,82	23,83	60,92
22,83	23,84	60,94
22,84	23,85	60,96
22,85	23,86	60,98
22,86	23,87	61,00
22,87	23,88	61,01
22,88	23,89	61,03
22,89	23,90	61,05
22,90	23,91	61,07
22,91	23,92	61,09
22,92	23,93	61,11
22,93	23,94	61,12
22,94	23,95	61,14
22,95	23,96	61,16
22,96	23,97	61,18
22,97	23,98	61,20
22,98	23,99	61,21
22,99	24,00	61,23
23,00	24,01	61,25
23,01	24,02	61,27
23,02	24,03	61,29
23,03	24,04	61,30
23,04	24,05	61,32



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,05	24,06	61,34
23,06	24,07	61,36
23,07	24,08	61,38
23,08	24,09	61,39
23,09	24,10	61,41
23,10	24,11	61,43
23,11	24,12	61,45
23,12	24,13	61,47
23,13	24,14	61,48
23,14	24,15	61,50
23,15	24,16	61,52
23,16	24,17	61,54
23,17	24,18	61,56
23,18	24,19	61,57
23,19	24,20	61,59
23,20	24,21	61,61
23,21	24,22	61,63
23,22	24,23	61,65
23,23	24,24	61,66
23,24	24,25	61,68
23,25	24,26	61,70
23,26	24,27	61,72
23,27	24,28	61,74
23,28	24,29	61,75
23,29	24,30	61,77
23,30	24,31	61,79
23,31	24,32	61,81
23,32	24,33	61,83
23,33	24,34	61,84
23,34	24,35	61,86
23,35	24,36	61,88
23,36	24,37	61,90
23,37	24,38	61,91
23,38	24,39	61,93
23,39	24,40	61,95
23,40	24,41	61,97
23,41	24,42	61,99
23,42	24,43	62,00
23,43	24,44	62,02
23,44	24,45	62,04
23,45	24,46	62,06
23,46	24,47	62,08
23,47	24,48	62,09
23,48	24,49	62,11



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,49	24,50	62,13
23,50	24,51	62,15
23,51	24,52	62,16
23,52	24,53	62,18
23,53	24,54	62,20
23,54	24,55	62,22
23,55	24,56	62,24
23,56	24,57	62,25
23,57	24,58	62,27
23,58	24,59	62,29
23,59	24,60	62,31
23,60	24,61	62,32
23,61	24,62	62,34
23,62	24,63	62,36
23,63	24,64	62,38
23,64	24,65	62,40
23,65	24,66	62,41
23,66	24,67	62,43
23,67	24,68	62,45
23,68	24,69	62,47
23,69	24,70	62,48
23,70	24,71	62,50
23,71	24,72	62,52
23,72	24,73	62,54
23,73	24,74	62,55
23,74	24,75	62,57
23,75	24,76	62,59
23,76	24,77	62,61
23,77	24,78	62,62
23,78	24,79	62,64
23,79	24,80	62,66
23,80	24,81	62,68
23,81	24,82	62,70
23,82	24,83	62,71
23,83	24,84	62,73
23,84	24,85	62,75
23,85	24,86	62,77
23,86	24,87	62,78
23,87	24,88	62,80
23,88	24,89	62,82
23,89	24,90	62,84
23,90	24,91	62,85
23,91	24,92	62,87
23,92	24,93	62,89



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,93	24,94	62,91
23,94	24,95	62,92
23,95	24,96	62,94
23,96	24,97	62,96
23,97	24,98	62,98
23,98	24,99	62,99
23,99	25,00	63,01
24,00	25,01	63,03
24,01	25,02	63,05
24,02	25,03	63,06
24,03	25,04	63,08
24,04	25,05	63,10
24,05	25,06	63,12
24,06	25,07	63,13
24,07	25,08	63,15
24,08	25,09	63,17
24,09	25,10	63,19
24,10	25,11	63,20
24,11	25,12	63,22
24,12	25,13	63,24
24,13	25,14	63,26
24,14	25,15	63,27
24,15	25,16	63,29
24,16	25,17	63,31
24,17	25,18	63,33
24,18	25,19	63,34
24,19	25,20	63,36
24,20	25,21	63,38
24,21	25,22	63,39
24,22	25,23	63,41
24,23	25,24	63,43
24,24	25,25	63,45
24,25	25,26	63,46
24,26	25,27	63,48
24,27	25,28	63,50
24,28	25,29	63,52
24,29	25,30	63,53
24,30	25,31	63,55
24,31	25,32	63,57
24,32	25,33	63,59
24,33	25,34	63,60
24,34	25,35	63,62
24,35	25,36	63,64
24,36	25,37	63,65



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,37	25,38	63,67
24,38	25,39	63,69
24,39	25,40	63,71
24,40	25,41	63,72
24,41	25,42	63,74
24,42	25,43	63,76
24,43	25,44	63,78
24,44	25,45	63,79
24,45	25,46	63,81
24,46	25,47	63,83
24,47	25,48	63,84
24,48	25,49	63,86
24,49	25,50	63,88
24,50	25,51	63,90
24,51	25,52	63,91
24,52	25,53	63,93
24,53	25,54	63,95
24,54	25,55	63,97
24,55	25,56	63,98
24,56	25,57	64,00
24,57	25,58	64,02
24,58	25,59	64,03
24,59	25,60	64,05
24,60	25,61	64,07
24,61	25,62	64,09
24,62	25,63	64,10
24,63	25,64	64,12
24,64	25,65	64,14
24,65	25,66	64,15
24,66	25,67	64,17
24,67	25,68	64,19
24,68	25,69	64,21
24,69	25,70	64,22
24,70	25,71	64,24
24,71	25,72	64,26
24,72	25,73	64,27
24,73	25,74	64,29
24,74	25,75	64,31
24,75	25,76	64,33
24,76	25,77	64,34
24,77	25,78	64,36
24,78	25,79	64,38
24,79	25,80	64,39
24,80	25,81	64,41



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	64,43
24,82	25,83	64,44
24,83	25,84	64,46
24,84	25,85	64,48
24,85	25,86	64,50
24,86	25,87	64,51
24,87	25,88	64,53
24,88	25,89	64,55
24,89	25,90	64,56
24,90	25,91	64,58
24,91	25,92	64,60
24,92	25,93	64,61
24,93	25,94	64,63
24,94	25,95	64,65
24,95	25,96	64,67
24,96	25,97	64,68
24,97	25,98	64,70
24,98	25,99	64,72
24,99	26,00	64,73
25,00	26,01	64,75
25,01	26,02	64,77
25,02	26,03	64,78
25,03	26,04	64,80
25,04	26,05	64,82
25,05	26,06	64,84
25,06	26,07	64,85
25,07	26,08	64,87
25,08	26,09	64,89
25,09	26,10	64,90
25,10	26,11	64,92
25,11	26,12	64,94
25,12	26,13	64,95
25,13	26,14	64,97
25,14	26,15	64,99
25,15	26,16	65,00
25,16	26,17	65,02
25,17	26,18	65,04
25,18	26,19	65,05
25,19	26,20	65,07
25,20	26,21	65,09
25,21	26,22	65,11
25,22	26,23	65,12
25,23	26,24	65,14
25,24	26,25	65,16



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	65,17
25,26	26,27	65,19
25,27	26,28	65,21
25,28	26,29	65,22
25,29	26,30	65,24
25,30	26,31	65,26
25,31	26,32	65,27
25,32	26,33	65,29
25,33	26,34	65,31
25,34	26,35	65,32
25,35	26,36	65,34
25,36	26,37	65,36
25,37	26,38	65,37
25,38	26,39	65,39
25,39	26,40	65,41
25,40	26,41	65,42
25,41	26,42	65,44
25,42	26,43	65,46
25,43	26,44	65,47
25,44	26,45	65,49
25,45	26,46	65,51
25,46	26,47	65,52
25,47	26,48	65,54
25,48	26,49	65,56
25,49	26,50	65,57
25,50	26,51	65,59
25,51	26,52	65,61
25,52	26,53	65,62
25,53	26,54	65,64
25,54	26,55	65,66
25,55	26,56	65,67
25,56	26,57	65,69
25,57	26,58	65,71
25,58	26,59	65,72
25,59	26,60	65,74
25,60	26,61	65,76
25,61	26,62	65,77
25,62	26,63	65,79
25,63	26,64	65,81
25,64	26,65	65,82
25,65	26,66	65,84
25,66	26,67	65,86
25,67	26,68	65,87
25,68	26,69	65,89



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,69	26,70	65,91
25,70	26,71	65,92
25,71	26,72	65,94
25,72	26,73	65,96
25,73	26,74	65,97
25,74	26,75	65,99
25,75	26,76	66,01
25,76	26,77	66,02
25,77	26,78	66,04
25,78	26,79	66,06
25,79	26,80	66,07
25,80	26,81	66,09
25,81	26,82	66,11
25,82	26,83	66,12
25,83	26,84	66,14
25,84	26,85	66,16
25,85	26,86	66,17
25,86	26,87	66,19
25,87	26,88	66,20
25,88	26,89	66,22
25,89	26,90	66,24
25,90	26,91	66,25
25,91	26,92	66,27
25,92	26,93	66,29
25,93	26,94	66,30
25,94	26,95	66,32
25,95	26,96	66,34
25,96	26,97	66,35
25,97	26,98	66,37
25,98	26,99	66,39
25,99	27,00	66,40
26,00	27,01	66,42
26,01	27,02	66,44
26,02	27,03	66,45
26,03	27,04	66,47
26,04	27,05	66,48
26,05	27,06	66,50
26,06	27,07	66,52
26,07	27,08	66,53
26,08	27,09	66,55
26,09	27,10	66,57
26,10	27,11	66,58
26,11	27,12	66,60
26,12	27,13	66,62



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	66,63
26,14	27,15	66,65
26,15	27,16	66,66
26,16	27,17	66,68
26,17	27,18	66,70
26,18	27,19	66,71
26,19	27,20	66,73
26,20	27,21	66,75
26,21	27,22	66,76
26,22	27,23	66,78
26,23	27,24	66,80
26,24	27,25	66,81
26,25	27,26	66,83
26,26	27,27	66,84
26,27	27,28	66,86
26,28	27,29	66,88
26,29	27,30	66,89
26,30	27,31	66,91
26,31	27,32	66,93
26,32	27,33	66,94
26,33	27,34	66,96
26,34	27,35	66,97
26,35	27,36	66,99
26,36	27,37	67,01
26,37	27,38	67,02
26,38	27,39	67,04
26,39	27,40	67,06
26,40	27,41	67,07
26,41	27,42	67,09
26,42	27,43	67,10
26,43	27,44	67,12
26,44	27,45	67,14
26,45	27,46	67,15
26,46	27,47	67,17
26,47	27,48	67,19
26,48	27,49	67,20
26,49	27,50	67,22
26,50	27,51	67,23
26,51	27,52	67,25
26,52	27,53	67,27
26,53	27,54	67,28
26,54	27,55	67,30
26,55	27,56	67,31
26,56	27,57	67,33



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
26,57	27,58	67,35
26,58	27,59	67,36
26,59	27,60	67,38
26,60	27,61	67,40
26,61	27,62	67,41
26,62	27,63	67,43
26,63	27,64	67,44
26,64	27,65	67,46
26,65	27,66	67,48
26,66	27,67	67,49
26,67	27,68	67,51
26,68	27,69	67,52
26,69	27,70	67,54
26,70	27,71	67,56
26,71	27,72	67,57
26,72	27,73	67,59
26,73	27,74	67,60
26,74	27,75	67,62
26,75	27,76	67,64
26,76	27,77	67,65
26,77	27,78	67,67
26,78	27,79	67,68
26,79	27,80	67,70
26,80	27,81	67,72
26,81	27,82	67,73
26,82	27,83	67,75
26,83	27,84	67,77
26,84	27,85	67,78
26,85	27,86	67,80
26,86	27,87	67,81
26,87	27,88	67,83
26,88	27,89	67,85
26,89	27,90	67,86
26,90	27,91	67,88
26,91	27,92	67,89
26,92	27,93	67,91
26,93	27,94	67,93
26,94	27,95	67,94
26,95	27,96	67,96
26,96	27,97	67,97
26,97	27,98	67,99
26,98	27,99	68,00
26,99	28,00	68,02
27,00	28,01	68,04



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	68,05
27,02	28,03	68,07
27,03	28,04	68,08
27,04	28,05	68,10
27,05	28,06	68,12
27,06	28,07	68,13
27,07	28,08	68,15
27,08	28,09	68,16
27,09	28,10	68,18
27,10	28,11	68,20
27,11	28,12	68,21
27,12	28,13	68,23
27,13	28,14	68,24
27,14	28,15	68,26
27,15	28,16	68,28
27,16	28,17	68,29
27,17	28,18	68,31
27,18	28,19	68,32
27,19	28,20	68,34
27,20	28,21	68,35
27,21	28,22	68,37
27,22	28,23	68,39
27,23	28,24	68,40
27,24	28,25	68,42
27,25	28,26	68,43
27,26	28,27	68,45
27,27	28,28	68,47
27,28	28,29	68,48
27,29	28,30	68,50
27,30	28,31	68,51
27,31	28,32	68,53
27,32	28,33	68,54
27,33	28,34	68,56
27,34	28,35	68,58
27,35	28,36	68,59
27,36	28,37	68,61
27,37	28,38	68,62
27,38	28,39	68,64
27,39	28,40	68,65
27,40	28,41	68,67
27,41	28,42	68,69
27,42	28,43	68,70
27,43	28,44	68,72
27,44	28,45	68,73



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	68,75
27,46	28,47	68,76
27,47	28,48	68,78
27,48	28,49	68,80
27,49	28,50	68,81
27,50	28,51	68,83
27,51	28,52	68,84
27,52	28,53	68,86
27,53	28,54	68,87
27,54	28,55	68,89
27,55	28,56	68,91
27,56	28,57	68,92
27,57	28,58	68,94
27,58	28,59	68,95
27,59	28,60	68,97
27,60	28,61	68,98
27,61	28,62	69,00
27,62	28,63	69,02
27,63	28,64	69,03
27,64	28,65	69,05
27,65	28,66	69,06
27,66	28,67	69,08
27,67	28,68	69,09
27,68	28,69	69,11
27,69	28,70	69,12
27,70	28,71	69,14
27,71	28,72	69,16
27,72	28,73	69,17
27,73	28,74	69,19
27,74	28,75	69,20
27,75	28,76	69,22
27,76	28,77	69,23
27,77	28,78	69,25
27,78	28,79	69,27
27,79	28,80	69,28
27,80	28,81	69,30
27,81	28,82	69,31
27,82	28,83	69,33
27,83	28,84	69,34
27,84	28,85	69,36
27,85	28,86	69,37
27,86	28,87	69,39
27,87	28,88	69,40
27,88	28,89	69,42



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	69,44
27,90	28,91	69,45
27,91	28,92	69,47
27,92	28,93	69,48
27,93	28,94	69,50
27,94	28,95	69,51
27,95	28,96	69,53
27,96	28,97	69,54
27,97	28,98	69,56
27,98	28,99	69,58
27,99	29,00	69,59
28,00	29,01	69,61
28,01	29,02	69,62
28,02	29,03	69,64
28,03	29,04	69,65
28,04	29,05	69,67
28,05	29,06	69,68
28,06	29,07	69,70
28,07	29,08	69,71
28,08	29,09	69,73
28,09	29,10	69,75
28,10	29,11	69,76
28,11	29,12	69,78
28,12	29,13	69,79
28,13	29,14	69,81
28,14	29,15	69,82
28,15	29,16	69,84
28,16	29,17	69,85
28,17	29,18	69,87
28,18	29,19	69,88
28,19	29,20	69,90
28,20	29,21	69,91
28,21	29,22	69,93
28,22	29,23	69,95
28,23	29,24	69,96
28,24	29,25	69,98
28,25	29,26	69,99
28,26	29,27	70,01
28,27	29,28	70,02
28,28	29,29	70,04
28,29	29,30	70,05
28,30	29,31	70,07
28,31	29,32	70,08
28,32	29,33	70,10



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	70,11
28,34	29,35	70,13
28,35	29,36	70,14
28,36	29,37	70,16
28,37	29,38	70,18
28,38	29,39	70,19
28,39	29,40	70,21
28,40	29,41	70,22
28,41	29,42	70,24
28,42	29,43	70,25
28,43	29,44	70,27
28,44	29,45	70,28
28,45	29,46	70,30
28,46	29,47	70,31
28,47	29,48	70,33
28,48	29,49	70,34
28,49	29,50	70,36
28,50	29,51	70,37
28,51	29,52	70,39
28,52	29,53	70,40
28,53	29,54	70,42
28,54	29,55	70,43
28,55	29,56	70,45
28,56	29,57	70,47
28,57	29,58	70,48
28,58	29,59	70,50
28,59	29,60	70,51
28,60	29,61	70,53
28,61	29,62	70,54
28,62	29,63	70,56
28,63	29,64	70,57
28,64	29,65	70,59
28,65	29,66	70,60
28,66	29,67	70,62
28,67	29,68	70,63
28,68	29,69	70,65
28,69	29,70	70,66
28,70	29,71	70,68
28,71	29,72	70,69
28,72	29,73	70,71
28,73	29,74	70,72
28,74	29,75	70,74
28,75	29,76	70,75
28,76	29,77	70,77



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	70,78
28,78	29,79	70,80
28,79	29,80	70,81
28,80	29,81	70,83
28,81	29,82	70,84
28,82	29,83	70,86
28,83	29,84	70,87
28,84	29,85	70,89
28,85	29,86	70,90
28,86	29,87	70,92
28,87	29,88	70,93
28,88	29,89	70,95
28,89	29,90	70,96
28,90	29,91	70,98
28,91	29,92	70,99
28,92	29,93	71,01
28,93	29,94	71,02
28,94	29,95	71,04
28,95	29,96	71,05
28,96	29,97	71,07
28,97	29,98	71,08
28,98	29,99	71,10
28,99	30,00	71,12
29,00	30,01	71,13
29,01	30,02	71,15
29,02	30,03	71,16
29,03	30,04	71,18
29,04	30,05	71,19
29,05	30,06	71,21
29,06	30,07	71,22
29,07	30,08	71,23
29,08	30,09	71,25
29,09	30,10	71,26
29,10	30,11	71,28
29,11	30,12	71,29
29,12	30,13	71,31
29,13	30,14	71,32
29,14	30,15	71,34
29,15	30,16	71,35
29,16	30,17	71,37
29,17	30,18	71,38
29,18	30,19	71,40
29,19	30,20	71,41
29,20	30,21	71,43



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	71,44
29,22	30,23	71,46
29,23	30,24	71,47
29,24	30,25	71,49
29,25	30,26	71,50
29,26	30,27	71,52
29,27	30,28	71,53
29,28	30,29	71,55
29,29	30,30	71,56
29,30	30,31	71,58
29,31	30,32	71,59
29,32	30,33	71,61
29,33	30,34	71,62
29,34	30,35	71,64
29,35	30,36	71,65
29,36	30,37	71,67
29,37	30,38	71,68
29,38	30,39	71,70
29,39	30,40	71,71
29,40	30,41	71,73
29,41	30,42	71,74
29,42	30,43	71,76
29,43	30,44	71,77
29,44	30,45	71,79
29,45	30,46	71,80
29,46	30,47	71,82
29,47	30,48	71,83
29,48	30,49	71,85
29,49	30,50	71,86
29,50	30,51	71,88
29,51	30,52	71,89
29,52	30,53	71,90
29,53	30,54	71,92
29,54	30,55	71,93
29,55	30,56	71,95
29,56	30,57	71,96
29,57	30,58	71,98
29,58	30,59	71,99
29,59	30,60	72,01
29,60	30,61	72,02
29,61	30,62	72,04
29,62	30,63	72,05
29,63	30,64	72,07
29,64	30,65	72,08



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
29,65	30,66	72,10
29,66	30,67	72,11
29,67	30,68	72,13
29,68	30,69	72,14
29,69	30,70	72,16
29,70	30,71	72,17
29,71	30,72	72,18
29,72	30,73	72,20
29,73	30,74	72,21
29,74	30,75	72,23
29,75	30,76	72,24
29,76	30,77	72,26
29,77	30,78	72,27
29,78	30,79	72,29
29,79	30,80	72,30
29,80	30,81	72,32
29,81	30,82	72,33
29,82	30,83	72,35
29,83	30,84	72,36
29,84	30,85	72,38
29,85	30,86	72,39
29,86	30,87	72,40
29,87	30,88	72,42
29,88	30,89	72,43
29,89	30,90	72,45
29,90	30,91	72,46
29,91	30,92	72,48
29,92	30,93	72,49
29,93	30,94	72,51
29,94	30,95	72,52
29,95	30,96	72,54
29,96	30,97	72,55
29,97	30,98	72,57
29,98	30,99	72,58
29,99	31,00	72,59
30,00	31,01	72,61
30,01	31,02	72,62
30,02	31,03	72,64
30,03	31,04	72,65
30,04	31,05	72,67
30,05	31,06	72,68
30,06	31,07	72,70
30,07	31,08	72,71
30,08	31,09	72,73



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,09	31,10	72,74
30,10	31,11	72,75
30,11	31,12	72,77
30,12	31,13	72,78
30,13	31,14	72,80
30,14	31,15	72,81
30,15	31,16	72,83
30,16	31,17	72,84
30,17	31,18	72,86
30,18	31,19	72,87
30,19	31,20	72,89
30,20	31,21	72,90
30,21	31,22	72,91
30,22	31,23	72,93
30,23	31,24	72,94
30,24	31,25	72,96
30,25	31,26	72,97
30,26	31,27	72,99
30,27	31,28	73,00
30,28	31,29	73,02
30,29	31,30	73,03
30,30	31,31	73,04
30,31	31,32	73,06
30,32	31,33	73,07
30,33	31,34	73,09
30,34	31,35	73,10
30,35	31,36	73,12
30,36	31,37	73,13
30,37	31,38	73,15
30,38	31,39	73,16
30,39	31,40	73,17
30,40	31,41	73,19
30,41	31,42	73,20
30,42	31,43	73,22
30,43	31,44	73,23
30,44	31,45	73,25
30,45	31,46	73,26
30,46	31,47	73,28
30,47	31,48	73,29
30,48	31,49	73,30
30,49	31,50	73,32
30,50	31,51	73,33
30,51	31,52	73,35
30,52	31,53	73,36



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	73,38
30,54	31,55	73,39
30,55	31,56	73,40
30,56	31,57	73,42
30,57	31,58	73,43
30,58	31,59	73,45
30,59	31,60	73,46
30,60	31,61	73,48
30,61	31,62	73,49
30,62	31,63	73,51
30,63	31,64	73,52
30,64	31,65	73,53
30,65	31,66	73,55
30,66	31,67	73,56
30,67	31,68	73,58
30,68	31,69	73,59
30,69	31,70	73,61
30,70	31,71	73,62
30,71	31,72	73,63
30,72	31,73	73,65
30,73	31,74	73,66
30,74	31,75	73,68
30,75	31,76	73,69
30,76	31,77	73,71
30,77	31,78	73,72
30,78	31,79	73,73
30,79	31,80	73,75
30,80	31,81	73,76
30,81	31,82	73,78
30,82	31,83	73,79
30,83	31,84	73,80
30,84	31,85	73,82
30,85	31,86	73,83
30,86	31,87	73,85
30,87	31,88	73,86
30,88	31,89	73,88
30,89	31,90	73,89
30,90	31,91	73,90
30,91	31,92	73,92
30,92	31,93	73,93
30,93	31,94	73,95
30,94	31,95	73,96
30,95	31,96	73,98
30,96	31,97	73,99



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,97	31,98	74,00
30,98	31,99	74,02
30,99	32,00	74,03
31,00	32,01	74,05
31,01	32,02	74,06
31,02	32,03	74,07
31,03	32,04	74,09
31,04	32,05	74,10
31,05	32,06	74,12
31,06	32,07	74,13
31,07	32,08	74,15
31,08	32,09	74,16
31,09	32,10	74,17
31,10	32,11	74,19
31,11	32,12	74,20
31,12	32,13	74,22
31,13	32,14	74,23
31,14	32,15	74,24
31,15	32,16	74,26
31,16	32,17	74,27
31,17	32,18	74,29
31,18	32,19	74,30
31,19	32,20	74,31
31,20	32,21	74,33
31,21	32,22	74,34
31,22	32,23	74,36
31,23	32,24	74,37
31,24	32,25	74,38
31,25	32,26	74,40
31,26	32,27	74,41
31,27	32,28	74,43
31,28	32,29	74,44
31,29	32,30	74,46
31,30	32,31	74,47
31,31	32,32	74,48
31,32	32,33	74,50
31,33	32,34	74,51
31,34	32,35	74,53
31,35	32,36	74,54
31,36	32,37	74,55
31,37	32,38	74,57
31,38	32,39	74,58
31,39	32,40	74,60
31,40	32,41	74,61



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	74,62
31,42	32,43	74,64
31,43	32,44	74,65
31,44	32,45	74,67
31,45	32,46	74,68
31,46	32,47	74,69
31,47	32,48	74,71
31,48	32,49	74,72
31,49	32,50	74,74
31,50	32,51	74,75
31,51	32,52	74,76
31,52	32,53	74,78
31,53	32,54	74,79
31,54	32,55	74,80
31,55	32,56	74,82
31,56	32,57	74,83
31,57	32,58	74,85
31,58	32,59	74,86
31,59	32,60	74,87
31,60	32,61	74,89
31,61	32,62	74,90
31,62	32,63	74,92
31,63	32,64	74,93
31,64	32,65	74,94
31,65	32,66	74,96
31,66	32,67	74,97
31,67	32,68	74,99
31,68	32,69	75,00
31,69	32,70	75,01
31,70	32,71	75,03
31,71	32,72	75,04
31,72	32,73	75,06
31,73	32,74	75,07
31,74	32,75	75,08
31,75	32,76	75,10
31,76	32,77	75,11
31,77	32,78	75,12
31,78	32,79	75,14
31,79	32,80	75,15
31,80	32,81	75,17
31,81	32,82	75,18
31,82	32,83	75,19
31,83	32,84	75,21
31,84	32,85	75,22



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	75,24
31,86	32,87	75,25
31,87	32,88	75,26
31,88	32,89	75,28
31,89	32,90	75,29
31,90	32,91	75,30
31,91	32,92	75,32
31,92	32,93	75,33
31,93	32,94	75,35
31,94	32,95	75,36
31,95	32,96	75,37
31,96	32,97	75,39
31,97	32,98	75,40
31,98	32,99	75,41
31,99	33,00	75,43
32,00	33,01	75,44
32,01	33,02	75,46
32,02	33,03	75,47
32,03	33,04	75,48
32,04	33,05	75,50
32,05	33,06	75,51
32,06	33,07	75,52
32,07	33,08	75,54
32,08	33,09	75,55
32,09	33,10	75,57
32,10	33,11	75,58
32,11	33,12	75,59
32,12	33,13	75,61
32,13	33,14	75,62
32,14	33,15	75,63
32,15	33,16	75,65
32,16	33,17	75,66
32,17	33,18	75,68
32,18	33,19	75,69
32,19	33,20	75,70
32,20	33,21	75,72
32,21	33,22	75,73
32,22	33,23	75,74
32,23	33,24	75,76
32,24	33,25	75,77
32,25	33,26	75,78
32,26	33,27	75,80
32,27	33,28	75,81
32,28	33,29	75,83



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	75,84
32,30	33,31	75,85
32,31	33,32	75,87
32,32	33,33	75,88
32,33	33,34	75,89
32,34	33,35	75,91
32,35	33,36	75,92
32,36	33,37	75,93
32,37	33,38	75,95
32,38	33,39	75,96
32,39	33,40	75,98
32,40	33,41	75,99
32,41	33,42	76,00
32,42	33,43	76,02
32,43	33,44	76,03
32,44	33,45	76,04
32,45	33,46	76,06
32,46	33,47	76,07
32,47	33,48	76,08
32,48	33,49	76,10
32,49	33,50	76,11
32,50	33,51	76,13
32,51	33,52	76,14
32,52	33,53	76,15
32,53	33,54	76,17
32,54	33,55	76,18
32,55	33,56	76,19
32,56	33,57	76,21
32,57	33,58	76,22
32,58	33,59	76,23
32,59	33,60	76,25
32,60	33,61	76,26
32,61	33,62	76,27
32,62	33,63	76,29
32,63	33,64	76,30
32,64	33,65	76,31
32,65	33,66	76,33
32,66	33,67	76,34
32,67	33,68	76,36
32,68	33,69	76,37
32,69	33,70	76,38
32,70	33,71	76,40
32,71	33,72	76,41
32,72	33,73	76,42



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,73	33,74	76,44
32,74	33,75	76,45
32,75	33,76	76,46
32,76	33,77	76,48
32,77	33,78	76,49
32,78	33,79	76,50
32,79	33,80	76,52
32,80	33,81	76,53
32,81	33,82	76,54
32,82	33,83	76,56
32,83	33,84	76,57
32,84	33,85	76,58
32,85	33,86	76,60
32,86	33,87	76,61
32,87	33,88	76,62
32,88	33,89	76,64
32,89	33,90	76,65
32,90	33,91	76,66
32,91	33,92	76,68
32,92	33,93	76,69
32,93	33,94	76,71
32,94	33,95	76,72
32,95	33,96	76,73
32,96	33,97	76,75
32,97	33,98	76,76
32,98	33,99	76,77
32,99	34,00	76,79
33,00	34,01	76,80
33,01	34,02	76,81
33,02	34,03	76,83
33,03	34,04	76,84
33,04	34,05	76,85
33,05	34,06	76,87
33,06	34,07	76,88
33,07	34,08	76,89
33,08	34,09	76,91
33,09	34,10	76,92
33,10	34,11	76,93
33,11	34,12	76,95
33,12	34,13	76,96
33,13	34,14	76,97
33,14	34,15	76,99
33,15	34,16	77,00
33,16	34,17	77,01



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,17	34,18	77,03
33,18	34,19	77,04
33,19	34,20	77,05
33,20	34,21	77,07
33,21	34,22	77,08
33,22	34,23	77,09
33,23	34,24	77,11
33,24	34,25	77,12
33,25	34,26	77,13
33,26	34,27	77,15
33,27	34,28	77,16
33,28	34,29	77,17
33,29	34,30	77,19
33,30	34,31	77,20
33,31	34,32	77,21
33,32	34,33	77,23
33,33	34,34	77,24
33,34	34,35	77,25
33,35	34,36	77,26
33,36	34,37	77,28
33,37	34,38	77,29
33,38	34,39	77,30
33,39	34,40	77,32
33,40	34,41	77,33
33,41	34,42	77,34
33,42	34,43	77,36
33,43	34,44	77,37
33,44	34,45	77,38
33,45	34,46	77,40
33,46	34,47	77,41
33,47	34,48	77,42
33,48	34,49	77,44
33,49	34,50	77,45
33,50	34,51	77,46
33,51	34,52	77,48
33,52	34,53	77,49
33,53	34,54	77,50
33,54	34,55	77,52
33,55	34,56	77,53
33,56	34,57	77,54
33,57	34,58	77,56
33,58	34,59	77,57
33,59	34,60	77,58
33,60	34,61	77,60



R421A		
V1.0_R421A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
33,61	34,62	77,61
33,62	34,63	77,62
33,63	34,64	77,63
33,64	34,65	77,65
33,65	34,66	77,66
33,66	34,67	77,67
33,67	34,68	77,69
33,68	34,69	77,70
33,69	34,70	77,71
33,70	34,71	77,73
33,71	34,72	77,74
33,72	34,73	77,75
33,73	34,74	77,77