



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-65,89
-0,70	0,31	-65,37
-0,69	0,32	-64,86
-0,68	0,33	-64,37
-0,67	0,34	-63,88
-0,66	0,35	-63,41
-0,65	0,36	-62,95
-0,64	0,37	-62,50
-0,63	0,38	-62,05
-0,62	0,39	-61,62
-0,61	0,40	-61,20
-0,60	0,41	-60,78
-0,59	0,42	-60,38
-0,58	0,43	-59,98
-0,57	0,44	-59,58
-0,56	0,45	-59,20
-0,55	0,46	-58,82
-0,54	0,47	-58,45
-0,53	0,48	-58,08
-0,52	0,49	-57,72
-0,51	0,50	-57,37
-0,50	0,51	-57,02
-0,49	0,52	-56,68
-0,48	0,53	-56,34
-0,47	0,54	-56,01
-0,46	0,55	-55,68
-0,45	0,56	-55,36
-0,44	0,57	-55,04
-0,43	0,58	-54,73
-0,42	0,59	-54,42
-0,41	0,60	-54,11
-0,40	0,61	-53,81
-0,39	0,62	-53,51
-0,38	0,63	-53,22
-0,37	0,64	-52,93
-0,36	0,65	-52,64
-0,35	0,66	-52,36
-0,34	0,67	-52,08
-0,33	0,68	-51,81
-0,32	0,69	-51,53
-0,31	0,70	-51,26
-0,30	0,71	-51,00
-0,29	0,72	-50,73
-0,28	0,73	-50,47



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-50,21
-0,26	0,75	-49,96
-0,25	0,76	-49,70
-0,24	0,77	-49,45
-0,23	0,78	-49,20
-0,22	0,79	-48,96
-0,21	0,80	-48,72
-0,20	0,81	-48,48
-0,19	0,82	-48,24
-0,18	0,83	-48,00
-0,17	0,84	-47,77
-0,16	0,85	-47,54
-0,15	0,86	-47,31
-0,14	0,87	-47,08
-0,13	0,88	-46,86
-0,12	0,89	-46,63
-0,11	0,90	-46,41
-0,10	0,91	-46,19
-0,09	0,92	-45,97
-0,08	0,93	-45,76
-0,07	0,94	-45,54
-0,06	0,95	-45,33
-0,05	0,96	-45,12
-0,04	0,97	-44,91
-0,03	0,98	-44,71
-0,02	0,99	-44,50
-0,01	1,00	-44,30
0,00	1,01	-44,10
0,01	1,02	-43,90
0,02	1,03	-43,70
0,03	1,04	-43,50
0,04	1,05	-43,30
0,05	1,06	-43,11
0,06	1,07	-42,92
0,07	1,08	-42,72
0,08	1,09	-42,53
0,09	1,10	-42,35
0,10	1,11	-42,16
0,11	1,12	-41,97
0,12	1,13	-41,79
0,13	1,14	-41,60
0,14	1,15	-41,42
0,15	1,16	-41,24
0,16	1,17	-41,06



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,17	1,18	-40,88
0,18	1,19	-40,70
0,19	1,20	-40,53
0,20	1,21	-40,35
0,21	1,22	-40,18
0,22	1,23	-40,00
0,23	1,24	-39,83
0,24	1,25	-39,66
0,25	1,26	-39,49
0,26	1,27	-39,32
0,27	1,28	-39,16
0,28	1,29	-38,99
0,29	1,30	-38,82
0,30	1,31	-38,66
0,31	1,32	-38,49
0,32	1,33	-38,33
0,33	1,34	-38,17
0,34	1,35	-38,01
0,35	1,36	-37,85
0,36	1,37	-37,69
0,37	1,38	-37,53
0,38	1,39	-37,37
0,39	1,40	-37,22
0,40	1,41	-37,06
0,41	1,42	-36,91
0,42	1,43	-36,75
0,43	1,44	-36,60
0,44	1,45	-36,45
0,45	1,46	-36,30
0,46	1,47	-36,15
0,47	1,48	-36,00
0,48	1,49	-35,85
0,49	1,50	-35,70
0,50	1,51	-35,55
0,51	1,52	-35,40
0,52	1,53	-35,26
0,53	1,54	-35,11
0,54	1,55	-34,97
0,55	1,56	-34,83
0,56	1,57	-34,68
0,57	1,58	-34,54
0,58	1,59	-34,40
0,59	1,60	-34,26
0,60	1,61	-34,12



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
0,61	1,62	-33,98
0,62	1,63	-33,84
0,63	1,64	-33,70
0,64	1,65	-33,56
0,65	1,66	-33,43
0,66	1,67	-33,29
0,67	1,68	-33,15
0,68	1,69	-33,02
0,69	1,70	-32,88
0,70	1,71	-32,75
0,71	1,72	-32,62
0,72	1,73	-32,48
0,73	1,74	-32,35
0,74	1,75	-32,22
0,75	1,76	-32,09
0,76	1,77	-31,96
0,77	1,78	-31,83
0,78	1,79	-31,70
0,79	1,80	-31,57
0,80	1,81	-31,44
0,81	1,82	-31,31
0,82	1,83	-31,19
0,83	1,84	-31,06
0,84	1,85	-30,94
0,85	1,86	-30,81
0,86	1,87	-30,68
0,87	1,88	-30,56
0,88	1,89	-30,44
0,89	1,90	-30,31
0,90	1,91	-30,19
0,91	1,92	-30,07
0,92	1,93	-29,95
0,93	1,94	-29,82
0,94	1,95	-29,70
0,95	1,96	-29,58
0,96	1,97	-29,46
0,97	1,98	-29,34
0,98	1,99	-29,22
0,99	2,00	-29,11
1,00	2,01	-28,99
1,01	2,02	-28,87
1,02	2,03	-28,75
1,03	2,04	-28,64
1,04	2,05	-28,52



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	-28,40
1,06	2,07	-28,29
1,07	2,08	-28,17
1,08	2,09	-28,06
1,09	2,10	-27,94
1,10	2,11	-27,83
1,11	2,12	-27,72
1,12	2,13	-27,60
1,13	2,14	-27,49
1,14	2,15	-27,38
1,15	2,16	-27,27
1,16	2,17	-27,15
1,17	2,18	-27,04
1,18	2,19	-26,93
1,19	2,20	-26,82
1,20	2,21	-26,71
1,21	2,22	-26,60
1,22	2,23	-26,49
1,23	2,24	-26,39
1,24	2,25	-26,28
1,25	2,26	-26,17
1,26	2,27	-26,06
1,27	2,28	-25,95
1,28	2,29	-25,85
1,29	2,30	-25,74
1,30	2,31	-25,63
1,31	2,32	-25,53
1,32	2,33	-25,42
1,33	2,34	-25,32
1,34	2,35	-25,21
1,35	2,36	-25,11
1,36	2,37	-25,00
1,37	2,38	-24,90
1,38	2,39	-24,80
1,39	2,40	-24,69
1,40	2,41	-24,59
1,41	2,42	-24,49
1,42	2,43	-24,39
1,43	2,44	-24,28
1,44	2,45	-24,18
1,45	2,46	-24,08
1,46	2,47	-23,98
1,47	2,48	-23,88
1,48	2,49	-23,78



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,49	2,50	-23,68
1,50	2,51	-23,58
1,51	2,52	-23,48
1,52	2,53	-23,38
1,53	2,54	-23,28
1,54	2,55	-23,18
1,55	2,56	-23,09
1,56	2,57	-22,99
1,57	2,58	-22,89
1,58	2,59	-22,79
1,59	2,60	-22,70
1,60	2,61	-22,60
1,61	2,62	-22,50
1,62	2,63	-22,41
1,63	2,64	-22,31
1,64	2,65	-22,22
1,65	2,66	-22,12
1,66	2,67	-22,03
1,67	2,68	-21,93
1,68	2,69	-21,84
1,69	2,70	-21,74
1,70	2,71	-21,65
1,71	2,72	-21,55
1,72	2,73	-21,46
1,73	2,74	-21,37
1,74	2,75	-21,27
1,75	2,76	-21,18
1,76	2,77	-21,09
1,77	2,78	-21,00
1,78	2,79	-20,91
1,79	2,80	-20,81
1,80	2,81	-20,72
1,81	2,82	-20,63
1,82	2,83	-20,54
1,83	2,84	-20,45
1,84	2,85	-20,36
1,85	2,86	-20,27
1,86	2,87	-20,18
1,87	2,88	-20,09
1,88	2,89	-20,00
1,89	2,90	-19,91
1,90	2,91	-19,82
1,91	2,92	-19,73
1,92	2,93	-19,64



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,93	2,94	-19,56
1,94	2,95	-19,47
1,95	2,96	-19,38
1,96	2,97	-19,29
1,97	2,98	-19,20
1,98	2,99	-19,12
1,99	3,00	-19,03
2,00	3,01	-18,94
2,01	3,02	-18,86
2,02	3,03	-18,77
2,03	3,04	-18,68
2,04	3,05	-18,60
2,05	3,06	-18,51
2,06	3,07	-18,43
2,07	3,08	-18,34
2,08	3,09	-18,26
2,09	3,10	-18,17
2,10	3,11	-18,09
2,11	3,12	-18,00
2,12	3,13	-17,92
2,13	3,14	-17,84
2,14	3,15	-17,75
2,15	3,16	-17,67
2,16	3,17	-17,58
2,17	3,18	-17,50
2,18	3,19	-17,42
2,19	3,20	-17,34
2,20	3,21	-17,25
2,21	3,22	-17,17
2,22	3,23	-17,09
2,23	3,24	-17,01
2,24	3,25	-16,92
2,25	3,26	-16,84
2,26	3,27	-16,76
2,27	3,28	-16,68
2,28	3,29	-16,60
2,29	3,30	-16,52
2,30	3,31	-16,44
2,31	3,32	-16,36
2,32	3,33	-16,28
2,33	3,34	-16,20
2,34	3,35	-16,12
2,35	3,36	-16,04
2,36	3,37	-15,96



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	-15,88
2,38	3,39	-15,80
2,39	3,40	-15,72
2,40	3,41	-15,64
2,41	3,42	-15,56
2,42	3,43	-15,48
2,43	3,44	-15,40
2,44	3,45	-15,33
2,45	3,46	-15,25
2,46	3,47	-15,17
2,47	3,48	-15,09
2,48	3,49	-15,02
2,49	3,50	-14,94
2,50	3,51	-14,86
2,51	3,52	-14,78
2,52	3,53	-14,71
2,53	3,54	-14,63
2,54	3,55	-14,55
2,55	3,56	-14,48
2,56	3,57	-14,40
2,57	3,58	-14,32
2,58	3,59	-14,25
2,59	3,60	-14,17
2,60	3,61	-14,10
2,61	3,62	-14,02
2,62	3,63	-13,95
2,63	3,64	-13,87
2,64	3,65	-13,80
2,65	3,66	-13,72
2,66	3,67	-13,65
2,67	3,68	-13,57
2,68	3,69	-13,50
2,69	3,70	-13,42
2,70	3,71	-13,35
2,71	3,72	-13,28
2,72	3,73	-13,20
2,73	3,74	-13,13
2,74	3,75	-13,06
2,75	3,76	-12,98
2,76	3,77	-12,91
2,77	3,78	-12,84
2,78	3,79	-12,76
2,79	3,80	-12,69
2,80	3,81	-12,62



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
2,81	3,82	-12,55
2,82	3,83	-12,47
2,83	3,84	-12,40
2,84	3,85	-12,33
2,85	3,86	-12,26
2,86	3,87	-12,19
2,87	3,88	-12,11
2,88	3,89	-12,04
2,89	3,90	-11,97
2,90	3,91	-11,90
2,91	3,92	-11,83
2,92	3,93	-11,76
2,93	3,94	-11,69
2,94	3,95	-11,62
2,95	3,96	-11,55
2,96	3,97	-11,48
2,97	3,98	-11,41
2,98	3,99	-11,34
2,99	4,00	-11,27
3,00	4,01	-11,20
3,01	4,02	-11,13
3,02	4,03	-11,06
3,03	4,04	-10,99
3,04	4,05	-10,92
3,05	4,06	-10,85
3,06	4,07	-10,78
3,07	4,08	-10,71
3,08	4,09	-10,64
3,09	4,10	-10,57
3,10	4,11	-10,51
3,11	4,12	-10,44
3,12	4,13	-10,37
3,13	4,14	-10,30
3,14	4,15	-10,23
3,15	4,16	-10,17
3,16	4,17	-10,10
3,17	4,18	-10,03
3,18	4,19	-9,96
3,19	4,20	-9,90
3,20	4,21	-9,83
3,21	4,22	-9,76
3,22	4,23	-9,69
3,23	4,24	-9,63
3,24	4,25	-9,56



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,25	4,26	-9,49
3,26	4,27	-9,43
3,27	4,28	-9,36
3,28	4,29	-9,29
3,29	4,30	-9,23
3,30	4,31	-9,16
3,31	4,32	-9,10
3,32	4,33	-9,03
3,33	4,34	-8,96
3,34	4,35	-8,90
3,35	4,36	-8,83
3,36	4,37	-8,77
3,37	4,38	-8,70
3,38	4,39	-8,64
3,39	4,40	-8,57
3,40	4,41	-8,51
3,41	4,42	-8,44
3,42	4,43	-8,38
3,43	4,44	-8,31
3,44	4,45	-8,25
3,45	4,46	-8,18
3,46	4,47	-8,12
3,47	4,48	-8,06
3,48	4,49	-7,99
3,49	4,50	-7,93
3,50	4,51	-7,86
3,51	4,52	-7,80
3,52	4,53	-7,74
3,53	4,54	-7,67
3,54	4,55	-7,61
3,55	4,56	-7,55
3,56	4,57	-7,48
3,57	4,58	-7,42
3,58	4,59	-7,36
3,59	4,60	-7,29
3,60	4,61	-7,23
3,61	4,62	-7,17
3,62	4,63	-7,11
3,63	4,64	-7,04
3,64	4,65	-6,98
3,65	4,66	-6,92
3,66	4,67	-6,86
3,67	4,68	-6,79
3,68	4,69	-6,73



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
3,69	4,70	-6,67
3,70	4,71	-6,61
3,71	4,72	-6,55
3,72	4,73	-6,48
3,73	4,74	-6,42
3,74	4,75	-6,36
3,75	4,76	-6,30
3,76	4,77	-6,24
3,77	4,78	-6,18
3,78	4,79	-6,12
3,79	4,80	-6,06
3,80	4,81	-6,00
3,81	4,82	-5,93
3,82	4,83	-5,87
3,83	4,84	-5,81
3,84	4,85	-5,75
3,85	4,86	-5,69
3,86	4,87	-5,63
3,87	4,88	-5,57
3,88	4,89	-5,51
3,89	4,90	-5,45
3,90	4,91	-5,39
3,91	4,92	-5,33
3,92	4,93	-5,27
3,93	4,94	-5,21
3,94	4,95	-5,15
3,95	4,96	-5,09
3,96	4,97	-5,03
3,97	4,98	-4,97
3,98	4,99	-4,92
3,99	5,00	-4,86
4,00	5,01	-4,80
4,01	5,02	-4,74
4,02	5,03	-4,68
4,03	5,04	-4,62
4,04	5,05	-4,56
4,05	5,06	-4,50
4,06	5,07	-4,45
4,07	5,08	-4,39
4,08	5,09	-4,33
4,09	5,10	-4,27
4,10	5,11	-4,21
4,11	5,12	-4,15
4,12	5,13	-4,10



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	-4,04
4,14	5,15	-3,98
4,15	5,16	-3,92
4,16	5,17	-3,87
4,17	5,18	-3,81
4,18	5,19	-3,75
4,19	5,20	-3,69
4,20	5,21	-3,64
4,21	5,22	-3,58
4,22	5,23	-3,52
4,23	5,24	-3,46
4,24	5,25	-3,41
4,25	5,26	-3,35
4,26	5,27	-3,29
4,27	5,28	-3,24
4,28	5,29	-3,18
4,29	5,30	-3,12
4,30	5,31	-3,07
4,31	5,32	-3,01
4,32	5,33	-2,95
4,33	5,34	-2,90
4,34	5,35	-2,84
4,35	5,36	-2,79
4,36	5,37	-2,73
4,37	5,38	-2,67
4,38	5,39	-2,62
4,39	5,40	-2,56
4,40	5,41	-2,51
4,41	5,42	-2,45
4,42	5,43	-2,40
4,43	5,44	-2,34
4,44	5,45	-2,28
4,45	5,46	-2,23
4,46	5,47	-2,17
4,47	5,48	-2,12
4,48	5,49	-2,06
4,49	5,50	-2,01
4,50	5,51	-1,95
4,51	5,52	-1,90
4,52	5,53	-1,84
4,53	5,54	-1,79
4,54	5,55	-1,73
4,55	5,56	-1,68
4,56	5,57	-1,63



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	-1,57
4,58	5,59	-1,52
4,59	5,60	-1,46
4,60	5,61	-1,41
4,61	5,62	-1,35
4,62	5,63	-1,30
4,63	5,64	-1,25
4,64	5,65	-1,19
4,65	5,66	-1,14
4,66	5,67	-1,08
4,67	5,68	-1,03
4,68	5,69	-0,98
4,69	5,70	-0,92
4,70	5,71	-0,87
4,71	5,72	-0,82
4,72	5,73	-0,76
4,73	5,74	-0,71
4,74	5,75	-0,66
4,75	5,76	-0,60
4,76	5,77	-0,55
4,77	5,78	-0,50
4,78	5,79	-0,45
4,79	5,80	-0,39
4,80	5,81	-0,34
4,81	5,82	-0,29
4,82	5,83	-0,23
4,83	5,84	-0,18
4,84	5,85	-0,13
4,85	5,86	-0,08
4,86	5,87	-0,02
4,87	5,88	0,03
4,88	5,89	0,08
4,89	5,90	0,13
4,90	5,91	0,18
4,91	5,92	0,24
4,92	5,93	0,29
4,93	5,94	0,34
4,94	5,95	0,39
4,95	5,96	0,44
4,96	5,97	0,50
4,97	5,98	0,55
4,98	5,99	0,60
4,99	6,00	0,65
5,00	6,01	0,70



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	0,75
5,02	6,03	0,81
5,03	6,04	0,86
5,04	6,05	0,91
5,05	6,06	0,96
5,06	6,07	1,01
5,07	6,08	1,06
5,08	6,09	1,11
5,09	6,10	1,16
5,10	6,11	1,21
5,11	6,12	1,26
5,12	6,13	1,32
5,13	6,14	1,37
5,14	6,15	1,42
5,15	6,16	1,47
5,16	6,17	1,52
5,17	6,18	1,57
5,18	6,19	1,62
5,19	6,20	1,67
5,20	6,21	1,72
5,21	6,22	1,77
5,22	6,23	1,82
5,23	6,24	1,87
5,24	6,25	1,92
5,25	6,26	1,97
5,26	6,27	2,02
5,27	6,28	2,07
5,28	6,29	2,12
5,29	6,30	2,17
5,30	6,31	2,22
5,31	6,32	2,27
5,32	6,33	2,32
5,33	6,34	2,37
5,34	6,35	2,42
5,35	6,36	2,46
5,36	6,37	2,51
5,37	6,38	2,56
5,38	6,39	2,61
5,39	6,40	2,66
5,40	6,41	2,71
5,41	6,42	2,76
5,42	6,43	2,81
5,43	6,44	2,86
5,44	6,45	2,91



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,45	6,46	2,96
5,46	6,47	3,00
5,47	6,48	3,05
5,48	6,49	3,10
5,49	6,50	3,15
5,50	6,51	3,20
5,51	6,52	3,25
5,52	6,53	3,29
5,53	6,54	3,34
5,54	6,55	3,39
5,55	6,56	3,44
5,56	6,57	3,49
5,57	6,58	3,54
5,58	6,59	3,58
5,59	6,60	3,63
5,60	6,61	3,68
5,61	6,62	3,73
5,62	6,63	3,78
5,63	6,64	3,82
5,64	6,65	3,87
5,65	6,66	3,92
5,66	6,67	3,97
5,67	6,68	4,01
5,68	6,69	4,06
5,69	6,70	4,11
5,70	6,71	4,16
5,71	6,72	4,20
5,72	6,73	4,25
5,73	6,74	4,30
5,74	6,75	4,35
5,75	6,76	4,39
5,76	6,77	4,44
5,77	6,78	4,49
5,78	6,79	4,53
5,79	6,80	4,58
5,80	6,81	4,63
5,81	6,82	4,67
5,82	6,83	4,72
5,83	6,84	4,77
5,84	6,85	4,81
5,85	6,86	4,86
5,86	6,87	4,91
5,87	6,88	4,95
5,88	6,89	5,00



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	5,05
5,90	6,91	5,09
5,91	6,92	5,14
5,92	6,93	5,19
5,93	6,94	5,23
5,94	6,95	5,28
5,95	6,96	5,32
5,96	6,97	5,37
5,97	6,98	5,42
5,98	6,99	5,46
5,99	7,00	5,51
6,00	7,01	5,55
6,01	7,02	5,60
6,02	7,03	5,65
6,03	7,04	5,69
6,04	7,05	5,74
6,05	7,06	5,78
6,06	7,07	5,83
6,07	7,08	5,87
6,08	7,09	5,92
6,09	7,10	5,96
6,10	7,11	6,01
6,11	7,12	6,06
6,12	7,13	6,10
6,13	7,14	6,15
6,14	7,15	6,19
6,15	7,16	6,24
6,16	7,17	6,28
6,17	7,18	6,33
6,18	7,19	6,37
6,19	7,20	6,42
6,20	7,21	6,46
6,21	7,22	6,51
6,22	7,23	6,55
6,23	7,24	6,60
6,24	7,25	6,64
6,25	7,26	6,69
6,26	7,27	6,73
6,27	7,28	6,77
6,28	7,29	6,82
6,29	7,30	6,86
6,30	7,31	6,91
6,31	7,32	6,95
6,32	7,33	7,00



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,33	7,34	7,04
6,34	7,35	7,09
6,35	7,36	7,13
6,36	7,37	7,17
6,37	7,38	7,22
6,38	7,39	7,26
6,39	7,40	7,31
6,40	7,41	7,35
6,41	7,42	7,39
6,42	7,43	7,44
6,43	7,44	7,48
6,44	7,45	7,53
6,45	7,46	7,57
6,46	7,47	7,61
6,47	7,48	7,66
6,48	7,49	7,70
6,49	7,50	7,74
6,50	7,51	7,79
6,51	7,52	7,83
6,52	7,53	7,87
6,53	7,54	7,92
6,54	7,55	7,96
6,55	7,56	8,00
6,56	7,57	8,05
6,57	7,58	8,09
6,58	7,59	8,13
6,59	7,60	8,18
6,60	7,61	8,22
6,61	7,62	8,26
6,62	7,63	8,31
6,63	7,64	8,35
6,64	7,65	8,39
6,65	7,66	8,44
6,66	7,67	8,48
6,67	7,68	8,52
6,68	7,69	8,56
6,69	7,70	8,61
6,70	7,71	8,65
6,71	7,72	8,69
6,72	7,73	8,74
6,73	7,74	8,78
6,74	7,75	8,82
6,75	7,76	8,86
6,76	7,77	8,91



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,77	7,78	8,95
6,78	7,79	8,99
6,79	7,80	9,03
6,80	7,81	9,07
6,81	7,82	9,12
6,82	7,83	9,16
6,83	7,84	9,20
6,84	7,85	9,24
6,85	7,86	9,29
6,86	7,87	9,33
6,87	7,88	9,37
6,88	7,89	9,41
6,89	7,90	9,45
6,90	7,91	9,50
6,91	7,92	9,54
6,92	7,93	9,58
6,93	7,94	9,62
6,94	7,95	9,66
6,95	7,96	9,70
6,96	7,97	9,75
6,97	7,98	9,79
6,98	7,99	9,83
6,99	8,00	9,87
7,00	8,01	9,91
7,01	8,02	9,95
7,02	8,03	10,00
7,03	8,04	10,04
7,04	8,05	10,08
7,05	8,06	10,12
7,06	8,07	10,16
7,07	8,08	10,20
7,08	8,09	10,24
7,09	8,10	10,28
7,10	8,11	10,33
7,11	8,12	10,37
7,12	8,13	10,41
7,13	8,14	10,45
7,14	8,15	10,49
7,15	8,16	10,53
7,16	8,17	10,57
7,17	8,18	10,61
7,18	8,19	10,65
7,19	8,20	10,69
7,20	8,21	10,74



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	10,78
7,22	8,23	10,82
7,23	8,24	10,86
7,24	8,25	10,90
7,25	8,26	10,94
7,26	8,27	10,98
7,27	8,28	11,02
7,28	8,29	11,06
7,29	8,30	11,10
7,30	8,31	11,14
7,31	8,32	11,18
7,32	8,33	11,22
7,33	8,34	11,26
7,34	8,35	11,30
7,35	8,36	11,34
7,36	8,37	11,38
7,37	8,38	11,42
7,38	8,39	11,46
7,39	8,40	11,50
7,40	8,41	11,54
7,41	8,42	11,58
7,42	8,43	11,62
7,43	8,44	11,66
7,44	8,45	11,70
7,45	8,46	11,74
7,46	8,47	11,78
7,47	8,48	11,82
7,48	8,49	11,86
7,49	8,50	11,90
7,50	8,51	11,94
7,51	8,52	11,98
7,52	8,53	12,02
7,53	8,54	12,06
7,54	8,55	12,10
7,55	8,56	12,14
7,56	8,57	12,18
7,57	8,58	12,22
7,58	8,59	12,26
7,59	8,60	12,30
7,60	8,61	12,34
7,61	8,62	12,38
7,62	8,63	12,41
7,63	8,64	12,45
7,64	8,65	12,49



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,65	8,66	12,53
7,66	8,67	12,57
7,67	8,68	12,61
7,68	8,69	12,65
7,69	8,70	12,69
7,70	8,71	12,73
7,71	8,72	12,77
7,72	8,73	12,81
7,73	8,74	12,84
7,74	8,75	12,88
7,75	8,76	12,92
7,76	8,77	12,96
7,77	8,78	13,00
7,78	8,79	13,04
7,79	8,80	13,08
7,80	8,81	13,12
7,81	8,82	13,15
7,82	8,83	13,19
7,83	8,84	13,23
7,84	8,85	13,27
7,85	8,86	13,31
7,86	8,87	13,35
7,87	8,88	13,39
7,88	8,89	13,42
7,89	8,90	13,46
7,90	8,91	13,50
7,91	8,92	13,54
7,92	8,93	13,58
7,93	8,94	13,62
7,94	8,95	13,65
7,95	8,96	13,69
7,96	8,97	13,73
7,97	8,98	13,77
7,98	8,99	13,81
7,99	9,00	13,84
8,00	9,01	13,88
8,01	9,02	13,92
8,02	9,03	13,96
8,03	9,04	14,00
8,04	9,05	14,03
8,05	9,06	14,07
8,06	9,07	14,11
8,07	9,08	14,15
8,08	9,09	14,19



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,09	9,10	14,22
8,10	9,11	14,26
8,11	9,12	14,30
8,12	9,13	14,34
8,13	9,14	14,37
8,14	9,15	14,41
8,15	9,16	14,45
8,16	9,17	14,49
8,17	9,18	14,52
8,18	9,19	14,56
8,19	9,20	14,60
8,20	9,21	14,64
8,21	9,22	14,67
8,22	9,23	14,71
8,23	9,24	14,75
8,24	9,25	14,79
8,25	9,26	14,82
8,26	9,27	14,86
8,27	9,28	14,90
8,28	9,29	14,93
8,29	9,30	14,97
8,30	9,31	15,01
8,31	9,32	15,05
8,32	9,33	15,08
8,33	9,34	15,12
8,34	9,35	15,16
8,35	9,36	15,19
8,36	9,37	15,23
8,37	9,38	15,27
8,38	9,39	15,30
8,39	9,40	15,34
8,40	9,41	15,38
8,41	9,42	15,41
8,42	9,43	15,45
8,43	9,44	15,49
8,44	9,45	15,53
8,45	9,46	15,56
8,46	9,47	15,60
8,47	9,48	15,63
8,48	9,49	15,67
8,49	9,50	15,71
8,50	9,51	15,74
8,51	9,52	15,78
8,52	9,53	15,82



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,53	9,54	15,85
8,54	9,55	15,89
8,55	9,56	15,93
8,56	9,57	15,96
8,57	9,58	16,00
8,58	9,59	16,04
8,59	9,60	16,07
8,60	9,61	16,11
8,61	9,62	16,14
8,62	9,63	16,18
8,63	9,64	16,22
8,64	9,65	16,25
8,65	9,66	16,29
8,66	9,67	16,33
8,67	9,68	16,36
8,68	9,69	16,40
8,69	9,70	16,43
8,70	9,71	16,47
8,71	9,72	16,51
8,72	9,73	16,54
8,73	9,74	16,58
8,74	9,75	16,61
8,75	9,76	16,65
8,76	9,77	16,68
8,77	9,78	16,72
8,78	9,79	16,76
8,79	9,80	16,79
8,80	9,81	16,83
8,81	9,82	16,86
8,82	9,83	16,90
8,83	9,84	16,93
8,84	9,85	16,97
8,85	9,86	17,01
8,86	9,87	17,04
8,87	9,88	17,08
8,88	9,89	17,11
8,89	9,90	17,15
8,90	9,91	17,18
8,91	9,92	17,22
8,92	9,93	17,25
8,93	9,94	17,29
8,94	9,95	17,32
8,95	9,96	17,36
8,96	9,97	17,39



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,97	9,98	17,43
8,98	9,99	17,47
8,99	10,00	17,50
9,00	10,01	17,54
9,01	10,02	17,57
9,02	10,03	17,61
9,03	10,04	17,64
9,04	10,05	17,68
9,05	10,06	17,71
9,06	10,07	17,75
9,07	10,08	17,78
9,08	10,09	17,82
9,09	10,10	17,85
9,10	10,11	17,89
9,11	10,12	17,92
9,12	10,13	17,96
9,13	10,14	17,99
9,14	10,15	18,02
9,15	10,16	18,06
9,16	10,17	18,09
9,17	10,18	18,13
9,18	10,19	18,16
9,19	10,20	18,20
9,20	10,21	18,23
9,21	10,22	18,27
9,22	10,23	18,30
9,23	10,24	18,34
9,24	10,25	18,37
9,25	10,26	18,41
9,26	10,27	18,44
9,27	10,28	18,47
9,28	10,29	18,51
9,29	10,30	18,54
9,30	10,31	18,58
9,31	10,32	18,61
9,32	10,33	18,65
9,33	10,34	18,68
9,34	10,35	18,72
9,35	10,36	18,75
9,36	10,37	18,78
9,37	10,38	18,82
9,38	10,39	18,85
9,39	10,40	18,89
9,40	10,41	18,92



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,41	10,42	18,95
9,42	10,43	18,99
9,43	10,44	19,02
9,44	10,45	19,06
9,45	10,46	19,09
9,46	10,47	19,12
9,47	10,48	19,16
9,48	10,49	19,19
9,49	10,50	19,23
9,50	10,51	19,26
9,51	10,52	19,29
9,52	10,53	19,33
9,53	10,54	19,36
9,54	10,55	19,40
9,55	10,56	19,43
9,56	10,57	19,46
9,57	10,58	19,50
9,58	10,59	19,53
9,59	10,60	19,56
9,60	10,61	19,60
9,61	10,62	19,63
9,62	10,63	19,67
9,63	10,64	19,70
9,64	10,65	19,73
9,65	10,66	19,77
9,66	10,67	19,80
9,67	10,68	19,83
9,68	10,69	19,87
9,69	10,70	19,90
9,70	10,71	19,93
9,71	10,72	19,97
9,72	10,73	20,00
9,73	10,74	20,03
9,74	10,75	20,07
9,75	10,76	20,10
9,76	10,77	20,13
9,77	10,78	20,17
9,78	10,79	20,20
9,79	10,80	20,23
9,80	10,81	20,27
9,81	10,82	20,30
9,82	10,83	20,33
9,83	10,84	20,37
9,84	10,85	20,40



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,85	10,86	20,43
9,86	10,87	20,47
9,87	10,88	20,50
9,88	10,89	20,53
9,89	10,90	20,56
9,90	10,91	20,60
9,91	10,92	20,63
9,92	10,93	20,66
9,93	10,94	20,70
9,94	10,95	20,73
9,95	10,96	20,76
9,96	10,97	20,79
9,97	10,98	20,83
9,98	10,99	20,86
9,99	11,00	20,89
10,00	11,01	20,93
10,01	11,02	20,96
10,02	11,03	20,99
10,03	11,04	21,02
10,04	11,05	21,06
10,05	11,06	21,09
10,06	11,07	21,12
10,07	11,08	21,15
10,08	11,09	21,19
10,09	11,10	21,22
10,10	11,11	21,25
10,11	11,12	21,28
10,12	11,13	21,32
10,13	11,14	21,35
10,14	11,15	21,38
10,15	11,16	21,41
10,16	11,17	21,45
10,17	11,18	21,48
10,18	11,19	21,51
10,19	11,20	21,54
10,20	11,21	21,58
10,21	11,22	21,61
10,22	11,23	21,64
10,23	11,24	21,67
10,24	11,25	21,70
10,25	11,26	21,74
10,26	11,27	21,77
10,27	11,28	21,80
10,28	11,29	21,83



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,29	11,30	21,87
10,30	11,31	21,90
10,31	11,32	21,93
10,32	11,33	21,96
10,33	11,34	21,99
10,34	11,35	22,03
10,35	11,36	22,06
10,36	11,37	22,09
10,37	11,38	22,12
10,38	11,39	22,15
10,39	11,40	22,19
10,40	11,41	22,22
10,41	11,42	22,25
10,42	11,43	22,28
10,43	11,44	22,31
10,44	11,45	22,34
10,45	11,46	22,38
10,46	11,47	22,41
10,47	11,48	22,44
10,48	11,49	22,47
10,49	11,50	22,50
10,50	11,51	22,54
10,51	11,52	22,57
10,52	11,53	22,60
10,53	11,54	22,63
10,54	11,55	22,66
10,55	11,56	22,69
10,56	11,57	22,72
10,57	11,58	22,76
10,58	11,59	22,79
10,59	11,60	22,82
10,60	11,61	22,85
10,61	11,62	22,88
10,62	11,63	22,91
10,63	11,64	22,95
10,64	11,65	22,98
10,65	11,66	23,01
10,66	11,67	23,04
10,67	11,68	23,07
10,68	11,69	23,10
10,69	11,70	23,13
10,70	11,71	23,16
10,71	11,72	23,20
10,72	11,73	23,23



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	23,26
10,74	11,75	23,29
10,75	11,76	23,32
10,76	11,77	23,35
10,77	11,78	23,38
10,78	11,79	23,41
10,79	11,80	23,44
10,80	11,81	23,48
10,81	11,82	23,51
10,82	11,83	23,54
10,83	11,84	23,57
10,84	11,85	23,60
10,85	11,86	23,63
10,86	11,87	23,66
10,87	11,88	23,69
10,88	11,89	23,72
10,89	11,90	23,75
10,90	11,91	23,79
10,91	11,92	23,82
10,92	11,93	23,85
10,93	11,94	23,88
10,94	11,95	23,91
10,95	11,96	23,94
10,96	11,97	23,97
10,97	11,98	24,00
10,98	11,99	24,03
10,99	12,00	24,06
11,00	12,01	24,09
11,01	12,02	24,12
11,02	12,03	24,15
11,03	12,04	24,19
11,04	12,05	24,22
11,05	12,06	24,25
11,06	12,07	24,28
11,07	12,08	24,31
11,08	12,09	24,34
11,09	12,10	24,37
11,10	12,11	24,40
11,11	12,12	24,43
11,12	12,13	24,46
11,13	12,14	24,49
11,14	12,15	24,52
11,15	12,16	24,55
11,16	12,17	24,58



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,17	12,18	24,61
11,18	12,19	24,64
11,19	12,20	24,67
11,20	12,21	24,70
11,21	12,22	24,73
11,22	12,23	24,76
11,23	12,24	24,79
11,24	12,25	24,82
11,25	12,26	24,85
11,26	12,27	24,88
11,27	12,28	24,91
11,28	12,29	24,94
11,29	12,30	24,97
11,30	12,31	25,01
11,31	12,32	25,04
11,32	12,33	25,07
11,33	12,34	25,10
11,34	12,35	25,13
11,35	12,36	25,16
11,36	12,37	25,19
11,37	12,38	25,22
11,38	12,39	25,25
11,39	12,40	25,28
11,40	12,41	25,31
11,41	12,42	25,34
11,42	12,43	25,37
11,43	12,44	25,39
11,44	12,45	25,42
11,45	12,46	25,45
11,46	12,47	25,48
11,47	12,48	25,51
11,48	12,49	25,54
11,49	12,50	25,57
11,50	12,51	25,60
11,51	12,52	25,63
11,52	12,53	25,66
11,53	12,54	25,69
11,54	12,55	25,72
11,55	12,56	25,75
11,56	12,57	25,78
11,57	12,58	25,81
11,58	12,59	25,84
11,59	12,60	25,87
11,60	12,61	25,90



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
11,61	12,62	25,93
11,62	12,63	25,96
11,63	12,64	25,99
11,64	12,65	26,02
11,65	12,66	26,05
11,66	12,67	26,08
11,67	12,68	26,11
11,68	12,69	26,14
11,69	12,70	26,17
11,70	12,71	26,20
11,71	12,72	26,22
11,72	12,73	26,25
11,73	12,74	26,28
11,74	12,75	26,31
11,75	12,76	26,34
11,76	12,77	26,37
11,77	12,78	26,40
11,78	12,79	26,43
11,79	12,80	26,46
11,80	12,81	26,49
11,81	12,82	26,52
11,82	12,83	26,55
11,83	12,84	26,58
11,84	12,85	26,61
11,85	12,86	26,63
11,86	12,87	26,66
11,87	12,88	26,69
11,88	12,89	26,72
11,89	12,90	26,75
11,90	12,91	26,78
11,91	12,92	26,81
11,92	12,93	26,84
11,93	12,94	26,87
11,94	12,95	26,90
11,95	12,96	26,92
11,96	12,97	26,95
11,97	12,98	26,98
11,98	12,99	27,01
11,99	13,00	27,04
12,00	13,01	27,07
12,01	13,02	27,10
12,02	13,03	27,13
12,03	13,04	27,16
12,04	13,05	27,19



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,05	13,06	27,21
12,06	13,07	27,24
12,07	13,08	27,27
12,08	13,09	27,30
12,09	13,10	27,33
12,10	13,11	27,36
12,11	13,12	27,39
12,12	13,13	27,42
12,13	13,14	27,44
12,14	13,15	27,47
12,15	13,16	27,50
12,16	13,17	27,53
12,17	13,18	27,56
12,18	13,19	27,59
12,19	13,20	27,62
12,20	13,21	27,64
12,21	13,22	27,67
12,22	13,23	27,70
12,23	13,24	27,73
12,24	13,25	27,76
12,25	13,26	27,79
12,26	13,27	27,82
12,27	13,28	27,84
12,28	13,29	27,87
12,29	13,30	27,90
12,30	13,31	27,93
12,31	13,32	27,96
12,32	13,33	27,99
12,33	13,34	28,01
12,34	13,35	28,04
12,35	13,36	28,07
12,36	13,37	28,10
12,37	13,38	28,13
12,38	13,39	28,16
12,39	13,40	28,18
12,40	13,41	28,21
12,41	13,42	28,24
12,42	13,43	28,27
12,43	13,44	28,30
12,44	13,45	28,33
12,45	13,46	28,35
12,46	13,47	28,38
12,47	13,48	28,41
12,48	13,49	28,44



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	28,47
12,50	13,51	28,49
12,51	13,52	28,52
12,52	13,53	28,55
12,53	13,54	28,58
12,54	13,55	28,61
12,55	13,56	28,63
12,56	13,57	28,66
12,57	13,58	28,69
12,58	13,59	28,72
12,59	13,60	28,75
12,60	13,61	28,77
12,61	13,62	28,80
12,62	13,63	28,83
12,63	13,64	28,86
12,64	13,65	28,89
12,65	13,66	28,91
12,66	13,67	28,94
12,67	13,68	28,97
12,68	13,69	29,00
12,69	13,70	29,02
12,70	13,71	29,05
12,71	13,72	29,08
12,72	13,73	29,11
12,73	13,74	29,14
12,74	13,75	29,16
12,75	13,76	29,19
12,76	13,77	29,22
12,77	13,78	29,25
12,78	13,79	29,27
12,79	13,80	29,30
12,80	13,81	29,33
12,81	13,82	29,36
12,82	13,83	29,39
12,83	13,84	29,41
12,84	13,85	29,44
12,85	13,86	29,47
12,86	13,87	29,50
12,87	13,88	29,52
12,88	13,89	29,55
12,89	13,90	29,58
12,90	13,91	29,61
12,91	13,92	29,63
12,92	13,93	29,66



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	29,69
12,94	13,95	29,72
12,95	13,96	29,74
12,96	13,97	29,77
12,97	13,98	29,80
12,98	13,99	29,82
12,99	14,00	29,85
13,00	14,01	29,88
13,01	14,02	29,91
13,02	14,03	29,93
13,03	14,04	29,96
13,04	14,05	29,99
13,05	14,06	30,02
13,06	14,07	30,04
13,07	14,08	30,07
13,08	14,09	30,10
13,09	14,10	30,12
13,10	14,11	30,15
13,11	14,12	30,18
13,12	14,13	30,21
13,13	14,14	30,23
13,14	14,15	30,26
13,15	14,16	30,29
13,16	14,17	30,31
13,17	14,18	30,34
13,18	14,19	30,37
13,19	14,20	30,40
13,20	14,21	30,42
13,21	14,22	30,45
13,22	14,23	30,48
13,23	14,24	30,50
13,24	14,25	30,53
13,25	14,26	30,56
13,26	14,27	30,59
13,27	14,28	30,61
13,28	14,29	30,64
13,29	14,30	30,67
13,30	14,31	30,69
13,31	14,32	30,72
13,32	14,33	30,75
13,33	14,34	30,77
13,34	14,35	30,80
13,35	14,36	30,83
13,36	14,37	30,85



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,37	14,38	30,88
13,38	14,39	30,91
13,39	14,40	30,93
13,40	14,41	30,96
13,41	14,42	30,99
13,42	14,43	31,01
13,43	14,44	31,04
13,44	14,45	31,07
13,45	14,46	31,10
13,46	14,47	31,12
13,47	14,48	31,15
13,48	14,49	31,18
13,49	14,50	31,20
13,50	14,51	31,23
13,51	14,52	31,25
13,52	14,53	31,28
13,53	14,54	31,31
13,54	14,55	31,33
13,55	14,56	31,36
13,56	14,57	31,39
13,57	14,58	31,41
13,58	14,59	31,44
13,59	14,60	31,47
13,60	14,61	31,49
13,61	14,62	31,52
13,62	14,63	31,55
13,63	14,64	31,57
13,64	14,65	31,60
13,65	14,66	31,63
13,66	14,67	31,65
13,67	14,68	31,68
13,68	14,69	31,71
13,69	14,70	31,73
13,70	14,71	31,76
13,71	14,72	31,78
13,72	14,73	31,81
13,73	14,74	31,84
13,74	14,75	31,86
13,75	14,76	31,89
13,76	14,77	31,92
13,77	14,78	31,94
13,78	14,79	31,97
13,79	14,80	31,99
13,80	14,81	32,02



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,81	14,82	32,05
13,82	14,83	32,07
13,83	14,84	32,10
13,84	14,85	32,13
13,85	14,86	32,15
13,86	14,87	32,18
13,87	14,88	32,20
13,88	14,89	32,23
13,89	14,90	32,26
13,90	14,91	32,28
13,91	14,92	32,31
13,92	14,93	32,33
13,93	14,94	32,36
13,94	14,95	32,39
13,95	14,96	32,41
13,96	14,97	32,44
13,97	14,98	32,46
13,98	14,99	32,49
13,99	15,00	32,52
14,00	15,01	32,54
14,01	15,02	32,57
14,02	15,03	32,59
14,03	15,04	32,62
14,04	15,05	32,65
14,05	15,06	32,67
14,06	15,07	32,70
14,07	15,08	32,72
14,08	15,09	32,75
14,09	15,10	32,78
14,10	15,11	32,80
14,11	15,12	32,83
14,12	15,13	32,85
14,13	15,14	32,88
14,14	15,15	32,90
14,15	15,16	32,93
14,16	15,17	32,96
14,17	15,18	32,98
14,18	15,19	33,01
14,19	15,20	33,03
14,20	15,21	33,06
14,21	15,22	33,09
14,22	15,23	33,11
14,23	15,24	33,14
14,24	15,25	33,16



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,25	15,26	33,19
14,26	15,27	33,21
14,27	15,28	33,24
14,28	15,29	33,26
14,29	15,30	33,29
14,30	15,31	33,32
14,31	15,32	33,34
14,32	15,33	33,37
14,33	15,34	33,39
14,34	15,35	33,42
14,35	15,36	33,44
14,36	15,37	33,47
14,37	15,38	33,49
14,38	15,39	33,52
14,39	15,40	33,55
14,40	15,41	33,57
14,41	15,42	33,60
14,42	15,43	33,62
14,43	15,44	33,65
14,44	15,45	33,67
14,45	15,46	33,70
14,46	15,47	33,72
14,47	15,48	33,75
14,48	15,49	33,77
14,49	15,50	33,80
14,50	15,51	33,82
14,51	15,52	33,85
14,52	15,53	33,88
14,53	15,54	33,90
14,54	15,55	33,93
14,55	15,56	33,95
14,56	15,57	33,98
14,57	15,58	34,00
14,58	15,59	34,03
14,59	15,60	34,05
14,60	15,61	34,08
14,61	15,62	34,10
14,62	15,63	34,13
14,63	15,64	34,15
14,64	15,65	34,18
14,65	15,66	34,20
14,66	15,67	34,23
14,67	15,68	34,25
14,68	15,69	34,28



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
14,69	15,70	34,30
14,70	15,71	34,33
14,71	15,72	34,35
14,72	15,73	34,38
14,73	15,74	34,40
14,74	15,75	34,43
14,75	15,76	34,45
14,76	15,77	34,48
14,77	15,78	34,50
14,78	15,79	34,53
14,79	15,80	34,55
14,80	15,81	34,58
14,81	15,82	34,60
14,82	15,83	34,63
14,83	15,84	34,65
14,84	15,85	34,68
14,85	15,86	34,70
14,86	15,87	34,73
14,87	15,88	34,75
14,88	15,89	34,78
14,89	15,90	34,80
14,90	15,91	34,83
14,91	15,92	34,85
14,92	15,93	34,88
14,93	15,94	34,90
14,94	15,95	34,93
14,95	15,96	34,95
14,96	15,97	34,98
14,97	15,98	35,00
14,98	15,99	35,03
14,99	16,00	35,05
15,00	16,01	35,08
15,01	16,02	35,10
15,02	16,03	35,13
15,03	16,04	35,15
15,04	16,05	35,17
15,05	16,06	35,20
15,06	16,07	35,22
15,07	16,08	35,25
15,08	16,09	35,27
15,09	16,10	35,30
15,10	16,11	35,32
15,11	16,12	35,35
15,12	16,13	35,37



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	35,40
15,14	16,15	35,42
15,15	16,16	35,45
15,16	16,17	35,47
15,17	16,18	35,49
15,18	16,19	35,52
15,19	16,20	35,54
15,20	16,21	35,57
15,21	16,22	35,59
15,22	16,23	35,62
15,23	16,24	35,64
15,24	16,25	35,67
15,25	16,26	35,69
15,26	16,27	35,72
15,27	16,28	35,74
15,28	16,29	35,76
15,29	16,30	35,79
15,30	16,31	35,81
15,31	16,32	35,84
15,32	16,33	35,86
15,33	16,34	35,89
15,34	16,35	35,91
15,35	16,36	35,93
15,36	16,37	35,96
15,37	16,38	35,98
15,38	16,39	36,01
15,39	16,40	36,03
15,40	16,41	36,06
15,41	16,42	36,08
15,42	16,43	36,10
15,43	16,44	36,13
15,44	16,45	36,15
15,45	16,46	36,18
15,46	16,47	36,20
15,47	16,48	36,23
15,48	16,49	36,25
15,49	16,50	36,27
15,50	16,51	36,30
15,51	16,52	36,32
15,52	16,53	36,35
15,53	16,54	36,37
15,54	16,55	36,39
15,55	16,56	36,42
15,56	16,57	36,44



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
15,57	16,58	36,47
15,58	16,59	36,49
15,59	16,60	36,52
15,60	16,61	36,54
15,61	16,62	36,56
15,62	16,63	36,59
15,63	16,64	36,61
15,64	16,65	36,64
15,65	16,66	36,66
15,66	16,67	36,68
15,67	16,68	36,71
15,68	16,69	36,73
15,69	16,70	36,76
15,70	16,71	36,78
15,71	16,72	36,80
15,72	16,73	36,83
15,73	16,74	36,85
15,74	16,75	36,87
15,75	16,76	36,90
15,76	16,77	36,92
15,77	16,78	36,95
15,78	16,79	36,97
15,79	16,80	36,99
15,80	16,81	37,02
15,81	16,82	37,04
15,82	16,83	37,07
15,83	16,84	37,09
15,84	16,85	37,11
15,85	16,86	37,14
15,86	16,87	37,16
15,87	16,88	37,18
15,88	16,89	37,21
15,89	16,90	37,23
15,90	16,91	37,26
15,91	16,92	37,28
15,92	16,93	37,30
15,93	16,94	37,33
15,94	16,95	37,35
15,95	16,96	37,37
15,96	16,97	37,40
15,97	16,98	37,42
15,98	16,99	37,45
15,99	17,00	37,47
16,00	17,01	37,49



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	37,52
16,02	17,03	37,54
16,03	17,04	37,56
16,04	17,05	37,59
16,05	17,06	37,61
16,06	17,07	37,63
16,07	17,08	37,66
16,08	17,09	37,68
16,09	17,10	37,71
16,10	17,11	37,73
16,11	17,12	37,75
16,12	17,13	37,78
16,13	17,14	37,80
16,14	17,15	37,82
16,15	17,16	37,85
16,16	17,17	37,87
16,17	17,18	37,89
16,18	17,19	37,92
16,19	17,20	37,94
16,20	17,21	37,96
16,21	17,22	37,99
16,22	17,23	38,01
16,23	17,24	38,03
16,24	17,25	38,06
16,25	17,26	38,08
16,26	17,27	38,10
16,27	17,28	38,13
16,28	17,29	38,15
16,29	17,30	38,17
16,30	17,31	38,20
16,31	17,32	38,22
16,32	17,33	38,24
16,33	17,34	38,27
16,34	17,35	38,29
16,35	17,36	38,31
16,36	17,37	38,34
16,37	17,38	38,36
16,38	17,39	38,38
16,39	17,40	38,41
16,40	17,41	38,43
16,41	17,42	38,45
16,42	17,43	38,48
16,43	17,44	38,50
16,44	17,45	38,52



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
16,45	17,46	38,55
16,46	17,47	38,57
16,47	17,48	38,59
16,48	17,49	38,61
16,49	17,50	38,64
16,50	17,51	38,66
16,51	17,52	38,68
16,52	17,53	38,71
16,53	17,54	38,73
16,54	17,55	38,75
16,55	17,56	38,78
16,56	17,57	38,80
16,57	17,58	38,82
16,58	17,59	38,85
16,59	17,60	38,87
16,60	17,61	38,89
16,61	17,62	38,91
16,62	17,63	38,94
16,63	17,64	38,96
16,64	17,65	38,98
16,65	17,66	39,01
16,66	17,67	39,03
16,67	17,68	39,05
16,68	17,69	39,08
16,69	17,70	39,10
16,70	17,71	39,12
16,71	17,72	39,14
16,72	17,73	39,17
16,73	17,74	39,19
16,74	17,75	39,21
16,75	17,76	39,24
16,76	17,77	39,26
16,77	17,78	39,28
16,78	17,79	39,30
16,79	17,80	39,33
16,80	17,81	39,35
16,81	17,82	39,37
16,82	17,83	39,40
16,83	17,84	39,42
16,84	17,85	39,44
16,85	17,86	39,46
16,86	17,87	39,49
16,87	17,88	39,51
16,88	17,89	39,53



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
16,89	17,90	39,56
16,90	17,91	39,58
16,91	17,92	39,60
16,92	17,93	39,62
16,93	17,94	39,65
16,94	17,95	39,67
16,95	17,96	39,69
16,96	17,97	39,71
16,97	17,98	39,74
16,98	17,99	39,76
16,99	18,00	39,78
17,00	18,01	39,80
17,01	18,02	39,83
17,02	18,03	39,85
17,03	18,04	39,87
17,04	18,05	39,89
17,05	18,06	39,92
17,06	18,07	39,94
17,07	18,08	39,96
17,08	18,09	39,99
17,09	18,10	40,01
17,10	18,11	40,03
17,11	18,12	40,05
17,12	18,13	40,08
17,13	18,14	40,10
17,14	18,15	40,12
17,15	18,16	40,14
17,16	18,17	40,17
17,17	18,18	40,19
17,18	18,19	40,21
17,19	18,20	40,23
17,20	18,21	40,26
17,21	18,22	40,28
17,22	18,23	40,30
17,23	18,24	40,32
17,24	18,25	40,34
17,25	18,26	40,37
17,26	18,27	40,39
17,27	18,28	40,41
17,28	18,29	40,43
17,29	18,30	40,46
17,30	18,31	40,48
17,31	18,32	40,50
17,32	18,33	40,52



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	40,55
17,34	18,35	40,57
17,35	18,36	40,59
17,36	18,37	40,61
17,37	18,38	40,64
17,38	18,39	40,66
17,39	18,40	40,68
17,40	18,41	40,70
17,41	18,42	40,72
17,42	18,43	40,75
17,43	18,44	40,77
17,44	18,45	40,79
17,45	18,46	40,81
17,46	18,47	40,84
17,47	18,48	40,86
17,48	18,49	40,88
17,49	18,50	40,90
17,50	18,51	40,92
17,51	18,52	40,95
17,52	18,53	40,97
17,53	18,54	40,99
17,54	18,55	41,01
17,55	18,56	41,03
17,56	18,57	41,06
17,57	18,58	41,08
17,58	18,59	41,10
17,59	18,60	41,12
17,60	18,61	41,15
17,61	18,62	41,17
17,62	18,63	41,19
17,63	18,64	41,21
17,64	18,65	41,23
17,65	18,66	41,26
17,66	18,67	41,28
17,67	18,68	41,30
17,68	18,69	41,32
17,69	18,70	41,34
17,70	18,71	41,37
17,71	18,72	41,39
17,72	18,73	41,41
17,73	18,74	41,43
17,74	18,75	41,45
17,75	18,76	41,48
17,76	18,77	41,50



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,77	18,78	41,52
17,78	18,79	41,54
17,79	18,80	41,56
17,80	18,81	41,58
17,81	18,82	41,61
17,82	18,83	41,63
17,83	18,84	41,65
17,84	18,85	41,67
17,85	18,86	41,69
17,86	18,87	41,72
17,87	18,88	41,74
17,88	18,89	41,76
17,89	18,90	41,78
17,90	18,91	41,80
17,91	18,92	41,82
17,92	18,93	41,85
17,93	18,94	41,87
17,94	18,95	41,89
17,95	18,96	41,91
17,96	18,97	41,93
17,97	18,98	41,96
17,98	18,99	41,98
17,99	19,00	42,00
18,00	19,01	42,02
18,01	19,02	42,04
18,02	19,03	42,06
18,03	19,04	42,09
18,04	19,05	42,11
18,05	19,06	42,13
18,06	19,07	42,15
18,07	19,08	42,17
18,08	19,09	42,19
18,09	19,10	42,22
18,10	19,11	42,24
18,11	19,12	42,26
18,12	19,13	42,28
18,13	19,14	42,30
18,14	19,15	42,32
18,15	19,16	42,35
18,16	19,17	42,37
18,17	19,18	42,39
18,18	19,19	42,41
18,19	19,20	42,43
18,20	19,21	42,45



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
18,21	19,22	42,47
18,22	19,23	42,50
18,23	19,24	42,52
18,24	19,25	42,54
18,25	19,26	42,56
18,26	19,27	42,58
18,27	19,28	42,60
18,28	19,29	42,63
18,29	19,30	42,65
18,30	19,31	42,67
18,31	19,32	42,69
18,32	19,33	42,71
18,33	19,34	42,73
18,34	19,35	42,75
18,35	19,36	42,78
18,36	19,37	42,80
18,37	19,38	42,82
18,38	19,39	42,84
18,39	19,40	42,86
18,40	19,41	42,88
18,41	19,42	42,90
18,42	19,43	42,93
18,43	19,44	42,95
18,44	19,45	42,97
18,45	19,46	42,99
18,46	19,47	43,01
18,47	19,48	43,03
18,48	19,49	43,05
18,49	19,50	43,07
18,50	19,51	43,10
18,51	19,52	43,12
18,52	19,53	43,14
18,53	19,54	43,16
18,54	19,55	43,18
18,55	19,56	43,20
18,56	19,57	43,22
18,57	19,58	43,24
18,58	19,59	43,27
18,59	19,60	43,29
18,60	19,61	43,31
18,61	19,62	43,33
18,62	19,63	43,35
18,63	19,64	43,37
18,64	19,65	43,39



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
18,65	19,66	43,41
18,66	19,67	43,44
18,67	19,68	43,46
18,68	19,69	43,48
18,69	19,70	43,50
18,70	19,71	43,52
18,71	19,72	43,54
18,72	19,73	43,56
18,73	19,74	43,58
18,74	19,75	43,60
18,75	19,76	43,63
18,76	19,77	43,65
18,77	19,78	43,67
18,78	19,79	43,69
18,79	19,80	43,71
18,80	19,81	43,73
18,81	19,82	43,75
18,82	19,83	43,77
18,83	19,84	43,79
18,84	19,85	43,81
18,85	19,86	43,84
18,86	19,87	43,86
18,87	19,88	43,88
18,88	19,89	43,90
18,89	19,90	43,92
18,90	19,91	43,94
18,91	19,92	43,96
18,92	19,93	43,98
18,93	19,94	44,00
18,94	19,95	44,02
18,95	19,96	44,05
18,96	19,97	44,07
18,97	19,98	44,09
18,98	19,99	44,11
18,99	20,00	44,13
19,00	20,01	44,15
19,01	20,02	44,17
19,02	20,03	44,19
19,03	20,04	44,21
19,04	20,05	44,23
19,05	20,06	44,25
19,06	20,07	44,27
19,07	20,08	44,30
19,08	20,09	44,32



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	44,34
19,10	20,11	44,36
19,11	20,12	44,38
19,12	20,13	44,40
19,13	20,14	44,42
19,14	20,15	44,44
19,15	20,16	44,46
19,16	20,17	44,48
19,17	20,18	44,50
19,18	20,19	44,52
19,19	20,20	44,55
19,20	20,21	44,57
19,21	20,22	44,59
19,22	20,23	44,61
19,23	20,24	44,63
19,24	20,25	44,65
19,25	20,26	44,67
19,26	20,27	44,69
19,27	20,28	44,71
19,28	20,29	44,73
19,29	20,30	44,75
19,30	20,31	44,77
19,31	20,32	44,79
19,32	20,33	44,81
19,33	20,34	44,83
19,34	20,35	44,86
19,35	20,36	44,88
19,36	20,37	44,90
19,37	20,38	44,92
19,38	20,39	44,94
19,39	20,40	44,96
19,40	20,41	44,98
19,41	20,42	45,00
19,42	20,43	45,02
19,43	20,44	45,04
19,44	20,45	45,06
19,45	20,46	45,08
19,46	20,47	45,10
19,47	20,48	45,12
19,48	20,49	45,14
19,49	20,50	45,16
19,50	20,51	45,18
19,51	20,52	45,20
19,52	20,53	45,22



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,53	20,54	45,25
19,54	20,55	45,27
19,55	20,56	45,29
19,56	20,57	45,31
19,57	20,58	45,33
19,58	20,59	45,35
19,59	20,60	45,37
19,60	20,61	45,39
19,61	20,62	45,41
19,62	20,63	45,43
19,63	20,64	45,45
19,64	20,65	45,47
19,65	20,66	45,49
19,66	20,67	45,51
19,67	20,68	45,53
19,68	20,69	45,55
19,69	20,70	45,57
19,70	20,71	45,59
19,71	20,72	45,61
19,72	20,73	45,63
19,73	20,74	45,65
19,74	20,75	45,67
19,75	20,76	45,69
19,76	20,77	45,71
19,77	20,78	45,73
19,78	20,79	45,75
19,79	20,80	45,77
19,80	20,81	45,80
19,81	20,82	45,82
19,82	20,83	45,84
19,83	20,84	45,86
19,84	20,85	45,88
19,85	20,86	45,90
19,86	20,87	45,92
19,87	20,88	45,94
19,88	20,89	45,96
19,89	20,90	45,98
19,90	20,91	46,00
19,91	20,92	46,02
19,92	20,93	46,04
19,93	20,94	46,06
19,94	20,95	46,08
19,95	20,96	46,10
19,96	20,97	46,12



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,97	20,98	46,14
19,98	20,99	46,16
19,99	21,00	46,18
20,00	21,01	46,20
20,01	21,02	46,22
20,02	21,03	46,24
20,03	21,04	46,26
20,04	21,05	46,28
20,05	21,06	46,30
20,06	21,07	46,32
20,07	21,08	46,34
20,08	21,09	46,36
20,09	21,10	46,38
20,10	21,11	46,40
20,11	21,12	46,42
20,12	21,13	46,44
20,13	21,14	46,46
20,14	21,15	46,48
20,15	21,16	46,50
20,16	21,17	46,52
20,17	21,18	46,54
20,18	21,19	46,56
20,19	21,20	46,58
20,20	21,21	46,60
20,21	21,22	46,62
20,22	21,23	46,64
20,23	21,24	46,66
20,24	21,25	46,68
20,25	21,26	46,70
20,26	21,27	46,72
20,27	21,28	46,74
20,28	21,29	46,76
20,29	21,30	46,78
20,30	21,31	46,80
20,31	21,32	46,82
20,32	21,33	46,84
20,33	21,34	46,86
20,34	21,35	46,88
20,35	21,36	46,90
20,36	21,37	46,92
20,37	21,38	46,94
20,38	21,39	46,96
20,39	21,40	46,98
20,40	21,41	47,00



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
20,41	21,42	47,02
20,42	21,43	47,04
20,43	21,44	47,06
20,44	21,45	47,08
20,45	21,46	47,10
20,46	21,47	47,12
20,47	21,48	47,14
20,48	21,49	47,16
20,49	21,50	47,18
20,50	21,51	47,20
20,51	21,52	47,22
20,52	21,53	47,23
20,53	21,54	47,25
20,54	21,55	47,27
20,55	21,56	47,29
20,56	21,57	47,31
20,57	21,58	47,33
20,58	21,59	47,35
20,59	21,60	47,37
20,60	21,61	47,39
20,61	21,62	47,41
20,62	21,63	47,43
20,63	21,64	47,45
20,64	21,65	47,47
20,65	21,66	47,49
20,66	21,67	47,51
20,67	21,68	47,53
20,68	21,69	47,55
20,69	21,70	47,57
20,70	21,71	47,59
20,71	21,72	47,61
20,72	21,73	47,63
20,73	21,74	47,65
20,74	21,75	47,67
20,75	21,76	47,69
20,76	21,77	47,71
20,77	21,78	47,73
20,78	21,79	47,75
20,79	21,80	47,77
20,80	21,81	47,78
20,81	21,82	47,80
20,82	21,83	47,82
20,83	21,84	47,84
20,84	21,85	47,86



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	47,88
20,86	21,87	47,90
20,87	21,88	47,92
20,88	21,89	47,94
20,89	21,90	47,96
20,90	21,91	47,98
20,91	21,92	48,00
20,92	21,93	48,02
20,93	21,94	48,04
20,94	21,95	48,06
20,95	21,96	48,08
20,96	21,97	48,10
20,97	21,98	48,12
20,98	21,99	48,14
20,99	22,00	48,15
21,00	22,01	48,17
21,01	22,02	48,19
21,02	22,03	48,21
21,03	22,04	48,23
21,04	22,05	48,25
21,05	22,06	48,27
21,06	22,07	48,29
21,07	22,08	48,31
21,08	22,09	48,33
21,09	22,10	48,35
21,10	22,11	48,37
21,11	22,12	48,39
21,12	22,13	48,41
21,13	22,14	48,43
21,14	22,15	48,44
21,15	22,16	48,46
21,16	22,17	48,48
21,17	22,18	48,50
21,18	22,19	48,52
21,19	22,20	48,54
21,20	22,21	48,56
21,21	22,22	48,58
21,22	22,23	48,60
21,23	22,24	48,62
21,24	22,25	48,64
21,25	22,26	48,66
21,26	22,27	48,68
21,27	22,28	48,70
21,28	22,29	48,71



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,29	22,30	48,73
21,30	22,31	48,75
21,31	22,32	48,77
21,32	22,33	48,79
21,33	22,34	48,81
21,34	22,35	48,83
21,35	22,36	48,85
21,36	22,37	48,87
21,37	22,38	48,89
21,38	22,39	48,91
21,39	22,40	48,93
21,40	22,41	48,94
21,41	22,42	48,96
21,42	22,43	48,98
21,43	22,44	49,00
21,44	22,45	49,02
21,45	22,46	49,04
21,46	22,47	49,06
21,47	22,48	49,08
21,48	22,49	49,10
21,49	22,50	49,12
21,50	22,51	49,14
21,51	22,52	49,15
21,52	22,53	49,17
21,53	22,54	49,19
21,54	22,55	49,21
21,55	22,56	49,23
21,56	22,57	49,25
21,57	22,58	49,27
21,58	22,59	49,29
21,59	22,60	49,31
21,60	22,61	49,33
21,61	22,62	49,34
21,62	22,63	49,36
21,63	22,64	49,38
21,64	22,65	49,40
21,65	22,66	49,42
21,66	22,67	49,44
21,67	22,68	49,46
21,68	22,69	49,48
21,69	22,70	49,50
21,70	22,71	49,52
21,71	22,72	49,53
21,72	22,73	49,55



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	49,57
21,74	22,75	49,59
21,75	22,76	49,61
21,76	22,77	49,63
21,77	22,78	49,65
21,78	22,79	49,67
21,79	22,80	49,69
21,80	22,81	49,70
21,81	22,82	49,72
21,82	22,83	49,74
21,83	22,84	49,76
21,84	22,85	49,78
21,85	22,86	49,80
21,86	22,87	49,82
21,87	22,88	49,84
21,88	22,89	49,86
21,89	22,90	49,87
21,90	22,91	49,89
21,91	22,92	49,91
21,92	22,93	49,93
21,93	22,94	49,95
21,94	22,95	49,97
21,95	22,96	49,99
21,96	22,97	50,01
21,97	22,98	50,02
21,98	22,99	50,04
21,99	23,00	50,06
22,00	23,01	50,08
22,01	23,02	50,10
22,02	23,03	50,12
22,03	23,04	50,14
22,04	23,05	50,16
22,05	23,06	50,17
22,06	23,07	50,19
22,07	23,08	50,21
22,08	23,09	50,23
22,09	23,10	50,25
22,10	23,11	50,27
22,11	23,12	50,29
22,12	23,13	50,31
22,13	23,14	50,32
22,14	23,15	50,34
22,15	23,16	50,36
22,16	23,17	50,38



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
22,17	23,18	50,40
22,18	23,19	50,42
22,19	23,20	50,44
22,20	23,21	50,45
22,21	23,22	50,47
22,22	23,23	50,49
22,23	23,24	50,51
22,24	23,25	50,53
22,25	23,26	50,55
22,26	23,27	50,57
22,27	23,28	50,58
22,28	23,29	50,60
22,29	23,30	50,62
22,30	23,31	50,64
22,31	23,32	50,66
22,32	23,33	50,68
22,33	23,34	50,70
22,34	23,35	50,71
22,35	23,36	50,73
22,36	23,37	50,75
22,37	23,38	50,77
22,38	23,39	50,79
22,39	23,40	50,81
22,40	23,41	50,83
22,41	23,42	50,84
22,42	23,43	50,86
22,43	23,44	50,88
22,44	23,45	50,90
22,45	23,46	50,92
22,46	23,47	50,94
22,47	23,48	50,95
22,48	23,49	50,97
22,49	23,50	50,99
22,50	23,51	51,01
22,51	23,52	51,03
22,52	23,53	51,05
22,53	23,54	51,06
22,54	23,55	51,08
22,55	23,56	51,10
22,56	23,57	51,12
22,57	23,58	51,14
22,58	23,59	51,16
22,59	23,60	51,18
22,60	23,61	51,19



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	51,21
22,62	23,63	51,23
22,63	23,64	51,25
22,64	23,65	51,27
22,65	23,66	51,29
22,66	23,67	51,30
22,67	23,68	51,32
22,68	23,69	51,34
22,69	23,70	51,36
22,70	23,71	51,38
22,71	23,72	51,40
22,72	23,73	51,41
22,73	23,74	51,43
22,74	23,75	51,45
22,75	23,76	51,47
22,76	23,77	51,49
22,77	23,78	51,50
22,78	23,79	51,52
22,79	23,80	51,54
22,80	23,81	51,56
22,81	23,82	51,58
22,82	23,83	51,60
22,83	23,84	51,61
22,84	23,85	51,63
22,85	23,86	51,65
22,86	23,87	51,67
22,87	23,88	51,69
22,88	23,89	51,71
22,89	23,90	51,72
22,90	23,91	51,74
22,91	23,92	51,76
22,92	23,93	51,78
22,93	23,94	51,80
22,94	23,95	51,81
22,95	23,96	51,83
22,96	23,97	51,85
22,97	23,98	51,87
22,98	23,99	51,89
22,99	24,00	51,91
23,00	24,01	51,92
23,01	24,02	51,94
23,02	24,03	51,96
23,03	24,04	51,98
23,04	24,05	52,00



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,05	24,06	52,01
23,06	24,07	52,03
23,07	24,08	52,05
23,08	24,09	52,07
23,09	24,10	52,09
23,10	24,11	52,10
23,11	24,12	52,12
23,12	24,13	52,14
23,13	24,14	52,16
23,14	24,15	52,18
23,15	24,16	52,19
23,16	24,17	52,21
23,17	24,18	52,23
23,18	24,19	52,25
23,19	24,20	52,27
23,20	24,21	52,28
23,21	24,22	52,30
23,22	24,23	52,32
23,23	24,24	52,34
23,24	24,25	52,36
23,25	24,26	52,37
23,26	24,27	52,39
23,27	24,28	52,41
23,28	24,29	52,43
23,29	24,30	52,45
23,30	24,31	52,46
23,31	24,32	52,48
23,32	24,33	52,50
23,33	24,34	52,52
23,34	24,35	52,54
23,35	24,36	52,55
23,36	24,37	52,57
23,37	24,38	52,59
23,38	24,39	52,61
23,39	24,40	52,63
23,40	24,41	52,64
23,41	24,42	52,66
23,42	24,43	52,68
23,43	24,44	52,70
23,44	24,45	52,71
23,45	24,46	52,73
23,46	24,47	52,75
23,47	24,48	52,77
23,48	24,49	52,79



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,49	24,50	52,80
23,50	24,51	52,82
23,51	24,52	52,84
23,52	24,53	52,86
23,53	24,54	52,88
23,54	24,55	52,89
23,55	24,56	52,91
23,56	24,57	52,93
23,57	24,58	52,95
23,58	24,59	52,96
23,59	24,60	52,98
23,60	24,61	53,00
23,61	24,62	53,02
23,62	24,63	53,04
23,63	24,64	53,05
23,64	24,65	53,07
23,65	24,66	53,09
23,66	24,67	53,11
23,67	24,68	53,12
23,68	24,69	53,14
23,69	24,70	53,16
23,70	24,71	53,18
23,71	24,72	53,20
23,72	24,73	53,21
23,73	24,74	53,23
23,74	24,75	53,25
23,75	24,76	53,27
23,76	24,77	53,28
23,77	24,78	53,30
23,78	24,79	53,32
23,79	24,80	53,34
23,80	24,81	53,35
23,81	24,82	53,37
23,82	24,83	53,39
23,83	24,84	53,41
23,84	24,85	53,42
23,85	24,86	53,44
23,86	24,87	53,46
23,87	24,88	53,48
23,88	24,89	53,50
23,89	24,90	53,51
23,90	24,91	53,53
23,91	24,92	53,55
23,92	24,93	53,57



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,93	24,94	53,58
23,94	24,95	53,60
23,95	24,96	53,62
23,96	24,97	53,64
23,97	24,98	53,65
23,98	24,99	53,67
23,99	25,00	53,69
24,00	25,01	53,71
24,01	25,02	53,72
24,02	25,03	53,74
24,03	25,04	53,76
24,04	25,05	53,78
24,05	25,06	53,79
24,06	25,07	53,81
24,07	25,08	53,83
24,08	25,09	53,85
24,09	25,10	53,86
24,10	25,11	53,88
24,11	25,12	53,90
24,12	25,13	53,92
24,13	25,14	53,93
24,14	25,15	53,95
24,15	25,16	53,97
24,16	25,17	53,99
24,17	25,18	54,00
24,18	25,19	54,02
24,19	25,20	54,04
24,20	25,21	54,06
24,21	25,22	54,07
24,22	25,23	54,09
24,23	25,24	54,11
24,24	25,25	54,13
24,25	25,26	54,14
24,26	25,27	54,16
24,27	25,28	54,18
24,28	25,29	54,20
24,29	25,30	54,21
24,30	25,31	54,23
24,31	25,32	54,25
24,32	25,33	54,26
24,33	25,34	54,28
24,34	25,35	54,30
24,35	25,36	54,32
24,36	25,37	54,33



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,37	25,38	54,35
24,38	25,39	54,37
24,39	25,40	54,39
24,40	25,41	54,40
24,41	25,42	54,42
24,42	25,43	54,44
24,43	25,44	54,46
24,44	25,45	54,47
24,45	25,46	54,49
24,46	25,47	54,51
24,47	25,48	54,52
24,48	25,49	54,54
24,49	25,50	54,56
24,50	25,51	54,58
24,51	25,52	54,59
24,52	25,53	54,61
24,53	25,54	54,63
24,54	25,55	54,65
24,55	25,56	54,66
24,56	25,57	54,68
24,57	25,58	54,70
24,58	25,59	54,71
24,59	25,60	54,73
24,60	25,61	54,75
24,61	25,62	54,77
24,62	25,63	54,78
24,63	25,64	54,80
24,64	25,65	54,82
24,65	25,66	54,83
24,66	25,67	54,85
24,67	25,68	54,87
24,68	25,69	54,89
24,69	25,70	54,90
24,70	25,71	54,92
24,71	25,72	54,94
24,72	25,73	54,95
24,73	25,74	54,97
24,74	25,75	54,99
24,75	25,76	55,01
24,76	25,77	55,02
24,77	25,78	55,04
24,78	25,79	55,06
24,79	25,80	55,07
24,80	25,81	55,09



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	55,11
24,82	25,83	55,13
24,83	25,84	55,14
24,84	25,85	55,16
24,85	25,86	55,18
24,86	25,87	55,19
24,87	25,88	55,21
24,88	25,89	55,23
24,89	25,90	55,25
24,90	25,91	55,26
24,91	25,92	55,28
24,92	25,93	55,30
24,93	25,94	55,31
24,94	25,95	55,33
24,95	25,96	55,35
24,96	25,97	55,36
24,97	25,98	55,38
24,98	25,99	55,40
24,99	26,00	55,42
25,00	26,01	55,43
25,01	26,02	55,45
25,02	26,03	55,47
25,03	26,04	55,48
25,04	26,05	55,50
25,05	26,06	55,52
25,06	26,07	55,53
25,07	26,08	55,55
25,08	26,09	55,57
25,09	26,10	55,59
25,10	26,11	55,60
25,11	26,12	55,62
25,12	26,13	55,64
25,13	26,14	55,65
25,14	26,15	55,67
25,15	26,16	55,69
25,16	26,17	55,70
25,17	26,18	55,72
25,18	26,19	55,74
25,19	26,20	55,75
25,20	26,21	55,77
25,21	26,22	55,79
25,22	26,23	55,81
25,23	26,24	55,82
25,24	26,25	55,84



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
25,25	26,26	55,86
25,26	26,27	55,87
25,27	26,28	55,89
25,28	26,29	55,91
25,29	26,30	55,92
25,30	26,31	55,94
25,31	26,32	55,96
25,32	26,33	55,97
25,33	26,34	55,99
25,34	26,35	56,01
25,35	26,36	56,02
25,36	26,37	56,04
25,37	26,38	56,06
25,38	26,39	56,08
25,39	26,40	56,09
25,40	26,41	56,11
25,41	26,42	56,13
25,42	26,43	56,14
25,43	26,44	56,16
25,44	26,45	56,18
25,45	26,46	56,19
25,46	26,47	56,21
25,47	26,48	56,23
25,48	26,49	56,24
25,49	26,50	56,26
25,50	26,51	56,28
25,51	26,52	56,29
25,52	26,53	56,31
25,53	26,54	56,33
25,54	26,55	56,34
25,55	26,56	56,36
25,56	26,57	56,38
25,57	26,58	56,39
25,58	26,59	56,41
25,59	26,60	56,43
25,60	26,61	56,44
25,61	26,62	56,46
25,62	26,63	56,48
25,63	26,64	56,49
25,64	26,65	56,51
25,65	26,66	56,53
25,66	26,67	56,54
25,67	26,68	56,56
25,68	26,69	56,58



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
25,69	26,70	56,59
25,70	26,71	56,61
25,71	26,72	56,63
25,72	26,73	56,64
25,73	26,74	56,66
25,74	26,75	56,68
25,75	26,76	56,69
25,76	26,77	56,71
25,77	26,78	56,73
25,78	26,79	56,74
25,79	26,80	56,76
25,80	26,81	56,78
25,81	26,82	56,79
25,82	26,83	56,81
25,83	26,84	56,83
25,84	26,85	56,84
25,85	26,86	56,86
25,86	26,87	56,88
25,87	26,88	56,89
25,88	26,89	56,91
25,89	26,90	56,92
25,90	26,91	56,94
25,91	26,92	56,96
25,92	26,93	56,97
25,93	26,94	56,99
25,94	26,95	57,01
25,95	26,96	57,02
25,96	26,97	57,04
25,97	26,98	57,06
25,98	26,99	57,07
25,99	27,00	57,09
26,00	27,01	57,11
26,01	27,02	57,12
26,02	27,03	57,14
26,03	27,04	57,16
26,04	27,05	57,17
26,05	27,06	57,19
26,06	27,07	57,21
26,07	27,08	57,22
26,08	27,09	57,24
26,09	27,10	57,25
26,10	27,11	57,27
26,11	27,12	57,29
26,12	27,13	57,30



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	57,32
26,14	27,15	57,34
26,15	27,16	57,35
26,16	27,17	57,37
26,17	27,18	57,39
26,18	27,19	57,40
26,19	27,20	57,42
26,20	27,21	57,44
26,21	27,22	57,45
26,22	27,23	57,47
26,23	27,24	57,48
26,24	27,25	57,50
26,25	27,26	57,52
26,26	27,27	57,53
26,27	27,28	57,55
26,28	27,29	57,57
26,29	27,30	57,58
26,30	27,31	57,60
26,31	27,32	57,62
26,32	27,33	57,63
26,33	27,34	57,65
26,34	27,35	57,66
26,35	27,36	57,68
26,36	27,37	57,70
26,37	27,38	57,71
26,38	27,39	57,73
26,39	27,40	57,75
26,40	27,41	57,76
26,41	27,42	57,78
26,42	27,43	57,79
26,43	27,44	57,81
26,44	27,45	57,83
26,45	27,46	57,84
26,46	27,47	57,86
26,47	27,48	57,88
26,48	27,49	57,89
26,49	27,50	57,91
26,50	27,51	57,92
26,51	27,52	57,94
26,52	27,53	57,96
26,53	27,54	57,97
26,54	27,55	57,99
26,55	27,56	58,01
26,56	27,57	58,02



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
26,57	27,58	58,04
26,58	27,59	58,05
26,59	27,60	58,07
26,60	27,61	58,09
26,61	27,62	58,10
26,62	27,63	58,12
26,63	27,64	58,13
26,64	27,65	58,15
26,65	27,66	58,17
26,66	27,67	58,18
26,67	27,68	58,20
26,68	27,69	58,22
26,69	27,70	58,23
26,70	27,71	58,25
26,71	27,72	58,26
26,72	27,73	58,28
26,73	27,74	58,30
26,74	27,75	58,31
26,75	27,76	58,33
26,76	27,77	58,34
26,77	27,78	58,36
26,78	27,79	58,38
26,79	27,80	58,39
26,80	27,81	58,41
26,81	27,82	58,43
26,82	27,83	58,44
26,83	27,84	58,46
26,84	27,85	58,47
26,85	27,86	58,49
26,86	27,87	58,51
26,87	27,88	58,52
26,88	27,89	58,54
26,89	27,90	58,55
26,90	27,91	58,57
26,91	27,92	58,59
26,92	27,93	58,60
26,93	27,94	58,62
26,94	27,95	58,63
26,95	27,96	58,65
26,96	27,97	58,67
26,97	27,98	58,68
26,98	27,99	58,70
26,99	28,00	58,71
27,00	28,01	58,73



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	58,75
27,02	28,03	58,76
27,03	28,04	58,78
27,04	28,05	58,79
27,05	28,06	58,81
27,06	28,07	58,83
27,07	28,08	58,84
27,08	28,09	58,86
27,09	28,10	58,87
27,10	28,11	58,89
27,11	28,12	58,91
27,12	28,13	58,92
27,13	28,14	58,94
27,14	28,15	58,95
27,15	28,16	58,97
27,16	28,17	58,98
27,17	28,18	59,00
27,18	28,19	59,02
27,19	28,20	59,03
27,20	28,21	59,05
27,21	28,22	59,06
27,22	28,23	59,08
27,23	28,24	59,10
27,24	28,25	59,11
27,25	28,26	59,13
27,26	28,27	59,14
27,27	28,28	59,16
27,28	28,29	59,18
27,29	28,30	59,19
27,30	28,31	59,21
27,31	28,32	59,22
27,32	28,33	59,24
27,33	28,34	59,25
27,34	28,35	59,27
27,35	28,36	59,29
27,36	28,37	59,30
27,37	28,38	59,32
27,38	28,39	59,33
27,39	28,40	59,35
27,40	28,41	59,37
27,41	28,42	59,38
27,42	28,43	59,40
27,43	28,44	59,41
27,44	28,45	59,43



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	59,44
27,46	28,47	59,46
27,47	28,48	59,48
27,48	28,49	59,49
27,49	28,50	59,51
27,50	28,51	59,52
27,51	28,52	59,54
27,52	28,53	59,55
27,53	28,54	59,57
27,54	28,55	59,59
27,55	28,56	59,60
27,56	28,57	59,62
27,57	28,58	59,63
27,58	28,59	59,65
27,59	28,60	59,66
27,60	28,61	59,68
27,61	28,62	59,70
27,62	28,63	59,71
27,63	28,64	59,73
27,64	28,65	59,74
27,65	28,66	59,76
27,66	28,67	59,77
27,67	28,68	59,79
27,68	28,69	59,81
27,69	28,70	59,82
27,70	28,71	59,84
27,71	28,72	59,85
27,72	28,73	59,87
27,73	28,74	59,88
27,74	28,75	59,90
27,75	28,76	59,92
27,76	28,77	59,93
27,77	28,78	59,95
27,78	28,79	59,96
27,79	28,80	59,98
27,80	28,81	59,99
27,81	28,82	60,01
27,82	28,83	60,02
27,83	28,84	60,04
27,84	28,85	60,06
27,85	28,86	60,07
27,86	28,87	60,09
27,87	28,88	60,10
27,88	28,89	60,12



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	60,13
27,90	28,91	60,15
27,91	28,92	60,16
27,92	28,93	60,18
27,93	28,94	60,20
27,94	28,95	60,21
27,95	28,96	60,23
27,96	28,97	60,24
27,97	28,98	60,26
27,98	28,99	60,27
27,99	29,00	60,29
28,00	29,01	60,30
28,01	29,02	60,32
28,02	29,03	60,34
28,03	29,04	60,35
28,04	29,05	60,37
28,05	29,06	60,38
28,06	29,07	60,40
28,07	29,08	60,41
28,08	29,09	60,43
28,09	29,10	60,44
28,10	29,11	60,46
28,11	29,12	60,48
28,12	29,13	60,49
28,13	29,14	60,51
28,14	29,15	60,52
28,15	29,16	60,54
28,16	29,17	60,55
28,17	29,18	60,57
28,18	29,19	60,58
28,19	29,20	60,60
28,20	29,21	60,61
28,21	29,22	60,63
28,22	29,23	60,64
28,23	29,24	60,66
28,24	29,25	60,68
28,25	29,26	60,69
28,26	29,27	60,71
28,27	29,28	60,72
28,28	29,29	60,74
28,29	29,30	60,75
28,30	29,31	60,77
28,31	29,32	60,78
28,32	29,33	60,80



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	60,81
28,34	29,35	60,83
28,35	29,36	60,84
28,36	29,37	60,86
28,37	29,38	60,88
28,38	29,39	60,89
28,39	29,40	60,91
28,40	29,41	60,92
28,41	29,42	60,94
28,42	29,43	60,95
28,43	29,44	60,97
28,44	29,45	60,98
28,45	29,46	61,00
28,46	29,47	61,01
28,47	29,48	61,03
28,48	29,49	61,04
28,49	29,50	61,06
28,50	29,51	61,07
28,51	29,52	61,09
28,52	29,53	61,11
28,53	29,54	61,12
28,54	29,55	61,14
28,55	29,56	61,15
28,56	29,57	61,17
28,57	29,58	61,18
28,58	29,59	61,20
28,59	29,60	61,21
28,60	29,61	61,23
28,61	29,62	61,24
28,62	29,63	61,26
28,63	29,64	61,27
28,64	29,65	61,29
28,65	29,66	61,30
28,66	29,67	61,32
28,67	29,68	61,33
28,68	29,69	61,35
28,69	29,70	61,36
28,70	29,71	61,38
28,71	29,72	61,39
28,72	29,73	61,41
28,73	29,74	61,43
28,74	29,75	61,44
28,75	29,76	61,46
28,76	29,77	61,47



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	61,49
28,78	29,79	61,50
28,79	29,80	61,52
28,80	29,81	61,53
28,81	29,82	61,55
28,82	29,83	61,56
28,83	29,84	61,58
28,84	29,85	61,59
28,85	29,86	61,61
28,86	29,87	61,62
28,87	29,88	61,64
28,88	29,89	61,65
28,89	29,90	61,67
28,90	29,91	61,68
28,91	29,92	61,70
28,92	29,93	61,71
28,93	29,94	61,73
28,94	29,95	61,74
28,95	29,96	61,76
28,96	29,97	61,77
28,97	29,98	61,79
28,98	29,99	61,80
28,99	30,00	61,82
29,00	30,01	61,83
29,01	30,02	61,85
29,02	30,03	61,86
29,03	30,04	61,88
29,04	30,05	61,89
29,05	30,06	61,91
29,06	30,07	61,92
29,07	30,08	61,94
29,08	30,09	61,95
29,09	30,10	61,97
29,10	30,11	61,98
29,11	30,12	62,00
29,12	30,13	62,01
29,13	30,14	62,03
29,14	30,15	62,04
29,15	30,16	62,06
29,16	30,17	62,07
29,17	30,18	62,09
29,18	30,19	62,10
29,19	30,20	62,12
29,20	30,21	62,13



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	62,15
29,22	30,23	62,16
29,23	30,24	62,18
29,24	30,25	62,19
29,25	30,26	62,21
29,26	30,27	62,22
29,27	30,28	62,24
29,28	30,29	62,25
29,29	30,30	62,27
29,30	30,31	62,28
29,31	30,32	62,30
29,32	30,33	62,31
29,33	30,34	62,33
29,34	30,35	62,34
29,35	30,36	62,36
29,36	30,37	62,37
29,37	30,38	62,39
29,38	30,39	62,40
29,39	30,40	62,42
29,40	30,41	62,43
29,41	30,42	62,45
29,42	30,43	62,46
29,43	30,44	62,48
29,44	30,45	62,49
29,45	30,46	62,51
29,46	30,47	62,52
29,47	30,48	62,54
29,48	30,49	62,55
29,49	30,50	62,57
29,50	30,51	62,58
29,51	30,52	62,60
29,52	30,53	62,61
29,53	30,54	62,63
29,54	30,55	62,64
29,55	30,56	62,65
29,56	30,57	62,67
29,57	30,58	62,68
29,58	30,59	62,70
29,59	30,60	62,71
29,60	30,61	62,73
29,61	30,62	62,74
29,62	30,63	62,76
29,63	30,64	62,77
29,64	30,65	62,79



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
29,65	30,66	62,80
29,66	30,67	62,82
29,67	30,68	62,83
29,68	30,69	62,85
29,69	30,70	62,86
29,70	30,71	62,88
29,71	30,72	62,89
29,72	30,73	62,91
29,73	30,74	62,92
29,74	30,75	62,94
29,75	30,76	62,95
29,76	30,77	62,97
29,77	30,78	62,98
29,78	30,79	62,99
29,79	30,80	63,01
29,80	30,81	63,02
29,81	30,82	63,04
29,82	30,83	63,05
29,83	30,84	63,07
29,84	30,85	63,08
29,85	30,86	63,10
29,86	30,87	63,11
29,87	30,88	63,13
29,88	30,89	63,14
29,89	30,90	63,16
29,90	30,91	63,17
29,91	30,92	63,19
29,92	30,93	63,20
29,93	30,94	63,21
29,94	30,95	63,23
29,95	30,96	63,24
29,96	30,97	63,26
29,97	30,98	63,27
29,98	30,99	63,29
29,99	31,00	63,30
30,00	31,01	63,32
30,01	31,02	63,33
30,02	31,03	63,35
30,03	31,04	63,36
30,04	31,05	63,38
30,05	31,06	63,39
30,06	31,07	63,40
30,07	31,08	63,42
30,08	31,09	63,43



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,09	31,10	63,45
30,10	31,11	63,46
30,11	31,12	63,48
30,12	31,13	63,49
30,13	31,14	63,51
30,14	31,15	63,52
30,15	31,16	63,54
30,16	31,17	63,55
30,17	31,18	63,57
30,18	31,19	63,58
30,19	31,20	63,59
30,20	31,21	63,61
30,21	31,22	63,62
30,22	31,23	63,64
30,23	31,24	63,65
30,24	31,25	63,67
30,25	31,26	63,68
30,26	31,27	63,70
30,27	31,28	63,71
30,28	31,29	63,72
30,29	31,30	63,74
30,30	31,31	63,75
30,31	31,32	63,77
30,32	31,33	63,78
30,33	31,34	63,80
30,34	31,35	63,81
30,35	31,36	63,83
30,36	31,37	63,84
30,37	31,38	63,86
30,38	31,39	63,87
30,39	31,40	63,88
30,40	31,41	63,90
30,41	31,42	63,91
30,42	31,43	63,93
30,43	31,44	63,94
30,44	31,45	63,96
30,45	31,46	63,97
30,46	31,47	63,99
30,47	31,48	64,00
30,48	31,49	64,01
30,49	31,50	64,03
30,50	31,51	64,04
30,51	31,52	64,06
30,52	31,53	64,07



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	64,09
30,54	31,55	64,10
30,55	31,56	64,11
30,56	31,57	64,13
30,57	31,58	64,14
30,58	31,59	64,16
30,59	31,60	64,17
30,60	31,61	64,19
30,61	31,62	64,20
30,62	31,63	64,22
30,63	31,64	64,23
30,64	31,65	64,24
30,65	31,66	64,26
30,66	31,67	64,27
30,67	31,68	64,29
30,68	31,69	64,30
30,69	31,70	64,32
30,70	31,71	64,33
30,71	31,72	64,34
30,72	31,73	64,36
30,73	31,74	64,37
30,74	31,75	64,39
30,75	31,76	64,40
30,76	31,77	64,42
30,77	31,78	64,43
30,78	31,79	64,44
30,79	31,80	64,46
30,80	31,81	64,47
30,81	31,82	64,49
30,82	31,83	64,50
30,83	31,84	64,52
30,84	31,85	64,53
30,85	31,86	64,54
30,86	31,87	64,56
30,87	31,88	64,57
30,88	31,89	64,59
30,89	31,90	64,60
30,90	31,91	64,62
30,91	31,92	64,63
30,92	31,93	64,64
30,93	31,94	64,66
30,94	31,95	64,67
30,95	31,96	64,69
30,96	31,97	64,70



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,97	31,98	64,71
30,98	31,99	64,73
30,99	32,00	64,74
31,00	32,01	64,76
31,01	32,02	64,77
31,02	32,03	64,79
31,03	32,04	64,80
31,04	32,05	64,81
31,05	32,06	64,83
31,06	32,07	64,84
31,07	32,08	64,86
31,08	32,09	64,87
31,09	32,10	64,88
31,10	32,11	64,90
31,11	32,12	64,91
31,12	32,13	64,93
31,13	32,14	64,94
31,14	32,15	64,96
31,15	32,16	64,97
31,16	32,17	64,98
31,17	32,18	65,00
31,18	32,19	65,01
31,19	32,20	65,03
31,20	32,21	65,04
31,21	32,22	65,05
31,22	32,23	65,07
31,23	32,24	65,08
31,24	32,25	65,10
31,25	32,26	65,11
31,26	32,27	65,12
31,27	32,28	65,14
31,28	32,29	65,15
31,29	32,30	65,17
31,30	32,31	65,18
31,31	32,32	65,19
31,32	32,33	65,21
31,33	32,34	65,22
31,34	32,35	65,24
31,35	32,36	65,25
31,36	32,37	65,26
31,37	32,38	65,28
31,38	32,39	65,29
31,39	32,40	65,31
31,40	32,41	65,32



R422A		
V1.0_R422A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	65,34
31,42	32,43	65,35
31,43	32,44	65,36
31,44	32,45	65,38
31,45	32,46	65,39
31,46	32,47	65,41
31,47	32,48	65,42
31,48	32,49	65,43
31,49	32,50	65,45
31,50	32,51	65,46
31,51	32,52	65,47
31,52	32,53	65,49
31,53	32,54	65,50
31,54	32,55	65,52
31,55	32,56	65,53
31,56	32,57	65,54
31,57	32,58	65,56
31,58	32,59	65,57
31,59	32,60	65,59
31,60	32,61	65,60
31,61	32,62	65,61
31,62	32,63	65,63
31,63	32,64	65,64
31,64	32,65	65,66
31,65	32,66	65,67
31,66	32,67	65,68
31,67	32,68	65,70
31,68	32,69	65,71