



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-58,20
-0,70	0,31	-57,66
-0,69	0,32	-57,14
-0,68	0,33	-56,63
-0,67	0,34	-56,14
-0,66	0,35	-55,66
-0,65	0,36	-55,18
-0,64	0,37	-54,72
-0,63	0,38	-54,27
-0,62	0,39	-53,83
-0,61	0,40	-53,40
-0,60	0,41	-52,97
-0,59	0,42	-52,55
-0,58	0,43	-52,15
-0,57	0,44	-51,75
-0,56	0,45	-51,35
-0,55	0,46	-50,97
-0,54	0,47	-50,59
-0,53	0,48	-50,21
-0,52	0,49	-49,85
-0,51	0,50	-49,48
-0,50	0,51	-49,13
-0,49	0,52	-48,78
-0,48	0,53	-48,43
-0,47	0,54	-48,10
-0,46	0,55	-47,76
-0,45	0,56	-47,43
-0,44	0,57	-47,11
-0,43	0,58	-46,79
-0,42	0,59	-46,47
-0,41	0,60	-46,16
-0,40	0,61	-45,85
-0,39	0,62	-45,55
-0,38	0,63	-45,25
-0,37	0,64	-44,95
-0,36	0,65	-44,66
-0,35	0,66	-44,37
-0,34	0,67	-44,09
-0,33	0,68	-43,80
-0,32	0,69	-43,53
-0,31	0,70	-43,25
-0,30	0,71	-42,98
-0,29	0,72	-42,71
-0,28	0,73	-42,44



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-42,18
-0,26	0,75	-41,92
-0,25	0,76	-41,66
-0,24	0,77	-41,41
-0,23	0,78	-41,15
-0,22	0,79	-40,90
-0,21	0,80	-40,66
-0,20	0,81	-40,41
-0,19	0,82	-40,17
-0,18	0,83	-39,93
-0,17	0,84	-39,69
-0,16	0,85	-39,46
-0,15	0,86	-39,22
-0,14	0,87	-38,99
-0,13	0,88	-38,76
-0,12	0,89	-38,53
-0,11	0,90	-38,31
-0,10	0,91	-38,08
-0,09	0,92	-37,86
-0,08	0,93	-37,64
-0,07	0,94	-37,43
-0,06	0,95	-37,21
-0,05	0,96	-37,00
-0,04	0,97	-36,78
-0,03	0,98	-36,57
-0,02	0,99	-36,37
-0,01	1,00	-36,16
0,00	1,01	-35,95
0,01	1,02	-35,75
0,02	1,03	-35,55
0,03	1,04	-35,35
0,04	1,05	-35,15
0,05	1,06	-34,95
0,06	1,07	-34,75
0,07	1,08	-34,56
0,08	1,09	-34,36
0,09	1,10	-34,17
0,10	1,11	-33,98
0,11	1,12	-33,79
0,12	1,13	-33,60
0,13	1,14	-33,42
0,14	1,15	-33,23
0,15	1,16	-33,05
0,16	1,17	-32,86



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,17	1,18	-32,68
0,18	1,19	-32,50
0,19	1,20	-32,32
0,20	1,21	-32,14
0,21	1,22	-31,97
0,22	1,23	-31,79
0,23	1,24	-31,62
0,24	1,25	-31,44
0,25	1,26	-31,27
0,26	1,27	-31,10
0,27	1,28	-30,93
0,28	1,29	-30,76
0,29	1,30	-30,59
0,30	1,31	-30,42
0,31	1,32	-30,26
0,32	1,33	-30,09
0,33	1,34	-29,93
0,34	1,35	-29,76
0,35	1,36	-29,60
0,36	1,37	-29,44
0,37	1,38	-29,28
0,38	1,39	-29,12
0,39	1,40	-28,96
0,40	1,41	-28,80
0,41	1,42	-28,64
0,42	1,43	-28,49
0,43	1,44	-28,33
0,44	1,45	-28,18
0,45	1,46	-28,02
0,46	1,47	-27,87
0,47	1,48	-27,72
0,48	1,49	-27,57
0,49	1,50	-27,42
0,50	1,51	-27,27
0,51	1,52	-27,12
0,52	1,53	-26,97
0,53	1,54	-26,82
0,54	1,55	-26,67
0,55	1,56	-26,53
0,56	1,57	-26,38
0,57	1,58	-26,24
0,58	1,59	-26,09
0,59	1,60	-25,95
0,60	1,61	-25,81



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,61	1,62	-25,67
0,62	1,63	-25,53
0,63	1,64	-25,39
0,64	1,65	-25,25
0,65	1,66	-25,11
0,66	1,67	-24,97
0,67	1,68	-24,83
0,68	1,69	-24,69
0,69	1,70	-24,56
0,70	1,71	-24,42
0,71	1,72	-24,29
0,72	1,73	-24,15
0,73	1,74	-24,02
0,74	1,75	-23,88
0,75	1,76	-23,75
0,76	1,77	-23,62
0,77	1,78	-23,49
0,78	1,79	-23,35
0,79	1,80	-23,22
0,80	1,81	-23,09
0,81	1,82	-22,96
0,82	1,83	-22,84
0,83	1,84	-22,71
0,84	1,85	-22,58
0,85	1,86	-22,45
0,86	1,87	-22,33
0,87	1,88	-22,20
0,88	1,89	-22,07
0,89	1,90	-21,95
0,90	1,91	-21,82
0,91	1,92	-21,70
0,92	1,93	-21,58
0,93	1,94	-21,45
0,94	1,95	-21,33
0,95	1,96	-21,21
0,96	1,97	-21,09
0,97	1,98	-20,96
0,98	1,99	-20,84
0,99	2,00	-20,72
1,00	2,01	-20,60
1,01	2,02	-20,48
1,02	2,03	-20,36
1,03	2,04	-20,25
1,04	2,05	-20,13



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	-20,01
1,06	2,07	-19,89
1,07	2,08	-19,78
1,08	2,09	-19,66
1,09	2,10	-19,54
1,10	2,11	-19,43
1,11	2,12	-19,31
1,12	2,13	-19,20
1,13	2,14	-19,09
1,14	2,15	-18,97
1,15	2,16	-18,86
1,16	2,17	-18,75
1,17	2,18	-18,63
1,18	2,19	-18,52
1,19	2,20	-18,41
1,20	2,21	-18,30
1,21	2,22	-18,19
1,22	2,23	-18,08
1,23	2,24	-17,97
1,24	2,25	-17,86
1,25	2,26	-17,75
1,26	2,27	-17,64
1,27	2,28	-17,53
1,28	2,29	-17,42
1,29	2,30	-17,31
1,30	2,31	-17,20
1,31	2,32	-17,10
1,32	2,33	-16,99
1,33	2,34	-16,88
1,34	2,35	-16,78
1,35	2,36	-16,67
1,36	2,37	-16,57
1,37	2,38	-16,46
1,38	2,39	-16,36
1,39	2,40	-16,25
1,40	2,41	-16,15
1,41	2,42	-16,04
1,42	2,43	-15,94
1,43	2,44	-15,84
1,44	2,45	-15,73
1,45	2,46	-15,63
1,46	2,47	-15,53
1,47	2,48	-15,43
1,48	2,49	-15,32



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,49	2,50	-15,22
1,50	2,51	-15,12
1,51	2,52	-15,02
1,52	2,53	-14,92
1,53	2,54	-14,82
1,54	2,55	-14,72
1,55	2,56	-14,62
1,56	2,57	-14,52
1,57	2,58	-14,42
1,58	2,59	-14,33
1,59	2,60	-14,23
1,60	2,61	-14,13
1,61	2,62	-14,03
1,62	2,63	-13,93
1,63	2,64	-13,84
1,64	2,65	-13,74
1,65	2,66	-13,64
1,66	2,67	-13,55
1,67	2,68	-13,45
1,68	2,69	-13,36
1,69	2,70	-13,26
1,70	2,71	-13,16
1,71	2,72	-13,07
1,72	2,73	-12,98
1,73	2,74	-12,88
1,74	2,75	-12,79
1,75	2,76	-12,69
1,76	2,77	-12,60
1,77	2,78	-12,51
1,78	2,79	-12,41
1,79	2,80	-12,32
1,80	2,81	-12,23
1,81	2,82	-12,14
1,82	2,83	-12,04
1,83	2,84	-11,95
1,84	2,85	-11,86
1,85	2,86	-11,77
1,86	2,87	-11,68
1,87	2,88	-11,59
1,88	2,89	-11,50
1,89	2,90	-11,41
1,90	2,91	-11,32
1,91	2,92	-11,23
1,92	2,93	-11,14



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,93	2,94	-11,05
1,94	2,95	-10,96
1,95	2,96	-10,87
1,96	2,97	-10,78
1,97	2,98	-10,69
1,98	2,99	-10,60
1,99	3,00	-10,51
2,00	3,01	-10,43
2,01	3,02	-10,34
2,02	3,03	-10,25
2,03	3,04	-10,16
2,04	3,05	-10,08
2,05	3,06	-9,99
2,06	3,07	-9,90
2,07	3,08	-9,82
2,08	3,09	-9,73
2,09	3,10	-9,65
2,10	3,11	-9,56
2,11	3,12	-9,47
2,12	3,13	-9,39
2,13	3,14	-9,30
2,14	3,15	-9,22
2,15	3,16	-9,14
2,16	3,17	-9,05
2,17	3,18	-8,97
2,18	3,19	-8,88
2,19	3,20	-8,80
2,20	3,21	-8,72
2,21	3,22	-8,63
2,22	3,23	-8,55
2,23	3,24	-8,47
2,24	3,25	-8,38
2,25	3,26	-8,30
2,26	3,27	-8,22
2,27	3,28	-8,14
2,28	3,29	-8,05
2,29	3,30	-7,97
2,30	3,31	-7,89
2,31	3,32	-7,81
2,32	3,33	-7,73
2,33	3,34	-7,65
2,34	3,35	-7,56
2,35	3,36	-7,48
2,36	3,37	-7,40



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
2,37	3,38	-7,32
2,38	3,39	-7,24
2,39	3,40	-7,16
2,40	3,41	-7,08
2,41	3,42	-7,00
2,42	3,43	-6,92
2,43	3,44	-6,84
2,44	3,45	-6,77
2,45	3,46	-6,69
2,46	3,47	-6,61
2,47	3,48	-6,53
2,48	3,49	-6,45
2,49	3,50	-6,37
2,50	3,51	-6,29
2,51	3,52	-6,22
2,52	3,53	-6,14
2,53	3,54	-6,06
2,54	3,55	-5,98
2,55	3,56	-5,91
2,56	3,57	-5,83
2,57	3,58	-5,75
2,58	3,59	-5,68
2,59	3,60	-5,60
2,60	3,61	-5,52
2,61	3,62	-5,45
2,62	3,63	-5,37
2,63	3,64	-5,29
2,64	3,65	-5,22
2,65	3,66	-5,14
2,66	3,67	-5,07
2,67	3,68	-4,99
2,68	3,69	-4,92
2,69	3,70	-4,84
2,70	3,71	-4,77
2,71	3,72	-4,69
2,72	3,73	-4,62
2,73	3,74	-4,54
2,74	3,75	-4,47
2,75	3,76	-4,39
2,76	3,77	-4,32
2,77	3,78	-4,25
2,78	3,79	-4,17
2,79	3,80	-4,10
2,80	3,81	-4,03



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
2,81	3,82	-3,95
2,82	3,83	-3,88
2,83	3,84	-3,81
2,84	3,85	-3,73
2,85	3,86	-3,66
2,86	3,87	-3,59
2,87	3,88	-3,52
2,88	3,89	-3,44
2,89	3,90	-3,37
2,90	3,91	-3,30
2,91	3,92	-3,23
2,92	3,93	-3,16
2,93	3,94	-3,09
2,94	3,95	-3,01
2,95	3,96	-2,94
2,96	3,97	-2,87
2,97	3,98	-2,80
2,98	3,99	-2,73
2,99	4,00	-2,66
3,00	4,01	-2,59
3,01	4,02	-2,52
3,02	4,03	-2,45
3,03	4,04	-2,38
3,04	4,05	-2,31
3,05	4,06	-2,24
3,06	4,07	-2,17
3,07	4,08	-2,10
3,08	4,09	-2,03
3,09	4,10	-1,96
3,10	4,11	-1,89
3,11	4,12	-1,82
3,12	4,13	-1,75
3,13	4,14	-1,68
3,14	4,15	-1,61
3,15	4,16	-1,55
3,16	4,17	-1,48
3,17	4,18	-1,41
3,18	4,19	-1,34
3,19	4,20	-1,27
3,20	4,21	-1,20
3,21	4,22	-1,14
3,22	4,23	-1,07
3,23	4,24	-1,00
3,24	4,25	-0,93



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
3,25	4,26	-0,87
3,26	4,27	-0,80
3,27	4,28	-0,73
3,28	4,29	-0,67
3,29	4,30	-0,60
3,30	4,31	-0,53
3,31	4,32	-0,46
3,32	4,33	-0,40
3,33	4,34	-0,33
3,34	4,35	-0,27
3,35	4,36	-0,20
3,36	4,37	-0,13
3,37	4,38	-0,07
3,38	4,39	0,00
3,39	4,40	0,06
3,40	4,41	0,13
3,41	4,42	0,20
3,42	4,43	0,26
3,43	4,44	0,33
3,44	4,45	0,39
3,45	4,46	0,46
3,46	4,47	0,52
3,47	4,48	0,59
3,48	4,49	0,65
3,49	4,50	0,72
3,50	4,51	0,78
3,51	4,52	0,85
3,52	4,53	0,91
3,53	4,54	0,97
3,54	4,55	1,04
3,55	4,56	1,10
3,56	4,57	1,17
3,57	4,58	1,23
3,58	4,59	1,29
3,59	4,60	1,36
3,60	4,61	1,42
3,61	4,62	1,48
3,62	4,63	1,55
3,63	4,64	1,61
3,64	4,65	1,67
3,65	4,66	1,74
3,66	4,67	1,80
3,67	4,68	1,86
3,68	4,69	1,92



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
3,69	4,70	1,99
3,70	4,71	2,05
3,71	4,72	2,11
3,72	4,73	2,17
3,73	4,74	2,24
3,74	4,75	2,30
3,75	4,76	2,36
3,76	4,77	2,42
3,77	4,78	2,48
3,78	4,79	2,55
3,79	4,80	2,61
3,80	4,81	2,67
3,81	4,82	2,73
3,82	4,83	2,79
3,83	4,84	2,85
3,84	4,85	2,91
3,85	4,86	2,97
3,86	4,87	3,04
3,87	4,88	3,10
3,88	4,89	3,16
3,89	4,90	3,22
3,90	4,91	3,28
3,91	4,92	3,34
3,92	4,93	3,40
3,93	4,94	3,46
3,94	4,95	3,52
3,95	4,96	3,58
3,96	4,97	3,64
3,97	4,98	3,70
3,98	4,99	3,76
3,99	5,00	3,82
4,00	5,01	3,88
4,01	5,02	3,94
4,02	5,03	4,00
4,03	5,04	4,06
4,04	5,05	4,12
4,05	5,06	4,18
4,06	5,07	4,23
4,07	5,08	4,29
4,08	5,09	4,35
4,09	5,10	4,41
4,10	5,11	4,47
4,11	5,12	4,53
4,12	5,13	4,59



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	4,65
4,14	5,15	4,70
4,15	5,16	4,76
4,16	5,17	4,82
4,17	5,18	4,88
4,18	5,19	4,94
4,19	5,20	4,99
4,20	5,21	5,05
4,21	5,22	5,11
4,22	5,23	5,17
4,23	5,24	5,23
4,24	5,25	5,28
4,25	5,26	5,34
4,26	5,27	5,40
4,27	5,28	5,46
4,28	5,29	5,51
4,29	5,30	5,57
4,30	5,31	5,63
4,31	5,32	5,68
4,32	5,33	5,74
4,33	5,34	5,80
4,34	5,35	5,85
4,35	5,36	5,91
4,36	5,37	5,97
4,37	5,38	6,02
4,38	5,39	6,08
4,39	5,40	6,14
4,40	5,41	6,19
4,41	5,42	6,25
4,42	5,43	6,30
4,43	5,44	6,36
4,44	5,45	6,42
4,45	5,46	6,47
4,46	5,47	6,53
4,47	5,48	6,58
4,48	5,49	6,64
4,49	5,50	6,70
4,50	5,51	6,75
4,51	5,52	6,81
4,52	5,53	6,86
4,53	5,54	6,92
4,54	5,55	6,97
4,55	5,56	7,03
4,56	5,57	7,08



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
4,57	5,58	7,14
4,58	5,59	7,19
4,59	5,60	7,25
4,60	5,61	7,30
4,61	5,62	7,36
4,62	5,63	7,41
4,63	5,64	7,47
4,64	5,65	7,52
4,65	5,66	7,57
4,66	5,67	7,63
4,67	5,68	7,68
4,68	5,69	7,74
4,69	5,70	7,79
4,70	5,71	7,84
4,71	5,72	7,90
4,72	5,73	7,95
4,73	5,74	8,01
4,74	5,75	8,06
4,75	5,76	8,11
4,76	5,77	8,17
4,77	5,78	8,22
4,78	5,79	8,27
4,79	5,80	8,33
4,80	5,81	8,38
4,81	5,82	8,43
4,82	5,83	8,49
4,83	5,84	8,54
4,84	5,85	8,59
4,85	5,86	8,65
4,86	5,87	8,70
4,87	5,88	8,75
4,88	5,89	8,81
4,89	5,90	8,86
4,90	5,91	8,91
4,91	5,92	8,96
4,92	5,93	9,02
4,93	5,94	9,07
4,94	5,95	9,12
4,95	5,96	9,17
4,96	5,97	9,22
4,97	5,98	9,28
4,98	5,99	9,33
4,99	6,00	9,38
5,00	6,01	9,43



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	9,48
5,02	6,03	9,54
5,03	6,04	9,59
5,04	6,05	9,64
5,05	6,06	9,69
5,06	6,07	9,74
5,07	6,08	9,79
5,08	6,09	9,85
5,09	6,10	9,90
5,10	6,11	9,95
5,11	6,12	10,00
5,12	6,13	10,05
5,13	6,14	10,10
5,14	6,15	10,15
5,15	6,16	10,20
5,16	6,17	10,26
5,17	6,18	10,31
5,18	6,19	10,36
5,19	6,20	10,41
5,20	6,21	10,46
5,21	6,22	10,51
5,22	6,23	10,56
5,23	6,24	10,61
5,24	6,25	10,66
5,25	6,26	10,71
5,26	6,27	10,76
5,27	6,28	10,81
5,28	6,29	10,86
5,29	6,30	10,91
5,30	6,31	10,96
5,31	6,32	11,01
5,32	6,33	11,06
5,33	6,34	11,11
5,34	6,35	11,16
5,35	6,36	11,21
5,36	6,37	11,26
5,37	6,38	11,31
5,38	6,39	11,36
5,39	6,40	11,41
5,40	6,41	11,46
5,41	6,42	11,51
5,42	6,43	11,56
5,43	6,44	11,61
5,44	6,45	11,66



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,45	6,46	11,71
5,46	6,47	11,76
5,47	6,48	11,80
5,48	6,49	11,85
5,49	6,50	11,90
5,50	6,51	11,95
5,51	6,52	12,00
5,52	6,53	12,05
5,53	6,54	12,10
5,54	6,55	12,15
5,55	6,56	12,20
5,56	6,57	12,24
5,57	6,58	12,29
5,58	6,59	12,34
5,59	6,60	12,39
5,60	6,61	12,44
5,61	6,62	12,49
5,62	6,63	12,53
5,63	6,64	12,58
5,64	6,65	12,63
5,65	6,66	12,68
5,66	6,67	12,73
5,67	6,68	12,78
5,68	6,69	12,82
5,69	6,70	12,87
5,70	6,71	12,92
5,71	6,72	12,97
5,72	6,73	13,01
5,73	6,74	13,06
5,74	6,75	13,11
5,75	6,76	13,16
5,76	6,77	13,20
5,77	6,78	13,25
5,78	6,79	13,30
5,79	6,80	13,35
5,80	6,81	13,39
5,81	6,82	13,44
5,82	6,83	13,49
5,83	6,84	13,54
5,84	6,85	13,58
5,85	6,86	13,63
5,86	6,87	13,68
5,87	6,88	13,72
5,88	6,89	13,77



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	13,82
5,90	6,91	13,86
5,91	6,92	13,91
5,92	6,93	13,96
5,93	6,94	14,00
5,94	6,95	14,05
5,95	6,96	14,10
5,96	6,97	14,14
5,97	6,98	14,19
5,98	6,99	14,24
5,99	7,00	14,28
6,00	7,01	14,33
6,01	7,02	14,38
6,02	7,03	14,42
6,03	7,04	14,47
6,04	7,05	14,51
6,05	7,06	14,56
6,06	7,07	14,61
6,07	7,08	14,65
6,08	7,09	14,70
6,09	7,10	14,74
6,10	7,11	14,79
6,11	7,12	14,84
6,12	7,13	14,88
6,13	7,14	14,93
6,14	7,15	14,97
6,15	7,16	15,02
6,16	7,17	15,06
6,17	7,18	15,11
6,18	7,19	15,15
6,19	7,20	15,20
6,20	7,21	15,24
6,21	7,22	15,29
6,22	7,23	15,34
6,23	7,24	15,38
6,24	7,25	15,43
6,25	7,26	15,47
6,26	7,27	15,52
6,27	7,28	15,56
6,28	7,29	15,61
6,29	7,30	15,65
6,30	7,31	15,70
6,31	7,32	15,74
6,32	7,33	15,78



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,33	7,34	15,83
6,34	7,35	15,87
6,35	7,36	15,92
6,36	7,37	15,96
6,37	7,38	16,01
6,38	7,39	16,05
6,39	7,40	16,10
6,40	7,41	16,14
6,41	7,42	16,19
6,42	7,43	16,23
6,43	7,44	16,27
6,44	7,45	16,32
6,45	7,46	16,36
6,46	7,47	16,41
6,47	7,48	16,45
6,48	7,49	16,49
6,49	7,50	16,54
6,50	7,51	16,58
6,51	7,52	16,63
6,52	7,53	16,67
6,53	7,54	16,71
6,54	7,55	16,76
6,55	7,56	16,80
6,56	7,57	16,85
6,57	7,58	16,89
6,58	7,59	16,93
6,59	7,60	16,98
6,60	7,61	17,02
6,61	7,62	17,06
6,62	7,63	17,11
6,63	7,64	17,15
6,64	7,65	17,19
6,65	7,66	17,24
6,66	7,67	17,28
6,67	7,68	17,32
6,68	7,69	17,37
6,69	7,70	17,41
6,70	7,71	17,45
6,71	7,72	17,50
6,72	7,73	17,54
6,73	7,74	17,58
6,74	7,75	17,62
6,75	7,76	17,67
6,76	7,77	17,71



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,77	7,78	17,75
6,78	7,79	17,80
6,79	7,80	17,84
6,80	7,81	17,88
6,81	7,82	17,92
6,82	7,83	17,97
6,83	7,84	18,01
6,84	7,85	18,05
6,85	7,86	18,09
6,86	7,87	18,14
6,87	7,88	18,18
6,88	7,89	18,22
6,89	7,90	18,26
6,90	7,91	18,31
6,91	7,92	18,35
6,92	7,93	18,39
6,93	7,94	18,43
6,94	7,95	18,47
6,95	7,96	18,52
6,96	7,97	18,56
6,97	7,98	18,60
6,98	7,99	18,64
6,99	8,00	18,68
7,00	8,01	18,73
7,01	8,02	18,77
7,02	8,03	18,81
7,03	8,04	18,85
7,04	8,05	18,89
7,05	8,06	18,94
7,06	8,07	18,98
7,07	8,08	19,02
7,08	8,09	19,06
7,09	8,10	19,10
7,10	8,11	19,14
7,11	8,12	19,18
7,12	8,13	19,23
7,13	8,14	19,27
7,14	8,15	19,31
7,15	8,16	19,35
7,16	8,17	19,39
7,17	8,18	19,43
7,18	8,19	19,47
7,19	8,20	19,51
7,20	8,21	19,56



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	19,60
7,22	8,23	19,64
7,23	8,24	19,68
7,24	8,25	19,72
7,25	8,26	19,76
7,26	8,27	19,80
7,27	8,28	19,84
7,28	8,29	19,88
7,29	8,30	19,92
7,30	8,31	19,96
7,31	8,32	20,01
7,32	8,33	20,05
7,33	8,34	20,09
7,34	8,35	20,13
7,35	8,36	20,17
7,36	8,37	20,21
7,37	8,38	20,25
7,38	8,39	20,29
7,39	8,40	20,33
7,40	8,41	20,37
7,41	8,42	20,41
7,42	8,43	20,45
7,43	8,44	20,49
7,44	8,45	20,53
7,45	8,46	20,57
7,46	8,47	20,61
7,47	8,48	20,65
7,48	8,49	20,69
7,49	8,50	20,73
7,50	8,51	20,77
7,51	8,52	20,81
7,52	8,53	20,85
7,53	8,54	20,89
7,54	8,55	20,93
7,55	8,56	20,97
7,56	8,57	21,01
7,57	8,58	21,05
7,58	8,59	21,09
7,59	8,60	21,13
7,60	8,61	21,17
7,61	8,62	21,21
7,62	8,63	21,25
7,63	8,64	21,29
7,64	8,65	21,33



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
7,65	8,66	21,37
7,66	8,67	21,41
7,67	8,68	21,45
7,68	8,69	21,49
7,69	8,70	21,53
7,70	8,71	21,56
7,71	8,72	21,60
7,72	8,73	21,64
7,73	8,74	21,68
7,74	8,75	21,72
7,75	8,76	21,76
7,76	8,77	21,80
7,77	8,78	21,84
7,78	8,79	21,88
7,79	8,80	21,92
7,80	8,81	21,96
7,81	8,82	22,00
7,82	8,83	22,03
7,83	8,84	22,07
7,84	8,85	22,11
7,85	8,86	22,15
7,86	8,87	22,19
7,87	8,88	22,23
7,88	8,89	22,27
7,89	8,90	22,31
7,90	8,91	22,34
7,91	8,92	22,38
7,92	8,93	22,42
7,93	8,94	22,46
7,94	8,95	22,50
7,95	8,96	22,54
7,96	8,97	22,58
7,97	8,98	22,61
7,98	8,99	22,65
7,99	9,00	22,69
8,00	9,01	22,73
8,01	9,02	22,77
8,02	9,03	22,81
8,03	9,04	22,84
8,04	9,05	22,88
8,05	9,06	22,92
8,06	9,07	22,96
8,07	9,08	23,00
8,08	9,09	23,03



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,09	9,10	23,07
8,10	9,11	23,11
8,11	9,12	23,15
8,12	9,13	23,19
8,13	9,14	23,22
8,14	9,15	23,26
8,15	9,16	23,30
8,16	9,17	23,34
8,17	9,18	23,38
8,18	9,19	23,41
8,19	9,20	23,45
8,20	9,21	23,49
8,21	9,22	23,53
8,22	9,23	23,56
8,23	9,24	23,60
8,24	9,25	23,64
8,25	9,26	23,68
8,26	9,27	23,71
8,27	9,28	23,75
8,28	9,29	23,79
8,29	9,30	23,83
8,30	9,31	23,86
8,31	9,32	23,90
8,32	9,33	23,94
8,33	9,34	23,98
8,34	9,35	24,01
8,35	9,36	24,05
8,36	9,37	24,09
8,37	9,38	24,13
8,38	9,39	24,16
8,39	9,40	24,20
8,40	9,41	24,24
8,41	9,42	24,27
8,42	9,43	24,31
8,43	9,44	24,35
8,44	9,45	24,39
8,45	9,46	24,42
8,46	9,47	24,46
8,47	9,48	24,50
8,48	9,49	24,53
8,49	9,50	24,57
8,50	9,51	24,61
8,51	9,52	24,64
8,52	9,53	24,68



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,53	9,54	24,72
8,54	9,55	24,75
8,55	9,56	24,79
8,56	9,57	24,83
8,57	9,58	24,86
8,58	9,59	24,90
8,59	9,60	24,94
8,60	9,61	24,97
8,61	9,62	25,01
8,62	9,63	25,05
8,63	9,64	25,08
8,64	9,65	25,12
8,65	9,66	25,16
8,66	9,67	25,19
8,67	9,68	25,23
8,68	9,69	25,26
8,69	9,70	25,30
8,70	9,71	25,34
8,71	9,72	25,37
8,72	9,73	25,41
8,73	9,74	25,45
8,74	9,75	25,48
8,75	9,76	25,52
8,76	9,77	25,55
8,77	9,78	25,59
8,78	9,79	25,63
8,79	9,80	25,66
8,80	9,81	25,70
8,81	9,82	25,73
8,82	9,83	25,77
8,83	9,84	25,81
8,84	9,85	25,84
8,85	9,86	25,88
8,86	9,87	25,91
8,87	9,88	25,95
8,88	9,89	25,98
8,89	9,90	26,02
8,90	9,91	26,06
8,91	9,92	26,09
8,92	9,93	26,13
8,93	9,94	26,16
8,94	9,95	26,20
8,95	9,96	26,23
8,96	9,97	26,27



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,97	9,98	26,30
8,98	9,99	26,34
8,99	10,00	26,38
9,00	10,01	26,41
9,01	10,02	26,45
9,02	10,03	26,48
9,03	10,04	26,52
9,04	10,05	26,55
9,05	10,06	26,59
9,06	10,07	26,62
9,07	10,08	26,66
9,08	10,09	26,69
9,09	10,10	26,73
9,10	10,11	26,76
9,11	10,12	26,80
9,12	10,13	26,83
9,13	10,14	26,87
9,14	10,15	26,90
9,15	10,16	26,94
9,16	10,17	26,97
9,17	10,18	27,01
9,18	10,19	27,04
9,19	10,20	27,08
9,20	10,21	27,11
9,21	10,22	27,15
9,22	10,23	27,18
9,23	10,24	27,22
9,24	10,25	27,25
9,25	10,26	27,29
9,26	10,27	27,32
9,27	10,28	27,36
9,28	10,29	27,39
9,29	10,30	27,43
9,30	10,31	27,46
9,31	10,32	27,50
9,32	10,33	27,53
9,33	10,34	27,57
9,34	10,35	27,60
9,35	10,36	27,63
9,36	10,37	27,67
9,37	10,38	27,70
9,38	10,39	27,74
9,39	10,40	27,77
9,40	10,41	27,81



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
9,41	10,42	27,84
9,42	10,43	27,88
9,43	10,44	27,91
9,44	10,45	27,94
9,45	10,46	27,98
9,46	10,47	28,01
9,47	10,48	28,05
9,48	10,49	28,08
9,49	10,50	28,12
9,50	10,51	28,15
9,51	10,52	28,18
9,52	10,53	28,22
9,53	10,54	28,25
9,54	10,55	28,29
9,55	10,56	28,32
9,56	10,57	28,35
9,57	10,58	28,39
9,58	10,59	28,42
9,59	10,60	28,46
9,60	10,61	28,49
9,61	10,62	28,52
9,62	10,63	28,56
9,63	10,64	28,59
9,64	10,65	28,63
9,65	10,66	28,66
9,66	10,67	28,69
9,67	10,68	28,73
9,68	10,69	28,76
9,69	10,70	28,79
9,70	10,71	28,83
9,71	10,72	28,86
9,72	10,73	28,90
9,73	10,74	28,93
9,74	10,75	28,96
9,75	10,76	29,00
9,76	10,77	29,03
9,77	10,78	29,06
9,78	10,79	29,10
9,79	10,80	29,13
9,80	10,81	29,16
9,81	10,82	29,20
9,82	10,83	29,23
9,83	10,84	29,26
9,84	10,85	29,30



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,85	10,86	29,33
9,86	10,87	29,36
9,87	10,88	29,40
9,88	10,89	29,43
9,89	10,90	29,46
9,90	10,91	29,50
9,91	10,92	29,53
9,92	10,93	29,56
9,93	10,94	29,60
9,94	10,95	29,63
9,95	10,96	29,66
9,96	10,97	29,70
9,97	10,98	29,73
9,98	10,99	29,76
9,99	11,00	29,79
10,00	11,01	29,83
10,01	11,02	29,86
10,02	11,03	29,89
10,03	11,04	29,93
10,04	11,05	29,96
10,05	11,06	29,99
10,06	11,07	30,02
10,07	11,08	30,06
10,08	11,09	30,09
10,09	11,10	30,12
10,10	11,11	30,16
10,11	11,12	30,19
10,12	11,13	30,22
10,13	11,14	30,25
10,14	11,15	30,29
10,15	11,16	30,32
10,16	11,17	30,35
10,17	11,18	30,38
10,18	11,19	30,42
10,19	11,20	30,45
10,20	11,21	30,48
10,21	11,22	30,51
10,22	11,23	30,55
10,23	11,24	30,58
10,24	11,25	30,61
10,25	11,26	30,64
10,26	11,27	30,68
10,27	11,28	30,71
10,28	11,29	30,74



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
10,29	11,30	30,77
10,30	11,31	30,81
10,31	11,32	30,84
10,32	11,33	30,87
10,33	11,34	30,90
10,34	11,35	30,94
10,35	11,36	30,97
10,36	11,37	31,00
10,37	11,38	31,03
10,38	11,39	31,06
10,39	11,40	31,10
10,40	11,41	31,13
10,41	11,42	31,16
10,42	11,43	31,19
10,43	11,44	31,23
10,44	11,45	31,26
10,45	11,46	31,29
10,46	11,47	31,32
10,47	11,48	31,35
10,48	11,49	31,39
10,49	11,50	31,42
10,50	11,51	31,45
10,51	11,52	31,48
10,52	11,53	31,51
10,53	11,54	31,54
10,54	11,55	31,58
10,55	11,56	31,61
10,56	11,57	31,64
10,57	11,58	31,67
10,58	11,59	31,70
10,59	11,60	31,74
10,60	11,61	31,77
10,61	11,62	31,80
10,62	11,63	31,83
10,63	11,64	31,86
10,64	11,65	31,89
10,65	11,66	31,92
10,66	11,67	31,96
10,67	11,68	31,99
10,68	11,69	32,02
10,69	11,70	32,05
10,70	11,71	32,08
10,71	11,72	32,11
10,72	11,73	32,15



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	32,18
10,74	11,75	32,21
10,75	11,76	32,24
10,76	11,77	32,27
10,77	11,78	32,30
10,78	11,79	32,33
10,79	11,80	32,37
10,80	11,81	32,40
10,81	11,82	32,43
10,82	11,83	32,46
10,83	11,84	32,49
10,84	11,85	32,52
10,85	11,86	32,55
10,86	11,87	32,58
10,87	11,88	32,62
10,88	11,89	32,65
10,89	11,90	32,68
10,90	11,91	32,71
10,91	11,92	32,74
10,92	11,93	32,77
10,93	11,94	32,80
10,94	11,95	32,83
10,95	11,96	32,86
10,96	11,97	32,89
10,97	11,98	32,93
10,98	11,99	32,96
10,99	12,00	32,99
11,00	12,01	33,02
11,01	12,02	33,05
11,02	12,03	33,08
11,03	12,04	33,11
11,04	12,05	33,14
11,05	12,06	33,17
11,06	12,07	33,20
11,07	12,08	33,23
11,08	12,09	33,26
11,09	12,10	33,30
11,10	12,11	33,33
11,11	12,12	33,36
11,12	12,13	33,39
11,13	12,14	33,42
11,14	12,15	33,45
11,15	12,16	33,48
11,16	12,17	33,51



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
11,17	12,18	33,54
11,18	12,19	33,57
11,19	12,20	33,60
11,20	12,21	33,63
11,21	12,22	33,66
11,22	12,23	33,69
11,23	12,24	33,72
11,24	12,25	33,75
11,25	12,26	33,78
11,26	12,27	33,82
11,27	12,28	33,85
11,28	12,29	33,88
11,29	12,30	33,91
11,30	12,31	33,94
11,31	12,32	33,97
11,32	12,33	34,00
11,33	12,34	34,03
11,34	12,35	34,06
11,35	12,36	34,09
11,36	12,37	34,12
11,37	12,38	34,15
11,38	12,39	34,18
11,39	12,40	34,21
11,40	12,41	34,24
11,41	12,42	34,27
11,42	12,43	34,30
11,43	12,44	34,33
11,44	12,45	34,36
11,45	12,46	34,39
11,46	12,47	34,42
11,47	12,48	34,45
11,48	12,49	34,48
11,49	12,50	34,51
11,50	12,51	34,54
11,51	12,52	34,57
11,52	12,53	34,60
11,53	12,54	34,63
11,54	12,55	34,66
11,55	12,56	34,69
11,56	12,57	34,72
11,57	12,58	34,75
11,58	12,59	34,78
11,59	12,60	34,81
11,60	12,61	34,84



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	34,87
11,62	12,63	34,90
11,63	12,64	34,93
11,64	12,65	34,96
11,65	12,66	34,99
11,66	12,67	35,02
11,67	12,68	35,05
11,68	12,69	35,08
11,69	12,70	35,11
11,70	12,71	35,14
11,71	12,72	35,16
11,72	12,73	35,19
11,73	12,74	35,22
11,74	12,75	35,25
11,75	12,76	35,28
11,76	12,77	35,31
11,77	12,78	35,34
11,78	12,79	35,37
11,79	12,80	35,40
11,80	12,81	35,43
11,81	12,82	35,46
11,82	12,83	35,49
11,83	12,84	35,52
11,84	12,85	35,55
11,85	12,86	35,58
11,86	12,87	35,61
11,87	12,88	35,64
11,88	12,89	35,67
11,89	12,90	35,69
11,90	12,91	35,72
11,91	12,92	35,75
11,92	12,93	35,78
11,93	12,94	35,81
11,94	12,95	35,84
11,95	12,96	35,87
11,96	12,97	35,90
11,97	12,98	35,93
11,98	12,99	35,96
11,99	13,00	35,99
12,00	13,01	36,02
12,01	13,02	36,04
12,02	13,03	36,07
12,03	13,04	36,10
12,04	13,05	36,13



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,05	13,06	36,16
12,06	13,07	36,19
12,07	13,08	36,22
12,08	13,09	36,25
12,09	13,10	36,28
12,10	13,11	36,31
12,11	13,12	36,33
12,12	13,13	36,36
12,13	13,14	36,39
12,14	13,15	36,42
12,15	13,16	36,45
12,16	13,17	36,48
12,17	13,18	36,51
12,18	13,19	36,54
12,19	13,20	36,57
12,20	13,21	36,59
12,21	13,22	36,62
12,22	13,23	36,65
12,23	13,24	36,68
12,24	13,25	36,71
12,25	13,26	36,74
12,26	13,27	36,77
12,27	13,28	36,80
12,28	13,29	36,82
12,29	13,30	36,85
12,30	13,31	36,88
12,31	13,32	36,91
12,32	13,33	36,94
12,33	13,34	36,97
12,34	13,35	37,00
12,35	13,36	37,02
12,36	13,37	37,05
12,37	13,38	37,08
12,38	13,39	37,11
12,39	13,40	37,14
12,40	13,41	37,17
12,41	13,42	37,19
12,42	13,43	37,22
12,43	13,44	37,25
12,44	13,45	37,28
12,45	13,46	37,31
12,46	13,47	37,34
12,47	13,48	37,36
12,48	13,49	37,39



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	37,42
12,50	13,51	37,45
12,51	13,52	37,48
12,52	13,53	37,51
12,53	13,54	37,53
12,54	13,55	37,56
12,55	13,56	37,59
12,56	13,57	37,62
12,57	13,58	37,65
12,58	13,59	37,68
12,59	13,60	37,70
12,60	13,61	37,73
12,61	13,62	37,76
12,62	13,63	37,79
12,63	13,64	37,82
12,64	13,65	37,84
12,65	13,66	37,87
12,66	13,67	37,90
12,67	13,68	37,93
12,68	13,69	37,96
12,69	13,70	37,98
12,70	13,71	38,01
12,71	13,72	38,04
12,72	13,73	38,07
12,73	13,74	38,10
12,74	13,75	38,12
12,75	13,76	38,15
12,76	13,77	38,18
12,77	13,78	38,21
12,78	13,79	38,24
12,79	13,80	38,26
12,80	13,81	38,29
12,81	13,82	38,32
12,82	13,83	38,35
12,83	13,84	38,37
12,84	13,85	38,40
12,85	13,86	38,43
12,86	13,87	38,46
12,87	13,88	38,49
12,88	13,89	38,51
12,89	13,90	38,54
12,90	13,91	38,57
12,91	13,92	38,60
12,92	13,93	38,62



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	38,65
12,94	13,95	38,68
12,95	13,96	38,71
12,96	13,97	38,73
12,97	13,98	38,76
12,98	13,99	38,79
12,99	14,00	38,82
13,00	14,01	38,84
13,01	14,02	38,87
13,02	14,03	38,90
13,03	14,04	38,93
13,04	14,05	38,95
13,05	14,06	38,98
13,06	14,07	39,01
13,07	14,08	39,04
13,08	14,09	39,06
13,09	14,10	39,09
13,10	14,11	39,12
13,11	14,12	39,15
13,12	14,13	39,17
13,13	14,14	39,20
13,14	14,15	39,23
13,15	14,16	39,26
13,16	14,17	39,28
13,17	14,18	39,31
13,18	14,19	39,34
13,19	14,20	39,36
13,20	14,21	39,39
13,21	14,22	39,42
13,22	14,23	39,45
13,23	14,24	39,47
13,24	14,25	39,50
13,25	14,26	39,53
13,26	14,27	39,56
13,27	14,28	39,58
13,28	14,29	39,61
13,29	14,30	39,64
13,30	14,31	39,66
13,31	14,32	39,69
13,32	14,33	39,72
13,33	14,34	39,74
13,34	14,35	39,77
13,35	14,36	39,80
13,36	14,37	39,83



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,37	14,38	39,85
13,38	14,39	39,88
13,39	14,40	39,91
13,40	14,41	39,93
13,41	14,42	39,96
13,42	14,43	39,99
13,43	14,44	40,01
13,44	14,45	40,04
13,45	14,46	40,07
13,46	14,47	40,09
13,47	14,48	40,12
13,48	14,49	40,15
13,49	14,50	40,18
13,50	14,51	40,20
13,51	14,52	40,23
13,52	14,53	40,26
13,53	14,54	40,28
13,54	14,55	40,31
13,55	14,56	40,34
13,56	14,57	40,36
13,57	14,58	40,39
13,58	14,59	40,42
13,59	14,60	40,44
13,60	14,61	40,47
13,61	14,62	40,50
13,62	14,63	40,52
13,63	14,64	40,55
13,64	14,65	40,58
13,65	14,66	40,60
13,66	14,67	40,63
13,67	14,68	40,66
13,68	14,69	40,68
13,69	14,70	40,71
13,70	14,71	40,74
13,71	14,72	40,76
13,72	14,73	40,79
13,73	14,74	40,82
13,74	14,75	40,84
13,75	14,76	40,87
13,76	14,77	40,89
13,77	14,78	40,92
13,78	14,79	40,95
13,79	14,80	40,97
13,80	14,81	41,00



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,81	14,82	41,03
13,82	14,83	41,05
13,83	14,84	41,08
13,84	14,85	41,11
13,85	14,86	41,13
13,86	14,87	41,16
13,87	14,88	41,18
13,88	14,89	41,21
13,89	14,90	41,24
13,90	14,91	41,26
13,91	14,92	41,29
13,92	14,93	41,32
13,93	14,94	41,34
13,94	14,95	41,37
13,95	14,96	41,39
13,96	14,97	41,42
13,97	14,98	41,45
13,98	14,99	41,47
13,99	15,00	41,50
14,00	15,01	41,53
14,01	15,02	41,55
14,02	15,03	41,58
14,03	15,04	41,60
14,04	15,05	41,63
14,05	15,06	41,66
14,06	15,07	41,68
14,07	15,08	41,71
14,08	15,09	41,73
14,09	15,10	41,76
14,10	15,11	41,79
14,11	15,12	41,81
14,12	15,13	41,84
14,13	15,14	41,86
14,14	15,15	41,89
14,15	15,16	41,92
14,16	15,17	41,94
14,17	15,18	41,97
14,18	15,19	41,99
14,19	15,20	42,02
14,20	15,21	42,05
14,21	15,22	42,07
14,22	15,23	42,10
14,23	15,24	42,12
14,24	15,25	42,15



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,25	15,26	42,17
14,26	15,27	42,20
14,27	15,28	42,23
14,28	15,29	42,25
14,29	15,30	42,28
14,30	15,31	42,30
14,31	15,32	42,33
14,32	15,33	42,35
14,33	15,34	42,38
14,34	15,35	42,41
14,35	15,36	42,43
14,36	15,37	42,46
14,37	15,38	42,48
14,38	15,39	42,51
14,39	15,40	42,53
14,40	15,41	42,56
14,41	15,42	42,59
14,42	15,43	42,61
14,43	15,44	42,64
14,44	15,45	42,66
14,45	15,46	42,69
14,46	15,47	42,71
14,47	15,48	42,74
14,48	15,49	42,76
14,49	15,50	42,79
14,50	15,51	42,82
14,51	15,52	42,84
14,52	15,53	42,87
14,53	15,54	42,89
14,54	15,55	42,92
14,55	15,56	42,94
14,56	15,57	42,97
14,57	15,58	42,99
14,58	15,59	43,02
14,59	15,60	43,04
14,60	15,61	43,07
14,61	15,62	43,09
14,62	15,63	43,12
14,63	15,64	43,15
14,64	15,65	43,17
14,65	15,66	43,20
14,66	15,67	43,22
14,67	15,68	43,25
14,68	15,69	43,27



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	43,30
14,70	15,71	43,32
14,71	15,72	43,35
14,72	15,73	43,37
14,73	15,74	43,40
14,74	15,75	43,42
14,75	15,76	43,45
14,76	15,77	43,47
14,77	15,78	43,50
14,78	15,79	43,52
14,79	15,80	43,55
14,80	15,81	43,57
14,81	15,82	43,60
14,82	15,83	43,62
14,83	15,84	43,65
14,84	15,85	43,67
14,85	15,86	43,70
14,86	15,87	43,72
14,87	15,88	43,75
14,88	15,89	43,77
14,89	15,90	43,80
14,90	15,91	43,82
14,91	15,92	43,85
14,92	15,93	43,87
14,93	15,94	43,90
14,94	15,95	43,92
14,95	15,96	43,95
14,96	15,97	43,97
14,97	15,98	44,00
14,98	15,99	44,02
14,99	16,00	44,05
15,00	16,01	44,07
15,01	16,02	44,10
15,02	16,03	44,12
15,03	16,04	44,15
15,04	16,05	44,17
15,05	16,06	44,20
15,06	16,07	44,22
15,07	16,08	44,25
15,08	16,09	44,27
15,09	16,10	44,30
15,10	16,11	44,32
15,11	16,12	44,35
15,12	16,13	44,37



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	44,40
15,14	16,15	44,42
15,15	16,16	44,45
15,16	16,17	44,47
15,17	16,18	44,50
15,18	16,19	44,52
15,19	16,20	44,54
15,20	16,21	44,57
15,21	16,22	44,59
15,22	16,23	44,62
15,23	16,24	44,64
15,24	16,25	44,67
15,25	16,26	44,69
15,26	16,27	44,72
15,27	16,28	44,74
15,28	16,29	44,77
15,29	16,30	44,79
15,30	16,31	44,82
15,31	16,32	44,84
15,32	16,33	44,86
15,33	16,34	44,89
15,34	16,35	44,91
15,35	16,36	44,94
15,36	16,37	44,96
15,37	16,38	44,99
15,38	16,39	45,01
15,39	16,40	45,04
15,40	16,41	45,06
15,41	16,42	45,08
15,42	16,43	45,11
15,43	16,44	45,13
15,44	16,45	45,16
15,45	16,46	45,18
15,46	16,47	45,21
15,47	16,48	45,23
15,48	16,49	45,26
15,49	16,50	45,28
15,50	16,51	45,30
15,51	16,52	45,33
15,52	16,53	45,35
15,53	16,54	45,38
15,54	16,55	45,40
15,55	16,56	45,43
15,56	16,57	45,45



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
15,57	16,58	45,47
15,58	16,59	45,50
15,59	16,60	45,52
15,60	16,61	45,55
15,61	16,62	45,57
15,62	16,63	45,59
15,63	16,64	45,62
15,64	16,65	45,64
15,65	16,66	45,67
15,66	16,67	45,69
15,67	16,68	45,72
15,68	16,69	45,74
15,69	16,70	45,76
15,70	16,71	45,79
15,71	16,72	45,81
15,72	16,73	45,84
15,73	16,74	45,86
15,74	16,75	45,88
15,75	16,76	45,91
15,76	16,77	45,93
15,77	16,78	45,96
15,78	16,79	45,98
15,79	16,80	46,00
15,80	16,81	46,03
15,81	16,82	46,05
15,82	16,83	46,08
15,83	16,84	46,10
15,84	16,85	46,12
15,85	16,86	46,15
15,86	16,87	46,17
15,87	16,88	46,20
15,88	16,89	46,22
15,89	16,90	46,24
15,90	16,91	46,27
15,91	16,92	46,29
15,92	16,93	46,32
15,93	16,94	46,34
15,94	16,95	46,36
15,95	16,96	46,39
15,96	16,97	46,41
15,97	16,98	46,43
15,98	16,99	46,46
15,99	17,00	46,48
16,00	17,01	46,51



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	46,53
16,02	17,03	46,55
16,03	17,04	46,58
16,04	17,05	46,60
16,05	17,06	46,62
16,06	17,07	46,65
16,07	17,08	46,67
16,08	17,09	46,70
16,09	17,10	46,72
16,10	17,11	46,74
16,11	17,12	46,77
16,12	17,13	46,79
16,13	17,14	46,81
16,14	17,15	46,84
16,15	17,16	46,86
16,16	17,17	46,88
16,17	17,18	46,91
16,18	17,19	46,93
16,19	17,20	46,96
16,20	17,21	46,98
16,21	17,22	47,00
16,22	17,23	47,03
16,23	17,24	47,05
16,24	17,25	47,07
16,25	17,26	47,10
16,26	17,27	47,12
16,27	17,28	47,14
16,28	17,29	47,17
16,29	17,30	47,19
16,30	17,31	47,21
16,31	17,32	47,24
16,32	17,33	47,26
16,33	17,34	47,28
16,34	17,35	47,31
16,35	17,36	47,33
16,36	17,37	47,35
16,37	17,38	47,38
16,38	17,39	47,40
16,39	17,40	47,42
16,40	17,41	47,45
16,41	17,42	47,47
16,42	17,43	47,49
16,43	17,44	47,52
16,44	17,45	47,54



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,45	17,46	47,56
16,46	17,47	47,59
16,47	17,48	47,61
16,48	17,49	47,63
16,49	17,50	47,66
16,50	17,51	47,68
16,51	17,52	47,70
16,52	17,53	47,73
16,53	17,54	47,75
16,54	17,55	47,77
16,55	17,56	47,80
16,56	17,57	47,82
16,57	17,58	47,84
16,58	17,59	47,87
16,59	17,60	47,89
16,60	17,61	47,91
16,61	17,62	47,94
16,62	17,63	47,96
16,63	17,64	47,98
16,64	17,65	48,00
16,65	17,66	48,03
16,66	17,67	48,05
16,67	17,68	48,07
16,68	17,69	48,10
16,69	17,70	48,12
16,70	17,71	48,14
16,71	17,72	48,17
16,72	17,73	48,19
16,73	17,74	48,21
16,74	17,75	48,24
16,75	17,76	48,26
16,76	17,77	48,28
16,77	17,78	48,30
16,78	17,79	48,33
16,79	17,80	48,35
16,80	17,81	48,37
16,81	17,82	48,40
16,82	17,83	48,42
16,83	17,84	48,44
16,84	17,85	48,47
16,85	17,86	48,49
16,86	17,87	48,51
16,87	17,88	48,53
16,88	17,89	48,56



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
16,89	17,90	48,58
16,90	17,91	48,60
16,91	17,92	48,63
16,92	17,93	48,65
16,93	17,94	48,67
16,94	17,95	48,69
16,95	17,96	48,72
16,96	17,97	48,74
16,97	17,98	48,76
16,98	17,99	48,78
16,99	18,00	48,81
17,00	18,01	48,83
17,01	18,02	48,85
17,02	18,03	48,88
17,03	18,04	48,90
17,04	18,05	48,92
17,05	18,06	48,94
17,06	18,07	48,97
17,07	18,08	48,99
17,08	18,09	49,01
17,09	18,10	49,03
17,10	18,11	49,06
17,11	18,12	49,08
17,12	18,13	49,10
17,13	18,14	49,13
17,14	18,15	49,15
17,15	18,16	49,17
17,16	18,17	49,19
17,17	18,18	49,22
17,18	18,19	49,24
17,19	18,20	49,26
17,20	18,21	49,28
17,21	18,22	49,31
17,22	18,23	49,33
17,23	18,24	49,35
17,24	18,25	49,37
17,25	18,26	49,40
17,26	18,27	49,42
17,27	18,28	49,44
17,28	18,29	49,46
17,29	18,30	49,49
17,30	18,31	49,51
17,31	18,32	49,53
17,32	18,33	49,55



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	49,58
17,34	18,35	49,60
17,35	18,36	49,62
17,36	18,37	49,64
17,37	18,38	49,67
17,38	18,39	49,69
17,39	18,40	49,71
17,40	18,41	49,73
17,41	18,42	49,76
17,42	18,43	49,78
17,43	18,44	49,80
17,44	18,45	49,82
17,45	18,46	49,84
17,46	18,47	49,87
17,47	18,48	49,89
17,48	18,49	49,91
17,49	18,50	49,93
17,50	18,51	49,96
17,51	18,52	49,98
17,52	18,53	50,00
17,53	18,54	50,02
17,54	18,55	50,05
17,55	18,56	50,07
17,56	18,57	50,09
17,57	18,58	50,11
17,58	18,59	50,13
17,59	18,60	50,16
17,60	18,61	50,18
17,61	18,62	50,20
17,62	18,63	50,22
17,63	18,64	50,24
17,64	18,65	50,27
17,65	18,66	50,29
17,66	18,67	50,31
17,67	18,68	50,33
17,68	18,69	50,36
17,69	18,70	50,38
17,70	18,71	50,40
17,71	18,72	50,42
17,72	18,73	50,44
17,73	18,74	50,47
17,74	18,75	50,49
17,75	18,76	50,51
17,76	18,77	50,53



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,77	18,78	50,55
17,78	18,79	50,58
17,79	18,80	50,60
17,80	18,81	50,62
17,81	18,82	50,64
17,82	18,83	50,66
17,83	18,84	50,69
17,84	18,85	50,71
17,85	18,86	50,73
17,86	18,87	50,75
17,87	18,88	50,77
17,88	18,89	50,80
17,89	18,90	50,82
17,90	18,91	50,84
17,91	18,92	50,86
17,92	18,93	50,88
17,93	18,94	50,91
17,94	18,95	50,93
17,95	18,96	50,95
17,96	18,97	50,97
17,97	18,98	50,99
17,98	18,99	51,01
17,99	19,00	51,04
18,00	19,01	51,06
18,01	19,02	51,08
18,02	19,03	51,10
18,03	19,04	51,12
18,04	19,05	51,15
18,05	19,06	51,17
18,06	19,07	51,19
18,07	19,08	51,21
18,08	19,09	51,23
18,09	19,10	51,25
18,10	19,11	51,28
18,11	19,12	51,30
18,12	19,13	51,32
18,13	19,14	51,34
18,14	19,15	51,36
18,15	19,16	51,39
18,16	19,17	51,41
18,17	19,18	51,43
18,18	19,19	51,45
18,19	19,20	51,47
18,20	19,21	51,49



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,21	19,22	51,52
18,22	19,23	51,54
18,23	19,24	51,56
18,24	19,25	51,58
18,25	19,26	51,60
18,26	19,27	51,62
18,27	19,28	51,64
18,28	19,29	51,67
18,29	19,30	51,69
18,30	19,31	51,71
18,31	19,32	51,73
18,32	19,33	51,75
18,33	19,34	51,77
18,34	19,35	51,80
18,35	19,36	51,82
18,36	19,37	51,84
18,37	19,38	51,86
18,38	19,39	51,88
18,39	19,40	51,90
18,40	19,41	51,92
18,41	19,42	51,95
18,42	19,43	51,97
18,43	19,44	51,99
18,44	19,45	52,01
18,45	19,46	52,03
18,46	19,47	52,05
18,47	19,48	52,08
18,48	19,49	52,10
18,49	19,50	52,12
18,50	19,51	52,14
18,51	19,52	52,16
18,52	19,53	52,18
18,53	19,54	52,20
18,54	19,55	52,22
18,55	19,56	52,25
18,56	19,57	52,27
18,57	19,58	52,29
18,58	19,59	52,31
18,59	19,60	52,33
18,60	19,61	52,35
18,61	19,62	52,37
18,62	19,63	52,40
18,63	19,64	52,42
18,64	19,65	52,44



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,65	19,66	52,46
18,66	19,67	52,48
18,67	19,68	52,50
18,68	19,69	52,52
18,69	19,70	52,54
18,70	19,71	52,57
18,71	19,72	52,59
18,72	19,73	52,61
18,73	19,74	52,63
18,74	19,75	52,65
18,75	19,76	52,67
18,76	19,77	52,69
18,77	19,78	52,71
18,78	19,79	52,74
18,79	19,80	52,76
18,80	19,81	52,78
18,81	19,82	52,80
18,82	19,83	52,82
18,83	19,84	52,84
18,84	19,85	52,86
18,85	19,86	52,88
18,86	19,87	52,90
18,87	19,88	52,93
18,88	19,89	52,95
18,89	19,90	52,97
18,90	19,91	52,99
18,91	19,92	53,01
18,92	19,93	53,03
18,93	19,94	53,05
18,94	19,95	53,07
18,95	19,96	53,09
18,96	19,97	53,11
18,97	19,98	53,14
18,98	19,99	53,16
18,99	20,00	53,18
19,00	20,01	53,20
19,01	20,02	53,22
19,02	20,03	53,24
19,03	20,04	53,26
19,04	20,05	53,28
19,05	20,06	53,30
19,06	20,07	53,32
19,07	20,08	53,35
19,08	20,09	53,37



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	53,39
19,10	20,11	53,41
19,11	20,12	53,43
19,12	20,13	53,45
19,13	20,14	53,47
19,14	20,15	53,49
19,15	20,16	53,51
19,16	20,17	53,53
19,17	20,18	53,55
19,18	20,19	53,58
19,19	20,20	53,60
19,20	20,21	53,62
19,21	20,22	53,64
19,22	20,23	53,66
19,23	20,24	53,68
19,24	20,25	53,70
19,25	20,26	53,72
19,26	20,27	53,74
19,27	20,28	53,76
19,28	20,29	53,78
19,29	20,30	53,80
19,30	20,31	53,82
19,31	20,32	53,85
19,32	20,33	53,87
19,33	20,34	53,89
19,34	20,35	53,91
19,35	20,36	53,93
19,36	20,37	53,95
19,37	20,38	53,97
19,38	20,39	53,99
19,39	20,40	54,01
19,40	20,41	54,03
19,41	20,42	54,05
19,42	20,43	54,07
19,43	20,44	54,09
19,44	20,45	54,11
19,45	20,46	54,14
19,46	20,47	54,16
19,47	20,48	54,18
19,48	20,49	54,20
19,49	20,50	54,22
19,50	20,51	54,24
19,51	20,52	54,26
19,52	20,53	54,28



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	54,30
19,54	20,55	54,32
19,55	20,56	54,34
19,56	20,57	54,36
19,57	20,58	54,38
19,58	20,59	54,40
19,59	20,60	54,42
19,60	20,61	54,44
19,61	20,62	54,46
19,62	20,63	54,48
19,63	20,64	54,51
19,64	20,65	54,53
19,65	20,66	54,55
19,66	20,67	54,57
19,67	20,68	54,59
19,68	20,69	54,61
19,69	20,70	54,63
19,70	20,71	54,65
19,71	20,72	54,67
19,72	20,73	54,69
19,73	20,74	54,71
19,74	20,75	54,73
19,75	20,76	54,75
19,76	20,77	54,77
19,77	20,78	54,79
19,78	20,79	54,81
19,79	20,80	54,83
19,80	20,81	54,85
19,81	20,82	54,87
19,82	20,83	54,89
19,83	20,84	54,91
19,84	20,85	54,93
19,85	20,86	54,95
19,86	20,87	54,97
19,87	20,88	54,99
19,88	20,89	55,01
19,89	20,90	55,04
19,90	20,91	55,06
19,91	20,92	55,08
19,92	20,93	55,10
19,93	20,94	55,12
19,94	20,95	55,14
19,95	20,96	55,16
19,96	20,97	55,18



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,97	20,98	55,20
19,98	20,99	55,22
19,99	21,00	55,24
20,00	21,01	55,26
20,01	21,02	55,28
20,02	21,03	55,30
20,03	21,04	55,32
20,04	21,05	55,34
20,05	21,06	55,36
20,06	21,07	55,38
20,07	21,08	55,40
20,08	21,09	55,42
20,09	21,10	55,44
20,10	21,11	55,46
20,11	21,12	55,48
20,12	21,13	55,50
20,13	21,14	55,52
20,14	21,15	55,54
20,15	21,16	55,56
20,16	21,17	55,58
20,17	21,18	55,60
20,18	21,19	55,62
20,19	21,20	55,64
20,20	21,21	55,66
20,21	21,22	55,68
20,22	21,23	55,70
20,23	21,24	55,72
20,24	21,25	55,74
20,25	21,26	55,76
20,26	21,27	55,78
20,27	21,28	55,80
20,28	21,29	55,82
20,29	21,30	55,84
20,30	21,31	55,86
20,31	21,32	55,88
20,32	21,33	55,90
20,33	21,34	55,92
20,34	21,35	55,94
20,35	21,36	55,96
20,36	21,37	55,98
20,37	21,38	56,00
20,38	21,39	56,02
20,39	21,40	56,04
20,40	21,41	56,06



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,41	21,42	56,08
20,42	21,43	56,10
20,43	21,44	56,12
20,44	21,45	56,14
20,45	21,46	56,16
20,46	21,47	56,18
20,47	21,48	56,20
20,48	21,49	56,22
20,49	21,50	56,24
20,50	21,51	56,26
20,51	21,52	56,28
20,52	21,53	56,30
20,53	21,54	56,32
20,54	21,55	56,34
20,55	21,56	56,36
20,56	21,57	56,38
20,57	21,58	56,40
20,58	21,59	56,42
20,59	21,60	56,44
20,60	21,61	56,46
20,61	21,62	56,48
20,62	21,63	56,50
20,63	21,64	56,52
20,64	21,65	56,54
20,65	21,66	56,56
20,66	21,67	56,58
20,67	21,68	56,60
20,68	21,69	56,62
20,69	21,70	56,63
20,70	21,71	56,65
20,71	21,72	56,67
20,72	21,73	56,69
20,73	21,74	56,71
20,74	21,75	56,73
20,75	21,76	56,75
20,76	21,77	56,77
20,77	21,78	56,79
20,78	21,79	56,81
20,79	21,80	56,83
20,80	21,81	56,85
20,81	21,82	56,87
20,82	21,83	56,89
20,83	21,84	56,91
20,84	21,85	56,93



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	56,95
20,86	21,87	56,97
20,87	21,88	56,99
20,88	21,89	57,01
20,89	21,90	57,03
20,90	21,91	57,05
20,91	21,92	57,07
20,92	21,93	57,09
20,93	21,94	57,11
20,94	21,95	57,13
20,95	21,96	57,14
20,96	21,97	57,16
20,97	21,98	57,18
20,98	21,99	57,20
20,99	22,00	57,22
21,00	22,01	57,24
21,01	22,02	57,26
21,02	22,03	57,28
21,03	22,04	57,30
21,04	22,05	57,32
21,05	22,06	57,34
21,06	22,07	57,36
21,07	22,08	57,38
21,08	22,09	57,40
21,09	22,10	57,42
21,10	22,11	57,44
21,11	22,12	57,46
21,12	22,13	57,48
21,13	22,14	57,50
21,14	22,15	57,51
21,15	22,16	57,53
21,16	22,17	57,55
21,17	22,18	57,57
21,18	22,19	57,59
21,19	22,20	57,61
21,20	22,21	57,63
21,21	22,22	57,65
21,22	22,23	57,67
21,23	22,24	57,69
21,24	22,25	57,71
21,25	22,26	57,73
21,26	22,27	57,75
21,27	22,28	57,77
21,28	22,29	57,79



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,29	22,30	57,80
21,30	22,31	57,82
21,31	22,32	57,84
21,32	22,33	57,86
21,33	22,34	57,88
21,34	22,35	57,90
21,35	22,36	57,92
21,36	22,37	57,94
21,37	22,38	57,96
21,38	22,39	57,98
21,39	22,40	58,00
21,40	22,41	58,02
21,41	22,42	58,04
21,42	22,43	58,05
21,43	22,44	58,07
21,44	22,45	58,09
21,45	22,46	58,11
21,46	22,47	58,13
21,47	22,48	58,15
21,48	22,49	58,17
21,49	22,50	58,19
21,50	22,51	58,21
21,51	22,52	58,23
21,52	22,53	58,25
21,53	22,54	58,27
21,54	22,55	58,28
21,55	22,56	58,30
21,56	22,57	58,32
21,57	22,58	58,34
21,58	22,59	58,36
21,59	22,60	58,38
21,60	22,61	58,40
21,61	22,62	58,42
21,62	22,63	58,44
21,63	22,64	58,46
21,64	22,65	58,48
21,65	22,66	58,49
21,66	22,67	58,51
21,67	22,68	58,53
21,68	22,69	58,55
21,69	22,70	58,57
21,70	22,71	58,59
21,71	22,72	58,61
21,72	22,73	58,63



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	58,65
21,74	22,75	58,67
21,75	22,76	58,68
21,76	22,77	58,70
21,77	22,78	58,72
21,78	22,79	58,74
21,79	22,80	58,76
21,80	22,81	58,78
21,81	22,82	58,80
21,82	22,83	58,82
21,83	22,84	58,84
21,84	22,85	58,86
21,85	22,86	58,87
21,86	22,87	58,89
21,87	22,88	58,91
21,88	22,89	58,93
21,89	22,90	58,95
21,90	22,91	58,97
21,91	22,92	58,99
21,92	22,93	59,01
21,93	22,94	59,03
21,94	22,95	59,04
21,95	22,96	59,06
21,96	22,97	59,08
21,97	22,98	59,10
21,98	22,99	59,12
21,99	23,00	59,14
22,00	23,01	59,16
22,01	23,02	59,18
22,02	23,03	59,19
22,03	23,04	59,21
22,04	23,05	59,23
22,05	23,06	59,25
22,06	23,07	59,27
22,07	23,08	59,29
22,08	23,09	59,31
22,09	23,10	59,33
22,10	23,11	59,35
22,11	23,12	59,36
22,12	23,13	59,38
22,13	23,14	59,40
22,14	23,15	59,42
22,15	23,16	59,44
22,16	23,17	59,46



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
22,17	23,18	59,48
22,18	23,19	59,50
22,19	23,20	59,51
22,20	23,21	59,53
22,21	23,22	59,55
22,22	23,23	59,57
22,23	23,24	59,59
22,24	23,25	59,61
22,25	23,26	59,63
22,26	23,27	59,64
22,27	23,28	59,66
22,28	23,29	59,68
22,29	23,30	59,70
22,30	23,31	59,72
22,31	23,32	59,74
22,32	23,33	59,76
22,33	23,34	59,77
22,34	23,35	59,79
22,35	23,36	59,81
22,36	23,37	59,83
22,37	23,38	59,85
22,38	23,39	59,87
22,39	23,40	59,89
22,40	23,41	59,90
22,41	23,42	59,92
22,42	23,43	59,94
22,43	23,44	59,96
22,44	23,45	59,98
22,45	23,46	60,00
22,46	23,47	60,02
22,47	23,48	60,03
22,48	23,49	60,05
22,49	23,50	60,07
22,50	23,51	60,09
22,51	23,52	60,11
22,52	23,53	60,13
22,53	23,54	60,15
22,54	23,55	60,16
22,55	23,56	60,18
22,56	23,57	60,20
22,57	23,58	60,22
22,58	23,59	60,24
22,59	23,60	60,26
22,60	23,61	60,28



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	60,29
22,62	23,63	60,31
22,63	23,64	60,33
22,64	23,65	60,35
22,65	23,66	60,37
22,66	23,67	60,39
22,67	23,68	60,40
22,68	23,69	60,42
22,69	23,70	60,44
22,70	23,71	60,46
22,71	23,72	60,48
22,72	23,73	60,50
22,73	23,74	60,51
22,74	23,75	60,53
22,75	23,76	60,55
22,76	23,77	60,57
22,77	23,78	60,59
22,78	23,79	60,61
22,79	23,80	60,62
22,80	23,81	60,64
22,81	23,82	60,66
22,82	23,83	60,68
22,83	23,84	60,70
22,84	23,85	60,72
22,85	23,86	60,73
22,86	23,87	60,75
22,87	23,88	60,77
22,88	23,89	60,79
22,89	23,90	60,81
22,90	23,91	60,83
22,91	23,92	60,84
22,92	23,93	60,86
22,93	23,94	60,88
22,94	23,95	60,90
22,95	23,96	60,92
22,96	23,97	60,93
22,97	23,98	60,95
22,98	23,99	60,97
22,99	24,00	60,99
23,00	24,01	61,01
23,01	24,02	61,03
23,02	24,03	61,04
23,03	24,04	61,06
23,04	24,05	61,08



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,05	24,06	61,10
23,06	24,07	61,12
23,07	24,08	61,13
23,08	24,09	61,15
23,09	24,10	61,17
23,10	24,11	61,19
23,11	24,12	61,21
23,12	24,13	61,23
23,13	24,14	61,24
23,14	24,15	61,26
23,15	24,16	61,28
23,16	24,17	61,30
23,17	24,18	61,32
23,18	24,19	61,33
23,19	24,20	61,35
23,20	24,21	61,37
23,21	24,22	61,39
23,22	24,23	61,41
23,23	24,24	61,42
23,24	24,25	61,44
23,25	24,26	61,46
23,26	24,27	61,48
23,27	24,28	61,50
23,28	24,29	61,51
23,29	24,30	61,53
23,30	24,31	61,55
23,31	24,32	61,57
23,32	24,33	61,59
23,33	24,34	61,60
23,34	24,35	61,62
23,35	24,36	61,64
23,36	24,37	61,66
23,37	24,38	61,68
23,38	24,39	61,69
23,39	24,40	61,71
23,40	24,41	61,73
23,41	24,42	61,75
23,42	24,43	61,77
23,43	24,44	61,78
23,44	24,45	61,80
23,45	24,46	61,82
23,46	24,47	61,84
23,47	24,48	61,86
23,48	24,49	61,87



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,49	24,50	61,89
23,50	24,51	61,91
23,51	24,52	61,93
23,52	24,53	61,95
23,53	24,54	61,96
23,54	24,55	61,98
23,55	24,56	62,00
23,56	24,57	62,02
23,57	24,58	62,04
23,58	24,59	62,05
23,59	24,60	62,07
23,60	24,61	62,09
23,61	24,62	62,11
23,62	24,63	62,12
23,63	24,64	62,14
23,64	24,65	62,16
23,65	24,66	62,18
23,66	24,67	62,20
23,67	24,68	62,21
23,68	24,69	62,23
23,69	24,70	62,25
23,70	24,71	62,27
23,71	24,72	62,28
23,72	24,73	62,30
23,73	24,74	62,32
23,74	24,75	62,34
23,75	24,76	62,36
23,76	24,77	62,37
23,77	24,78	62,39
23,78	24,79	62,41
23,79	24,80	62,43
23,80	24,81	62,44
23,81	24,82	62,46
23,82	24,83	62,48
23,83	24,84	62,50
23,84	24,85	62,52
23,85	24,86	62,53
23,86	24,87	62,55
23,87	24,88	62,57
23,88	24,89	62,59
23,89	24,90	62,60
23,90	24,91	62,62
23,91	24,92	62,64
23,92	24,93	62,66



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,93	24,94	62,67
23,94	24,95	62,69
23,95	24,96	62,71
23,96	24,97	62,73
23,97	24,98	62,74
23,98	24,99	62,76
23,99	25,00	62,78
24,00	25,01	62,80
24,01	25,02	62,82
24,02	25,03	62,83
24,03	25,04	62,85
24,04	25,05	62,87
24,05	25,06	62,89
24,06	25,07	62,90
24,07	25,08	62,92
24,08	25,09	62,94
24,09	25,10	62,96
24,10	25,11	62,97
24,11	25,12	62,99
24,12	25,13	63,01
24,13	25,14	63,03
24,14	25,15	63,04
24,15	25,16	63,06
24,16	25,17	63,08
24,17	25,18	63,10
24,18	25,19	63,11
24,19	25,20	63,13
24,20	25,21	63,15
24,21	25,22	63,17
24,22	25,23	63,18
24,23	25,24	63,20
24,24	25,25	63,22
24,25	25,26	63,24
24,26	25,27	63,25
24,27	25,28	63,27
24,28	25,29	63,29
24,29	25,30	63,31
24,30	25,31	63,32
24,31	25,32	63,34
24,32	25,33	63,36
24,33	25,34	63,38
24,34	25,35	63,39
24,35	25,36	63,41
24,36	25,37	63,43



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,37	25,38	63,45
24,38	25,39	63,46
24,39	25,40	63,48
24,40	25,41	63,50
24,41	25,42	63,51
24,42	25,43	63,53
24,43	25,44	63,55
24,44	25,45	63,57
24,45	25,46	63,58
24,46	25,47	63,60
24,47	25,48	63,62
24,48	25,49	63,64
24,49	25,50	63,65
24,50	25,51	63,67
24,51	25,52	63,69
24,52	25,53	63,71
24,53	25,54	63,72
24,54	25,55	63,74
24,55	25,56	63,76
24,56	25,57	63,77
24,57	25,58	63,79
24,58	25,59	63,81
24,59	25,60	63,83
24,60	25,61	63,84
24,61	25,62	63,86
24,62	25,63	63,88
24,63	25,64	63,90
24,64	25,65	63,91
24,65	25,66	63,93
24,66	25,67	63,95
24,67	25,68	63,96
24,68	25,69	63,98
24,69	25,70	64,00
24,70	25,71	64,02
24,71	25,72	64,03
24,72	25,73	64,05
24,73	25,74	64,07
24,74	25,75	64,09
24,75	25,76	64,10
24,76	25,77	64,12
24,77	25,78	64,14
24,78	25,79	64,15
24,79	25,80	64,17
24,80	25,81	64,19



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	64,21
24,82	25,83	64,22
24,83	25,84	64,24
24,84	25,85	64,26
24,85	25,86	64,27
24,86	25,87	64,29
24,87	25,88	64,31
24,88	25,89	64,33
24,89	25,90	64,34
24,90	25,91	64,36
24,91	25,92	64,38
24,92	25,93	64,39
24,93	25,94	64,41
24,94	25,95	64,43
24,95	25,96	64,45
24,96	25,97	64,46
24,97	25,98	64,48
24,98	25,99	64,50
24,99	26,00	64,51
25,00	26,01	64,53
25,01	26,02	64,55
25,02	26,03	64,56
25,03	26,04	64,58
25,04	26,05	64,60
25,05	26,06	64,62
25,06	26,07	64,63
25,07	26,08	64,65
25,08	26,09	64,67
25,09	26,10	64,68
25,10	26,11	64,70
25,11	26,12	64,72
25,12	26,13	64,73
25,13	26,14	64,75
25,14	26,15	64,77
25,15	26,16	64,79
25,16	26,17	64,80
25,17	26,18	64,82
25,18	26,19	64,84
25,19	26,20	64,85
25,20	26,21	64,87
25,21	26,22	64,89
25,22	26,23	64,90
25,23	26,24	64,92
25,24	26,25	64,94



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	64,96
25,26	26,27	64,97
25,27	26,28	64,99
25,28	26,29	65,01
25,29	26,30	65,02
25,30	26,31	65,04
25,31	26,32	65,06
25,32	26,33	65,07
25,33	26,34	65,09
25,34	26,35	65,11
25,35	26,36	65,12
25,36	26,37	65,14
25,37	26,38	65,16
25,38	26,39	65,18
25,39	26,40	65,19
25,40	26,41	65,21
25,41	26,42	65,23
25,42	26,43	65,24
25,43	26,44	65,26
25,44	26,45	65,28
25,45	26,46	65,29
25,46	26,47	65,31
25,47	26,48	65,33
25,48	26,49	65,34
25,49	26,50	65,36
25,50	26,51	65,38
25,51	26,52	65,39
25,52	26,53	65,41
25,53	26,54	65,43
25,54	26,55	65,44
25,55	26,56	65,46
25,56	26,57	65,48
25,57	26,58	65,49
25,58	26,59	65,51
25,59	26,60	65,53
25,60	26,61	65,54
25,61	26,62	65,56
25,62	26,63	65,58
25,63	26,64	65,59
25,64	26,65	65,61
25,65	26,66	65,63
25,66	26,67	65,64
25,67	26,68	65,66
25,68	26,69	65,68



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
25,69	26,70	65,70
25,70	26,71	65,71
25,71	26,72	65,73
25,72	26,73	65,75
25,73	26,74	65,76
25,74	26,75	65,78
25,75	26,76	65,80
25,76	26,77	65,81
25,77	26,78	65,83
25,78	26,79	65,85
25,79	26,80	65,86
25,80	26,81	65,88
25,81	26,82	65,89
25,82	26,83	65,91
25,83	26,84	65,93
25,84	26,85	65,94
25,85	26,86	65,96
25,86	26,87	65,98
25,87	26,88	65,99
25,88	26,89	66,01
25,89	26,90	66,03
25,90	26,91	66,04
25,91	26,92	66,06
25,92	26,93	66,08
25,93	26,94	66,09
25,94	26,95	66,11
25,95	26,96	66,13
25,96	26,97	66,14
25,97	26,98	66,16
25,98	26,99	66,18
25,99	27,00	66,19
26,00	27,01	66,21
26,01	27,02	66,23
26,02	27,03	66,24
26,03	27,04	66,26
26,04	27,05	66,28
26,05	27,06	66,29
26,06	27,07	66,31
26,07	27,08	66,33
26,08	27,09	66,34
26,09	27,10	66,36
26,10	27,11	66,38
26,11	27,12	66,39
26,12	27,13	66,41



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	66,42
26,14	27,15	66,44
26,15	27,16	66,46
26,16	27,17	66,47
26,17	27,18	66,49
26,18	27,19	66,51
26,19	27,20	66,52
26,20	27,21	66,54
26,21	27,22	66,56
26,22	27,23	66,57
26,23	27,24	66,59
26,24	27,25	66,61
26,25	27,26	66,62
26,26	27,27	66,64
26,27	27,28	66,65
26,28	27,29	66,67
26,29	27,30	66,69
26,30	27,31	66,70
26,31	27,32	66,72
26,32	27,33	66,74
26,33	27,34	66,75
26,34	27,35	66,77
26,35	27,36	66,79
26,36	27,37	66,80
26,37	27,38	66,82
26,38	27,39	66,83
26,39	27,40	66,85
26,40	27,41	66,87
26,41	27,42	66,88
26,42	27,43	66,90
26,43	27,44	66,92
26,44	27,45	66,93
26,45	27,46	66,95
26,46	27,47	66,97
26,47	27,48	66,98
26,48	27,49	67,00
26,49	27,50	67,01
26,50	27,51	67,03
26,51	27,52	67,05
26,52	27,53	67,06
26,53	27,54	67,08
26,54	27,55	67,10
26,55	27,56	67,11
26,56	27,57	67,13



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,57	27,58	67,14
26,58	27,59	67,16
26,59	27,60	67,18
26,60	27,61	67,19
26,61	27,62	67,21
26,62	27,63	67,23
26,63	27,64	67,24
26,64	27,65	67,26
26,65	27,66	67,27
26,66	27,67	67,29
26,67	27,68	67,31
26,68	27,69	67,32
26,69	27,70	67,34
26,70	27,71	67,36
26,71	27,72	67,37
26,72	27,73	67,39
26,73	27,74	67,40
26,74	27,75	67,42
26,75	27,76	67,44
26,76	27,77	67,45
26,77	27,78	67,47
26,78	27,79	67,48
26,79	27,80	67,50
26,80	27,81	67,52
26,81	27,82	67,53
26,82	27,83	67,55
26,83	27,84	67,57
26,84	27,85	67,58
26,85	27,86	67,60
26,86	27,87	67,61
26,87	27,88	67,63
26,88	27,89	67,65
26,89	27,90	67,66
26,90	27,91	67,68
26,91	27,92	67,69
26,92	27,93	67,71
26,93	27,94	67,73
26,94	27,95	67,74
26,95	27,96	67,76
26,96	27,97	67,77
26,97	27,98	67,79
26,98	27,99	67,81
26,99	28,00	67,82
27,00	28,01	67,84



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	67,85
27,02	28,03	67,87
27,03	28,04	67,89
27,04	28,05	67,90
27,05	28,06	67,92
27,06	28,07	67,93
27,07	28,08	67,95
27,08	28,09	67,97
27,09	28,10	67,98
27,10	28,11	68,00
27,11	28,12	68,01
27,12	28,13	68,03
27,13	28,14	68,05
27,14	28,15	68,06
27,15	28,16	68,08
27,16	28,17	68,09
27,17	28,18	68,11
27,18	28,19	68,13
27,19	28,20	68,14
27,20	28,21	68,16
27,21	28,22	68,17
27,22	28,23	68,19
27,23	28,24	68,21
27,24	28,25	68,22
27,25	28,26	68,24
27,26	28,27	68,25
27,27	28,28	68,27
27,28	28,29	68,29
27,29	28,30	68,30
27,30	28,31	68,32
27,31	28,32	68,33
27,32	28,33	68,35
27,33	28,34	68,37
27,34	28,35	68,38
27,35	28,36	68,40
27,36	28,37	68,41
27,37	28,38	68,43
27,38	28,39	68,44
27,39	28,40	68,46
27,40	28,41	68,48
27,41	28,42	68,49
27,42	28,43	68,51
27,43	28,44	68,52
27,44	28,45	68,54



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	68,56
27,46	28,47	68,57
27,47	28,48	68,59
27,48	28,49	68,60
27,49	28,50	68,62
27,50	28,51	68,63
27,51	28,52	68,65
27,52	28,53	68,67
27,53	28,54	68,68
27,54	28,55	68,70
27,55	28,56	68,71
27,56	28,57	68,73
27,57	28,58	68,74
27,58	28,59	68,76
27,59	28,60	68,78
27,60	28,61	68,79
27,61	28,62	68,81
27,62	28,63	68,82
27,63	28,64	68,84
27,64	28,65	68,86
27,65	28,66	68,87
27,66	28,67	68,89
27,67	28,68	68,90
27,68	28,69	68,92
27,69	28,70	68,93
27,70	28,71	68,95
27,71	28,72	68,97
27,72	28,73	68,98
27,73	28,74	69,00
27,74	28,75	69,01
27,75	28,76	69,03
27,76	28,77	69,04
27,77	28,78	69,06
27,78	28,79	69,08
27,79	28,80	69,09
27,80	28,81	69,11
27,81	28,82	69,12
27,82	28,83	69,14
27,83	28,84	69,15
27,84	28,85	69,17
27,85	28,86	69,18
27,86	28,87	69,20
27,87	28,88	69,22
27,88	28,89	69,23



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	69,25
27,90	28,91	69,26
27,91	28,92	69,28
27,92	28,93	69,29
27,93	28,94	69,31
27,94	28,95	69,33
27,95	28,96	69,34
27,96	28,97	69,36
27,97	28,98	69,37
27,98	28,99	69,39
27,99	29,00	69,40
28,00	29,01	69,42
28,01	29,02	69,43
28,02	29,03	69,45
28,03	29,04	69,47
28,04	29,05	69,48
28,05	29,06	69,50
28,06	29,07	69,51
28,07	29,08	69,53
28,08	29,09	69,54
28,09	29,10	69,56
28,10	29,11	69,57
28,11	29,12	69,59
28,12	29,13	69,61
28,13	29,14	69,62
28,14	29,15	69,64
28,15	29,16	69,65
28,16	29,17	69,67
28,17	29,18	69,68
28,18	29,19	69,70
28,19	29,20	69,71
28,20	29,21	69,73
28,21	29,22	69,74
28,22	29,23	69,76
28,23	29,24	69,78
28,24	29,25	69,79
28,25	29,26	69,81
28,26	29,27	69,82
28,27	29,28	69,84
28,28	29,29	69,85
28,29	29,30	69,87
28,30	29,31	69,88
28,31	29,32	69,90
28,32	29,33	69,91



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	69,93
28,34	29,35	69,95
28,35	29,36	69,96
28,36	29,37	69,98
28,37	29,38	69,99
28,38	29,39	70,01
28,39	29,40	70,02
28,40	29,41	70,04
28,41	29,42	70,05
28,42	29,43	70,07
28,43	29,44	70,08
28,44	29,45	70,10
28,45	29,46	70,11
28,46	29,47	70,13
28,47	29,48	70,14
28,48	29,49	70,16
28,49	29,50	70,18
28,50	29,51	70,19
28,51	29,52	70,21
28,52	29,53	70,22
28,53	29,54	70,24
28,54	29,55	70,25
28,55	29,56	70,27
28,56	29,57	70,28
28,57	29,58	70,30
28,58	29,59	70,31
28,59	29,60	70,33
28,60	29,61	70,34
28,61	29,62	70,36
28,62	29,63	70,37
28,63	29,64	70,39
28,64	29,65	70,41
28,65	29,66	70,42
28,66	29,67	70,44
28,67	29,68	70,45
28,68	29,69	70,47
28,69	29,70	70,48
28,70	29,71	70,50
28,71	29,72	70,51
28,72	29,73	70,53
28,73	29,74	70,54
28,74	29,75	70,56
28,75	29,76	70,57
28,76	29,77	70,59



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	70,60
28,78	29,79	70,62
28,79	29,80	70,63
28,80	29,81	70,65
28,81	29,82	70,66
28,82	29,83	70,68
28,83	29,84	70,69
28,84	29,85	70,71
28,85	29,86	70,72
28,86	29,87	70,74
28,87	29,88	70,76
28,88	29,89	70,77
28,89	29,90	70,79
28,90	29,91	70,80
28,91	29,92	70,82
28,92	29,93	70,83
28,93	29,94	70,85
28,94	29,95	70,86
28,95	29,96	70,88
28,96	29,97	70,89
28,97	29,98	70,91
28,98	29,99	70,92
28,99	30,00	70,94
29,00	30,01	70,95
29,01	30,02	70,97
29,02	30,03	70,98
29,03	30,04	71,00
29,04	30,05	71,01
29,05	30,06	71,03
29,06	30,07	71,04
29,07	30,08	71,06
29,08	30,09	71,07
29,09	30,10	71,09
29,10	30,11	71,10
29,11	30,12	71,12
29,12	30,13	71,13
29,13	30,14	71,15
29,14	30,15	71,16
29,15	30,16	71,18
29,16	30,17	71,19
29,17	30,18	71,21
29,18	30,19	71,22
29,19	30,20	71,24
29,20	30,21	71,25



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	71,27
29,22	30,23	71,28
29,23	30,24	71,30
29,24	30,25	71,31
29,25	30,26	71,33
29,26	30,27	71,34
29,27	30,28	71,36
29,28	30,29	71,37
29,29	30,30	71,39
29,30	30,31	71,40
29,31	30,32	71,42
29,32	30,33	71,43
29,33	30,34	71,45
29,34	30,35	71,46
29,35	30,36	71,48
29,36	30,37	71,49
29,37	30,38	71,51
29,38	30,39	71,52
29,39	30,40	71,54
29,40	30,41	71,55
29,41	30,42	71,57
29,42	30,43	71,58
29,43	30,44	71,60
29,44	30,45	71,61
29,45	30,46	71,63
29,46	30,47	71,64
29,47	30,48	71,66
29,48	30,49	71,67
29,49	30,50	71,69
29,50	30,51	71,70
29,51	30,52	71,72
29,52	30,53	71,73
29,53	30,54	71,75
29,54	30,55	71,76
29,55	30,56	71,78
29,56	30,57	71,79
29,57	30,58	71,81
29,58	30,59	71,82
29,59	30,60	71,84
29,60	30,61	71,85
29,61	30,62	71,87
29,62	30,63	71,88
29,63	30,64	71,90
29,64	30,65	71,91



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,65	30,66	71,92
29,66	30,67	71,94
29,67	30,68	71,95
29,68	30,69	71,97
29,69	30,70	71,98
29,70	30,71	72,00
29,71	30,72	72,01
29,72	30,73	72,03
29,73	30,74	72,04
29,74	30,75	72,06
29,75	30,76	72,07
29,76	30,77	72,09
29,77	30,78	72,10
29,78	30,79	72,12
29,79	30,80	72,13
29,80	30,81	72,15
29,81	30,82	72,16
29,82	30,83	72,18
29,83	30,84	72,19
29,84	30,85	72,21
29,85	30,86	72,22
29,86	30,87	72,23
29,87	30,88	72,25
29,88	30,89	72,26
29,89	30,90	72,28
29,90	30,91	72,29
29,91	30,92	72,31
29,92	30,93	72,32
29,93	30,94	72,34
29,94	30,95	72,35
29,95	30,96	72,37
29,96	30,97	72,38
29,97	30,98	72,40
29,98	30,99	72,41
29,99	31,00	72,43
30,00	31,01	72,44
30,01	31,02	72,46
30,02	31,03	72,47
30,03	31,04	72,48
30,04	31,05	72,50
30,05	31,06	72,51
30,06	31,07	72,53
30,07	31,08	72,54
30,08	31,09	72,56



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,09	31,10	72,57
30,10	31,11	72,59
30,11	31,12	72,60
30,12	31,13	72,62
30,13	31,14	72,63
30,14	31,15	72,65
30,15	31,16	72,66
30,16	31,17	72,67
30,17	31,18	72,69
30,18	31,19	72,70
30,19	31,20	72,72
30,20	31,21	72,73
30,21	31,22	72,75
30,22	31,23	72,76
30,23	31,24	72,78
30,24	31,25	72,79
30,25	31,26	72,81
30,26	31,27	72,82
30,27	31,28	72,84
30,28	31,29	72,85
30,29	31,30	72,86
30,30	31,31	72,88
30,31	31,32	72,89
30,32	31,33	72,91
30,33	31,34	72,92
30,34	31,35	72,94
30,35	31,36	72,95
30,36	31,37	72,97
30,37	31,38	72,98
30,38	31,39	72,99
30,39	31,40	73,01
30,40	31,41	73,02
30,41	31,42	73,04
30,42	31,43	73,05
30,43	31,44	73,07
30,44	31,45	73,08
30,45	31,46	73,10
30,46	31,47	73,11
30,47	31,48	73,13
30,48	31,49	73,14
30,49	31,50	73,15
30,50	31,51	73,17
30,51	31,52	73,18
30,52	31,53	73,20



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	73,21
30,54	31,55	73,23
30,55	31,56	73,24
30,56	31,57	73,26
30,57	31,58	73,27
30,58	31,59	73,28
30,59	31,60	73,30
30,60	31,61	73,31
30,61	31,62	73,33
30,62	31,63	73,34
30,63	31,64	73,36
30,64	31,65	73,37
30,65	31,66	73,38
30,66	31,67	73,40
30,67	31,68	73,41
30,68	31,69	73,43
30,69	31,70	73,44
30,70	31,71	73,46
30,71	31,72	73,47
30,72	31,73	73,49
30,73	31,74	73,50
30,74	31,75	73,51
30,75	31,76	73,53
30,76	31,77	73,54
30,77	31,78	73,56
30,78	31,79	73,57
30,79	31,80	73,59
30,80	31,81	73,60
30,81	31,82	73,61
30,82	31,83	73,63
30,83	31,84	73,64
30,84	31,85	73,66
30,85	31,86	73,67
30,86	31,87	73,69
30,87	31,88	73,70
30,88	31,89	73,71
30,89	31,90	73,73
30,90	31,91	73,74
30,91	31,92	73,76
30,92	31,93	73,77
30,93	31,94	73,79
30,94	31,95	73,80
30,95	31,96	73,81
30,96	31,97	73,83



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
30,97	31,98	73,84
30,98	31,99	73,86
30,99	32,00	73,87
31,00	32,01	73,89
31,01	32,02	73,90
31,02	32,03	73,91
31,03	32,04	73,93
31,04	32,05	73,94
31,05	32,06	73,96
31,06	32,07	73,97
31,07	32,08	73,99
31,08	32,09	74,00
31,09	32,10	74,01
31,10	32,11	74,03
31,11	32,12	74,04
31,12	32,13	74,06
31,13	32,14	74,07
31,14	32,15	74,08
31,15	32,16	74,10
31,16	32,17	74,11
31,17	32,18	74,13
31,18	32,19	74,14
31,19	32,20	74,16
31,20	32,21	74,17
31,21	32,22	74,18
31,22	32,23	74,20
31,23	32,24	74,21
31,24	32,25	74,23
31,25	32,26	74,24
31,26	32,27	74,25
31,27	32,28	74,27
31,28	32,29	74,28
31,29	32,30	74,30
31,30	32,31	74,31
31,31	32,32	74,32
31,32	32,33	74,34
31,33	32,34	74,35
31,34	32,35	74,37
31,35	32,36	74,38
31,36	32,37	74,40
31,37	32,38	74,41
31,38	32,39	74,42
31,39	32,40	74,44
31,40	32,41	74,45



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	74,47
31,42	32,43	74,48
31,43	32,44	74,49
31,44	32,45	74,51
31,45	32,46	74,52
31,46	32,47	74,54
31,47	32,48	74,55
31,48	32,49	74,56
31,49	32,50	74,58
31,50	32,51	74,59
31,51	32,52	74,61
31,52	32,53	74,62
31,53	32,54	74,63
31,54	32,55	74,65
31,55	32,56	74,66
31,56	32,57	74,68
31,57	32,58	74,69
31,58	32,59	74,70
31,59	32,60	74,72
31,60	32,61	74,73
31,61	32,62	74,75
31,62	32,63	74,76
31,63	32,64	74,77
31,64	32,65	74,79
31,65	32,66	74,80
31,66	32,67	74,82
31,67	32,68	74,83
31,68	32,69	74,84
31,69	32,70	74,86
31,70	32,71	74,87
31,71	32,72	74,89
31,72	32,73	74,90
31,73	32,74	74,91
31,74	32,75	74,93
31,75	32,76	74,94
31,76	32,77	74,96
31,77	32,78	74,97
31,78	32,79	74,98
31,79	32,80	75,00
31,80	32,81	75,01
31,81	32,82	75,02
31,82	32,83	75,04
31,83	32,84	75,05
31,84	32,85	75,07



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	75,08
31,86	32,87	75,09
31,87	32,88	75,11
31,88	32,89	75,12
31,89	32,90	75,14
31,90	32,91	75,15
31,91	32,92	75,16
31,92	32,93	75,18
31,93	32,94	75,19
31,94	32,95	75,20
31,95	32,96	75,22
31,96	32,97	75,23
31,97	32,98	75,25
31,98	32,99	75,26
31,99	33,00	75,27
32,00	33,01	75,29
32,01	33,02	75,30
32,02	33,03	75,32
32,03	33,04	75,33
32,04	33,05	75,34
32,05	33,06	75,36
32,06	33,07	75,37
32,07	33,08	75,38
32,08	33,09	75,40
32,09	33,10	75,41
32,10	33,11	75,43
32,11	33,12	75,44
32,12	33,13	75,45
32,13	33,14	75,47
32,14	33,15	75,48
32,15	33,16	75,49
32,16	33,17	75,51
32,17	33,18	75,52
32,18	33,19	75,54
32,19	33,20	75,55
32,20	33,21	75,56
32,21	33,22	75,58
32,22	33,23	75,59
32,23	33,24	75,60
32,24	33,25	75,62
32,25	33,26	75,63
32,26	33,27	75,65
32,27	33,28	75,66
32,28	33,29	75,67



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	75,69
32,30	33,31	75,70
32,31	33,32	75,71
32,32	33,33	75,73
32,33	33,34	75,74
32,34	33,35	75,75
32,35	33,36	75,77
32,36	33,37	75,78
32,37	33,38	75,80
32,38	33,39	75,81
32,39	33,40	75,82
32,40	33,41	75,84
32,41	33,42	75,85
32,42	33,43	75,86
32,43	33,44	75,88
32,44	33,45	75,89
32,45	33,46	75,90
32,46	33,47	75,92
32,47	33,48	75,93
32,48	33,49	75,95
32,49	33,50	75,96
32,50	33,51	75,97
32,51	33,52	75,99
32,52	33,53	76,00
32,53	33,54	76,01
32,54	33,55	76,03
32,55	33,56	76,04
32,56	33,57	76,05
32,57	33,58	76,07
32,58	33,59	76,08
32,59	33,60	76,09
32,60	33,61	76,11
32,61	33,62	76,12
32,62	33,63	76,14
32,63	33,64	76,15
32,64	33,65	76,16
32,65	33,66	76,18
32,66	33,67	76,19
32,67	33,68	76,20
32,68	33,69	76,22
32,69	33,70	76,23
32,70	33,71	76,24
32,71	33,72	76,26
32,72	33,73	76,27



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,73	33,74	76,28
32,74	33,75	76,30
32,75	33,76	76,31
32,76	33,77	76,32
32,77	33,78	76,34
32,78	33,79	76,35
32,79	33,80	76,37
32,80	33,81	76,38
32,81	33,82	76,39
32,82	33,83	76,41
32,83	33,84	76,42
32,84	33,85	76,43
32,85	33,86	76,45
32,86	33,87	76,46
32,87	33,88	76,47
32,88	33,89	76,49
32,89	33,90	76,50
32,90	33,91	76,51
32,91	33,92	76,53
32,92	33,93	76,54
32,93	33,94	76,55
32,94	33,95	76,57
32,95	33,96	76,58
32,96	33,97	76,59
32,97	33,98	76,61
32,98	33,99	76,62
32,99	34,00	76,63
33,00	34,01	76,65
33,01	34,02	76,66
33,02	34,03	76,67
33,03	34,04	76,69
33,04	34,05	76,70
33,05	34,06	76,71
33,06	34,07	76,73
33,07	34,08	76,74
33,08	34,09	76,75
33,09	34,10	76,77
33,10	34,11	76,78
33,11	34,12	76,79
33,12	34,13	76,81
33,13	34,14	76,82
33,14	34,15	76,83
33,15	34,16	76,85
33,16	34,17	76,86



R422B		
V1.0_R422B		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
33,17	34,18	76,87
33,18	34,19	76,89
33,19	34,20	76,90
33,20	34,21	76,91
33,21	34,22	76,93
33,22	34,23	76,94
33,23	34,24	76,95
33,24	34,25	76,97