



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-47,09
-0,70	0,31	-46,52
-0,69	0,32	-45,96
-0,68	0,33	-45,41
-0,67	0,34	-44,88
-0,66	0,35	-44,36
-0,65	0,36	-43,86
-0,64	0,37	-43,36
-0,63	0,38	-42,88
-0,62	0,39	-42,40
-0,61	0,40	-41,94
-0,60	0,41	-41,48
-0,59	0,42	-41,04
-0,58	0,43	-40,60
-0,57	0,44	-40,17
-0,56	0,45	-39,75
-0,55	0,46	-39,33
-0,54	0,47	-38,92
-0,53	0,48	-38,52
-0,52	0,49	-38,13
-0,51	0,50	-37,74
-0,50	0,51	-37,36
-0,49	0,52	-36,99
-0,48	0,53	-36,62
-0,47	0,54	-36,25
-0,46	0,55	-35,90
-0,45	0,56	-35,54
-0,44	0,57	-35,19
-0,43	0,58	-34,85
-0,42	0,59	-34,51
-0,41	0,60	-34,18
-0,40	0,61	-33,85
-0,39	0,62	-33,52
-0,38	0,63	-33,20
-0,37	0,64	-32,89
-0,36	0,65	-32,57
-0,35	0,66	-32,26
-0,34	0,67	-31,96
-0,33	0,68	-31,66
-0,32	0,69	-31,36
-0,31	0,70	-31,06
-0,30	0,71	-30,77
-0,29	0,72	-30,48
-0,28	0,73	-30,20



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-29,92
-0,26	0,75	-29,64
-0,25	0,76	-29,36
-0,24	0,77	-29,09
-0,23	0,78	-28,82
-0,22	0,79	-28,55
-0,21	0,80	-28,28
-0,20	0,81	-28,02
-0,19	0,82	-27,76
-0,18	0,83	-27,51
-0,17	0,84	-27,25
-0,16	0,85	-27,00
-0,15	0,86	-26,75
-0,14	0,87	-26,50
-0,13	0,88	-26,25
-0,12	0,89	-26,01
-0,11	0,90	-25,77
-0,10	0,91	-25,53
-0,09	0,92	-25,29
-0,08	0,93	-25,06
-0,07	0,94	-24,83
-0,06	0,95	-24,60
-0,05	0,96	-24,37
-0,04	0,97	-24,14
-0,03	0,98	-23,91
-0,02	0,99	-23,69
-0,01	1,00	-23,47
0,00	1,01	-23,25
0,01	1,02	-23,03
0,02	1,03	-22,82
0,03	1,04	-22,60
0,04	1,05	-22,39
0,05	1,06	-22,18
0,06	1,07	-21,97
0,07	1,08	-21,76
0,08	1,09	-21,55
0,09	1,10	-21,34
0,10	1,11	-21,14
0,11	1,12	-20,94
0,12	1,13	-20,74
0,13	1,14	-20,54
0,14	1,15	-20,34
0,15	1,16	-20,14
0,16	1,17	-19,95



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,17	1,18	-19,75
0,18	1,19	-19,56
0,19	1,20	-19,37
0,20	1,21	-19,18
0,21	1,22	-18,99
0,22	1,23	-18,80
0,23	1,24	-18,61
0,24	1,25	-18,43
0,25	1,26	-18,24
0,26	1,27	-18,06
0,27	1,28	-17,88
0,28	1,29	-17,70
0,29	1,30	-17,52
0,30	1,31	-17,34
0,31	1,32	-17,16
0,32	1,33	-16,98
0,33	1,34	-16,81
0,34	1,35	-16,63
0,35	1,36	-16,46
0,36	1,37	-16,29
0,37	1,38	-16,11
0,38	1,39	-15,94
0,39	1,40	-15,77
0,40	1,41	-15,60
0,41	1,42	-15,44
0,42	1,43	-15,27
0,43	1,44	-15,10
0,44	1,45	-14,94
0,45	1,46	-14,77
0,46	1,47	-14,61
0,47	1,48	-14,45
0,48	1,49	-14,29
0,49	1,50	-14,13
0,50	1,51	-13,97
0,51	1,52	-13,81
0,52	1,53	-13,65
0,53	1,54	-13,49
0,54	1,55	-13,33
0,55	1,56	-13,18
0,56	1,57	-13,02
0,57	1,58	-12,87
0,58	1,59	-12,72
0,59	1,60	-12,56
0,60	1,61	-12,41



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,61	1,62	-12,26
0,62	1,63	-12,11
0,63	1,64	-11,96
0,64	1,65	-11,81
0,65	1,66	-11,66
0,66	1,67	-11,51
0,67	1,68	-11,37
0,68	1,69	-11,22
0,69	1,70	-11,07
0,70	1,71	-10,93
0,71	1,72	-10,78
0,72	1,73	-10,64
0,73	1,74	-10,50
0,74	1,75	-10,36
0,75	1,76	-10,21
0,76	1,77	-10,07
0,77	1,78	-9,93
0,78	1,79	-9,79
0,79	1,80	-9,65
0,80	1,81	-9,51
0,81	1,82	-9,38
0,82	1,83	-9,24
0,83	1,84	-9,10
0,84	1,85	-8,97
0,85	1,86	-8,83
0,86	1,87	-8,69
0,87	1,88	-8,56
0,88	1,89	-8,43
0,89	1,90	-8,29
0,90	1,91	-8,16
0,91	1,92	-8,03
0,92	1,93	-7,89
0,93	1,94	-7,76
0,94	1,95	-7,63
0,95	1,96	-7,50
0,96	1,97	-7,37
0,97	1,98	-7,24
0,98	1,99	-7,11
0,99	2,00	-6,99
1,00	2,01	-6,86
1,01	2,02	-6,73
1,02	2,03	-6,60
1,03	2,04	-6,48
1,04	2,05	-6,35



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	-6,23
1,06	2,07	-6,10
1,07	2,08	-5,98
1,08	2,09	-5,85
1,09	2,10	-5,73
1,10	2,11	-5,61
1,11	2,12	-5,48
1,12	2,13	-5,36
1,13	2,14	-5,24
1,14	2,15	-5,12
1,15	2,16	-5,00
1,16	2,17	-4,88
1,17	2,18	-4,76
1,18	2,19	-4,64
1,19	2,20	-4,52
1,20	2,21	-4,40
1,21	2,22	-4,28
1,22	2,23	-4,16
1,23	2,24	-4,05
1,24	2,25	-3,93
1,25	2,26	-3,81
1,26	2,27	-3,70
1,27	2,28	-3,58
1,28	2,29	-3,47
1,29	2,30	-3,35
1,30	2,31	-3,24
1,31	2,32	-3,12
1,32	2,33	-3,01
1,33	2,34	-2,89
1,34	2,35	-2,78
1,35	2,36	-2,67
1,36	2,37	-2,56
1,37	2,38	-2,44
1,38	2,39	-2,33
1,39	2,40	-2,22
1,40	2,41	-2,11
1,41	2,42	-2,00
1,42	2,43	-1,89
1,43	2,44	-1,78
1,44	2,45	-1,67
1,45	2,46	-1,56
1,46	2,47	-1,45
1,47	2,48	-1,34
1,48	2,49	-1,24



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,49	2,50	-1,13
1,50	2,51	-1,02
1,51	2,52	-0,91
1,52	2,53	-0,81
1,53	2,54	-0,70
1,54	2,55	-0,59
1,55	2,56	-0,49
1,56	2,57	-0,38
1,57	2,58	-0,28
1,58	2,59	-0,17
1,59	2,60	-0,07
1,60	2,61	0,04
1,61	2,62	0,14
1,62	2,63	0,24
1,63	2,64	0,35
1,64	2,65	0,45
1,65	2,66	0,55
1,66	2,67	0,66
1,67	2,68	0,76
1,68	2,69	0,86
1,69	2,70	0,96
1,70	2,71	1,06
1,71	2,72	1,16
1,72	2,73	1,26
1,73	2,74	1,36
1,74	2,75	1,46
1,75	2,76	1,56
1,76	2,77	1,66
1,77	2,78	1,76
1,78	2,79	1,86
1,79	2,80	1,96
1,80	2,81	2,06
1,81	2,82	2,16
1,82	2,83	2,26
1,83	2,84	2,35
1,84	2,85	2,45
1,85	2,86	2,55
1,86	2,87	2,64
1,87	2,88	2,74
1,88	2,89	2,84
1,89	2,90	2,93
1,90	2,91	3,03
1,91	2,92	3,12
1,92	2,93	3,22



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,93	2,94	3,32
1,94	2,95	3,41
1,95	2,96	3,50
1,96	2,97	3,60
1,97	2,98	3,69
1,98	2,99	3,79
1,99	3,00	3,88
2,00	3,01	3,97
2,01	3,02	4,07
2,02	3,03	4,16
2,03	3,04	4,25
2,04	3,05	4,34
2,05	3,06	4,44
2,06	3,07	4,53
2,07	3,08	4,62
2,08	3,09	4,71
2,09	3,10	4,80
2,10	3,11	4,89
2,11	3,12	4,99
2,12	3,13	5,08
2,13	3,14	5,17
2,14	3,15	5,26
2,15	3,16	5,35
2,16	3,17	5,44
2,17	3,18	5,53
2,18	3,19	5,61
2,19	3,20	5,70
2,20	3,21	5,79
2,21	3,22	5,88
2,22	3,23	5,97
2,23	3,24	6,06
2,24	3,25	6,15
2,25	3,26	6,23
2,26	3,27	6,32
2,27	3,28	6,41
2,28	3,29	6,50
2,29	3,30	6,58
2,30	3,31	6,67
2,31	3,32	6,76
2,32	3,33	6,84
2,33	3,34	6,93
2,34	3,35	7,01
2,35	3,36	7,10
2,36	3,37	7,19



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	7,27
2,38	3,39	7,36
2,39	3,40	7,44
2,40	3,41	7,53
2,41	3,42	7,61
2,42	3,43	7,69
2,43	3,44	7,78
2,44	3,45	7,86
2,45	3,46	7,95
2,46	3,47	8,03
2,47	3,48	8,11
2,48	3,49	8,20
2,49	3,50	8,28
2,50	3,51	8,36
2,51	3,52	8,45
2,52	3,53	8,53
2,53	3,54	8,61
2,54	3,55	8,69
2,55	3,56	8,77
2,56	3,57	8,86
2,57	3,58	8,94
2,58	3,59	9,02
2,59	3,60	9,10
2,60	3,61	9,18
2,61	3,62	9,26
2,62	3,63	9,34
2,63	3,64	9,42
2,64	3,65	9,50
2,65	3,66	9,58
2,66	3,67	9,66
2,67	3,68	9,74
2,68	3,69	9,82
2,69	3,70	9,90
2,70	3,71	9,98
2,71	3,72	10,06
2,72	3,73	10,14
2,73	3,74	10,22
2,74	3,75	10,30
2,75	3,76	10,38
2,76	3,77	10,46
2,77	3,78	10,53
2,78	3,79	10,61
2,79	3,80	10,69
2,80	3,81	10,77



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,81	3,82	10,85
2,82	3,83	10,92
2,83	3,84	11,00
2,84	3,85	11,08
2,85	3,86	11,16
2,86	3,87	11,23
2,87	3,88	11,31
2,88	3,89	11,39
2,89	3,90	11,46
2,90	3,91	11,54
2,91	3,92	11,61
2,92	3,93	11,69
2,93	3,94	11,77
2,94	3,95	11,84
2,95	3,96	11,92
2,96	3,97	11,99
2,97	3,98	12,07
2,98	3,99	12,14
2,99	4,00	12,22
3,00	4,01	12,29
3,01	4,02	12,37
3,02	4,03	12,44
3,03	4,04	12,52
3,04	4,05	12,59
3,05	4,06	12,66
3,06	4,07	12,74
3,07	4,08	12,81
3,08	4,09	12,89
3,09	4,10	12,96
3,10	4,11	13,03
3,11	4,12	13,11
3,12	4,13	13,18
3,13	4,14	13,25
3,14	4,15	13,33
3,15	4,16	13,40
3,16	4,17	13,47
3,17	4,18	13,54
3,18	4,19	13,62
3,19	4,20	13,69
3,20	4,21	13,76
3,21	4,22	13,83
3,22	4,23	13,90
3,23	4,24	13,98
3,24	4,25	14,05



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
3,25	4,26	14,12
3,26	4,27	14,19
3,27	4,28	14,26
3,28	4,29	14,33
3,29	4,30	14,40
3,30	4,31	14,47
3,31	4,32	14,54
3,32	4,33	14,61
3,33	4,34	14,68
3,34	4,35	14,76
3,35	4,36	14,83
3,36	4,37	14,90
3,37	4,38	14,97
3,38	4,39	15,03
3,39	4,40	15,10
3,40	4,41	15,17
3,41	4,42	15,24
3,42	4,43	15,31
3,43	4,44	15,38
3,44	4,45	15,45
3,45	4,46	15,52
3,46	4,47	15,59
3,47	4,48	15,66
3,48	4,49	15,73
3,49	4,50	15,79
3,50	4,51	15,86
3,51	4,52	15,93
3,52	4,53	16,00
3,53	4,54	16,07
3,54	4,55	16,13
3,55	4,56	16,20
3,56	4,57	16,27
3,57	4,58	16,34
3,58	4,59	16,41
3,59	4,60	16,47
3,60	4,61	16,54
3,61	4,62	16,61
3,62	4,63	16,67
3,63	4,64	16,74
3,64	4,65	16,81
3,65	4,66	16,87
3,66	4,67	16,94
3,67	4,68	17,01
3,68	4,69	17,07



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
3,69	4,70	17,14
3,70	4,71	17,21
3,71	4,72	17,27
3,72	4,73	17,34
3,73	4,74	17,40
3,74	4,75	17,47
3,75	4,76	17,53
3,76	4,77	17,60
3,77	4,78	17,67
3,78	4,79	17,73
3,79	4,80	17,80
3,80	4,81	17,86
3,81	4,82	17,93
3,82	4,83	17,99
3,83	4,84	18,06
3,84	4,85	18,12
3,85	4,86	18,18
3,86	4,87	18,25
3,87	4,88	18,31
3,88	4,89	18,38
3,89	4,90	18,44
3,90	4,91	18,51
3,91	4,92	18,57
3,92	4,93	18,63
3,93	4,94	18,70
3,94	4,95	18,76
3,95	4,96	18,82
3,96	4,97	18,89
3,97	4,98	18,95
3,98	4,99	19,01
3,99	5,00	19,08
4,00	5,01	19,14
4,01	5,02	19,20
4,02	5,03	19,27
4,03	5,04	19,33
4,04	5,05	19,39
4,05	5,06	19,45
4,06	5,07	19,52
4,07	5,08	19,58
4,08	5,09	19,64
4,09	5,10	19,70
4,10	5,11	19,77
4,11	5,12	19,83
4,12	5,13	19,89



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	19,95
4,14	5,15	20,01
4,15	5,16	20,07
4,16	5,17	20,14
4,17	5,18	20,20
4,18	5,19	20,26
4,19	5,20	20,32
4,20	5,21	20,38
4,21	5,22	20,44
4,22	5,23	20,50
4,23	5,24	20,56
4,24	5,25	20,63
4,25	5,26	20,69
4,26	5,27	20,75
4,27	5,28	20,81
4,28	5,29	20,87
4,29	5,30	20,93
4,30	5,31	20,99
4,31	5,32	21,05
4,32	5,33	21,11
4,33	5,34	21,17
4,34	5,35	21,23
4,35	5,36	21,29
4,36	5,37	21,35
4,37	5,38	21,41
4,38	5,39	21,47
4,39	5,40	21,53
4,40	5,41	21,59
4,41	5,42	21,65
4,42	5,43	21,71
4,43	5,44	21,76
4,44	5,45	21,82
4,45	5,46	21,88
4,46	5,47	21,94
4,47	5,48	22,00
4,48	5,49	22,06
4,49	5,50	22,12
4,50	5,51	22,18
4,51	5,52	22,23
4,52	5,53	22,29
4,53	5,54	22,35
4,54	5,55	22,41
4,55	5,56	22,47
4,56	5,57	22,53



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
4,57	5,58	22,58
4,58	5,59	22,64
4,59	5,60	22,70
4,60	5,61	22,76
4,61	5,62	22,82
4,62	5,63	22,87
4,63	5,64	22,93
4,64	5,65	22,99
4,65	5,66	23,05
4,66	5,67	23,10
4,67	5,68	23,16
4,68	5,69	23,22
4,69	5,70	23,27
4,70	5,71	23,33
4,71	5,72	23,39
4,72	5,73	23,45
4,73	5,74	23,50
4,74	5,75	23,56
4,75	5,76	23,62
4,76	5,77	23,67
4,77	5,78	23,73
4,78	5,79	23,78
4,79	5,80	23,84
4,80	5,81	23,90
4,81	5,82	23,95
4,82	5,83	24,01
4,83	5,84	24,07
4,84	5,85	24,12
4,85	5,86	24,18
4,86	5,87	24,23
4,87	5,88	24,29
4,88	5,89	24,35
4,89	5,90	24,40
4,90	5,91	24,46
4,91	5,92	24,51
4,92	5,93	24,57
4,93	5,94	24,62
4,94	5,95	24,68
4,95	5,96	24,73
4,96	5,97	24,79
4,97	5,98	24,84
4,98	5,99	24,90
4,99	6,00	24,95
5,00	6,01	25,01



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	25,06
5,02	6,03	25,12
5,03	6,04	25,17
5,04	6,05	25,23
5,05	6,06	25,28
5,06	6,07	25,34
5,07	6,08	25,39
5,08	6,09	25,44
5,09	6,10	25,50
5,10	6,11	25,55
5,11	6,12	25,61
5,12	6,13	25,66
5,13	6,14	25,71
5,14	6,15	25,77
5,15	6,16	25,82
5,16	6,17	25,88
5,17	6,18	25,93
5,18	6,19	25,98
5,19	6,20	26,04
5,20	6,21	26,09
5,21	6,22	26,14
5,22	6,23	26,20
5,23	6,24	26,25
5,24	6,25	26,30
5,25	6,26	26,36
5,26	6,27	26,41
5,27	6,28	26,46
5,28	6,29	26,52
5,29	6,30	26,57
5,30	6,31	26,62
5,31	6,32	26,67
5,32	6,33	26,73
5,33	6,34	26,78
5,34	6,35	26,83
5,35	6,36	26,88
5,36	6,37	26,94
5,37	6,38	26,99
5,38	6,39	27,04
5,39	6,40	27,09
5,40	6,41	27,15
5,41	6,42	27,20
5,42	6,43	27,25
5,43	6,44	27,30
5,44	6,45	27,35



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,45	6,46	27,41
5,46	6,47	27,46
5,47	6,48	27,51
5,48	6,49	27,56
5,49	6,50	27,61
5,50	6,51	27,66
5,51	6,52	27,72
5,52	6,53	27,77
5,53	6,54	27,82
5,54	6,55	27,87
5,55	6,56	27,92
5,56	6,57	27,97
5,57	6,58	28,02
5,58	6,59	28,07
5,59	6,60	28,13
5,60	6,61	28,18
5,61	6,62	28,23
5,62	6,63	28,28
5,63	6,64	28,33
5,64	6,65	28,38
5,65	6,66	28,43
5,66	6,67	28,48
5,67	6,68	28,53
5,68	6,69	28,58
5,69	6,70	28,63
5,70	6,71	28,68
5,71	6,72	28,73
5,72	6,73	28,78
5,73	6,74	28,83
5,74	6,75	28,88
5,75	6,76	28,93
5,76	6,77	28,98
5,77	6,78	29,03
5,78	6,79	29,08
5,79	6,80	29,13
5,80	6,81	29,18
5,81	6,82	29,23
5,82	6,83	29,28
5,83	6,84	29,33
5,84	6,85	29,38
5,85	6,86	29,43
5,86	6,87	29,48
5,87	6,88	29,53
5,88	6,89	29,58



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	29,63
5,90	6,91	29,68
5,91	6,92	29,73
5,92	6,93	29,78
5,93	6,94	29,83
5,94	6,95	29,88
5,95	6,96	29,92
5,96	6,97	29,97
5,97	6,98	30,02
5,98	6,99	30,07
5,99	7,00	30,12
6,00	7,01	30,17
6,01	7,02	30,22
6,02	7,03	30,27
6,03	7,04	30,32
6,04	7,05	30,36
6,05	7,06	30,41
6,06	7,07	30,46
6,07	7,08	30,51
6,08	7,09	30,56
6,09	7,10	30,61
6,10	7,11	30,65
6,11	7,12	30,70
6,12	7,13	30,75
6,13	7,14	30,80
6,14	7,15	30,85
6,15	7,16	30,89
6,16	7,17	30,94
6,17	7,18	30,99
6,18	7,19	31,04
6,19	7,20	31,09
6,20	7,21	31,13
6,21	7,22	31,18
6,22	7,23	31,23
6,23	7,24	31,28
6,24	7,25	31,32
6,25	7,26	31,37
6,26	7,27	31,42
6,27	7,28	31,47
6,28	7,29	31,51
6,29	7,30	31,56
6,30	7,31	31,61
6,31	7,32	31,65
6,32	7,33	31,70



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,33	7,34	31,75
6,34	7,35	31,80
6,35	7,36	31,84
6,36	7,37	31,89
6,37	7,38	31,94
6,38	7,39	31,98
6,39	7,40	32,03
6,40	7,41	32,08
6,41	7,42	32,12
6,42	7,43	32,17
6,43	7,44	32,22
6,44	7,45	32,26
6,45	7,46	32,31
6,46	7,47	32,36
6,47	7,48	32,40
6,48	7,49	32,45
6,49	7,50	32,49
6,50	7,51	32,54
6,51	7,52	32,59
6,52	7,53	32,63
6,53	7,54	32,68
6,54	7,55	32,73
6,55	7,56	32,77
6,56	7,57	32,82
6,57	7,58	32,86
6,58	7,59	32,91
6,59	7,60	32,95
6,60	7,61	33,00
6,61	7,62	33,05
6,62	7,63	33,09
6,63	7,64	33,14
6,64	7,65	33,18
6,65	7,66	33,23
6,66	7,67	33,27
6,67	7,68	33,32
6,68	7,69	33,37
6,69	7,70	33,41
6,70	7,71	33,46
6,71	7,72	33,50
6,72	7,73	33,55
6,73	7,74	33,59
6,74	7,75	33,64
6,75	7,76	33,68
6,76	7,77	33,73



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,77	7,78	33,77
6,78	7,79	33,82
6,79	7,80	33,86
6,80	7,81	33,91
6,81	7,82	33,95
6,82	7,83	34,00
6,83	7,84	34,04
6,84	7,85	34,09
6,85	7,86	34,13
6,86	7,87	34,17
6,87	7,88	34,22
6,88	7,89	34,26
6,89	7,90	34,31
6,90	7,91	34,35
6,91	7,92	34,40
6,92	7,93	34,44
6,93	7,94	34,49
6,94	7,95	34,53
6,95	7,96	34,57
6,96	7,97	34,62
6,97	7,98	34,66
6,98	7,99	34,71
6,99	8,00	34,75
7,00	8,01	34,79
7,01	8,02	34,84
7,02	8,03	34,88
7,03	8,04	34,93
7,04	8,05	34,97
7,05	8,06	35,01
7,06	8,07	35,06
7,07	8,08	35,10
7,08	8,09	35,15
7,09	8,10	35,19
7,10	8,11	35,23
7,11	8,12	35,28
7,12	8,13	35,32
7,13	8,14	35,36
7,14	8,15	35,41
7,15	8,16	35,45
7,16	8,17	35,49
7,17	8,18	35,54
7,18	8,19	35,58
7,19	8,20	35,62
7,20	8,21	35,67



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	35,71
7,22	8,23	35,75
7,23	8,24	35,80
7,24	8,25	35,84
7,25	8,26	35,88
7,26	8,27	35,92
7,27	8,28	35,97
7,28	8,29	36,01
7,29	8,30	36,05
7,30	8,31	36,10
7,31	8,32	36,14
7,32	8,33	36,18
7,33	8,34	36,22
7,34	8,35	36,27
7,35	8,36	36,31
7,36	8,37	36,35
7,37	8,38	36,39
7,38	8,39	36,44
7,39	8,40	36,48
7,40	8,41	36,52
7,41	8,42	36,56
7,42	8,43	36,61
7,43	8,44	36,65
7,44	8,45	36,69
7,45	8,46	36,73
7,46	8,47	36,77
7,47	8,48	36,82
7,48	8,49	36,86
7,49	8,50	36,90
7,50	8,51	36,94
7,51	8,52	36,99
7,52	8,53	37,03
7,53	8,54	37,07
7,54	8,55	37,11
7,55	8,56	37,15
7,56	8,57	37,19
7,57	8,58	37,24
7,58	8,59	37,28
7,59	8,60	37,32
7,60	8,61	37,36
7,61	8,62	37,40
7,62	8,63	37,44
7,63	8,64	37,49
7,64	8,65	37,53



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,65	8,66	37,57
7,66	8,67	37,61
7,67	8,68	37,65
7,68	8,69	37,69
7,69	8,70	37,73
7,70	8,71	37,78
7,71	8,72	37,82
7,72	8,73	37,86
7,73	8,74	37,90
7,74	8,75	37,94
7,75	8,76	37,98
7,76	8,77	38,02
7,77	8,78	38,06
7,78	8,79	38,10
7,79	8,80	38,15
7,80	8,81	38,19
7,81	8,82	38,23
7,82	8,83	38,27
7,83	8,84	38,31
7,84	8,85	38,35
7,85	8,86	38,39
7,86	8,87	38,43
7,87	8,88	38,47
7,88	8,89	38,51
7,89	8,90	38,55
7,90	8,91	38,59
7,91	8,92	38,63
7,92	8,93	38,67
7,93	8,94	38,72
7,94	8,95	38,76
7,95	8,96	38,80
7,96	8,97	38,84
7,97	8,98	38,88
7,98	8,99	38,92
7,99	9,00	38,96
8,00	9,01	39,00
8,01	9,02	39,04
8,02	9,03	39,08
8,03	9,04	39,12
8,04	9,05	39,16
8,05	9,06	39,20
8,06	9,07	39,24
8,07	9,08	39,28
8,08	9,09	39,32



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
8,09	9,10	39,36
8,10	9,11	39,40
8,11	9,12	39,44
8,12	9,13	39,48
8,13	9,14	39,52
8,14	9,15	39,56
8,15	9,16	39,60
8,16	9,17	39,64
8,17	9,18	39,68
8,18	9,19	39,72
8,19	9,20	39,75
8,20	9,21	39,79
8,21	9,22	39,83
8,22	9,23	39,87
8,23	9,24	39,91
8,24	9,25	39,95
8,25	9,26	39,99
8,26	9,27	40,03
8,27	9,28	40,07
8,28	9,29	40,11
8,29	9,30	40,15
8,30	9,31	40,19
8,31	9,32	40,23
8,32	9,33	40,27
8,33	9,34	40,31
8,34	9,35	40,34
8,35	9,36	40,38
8,36	9,37	40,42
8,37	9,38	40,46
8,38	9,39	40,50
8,39	9,40	40,54
8,40	9,41	40,58
8,41	9,42	40,62
8,42	9,43	40,66
8,43	9,44	40,70
8,44	9,45	40,73
8,45	9,46	40,77
8,46	9,47	40,81
8,47	9,48	40,85
8,48	9,49	40,89
8,49	9,50	40,93
8,50	9,51	40,97
8,51	9,52	41,00
8,52	9,53	41,04



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,53	9,54	41,08
8,54	9,55	41,12
8,55	9,56	41,16
8,56	9,57	41,20
8,57	9,58	41,24
8,58	9,59	41,27
8,59	9,60	41,31
8,60	9,61	41,35
8,61	9,62	41,39
8,62	9,63	41,43
8,63	9,64	41,46
8,64	9,65	41,50
8,65	9,66	41,54
8,66	9,67	41,58
8,67	9,68	41,62
8,68	9,69	41,66
8,69	9,70	41,69
8,70	9,71	41,73
8,71	9,72	41,77
8,72	9,73	41,81
8,73	9,74	41,84
8,74	9,75	41,88
8,75	9,76	41,92
8,76	9,77	41,96
8,77	9,78	42,00
8,78	9,79	42,03
8,79	9,80	42,07
8,80	9,81	42,11
8,81	9,82	42,15
8,82	9,83	42,18
8,83	9,84	42,22
8,84	9,85	42,26
8,85	9,86	42,30
8,86	9,87	42,33
8,87	9,88	42,37
8,88	9,89	42,41
8,89	9,90	42,45
8,90	9,91	42,48
8,91	9,92	42,52
8,92	9,93	42,56
8,93	9,94	42,60
8,94	9,95	42,63
8,95	9,96	42,67
8,96	9,97	42,71



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,97	9,98	42,75
8,98	9,99	42,78
8,99	10,00	42,82
9,00	10,01	42,86
9,01	10,02	42,89
9,02	10,03	42,93
9,03	10,04	42,97
9,04	10,05	43,00
9,05	10,06	43,04
9,06	10,07	43,08
9,07	10,08	43,12
9,08	10,09	43,15
9,09	10,10	43,19
9,10	10,11	43,23
9,11	10,12	43,26
9,12	10,13	43,30
9,13	10,14	43,34
9,14	10,15	43,37
9,15	10,16	43,41
9,16	10,17	43,45
9,17	10,18	43,48
9,18	10,19	43,52
9,19	10,20	43,56
9,20	10,21	43,59
9,21	10,22	43,63
9,22	10,23	43,67
9,23	10,24	43,70
9,24	10,25	43,74
9,25	10,26	43,77
9,26	10,27	43,81
9,27	10,28	43,85
9,28	10,29	43,88
9,29	10,30	43,92
9,30	10,31	43,96
9,31	10,32	43,99
9,32	10,33	44,03
9,33	10,34	44,07
9,34	10,35	44,10
9,35	10,36	44,14
9,36	10,37	44,17
9,37	10,38	44,21
9,38	10,39	44,25
9,39	10,40	44,28
9,40	10,41	44,32



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,41	10,42	44,35
9,42	10,43	44,39
9,43	10,44	44,43
9,44	10,45	44,46
9,45	10,46	44,50
9,46	10,47	44,53
9,47	10,48	44,57
9,48	10,49	44,60
9,49	10,50	44,64
9,50	10,51	44,68
9,51	10,52	44,71
9,52	10,53	44,75
9,53	10,54	44,78
9,54	10,55	44,82
9,55	10,56	44,85
9,56	10,57	44,89
9,57	10,58	44,93
9,58	10,59	44,96
9,59	10,60	45,00
9,60	10,61	45,03
9,61	10,62	45,07
9,62	10,63	45,10
9,63	10,64	45,14
9,64	10,65	45,17
9,65	10,66	45,21
9,66	10,67	45,24
9,67	10,68	45,28
9,68	10,69	45,32
9,69	10,70	45,35
9,70	10,71	45,39
9,71	10,72	45,42
9,72	10,73	45,46
9,73	10,74	45,49
9,74	10,75	45,53
9,75	10,76	45,56
9,76	10,77	45,60
9,77	10,78	45,63
9,78	10,79	45,67
9,79	10,80	45,70
9,80	10,81	45,74
9,81	10,82	45,77
9,82	10,83	45,81
9,83	10,84	45,84
9,84	10,85	45,88



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,85	10,86	45,91
9,86	10,87	45,95
9,87	10,88	45,98
9,88	10,89	46,02
9,89	10,90	46,05
9,90	10,91	46,08
9,91	10,92	46,12
9,92	10,93	46,15
9,93	10,94	46,19
9,94	10,95	46,22
9,95	10,96	46,26
9,96	10,97	46,29
9,97	10,98	46,33
9,98	10,99	46,36
9,99	11,00	46,40
10,00	11,01	46,43
10,01	11,02	46,47
10,02	11,03	46,50
10,03	11,04	46,53
10,04	11,05	46,57
10,05	11,06	46,60
10,06	11,07	46,64
10,07	11,08	46,67
10,08	11,09	46,71
10,09	11,10	46,74
10,10	11,11	46,77
10,11	11,12	46,81
10,12	11,13	46,84
10,13	11,14	46,88
10,14	11,15	46,91
10,15	11,16	46,94
10,16	11,17	46,98
10,17	11,18	47,01
10,18	11,19	47,05
10,19	11,20	47,08
10,20	11,21	47,12
10,21	11,22	47,15
10,22	11,23	47,18
10,23	11,24	47,22
10,24	11,25	47,25
10,25	11,26	47,28
10,26	11,27	47,32
10,27	11,28	47,35
10,28	11,29	47,39



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,29	11,30	47,42
10,30	11,31	47,45
10,31	11,32	47,49
10,32	11,33	47,52
10,33	11,34	47,56
10,34	11,35	47,59
10,35	11,36	47,62
10,36	11,37	47,66
10,37	11,38	47,69
10,38	11,39	47,72
10,39	11,40	47,76
10,40	11,41	47,79
10,41	11,42	47,82
10,42	11,43	47,86
10,43	11,44	47,89
10,44	11,45	47,92
10,45	11,46	47,96
10,46	11,47	47,99
10,47	11,48	48,02
10,48	11,49	48,06
10,49	11,50	48,09
10,50	11,51	48,12
10,51	11,52	48,16
10,52	11,53	48,19
10,53	11,54	48,22
10,54	11,55	48,26
10,55	11,56	48,29
10,56	11,57	48,32
10,57	11,58	48,36
10,58	11,59	48,39
10,59	11,60	48,42
10,60	11,61	48,46
10,61	11,62	48,49
10,62	11,63	48,52
10,63	11,64	48,56
10,64	11,65	48,59
10,65	11,66	48,62
10,66	11,67	48,65
10,67	11,68	48,69
10,68	11,69	48,72
10,69	11,70	48,75
10,70	11,71	48,79
10,71	11,72	48,82
10,72	11,73	48,85



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	48,89
10,74	11,75	48,92
10,75	11,76	48,95
10,76	11,77	48,98
10,77	11,78	49,02
10,78	11,79	49,05
10,79	11,80	49,08
10,80	11,81	49,11
10,81	11,82	49,15
10,82	11,83	49,18
10,83	11,84	49,21
10,84	11,85	49,24
10,85	11,86	49,28
10,86	11,87	49,31
10,87	11,88	49,34
10,88	11,89	49,37
10,89	11,90	49,41
10,90	11,91	49,44
10,91	11,92	49,47
10,92	11,93	49,50
10,93	11,94	49,54
10,94	11,95	49,57
10,95	11,96	49,60
10,96	11,97	49,63
10,97	11,98	49,67
10,98	11,99	49,70
10,99	12,00	49,73
11,00	12,01	49,76
11,01	12,02	49,80
11,02	12,03	49,83
11,03	12,04	49,86
11,04	12,05	49,89
11,05	12,06	49,92
11,06	12,07	49,96
11,07	12,08	49,99
11,08	12,09	50,02
11,09	12,10	50,05
11,10	12,11	50,08
11,11	12,12	50,12
11,12	12,13	50,15
11,13	12,14	50,18
11,14	12,15	50,21
11,15	12,16	50,24
11,16	12,17	50,28



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,17	12,18	50,31
11,18	12,19	50,34
11,19	12,20	50,37
11,20	12,21	50,40
11,21	12,22	50,44
11,22	12,23	50,47
11,23	12,24	50,50
11,24	12,25	50,53
11,25	12,26	50,56
11,26	12,27	50,59
11,27	12,28	50,63
11,28	12,29	50,66
11,29	12,30	50,69
11,30	12,31	50,72
11,31	12,32	50,75
11,32	12,33	50,78
11,33	12,34	50,82
11,34	12,35	50,85
11,35	12,36	50,88
11,36	12,37	50,91
11,37	12,38	50,94
11,38	12,39	50,97
11,39	12,40	51,00
11,40	12,41	51,04
11,41	12,42	51,07
11,42	12,43	51,10
11,43	12,44	51,13
11,44	12,45	51,16
11,45	12,46	51,19
11,46	12,47	51,22
11,47	12,48	51,26
11,48	12,49	51,29
11,49	12,50	51,32
11,50	12,51	51,35
11,51	12,52	51,38
11,52	12,53	51,41
11,53	12,54	51,44
11,54	12,55	51,47
11,55	12,56	51,51
11,56	12,57	51,54
11,57	12,58	51,57
11,58	12,59	51,60
11,59	12,60	51,63
11,60	12,61	51,66



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
11,61	12,62	51,69
11,62	12,63	51,72
11,63	12,64	51,75
11,64	12,65	51,79
11,65	12,66	51,82
11,66	12,67	51,85
11,67	12,68	51,88
11,68	12,69	51,91
11,69	12,70	51,94
11,70	12,71	51,97
11,71	12,72	52,00
11,72	12,73	52,03
11,73	12,74	52,06
11,74	12,75	52,09
11,75	12,76	52,12
11,76	12,77	52,16
11,77	12,78	52,19
11,78	12,79	52,22
11,79	12,80	52,25
11,80	12,81	52,28
11,81	12,82	52,31
11,82	12,83	52,34
11,83	12,84	52,37
11,84	12,85	52,40
11,85	12,86	52,43
11,86	12,87	52,46
11,87	12,88	52,49
11,88	12,89	52,52
11,89	12,90	52,55
11,90	12,91	52,58
11,91	12,92	52,61
11,92	12,93	52,64
11,93	12,94	52,68
11,94	12,95	52,71
11,95	12,96	52,74
11,96	12,97	52,77
11,97	12,98	52,80
11,98	12,99	52,83
11,99	13,00	52,86
12,00	13,01	52,89
12,01	13,02	52,92
12,02	13,03	52,95
12,03	13,04	52,98
12,04	13,05	53,01



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,05	13,06	53,04
12,06	13,07	53,07
12,07	13,08	53,10
12,08	13,09	53,13
12,09	13,10	53,16
12,10	13,11	53,19
12,11	13,12	53,22
12,12	13,13	53,25
12,13	13,14	53,28
12,14	13,15	53,31
12,15	13,16	53,34
12,16	13,17	53,37
12,17	13,18	53,40
12,18	13,19	53,43
12,19	13,20	53,46
12,20	13,21	53,49
12,21	13,22	53,52
12,22	13,23	53,55
12,23	13,24	53,58
12,24	13,25	53,61
12,25	13,26	53,64
12,26	13,27	53,67
12,27	13,28	53,70
12,28	13,29	53,73
12,29	13,30	53,76
12,30	13,31	53,79
12,31	13,32	53,82
12,32	13,33	53,85
12,33	13,34	53,88
12,34	13,35	53,91
12,35	13,36	53,94
12,36	13,37	53,97
12,37	13,38	54,00
12,38	13,39	54,03
12,39	13,40	54,06
12,40	13,41	54,09
12,41	13,42	54,12
12,42	13,43	54,15
12,43	13,44	54,17
12,44	13,45	54,20
12,45	13,46	54,23
12,46	13,47	54,26
12,47	13,48	54,29
12,48	13,49	54,32



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,49	13,50	54,35
12,50	13,51	54,38
12,51	13,52	54,41
12,52	13,53	54,44
12,53	13,54	54,47
12,54	13,55	54,50
12,55	13,56	54,53
12,56	13,57	54,56
12,57	13,58	54,59
12,58	13,59	54,62
12,59	13,60	54,65
12,60	13,61	54,67
12,61	13,62	54,70
12,62	13,63	54,73
12,63	13,64	54,76
12,64	13,65	54,79
12,65	13,66	54,82
12,66	13,67	54,85
12,67	13,68	54,88
12,68	13,69	54,91
12,69	13,70	54,94
12,70	13,71	54,97
12,71	13,72	55,00
12,72	13,73	55,02
12,73	13,74	55,05
12,74	13,75	55,08
12,75	13,76	55,11
12,76	13,77	55,14
12,77	13,78	55,17
12,78	13,79	55,20
12,79	13,80	55,23
12,80	13,81	55,26
12,81	13,82	55,29
12,82	13,83	55,31
12,83	13,84	55,34
12,84	13,85	55,37
12,85	13,86	55,40
12,86	13,87	55,43
12,87	13,88	55,46
12,88	13,89	55,49
12,89	13,90	55,52
12,90	13,91	55,55
12,91	13,92	55,57
12,92	13,93	55,60



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	55,63
12,94	13,95	55,66
12,95	13,96	55,69
12,96	13,97	55,72
12,97	13,98	55,75
12,98	13,99	55,78
12,99	14,00	55,80
13,00	14,01	55,83
13,01	14,02	55,86
13,02	14,03	55,89
13,03	14,04	55,92
13,04	14,05	55,95
13,05	14,06	55,98
13,06	14,07	56,00
13,07	14,08	56,03
13,08	14,09	56,06
13,09	14,10	56,09
13,10	14,11	56,12
13,11	14,12	56,15
13,12	14,13	56,17
13,13	14,14	56,20
13,14	14,15	56,23
13,15	14,16	56,26
13,16	14,17	56,29
13,17	14,18	56,32
13,18	14,19	56,34
13,19	14,20	56,37
13,20	14,21	56,40
13,21	14,22	56,43
13,22	14,23	56,46
13,23	14,24	56,49
13,24	14,25	56,51
13,25	14,26	56,54
13,26	14,27	56,57
13,27	14,28	56,60
13,28	14,29	56,63
13,29	14,30	56,66
13,30	14,31	56,68
13,31	14,32	56,71
13,32	14,33	56,74
13,33	14,34	56,77
13,34	14,35	56,80
13,35	14,36	56,82
13,36	14,37	56,85



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,37	14,38	56,88
13,38	14,39	56,91
13,39	14,40	56,94
13,40	14,41	56,96
13,41	14,42	56,99
13,42	14,43	57,02
13,43	14,44	57,05
13,44	14,45	57,08
13,45	14,46	57,10
13,46	14,47	57,13
13,47	14,48	57,16
13,48	14,49	57,19
13,49	14,50	57,22
13,50	14,51	57,24
13,51	14,52	57,27
13,52	14,53	57,30
13,53	14,54	57,33
13,54	14,55	57,35
13,55	14,56	57,38
13,56	14,57	57,41
13,57	14,58	57,44
13,58	14,59	57,47
13,59	14,60	57,49
13,60	14,61	57,52
13,61	14,62	57,55
13,62	14,63	57,58
13,63	14,64	57,60
13,64	14,65	57,63
13,65	14,66	57,66
13,66	14,67	57,69
13,67	14,68	57,71
13,68	14,69	57,74
13,69	14,70	57,77
13,70	14,71	57,80
13,71	14,72	57,83
13,72	14,73	57,85
13,73	14,74	57,88
13,74	14,75	57,91
13,75	14,76	57,94
13,76	14,77	57,96
13,77	14,78	57,99
13,78	14,79	58,02
13,79	14,80	58,05
13,80	14,81	58,07



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,81	14,82	58,10
13,82	14,83	58,13
13,83	14,84	58,15
13,84	14,85	58,18
13,85	14,86	58,21
13,86	14,87	58,24
13,87	14,88	58,26
13,88	14,89	58,29
13,89	14,90	58,32
13,90	14,91	58,35
13,91	14,92	58,37
13,92	14,93	58,40
13,93	14,94	58,43
13,94	14,95	58,45
13,95	14,96	58,48
13,96	14,97	58,51
13,97	14,98	58,54
13,98	14,99	58,56
13,99	15,00	58,59
14,00	15,01	58,62
14,01	15,02	58,64
14,02	15,03	58,67
14,03	15,04	58,70
14,04	15,05	58,73
14,05	15,06	58,75
14,06	15,07	58,78
14,07	15,08	58,81
14,08	15,09	58,83
14,09	15,10	58,86
14,10	15,11	58,89
14,11	15,12	58,92
14,12	15,13	58,94
14,13	15,14	58,97
14,14	15,15	59,00
14,15	15,16	59,02
14,16	15,17	59,05
14,17	15,18	59,08
14,18	15,19	59,10
14,19	15,20	59,13
14,20	15,21	59,16
14,21	15,22	59,18
14,22	15,23	59,21
14,23	15,24	59,24
14,24	15,25	59,26



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
14,25	15,26	59,29
14,26	15,27	59,32
14,27	15,28	59,34
14,28	15,29	59,37
14,29	15,30	59,40
14,30	15,31	59,43
14,31	15,32	59,45
14,32	15,33	59,48
14,33	15,34	59,51
14,34	15,35	59,53
14,35	15,36	59,56
14,36	15,37	59,59
14,37	15,38	59,61
14,38	15,39	59,64
14,39	15,40	59,66
14,40	15,41	59,69
14,41	15,42	59,72
14,42	15,43	59,74
14,43	15,44	59,77
14,44	15,45	59,80
14,45	15,46	59,82
14,46	15,47	59,85
14,47	15,48	59,88
14,48	15,49	59,90
14,49	15,50	59,93
14,50	15,51	59,96
14,51	15,52	59,98
14,52	15,53	60,01
14,53	15,54	60,04
14,54	15,55	60,06
14,55	15,56	60,09
14,56	15,57	60,11
14,57	15,58	60,14
14,58	15,59	60,17
14,59	15,60	60,19
14,60	15,61	60,22
14,61	15,62	60,25
14,62	15,63	60,27
14,63	15,64	60,30
14,64	15,65	60,33
14,65	15,66	60,35
14,66	15,67	60,38
14,67	15,68	60,40
14,68	15,69	60,43



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	60,46
14,70	15,71	60,48
14,71	15,72	60,51
14,72	15,73	60,53
14,73	15,74	60,56
14,74	15,75	60,59
14,75	15,76	60,61
14,76	15,77	60,64
14,77	15,78	60,67
14,78	15,79	60,69
14,79	15,80	60,72
14,80	15,81	60,74
14,81	15,82	60,77
14,82	15,83	60,80
14,83	15,84	60,82
14,84	15,85	60,85
14,85	15,86	60,87
14,86	15,87	60,90
14,87	15,88	60,93
14,88	15,89	60,95
14,89	15,90	60,98
14,90	15,91	61,00
14,91	15,92	61,03
14,92	15,93	61,06
14,93	15,94	61,08
14,94	15,95	61,11
14,95	15,96	61,13
14,96	15,97	61,16
14,97	15,98	61,18
14,98	15,99	61,21
14,99	16,00	61,24
15,00	16,01	61,26
15,01	16,02	61,29
15,02	16,03	61,31
15,03	16,04	61,34
15,04	16,05	61,36
15,05	16,06	61,39
15,06	16,07	61,42
15,07	16,08	61,44
15,08	16,09	61,47
15,09	16,10	61,49
15,10	16,11	61,52
15,11	16,12	61,54
15,12	16,13	61,57



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
15,13	16,14	61,60
15,14	16,15	61,62
15,15	16,16	61,65
15,16	16,17	61,67
15,17	16,18	61,70
15,18	16,19	61,72
15,19	16,20	61,75
15,20	16,21	61,78
15,21	16,22	61,80
15,22	16,23	61,83
15,23	16,24	61,85
15,24	16,25	61,88
15,25	16,26	61,90
15,26	16,27	61,93
15,27	16,28	61,95
15,28	16,29	61,98
15,29	16,30	62,00
15,30	16,31	62,03
15,31	16,32	62,06
15,32	16,33	62,08
15,33	16,34	62,11
15,34	16,35	62,13
15,35	16,36	62,16
15,36	16,37	62,18
15,37	16,38	62,21
15,38	16,39	62,23
15,39	16,40	62,26
15,40	16,41	62,28
15,41	16,42	62,31
15,42	16,43	62,33
15,43	16,44	62,36
15,44	16,45	62,38
15,45	16,46	62,41
15,46	16,47	62,43
15,47	16,48	62,46
15,48	16,49	62,49
15,49	16,50	62,51
15,50	16,51	62,54
15,51	16,52	62,56
15,52	16,53	62,59
15,53	16,54	62,61
15,54	16,55	62,64
15,55	16,56	62,66
15,56	16,57	62,69



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
15,57	16,58	62,71
15,58	16,59	62,74
15,59	16,60	62,76
15,60	16,61	62,79
15,61	16,62	62,81
15,62	16,63	62,84
15,63	16,64	62,86
15,64	16,65	62,89
15,65	16,66	62,91
15,66	16,67	62,94
15,67	16,68	62,96
15,68	16,69	62,99
15,69	16,70	63,01
15,70	16,71	63,04
15,71	16,72	63,06
15,72	16,73	63,09
15,73	16,74	63,11
15,74	16,75	63,14
15,75	16,76	63,16
15,76	16,77	63,19
15,77	16,78	63,21
15,78	16,79	63,24
15,79	16,80	63,26
15,80	16,81	63,29
15,81	16,82	63,31
15,82	16,83	63,34
15,83	16,84	63,36
15,84	16,85	63,38
15,85	16,86	63,41
15,86	16,87	63,43
15,87	16,88	63,46
15,88	16,89	63,48
15,89	16,90	63,51
15,90	16,91	63,53
15,91	16,92	63,56
15,92	16,93	63,58
15,93	16,94	63,61
15,94	16,95	63,63
15,95	16,96	63,66
15,96	16,97	63,68
15,97	16,98	63,71
15,98	16,99	63,73
15,99	17,00	63,75
16,00	17,01	63,78



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	63,80
16,02	17,03	63,83
16,03	17,04	63,85
16,04	17,05	63,88
16,05	17,06	63,90
16,06	17,07	63,93
16,07	17,08	63,95
16,08	17,09	63,98
16,09	17,10	64,00
16,10	17,11	64,02
16,11	17,12	64,05
16,12	17,13	64,07
16,13	17,14	64,10
16,14	17,15	64,12
16,15	17,16	64,15
16,16	17,17	64,17
16,17	17,18	64,20
16,18	17,19	64,22
16,19	17,20	64,24
16,20	17,21	64,27
16,21	17,22	64,29
16,22	17,23	64,32
16,23	17,24	64,34
16,24	17,25	64,37
16,25	17,26	64,39
16,26	17,27	64,41
16,27	17,28	64,44
16,28	17,29	64,46
16,29	17,30	64,49
16,30	17,31	64,51
16,31	17,32	64,54
16,32	17,33	64,56
16,33	17,34	64,58
16,34	17,35	64,61
16,35	17,36	64,63
16,36	17,37	64,66
16,37	17,38	64,68
16,38	17,39	64,71
16,39	17,40	64,73
16,40	17,41	64,75
16,41	17,42	64,78
16,42	17,43	64,80
16,43	17,44	64,83
16,44	17,45	64,85



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,45	17,46	64,87
16,46	17,47	64,90
16,47	17,48	64,92
16,48	17,49	64,95
16,49	17,50	64,97
16,50	17,51	64,99
16,51	17,52	65,02
16,52	17,53	65,04
16,53	17,54	65,07
16,54	17,55	65,09
16,55	17,56	65,11
16,56	17,57	65,14
16,57	17,58	65,16
16,58	17,59	65,19
16,59	17,60	65,21
16,60	17,61	65,23
16,61	17,62	65,26
16,62	17,63	65,28
16,63	17,64	65,31
16,64	17,65	65,33
16,65	17,66	65,35
16,66	17,67	65,38
16,67	17,68	65,40
16,68	17,69	65,43
16,69	17,70	65,45
16,70	17,71	65,47
16,71	17,72	65,50
16,72	17,73	65,52
16,73	17,74	65,54
16,74	17,75	65,57
16,75	17,76	65,59
16,76	17,77	65,62
16,77	17,78	65,64
16,78	17,79	65,66
16,79	17,80	65,69
16,80	17,81	65,71
16,81	17,82	65,73
16,82	17,83	65,76
16,83	17,84	65,78
16,84	17,85	65,81
16,85	17,86	65,83
16,86	17,87	65,85
16,87	17,88	65,88
16,88	17,89	65,90



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	65,92
16,90	17,91	65,95
16,91	17,92	65,97
16,92	17,93	65,99
16,93	17,94	66,02
16,94	17,95	66,04
16,95	17,96	66,07
16,96	17,97	66,09
16,97	17,98	66,11
16,98	17,99	66,14
16,99	18,00	66,16
17,00	18,01	66,18
17,01	18,02	66,21
17,02	18,03	66,23
17,03	18,04	66,25
17,04	18,05	66,28
17,05	18,06	66,30
17,06	18,07	66,32
17,07	18,08	66,35
17,08	18,09	66,37
17,09	18,10	66,39
17,10	18,11	66,42
17,11	18,12	66,44
17,12	18,13	66,46
17,13	18,14	66,49
17,14	18,15	66,51
17,15	18,16	66,53
17,16	18,17	66,56
17,17	18,18	66,58
17,18	18,19	66,60
17,19	18,20	66,63
17,20	18,21	66,65
17,21	18,22	66,67
17,22	18,23	66,70
17,23	18,24	66,72
17,24	18,25	66,74
17,25	18,26	66,77
17,26	18,27	66,79
17,27	18,28	66,81
17,28	18,29	66,84
17,29	18,30	66,86
17,30	18,31	66,88
17,31	18,32	66,91
17,32	18,33	66,93



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	66,95
17,34	18,35	66,98
17,35	18,36	67,00
17,36	18,37	67,02
17,37	18,38	67,05
17,38	18,39	67,07
17,39	18,40	67,09
17,40	18,41	67,11
17,41	18,42	67,14
17,42	18,43	67,16
17,43	18,44	67,18
17,44	18,45	67,21
17,45	18,46	67,23
17,46	18,47	67,25
17,47	18,48	67,28
17,48	18,49	67,30
17,49	18,50	67,32
17,50	18,51	67,34
17,51	18,52	67,37
17,52	18,53	67,39
17,53	18,54	67,41
17,54	18,55	67,44
17,55	18,56	67,46
17,56	18,57	67,48
17,57	18,58	67,51
17,58	18,59	67,53
17,59	18,60	67,55
17,60	18,61	67,57
17,61	18,62	67,60
17,62	18,63	67,62
17,63	18,64	67,64
17,64	18,65	67,67
17,65	18,66	67,69
17,66	18,67	67,71
17,67	18,68	67,73
17,68	18,69	67,76
17,69	18,70	67,78
17,70	18,71	67,80
17,71	18,72	67,83
17,72	18,73	67,85
17,73	18,74	67,87
17,74	18,75	67,89
17,75	18,76	67,92
17,76	18,77	67,94



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
17,77	18,78	67,96
17,78	18,79	67,98
17,79	18,80	68,01
17,80	18,81	68,03
17,81	18,82	68,05
17,82	18,83	68,08
17,83	18,84	68,10
17,84	18,85	68,12
17,85	18,86	68,14
17,86	18,87	68,17
17,87	18,88	68,19
17,88	18,89	68,21
17,89	18,90	68,23
17,90	18,91	68,26
17,91	18,92	68,28
17,92	18,93	68,30
17,93	18,94	68,32
17,94	18,95	68,35
17,95	18,96	68,37
17,96	18,97	68,39
17,97	18,98	68,41
17,98	18,99	68,44
17,99	19,00	68,46
18,00	19,01	68,48
18,01	19,02	68,50
18,02	19,03	68,53
18,03	19,04	68,55
18,04	19,05	68,57
18,05	19,06	68,59
18,06	19,07	68,62
18,07	19,08	68,64
18,08	19,09	68,66
18,09	19,10	68,68
18,10	19,11	68,71
18,11	19,12	68,73
18,12	19,13	68,75
18,13	19,14	68,77
18,14	19,15	68,80
18,15	19,16	68,82
18,16	19,17	68,84
18,17	19,18	68,86
18,18	19,19	68,89
18,19	19,20	68,91
18,20	19,21	68,93



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
18,21	19,22	68,95
18,22	19,23	68,98
18,23	19,24	69,00
18,24	19,25	69,02
18,25	19,26	69,04
18,26	19,27	69,06
18,27	19,28	69,09
18,28	19,29	69,11
18,29	19,30	69,13
18,30	19,31	69,15
18,31	19,32	69,18
18,32	19,33	69,20
18,33	19,34	69,22
18,34	19,35	69,24
18,35	19,36	69,26
18,36	19,37	69,29
18,37	19,38	69,31
18,38	19,39	69,33
18,39	19,40	69,35
18,40	19,41	69,38
18,41	19,42	69,40
18,42	19,43	69,42
18,43	19,44	69,44
18,44	19,45	69,46
18,45	19,46	69,49
18,46	19,47	69,51
18,47	19,48	69,53
18,48	19,49	69,55
18,49	19,50	69,57
18,50	19,51	69,60
18,51	19,52	69,62
18,52	19,53	69,64
18,53	19,54	69,66
18,54	19,55	69,68
18,55	19,56	69,71
18,56	19,57	69,73
18,57	19,58	69,75
18,58	19,59	69,77
18,59	19,60	69,79
18,60	19,61	69,82
18,61	19,62	69,84
18,62	19,63	69,86
18,63	19,64	69,88
18,64	19,65	69,90



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
18,65	19,66	69,93
18,66	19,67	69,95
18,67	19,68	69,97
18,68	19,69	69,99
18,69	19,70	70,01
18,70	19,71	70,04
18,71	19,72	70,06
18,72	19,73	70,08
18,73	19,74	70,10
18,74	19,75	70,12
18,75	19,76	70,14
18,76	19,77	70,17
18,77	19,78	70,19
18,78	19,79	70,21
18,79	19,80	70,23
18,80	19,81	70,25
18,81	19,82	70,28
18,82	19,83	70,30
18,83	19,84	70,32
18,84	19,85	70,34
18,85	19,86	70,36
18,86	19,87	70,38
18,87	19,88	70,41
18,88	19,89	70,43
18,89	19,90	70,45
18,90	19,91	70,47
18,91	19,92	70,49
18,92	19,93	70,51
18,93	19,94	70,54
18,94	19,95	70,56
18,95	19,96	70,58
18,96	19,97	70,60
18,97	19,98	70,62
18,98	19,99	70,64
18,99	20,00	70,67
19,00	20,01	70,69
19,01	20,02	70,71
19,02	20,03	70,73
19,03	20,04	70,75
19,04	20,05	70,77
19,05	20,06	70,79
19,06	20,07	70,82
19,07	20,08	70,84
19,08	20,09	70,86



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	70,88
19,10	20,11	70,90
19,11	20,12	70,92
19,12	20,13	70,95
19,13	20,14	70,97
19,14	20,15	70,99
19,15	20,16	71,01
19,16	20,17	71,03
19,17	20,18	71,05
19,18	20,19	71,07
19,19	20,20	71,10
19,20	20,21	71,12
19,21	20,22	71,14
19,22	20,23	71,16
19,23	20,24	71,18
19,24	20,25	71,20
19,25	20,26	71,22
19,26	20,27	71,25
19,27	20,28	71,27
19,28	20,29	71,29
19,29	20,30	71,31
19,30	20,31	71,33
19,31	20,32	71,35
19,32	20,33	71,37
19,33	20,34	71,40
19,34	20,35	71,42
19,35	20,36	71,44
19,36	20,37	71,46
19,37	20,38	71,48
19,38	20,39	71,50
19,39	20,40	71,52
19,40	20,41	71,54
19,41	20,42	71,57
19,42	20,43	71,59
19,43	20,44	71,61
19,44	20,45	71,63
19,45	20,46	71,65
19,46	20,47	71,67
19,47	20,48	71,69
19,48	20,49	71,71
19,49	20,50	71,74
19,50	20,51	71,76
19,51	20,52	71,78
19,52	20,53	71,80



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	71,82
19,54	20,55	71,84
19,55	20,56	71,86
19,56	20,57	71,88
19,57	20,58	71,90
19,58	20,59	71,93
19,59	20,60	71,95
19,60	20,61	71,97
19,61	20,62	71,99
19,62	20,63	72,01
19,63	20,64	72,03
19,64	20,65	72,05
19,65	20,66	72,07
19,66	20,67	72,09
19,67	20,68	72,11
19,68	20,69	72,14
19,69	20,70	72,16
19,70	20,71	72,18
19,71	20,72	72,20
19,72	20,73	72,22
19,73	20,74	72,24
19,74	20,75	72,26
19,75	20,76	72,28
19,76	20,77	72,30
19,77	20,78	72,32
19,78	20,79	72,35
19,79	20,80	72,37
19,80	20,81	72,39
19,81	20,82	72,41
19,82	20,83	72,43
19,83	20,84	72,45
19,84	20,85	72,47
19,85	20,86	72,49
19,86	20,87	72,51
19,87	20,88	72,53
19,88	20,89	72,55
19,89	20,90	72,58
19,90	20,91	72,60
19,91	20,92	72,62
19,92	20,93	72,64
19,93	20,94	72,66
19,94	20,95	72,68
19,95	20,96	72,70
19,96	20,97	72,72



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,97	20,98	72,74
19,98	20,99	72,76
19,99	21,00	72,78
20,00	21,01	72,80
20,01	21,02	72,83
20,02	21,03	72,85
20,03	21,04	72,87
20,04	21,05	72,89
20,05	21,06	72,91
20,06	21,07	72,93
20,07	21,08	72,95
20,08	21,09	72,97
20,09	21,10	72,99
20,10	21,11	73,01
20,11	21,12	73,03
20,12	21,13	73,05
20,13	21,14	73,07
20,14	21,15	73,09
20,15	21,16	73,11
20,16	21,17	73,14
20,17	21,18	73,16
20,18	21,19	73,18
20,19	21,20	73,20
20,20	21,21	73,22
20,21	21,22	73,24
20,22	21,23	73,26
20,23	21,24	73,28
20,24	21,25	73,30
20,25	21,26	73,32
20,26	21,27	73,34
20,27	21,28	73,36
20,28	21,29	73,38
20,29	21,30	73,40
20,30	21,31	73,42
20,31	21,32	73,44
20,32	21,33	73,46
20,33	21,34	73,49
20,34	21,35	73,51
20,35	21,36	73,53
20,36	21,37	73,55
20,37	21,38	73,57
20,38	21,39	73,59
20,39	21,40	73,61
20,40	21,41	73,63



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,41	21,42	73,65
20,42	21,43	73,67
20,43	21,44	73,69
20,44	21,45	73,71
20,45	21,46	73,73
20,46	21,47	73,75
20,47	21,48	73,77
20,48	21,49	73,79
20,49	21,50	73,81
20,50	21,51	73,83
20,51	21,52	73,85
20,52	21,53	73,87
20,53	21,54	73,89
20,54	21,55	73,91
20,55	21,56	73,93
20,56	21,57	73,95
20,57	21,58	73,97
20,58	21,59	74,00
20,59	21,60	74,02
20,60	21,61	74,04
20,61	21,62	74,06
20,62	21,63	74,08
20,63	21,64	74,10
20,64	21,65	74,12
20,65	21,66	74,14
20,66	21,67	74,16
20,67	21,68	74,18
20,68	21,69	74,20
20,69	21,70	74,22
20,70	21,71	74,24
20,71	21,72	74,26
20,72	21,73	74,28
20,73	21,74	74,30
20,74	21,75	74,32
20,75	21,76	74,34
20,76	21,77	74,36
20,77	21,78	74,38
20,78	21,79	74,40
20,79	21,80	74,42
20,80	21,81	74,44
20,81	21,82	74,46
20,82	21,83	74,48
20,83	21,84	74,50
20,84	21,85	74,52



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	74,54
20,86	21,87	74,56
20,87	21,88	74,58
20,88	21,89	74,60
20,89	21,90	74,62
20,90	21,91	74,64
20,91	21,92	74,66
20,92	21,93	74,68
20,93	21,94	74,70
20,94	21,95	74,72
20,95	21,96	74,74
20,96	21,97	74,76
20,97	21,98	74,78
20,98	21,99	74,80
20,99	22,00	74,82
21,00	22,01	74,84
21,01	22,02	74,86
21,02	22,03	74,88
21,03	22,04	74,90
21,04	22,05	74,92
21,05	22,06	74,94
21,06	22,07	74,96
21,07	22,08	74,98
21,08	22,09	75,00
21,09	22,10	75,02
21,10	22,11	75,04
21,11	22,12	75,06
21,12	22,13	75,08
21,13	22,14	75,10
21,14	22,15	75,12
21,15	22,16	75,14
21,16	22,17	75,16
21,17	22,18	75,18
21,18	22,19	75,20
21,19	22,20	75,22
21,20	22,21	75,24
21,21	22,22	75,26
21,22	22,23	75,28
21,23	22,24	75,30
21,24	22,25	75,32
21,25	22,26	75,34
21,26	22,27	75,36
21,27	22,28	75,38
21,28	22,29	75,40



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
21,29	22,30	75,42
21,30	22,31	75,44
21,31	22,32	75,46
21,32	22,33	75,48
21,33	22,34	75,50
21,34	22,35	75,52
21,35	22,36	75,54
21,36	22,37	75,56
21,37	22,38	75,58
21,38	22,39	75,60
21,39	22,40	75,62
21,40	22,41	75,63
21,41	22,42	75,65
21,42	22,43	75,67
21,43	22,44	75,69
21,44	22,45	75,71
21,45	22,46	75,73
21,46	22,47	75,75
21,47	22,48	75,77
21,48	22,49	75,79
21,49	22,50	75,81
21,50	22,51	75,83
21,51	22,52	75,85
21,52	22,53	75,87
21,53	22,54	75,89
21,54	22,55	75,91
21,55	22,56	75,93
21,56	22,57	75,95
21,57	22,58	75,97
21,58	22,59	75,99
21,59	22,60	76,01
21,60	22,61	76,03
21,61	22,62	76,05
21,62	22,63	76,07
21,63	22,64	76,09
21,64	22,65	76,11
21,65	22,66	76,12
21,66	22,67	76,14
21,67	22,68	76,16
21,68	22,69	76,18
21,69	22,70	76,20
21,70	22,71	76,22
21,71	22,72	76,24
21,72	22,73	76,26



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
21,73	22,74	76,28
21,74	22,75	76,30
21,75	22,76	76,32
21,76	22,77	76,34
21,77	22,78	76,36
21,78	22,79	76,38
21,79	22,80	76,40
21,80	22,81	76,42
21,81	22,82	76,44
21,82	22,83	76,46
21,83	22,84	76,47
21,84	22,85	76,49
21,85	22,86	76,51
21,86	22,87	76,53
21,87	22,88	76,55
21,88	22,89	76,57
21,89	22,90	76,59
21,90	22,91	76,61
21,91	22,92	76,63
21,92	22,93	76,65
21,93	22,94	76,67
21,94	22,95	76,69
21,95	22,96	76,71
21,96	22,97	76,73
21,97	22,98	76,75
21,98	22,99	76,76
21,99	23,00	76,78
22,00	23,01	76,80
22,01	23,02	76,82
22,02	23,03	76,84
22,03	23,04	76,86
22,04	23,05	76,88
22,05	23,06	76,90
22,06	23,07	76,92
22,07	23,08	76,94
22,08	23,09	76,96
22,09	23,10	76,98
22,10	23,11	77,00
22,11	23,12	77,01
22,12	23,13	77,03
22,13	23,14	77,05
22,14	23,15	77,07
22,15	23,16	77,09
22,16	23,17	77,11



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
22,17	23,18	77,13
22,18	23,19	77,15
22,19	23,20	77,17
22,20	23,21	77,19
22,21	23,22	77,21
22,22	23,23	77,23
22,23	23,24	77,24
22,24	23,25	77,26
22,25	23,26	77,28
22,26	23,27	77,30
22,27	23,28	77,32
22,28	23,29	77,34
22,29	23,30	77,36
22,30	23,31	77,38
22,31	23,32	77,40
22,32	23,33	77,42
22,33	23,34	77,44
22,34	23,35	77,45
22,35	23,36	77,47
22,36	23,37	77,49
22,37	23,38	77,51
22,38	23,39	77,53
22,39	23,40	77,55
22,40	23,41	77,57
22,41	23,42	77,59
22,42	23,43	77,61
22,43	23,44	77,63
22,44	23,45	77,64
22,45	23,46	77,66
22,46	23,47	77,68
22,47	23,48	77,70
22,48	23,49	77,72
22,49	23,50	77,74
22,50	23,51	77,76
22,51	23,52	77,78
22,52	23,53	77,80
22,53	23,54	77,81
22,54	23,55	77,83
22,55	23,56	77,85
22,56	23,57	77,87
22,57	23,58	77,89
22,58	23,59	77,91
22,59	23,60	77,93
22,60	23,61	77,95



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	77,97
22,62	23,63	77,98
22,63	23,64	78,00
22,64	23,65	78,02
22,65	23,66	78,04
22,66	23,67	78,06
22,67	23,68	78,08
22,68	23,69	78,10
22,69	23,70	78,12
22,70	23,71	78,13
22,71	23,72	78,15
22,72	23,73	78,17
22,73	23,74	78,19
22,74	23,75	78,21
22,75	23,76	78,23
22,76	23,77	78,25
22,77	23,78	78,27
22,78	23,79	78,28
22,79	23,80	78,30
22,80	23,81	78,32
22,81	23,82	78,34
22,82	23,83	78,36
22,83	23,84	78,38
22,84	23,85	78,40
22,85	23,86	78,42
22,86	23,87	78,43
22,87	23,88	78,45
22,88	23,89	78,47
22,89	23,90	78,49
22,90	23,91	78,51
22,91	23,92	78,53
22,92	23,93	78,55
22,93	23,94	78,57
22,94	23,95	78,58
22,95	23,96	78,60
22,96	23,97	78,62
22,97	23,98	78,64
22,98	23,99	78,66
22,99	24,00	78,68
23,00	24,01	78,70
23,01	24,02	78,71
23,02	24,03	78,73
23,03	24,04	78,75
23,04	24,05	78,77



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,05	24,06	78,79
23,06	24,07	78,81
23,07	24,08	78,83
23,08	24,09	78,84
23,09	24,10	78,86
23,10	24,11	78,88
23,11	24,12	78,90
23,12	24,13	78,92
23,13	24,14	78,94
23,14	24,15	78,95
23,15	24,16	78,97
23,16	24,17	78,99
23,17	24,18	79,01
23,18	24,19	79,03
23,19	24,20	79,05
23,20	24,21	79,07
23,21	24,22	79,08
23,22	24,23	79,10
23,23	24,24	79,12
23,24	24,25	79,14
23,25	24,26	79,16
23,26	24,27	79,18
23,27	24,28	79,19
23,28	24,29	79,21
23,29	24,30	79,23
23,30	24,31	79,25
23,31	24,32	79,27
23,32	24,33	79,29
23,33	24,34	79,31
23,34	24,35	79,32
23,35	24,36	79,34
23,36	24,37	79,36
23,37	24,38	79,38
23,38	24,39	79,40
23,39	24,40	79,42
23,40	24,41	79,43
23,41	24,42	79,45
23,42	24,43	79,47
23,43	24,44	79,49
23,44	24,45	79,51
23,45	24,46	79,53
23,46	24,47	79,54
23,47	24,48	79,56
23,48	24,49	79,58



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,49	24,50	79,60
23,50	24,51	79,62
23,51	24,52	79,63
23,52	24,53	79,65
23,53	24,54	79,67
23,54	24,55	79,69
23,55	24,56	79,71
23,56	24,57	79,73
23,57	24,58	79,74
23,58	24,59	79,76
23,59	24,60	79,78
23,60	24,61	79,80
23,61	24,62	79,82
23,62	24,63	79,84
23,63	24,64	79,85
23,64	24,65	79,87
23,65	24,66	79,89
23,66	24,67	79,91
23,67	24,68	79,93
23,68	24,69	79,94
23,69	24,70	79,96
23,70	24,71	79,98
23,71	24,72	80,00
23,72	24,73	80,02
23,73	24,74	80,04
23,74	24,75	80,05
23,75	24,76	80,07
23,76	24,77	80,09
23,77	24,78	80,11
23,78	24,79	80,13
23,79	24,80	80,14
23,80	24,81	80,16
23,81	24,82	80,18
23,82	24,83	80,20
23,83	24,84	80,22
23,84	24,85	80,23
23,85	24,86	80,25
23,86	24,87	80,27
23,87	24,88	80,29
23,88	24,89	80,31
23,89	24,90	80,32
23,90	24,91	80,34
23,91	24,92	80,36
23,92	24,93	80,38



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,93	24,94	80,40
23,94	24,95	80,41
23,95	24,96	80,43
23,96	24,97	80,45
23,97	24,98	80,47
23,98	24,99	80,49
23,99	25,00	80,50
24,00	25,01	80,52
24,01	25,02	80,54
24,02	25,03	80,56
24,03	25,04	80,58
24,04	25,05	80,59
24,05	25,06	80,61
24,06	25,07	80,63
24,07	25,08	80,65
24,08	25,09	80,67
24,09	25,10	80,68
24,10	25,11	80,70
24,11	25,12	80,72
24,12	25,13	80,74
24,13	25,14	80,75
24,14	25,15	80,77
24,15	25,16	80,79
24,16	25,17	80,81
24,17	25,18	80,83
24,18	25,19	80,84
24,19	25,20	80,86
24,20	25,21	80,88
24,21	25,22	80,90
24,22	25,23	80,92
24,23	25,24	80,93
24,24	25,25	80,95
24,25	25,26	80,97
24,26	25,27	80,99
24,27	25,28	81,00
24,28	25,29	81,02
24,29	25,30	81,04
24,30	25,31	81,06
24,31	25,32	81,08
24,32	25,33	81,09
24,33	25,34	81,11
24,34	25,35	81,13
24,35	25,36	81,15
24,36	25,37	81,16



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,37	25,38	81,18
24,38	25,39	81,20
24,39	25,40	81,22
24,40	25,41	81,24
24,41	25,42	81,25
24,42	25,43	81,27
24,43	25,44	81,29
24,44	25,45	81,31
24,45	25,46	81,32
24,46	25,47	81,34
24,47	25,48	81,36
24,48	25,49	81,38
24,49	25,50	81,39
24,50	25,51	81,41
24,51	25,52	81,43
24,52	25,53	81,45
24,53	25,54	81,47
24,54	25,55	81,48
24,55	25,56	81,50
24,56	25,57	81,52
24,57	25,58	81,54
24,58	25,59	81,55
24,59	25,60	81,57
24,60	25,61	81,59
24,61	25,62	81,61
24,62	25,63	81,62
24,63	25,64	81,64
24,64	25,65	81,66
24,65	25,66	81,68
24,66	25,67	81,69
24,67	25,68	81,71
24,68	25,69	81,73
24,69	25,70	81,75
24,70	25,71	81,76
24,71	25,72	81,78
24,72	25,73	81,80
24,73	25,74	81,82
24,74	25,75	81,83
24,75	25,76	81,85
24,76	25,77	81,87
24,77	25,78	81,89
24,78	25,79	81,90
24,79	25,80	81,92
24,80	25,81	81,94



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,81	25,82	81,96
24,82	25,83	81,97
24,83	25,84	81,99
24,84	25,85	82,01
24,85	25,86	82,03
24,86	25,87	82,04
24,87	25,88	82,06
24,88	25,89	82,08
24,89	25,90	82,10
24,90	25,91	82,11
24,91	25,92	82,13
24,92	25,93	82,15
24,93	25,94	82,17
24,94	25,95	82,18
24,95	25,96	82,20
24,96	25,97	82,22
24,97	25,98	82,24
24,98	25,99	82,25
24,99	26,00	82,27
25,00	26,01	82,29
25,01	26,02	82,30
25,02	26,03	82,32
25,03	26,04	82,34
25,04	26,05	82,36
25,05	26,06	82,37
25,06	26,07	82,39
25,07	26,08	82,41
25,08	26,09	82,43
25,09	26,10	82,44
25,10	26,11	82,46
25,11	26,12	82,48
25,12	26,13	82,50
25,13	26,14	82,51
25,14	26,15	82,53
25,15	26,16	82,55
25,16	26,17	82,56
25,17	26,18	82,58
25,18	26,19	82,60
25,19	26,20	82,62
25,20	26,21	82,63
25,21	26,22	82,65
25,22	26,23	82,67
25,23	26,24	82,68
25,24	26,25	82,70



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	82,72
25,26	26,27	82,74
25,27	26,28	82,75
25,28	26,29	82,77
25,29	26,30	82,79
25,30	26,31	82,81
25,31	26,32	82,82
25,32	26,33	82,84
25,33	26,34	82,86
25,34	26,35	82,87
25,35	26,36	82,89
25,36	26,37	82,91
25,37	26,38	82,93
25,38	26,39	82,94
25,39	26,40	82,96
25,40	26,41	82,98
25,41	26,42	82,99
25,42	26,43	83,01
25,43	26,44	83,03
25,44	26,45	83,05
25,45	26,46	83,06
25,46	26,47	83,08
25,47	26,48	83,10
25,48	26,49	83,11
25,49	26,50	83,13
25,50	26,51	83,15
25,51	26,52	83,16
25,52	26,53	83,18
25,53	26,54	83,20
25,54	26,55	83,22
25,55	26,56	83,23
25,56	26,57	83,25
25,57	26,58	83,27
25,58	26,59	83,28
25,59	26,60	83,30
25,60	26,61	83,32
25,61	26,62	83,34
25,62	26,63	83,35
25,63	26,64	83,37
25,64	26,65	83,39
25,65	26,66	83,40
25,66	26,67	83,42
25,67	26,68	83,44
25,68	26,69	83,45



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,69	26,70	83,47
25,70	26,71	83,49
25,71	26,72	83,50
25,72	26,73	83,52
25,73	26,74	83,54
25,74	26,75	83,56
25,75	26,76	83,57
25,76	26,77	83,59
25,77	26,78	83,61
25,78	26,79	83,62
25,79	26,80	83,64
25,80	26,81	83,66
25,81	26,82	83,67
25,82	26,83	83,69
25,83	26,84	83,71
25,84	26,85	83,72
25,85	26,86	83,74
25,86	26,87	83,76
25,87	26,88	83,78
25,88	26,89	83,79
25,89	26,90	83,81
25,90	26,91	83,83
25,91	26,92	83,84
25,92	26,93	83,86
25,93	26,94	83,88
25,94	26,95	83,89
25,95	26,96	83,91
25,96	26,97	83,93
25,97	26,98	83,94
25,98	26,99	83,96
25,99	27,00	83,98
26,00	27,01	83,99
26,01	27,02	84,01
26,02	27,03	84,03
26,03	27,04	84,04
26,04	27,05	84,06
26,05	27,06	84,08
26,06	27,07	84,09
26,07	27,08	84,11
26,08	27,09	84,13
26,09	27,10	84,15
26,10	27,11	84,16
26,11	27,12	84,18
26,12	27,13	84,20



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	84,21
26,14	27,15	84,23
26,15	27,16	84,25
26,16	27,17	84,26
26,17	27,18	84,28
26,18	27,19	84,30
26,19	27,20	84,31
26,20	27,21	84,33
26,21	27,22	84,35
26,22	27,23	84,36
26,23	27,24	84,38
26,24	27,25	84,40
26,25	27,26	84,41
26,26	27,27	84,43
26,27	27,28	84,45
26,28	27,29	84,46
26,29	27,30	84,48
26,30	27,31	84,50
26,31	27,32	84,51
26,32	27,33	84,53
26,33	27,34	84,55
26,34	27,35	84,56
26,35	27,36	84,58
26,36	27,37	84,60
26,37	27,38	84,61
26,38	27,39	84,63
26,39	27,40	84,64
26,40	27,41	84,66
26,41	27,42	84,68
26,42	27,43	84,69
26,43	27,44	84,71
26,44	27,45	84,73
26,45	27,46	84,74
26,46	27,47	84,76
26,47	27,48	84,78
26,48	27,49	84,79
26,49	27,50	84,81
26,50	27,51	84,83
26,51	27,52	84,84
26,52	27,53	84,86
26,53	27,54	84,88
26,54	27,55	84,89
26,55	27,56	84,91
26,56	27,57	84,93



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
26,57	27,58	84,94
26,58	27,59	84,96
26,59	27,60	84,98
26,60	27,61	84,99
26,61	27,62	85,01
26,62	27,63	85,02
26,63	27,64	85,04
26,64	27,65	85,06
26,65	27,66	85,07
26,66	27,67	85,09
26,67	27,68	85,11
26,68	27,69	85,12
26,69	27,70	85,14
26,70	27,71	85,16
26,71	27,72	85,17
26,72	27,73	85,19
26,73	27,74	85,21
26,74	27,75	85,22
26,75	27,76	85,24
26,76	27,77	85,25
26,77	27,78	85,27
26,78	27,79	85,29
26,79	27,80	85,30
26,80	27,81	85,32
26,81	27,82	85,34
26,82	27,83	85,35
26,83	27,84	85,37
26,84	27,85	85,39
26,85	27,86	85,40
26,86	27,87	85,42
26,87	27,88	85,43
26,88	27,89	85,45
26,89	27,90	85,47
26,90	27,91	85,48
26,91	27,92	85,50
26,92	27,93	85,52
26,93	27,94	85,53
26,94	27,95	85,55
26,95	27,96	85,56
26,96	27,97	85,58
26,97	27,98	85,60
26,98	27,99	85,61
26,99	28,00	85,63
27,00	28,01	85,65



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	85,66
27,02	28,03	85,68
27,03	28,04	85,69
27,04	28,05	85,71
27,05	28,06	85,73
27,06	28,07	85,74
27,07	28,08	85,76
27,08	28,09	85,78
27,09	28,10	85,79
27,10	28,11	85,81
27,11	28,12	85,82
27,12	28,13	85,84
27,13	28,14	85,86
27,14	28,15	85,87
27,15	28,16	85,89
27,16	28,17	85,91
27,17	28,18	85,92
27,18	28,19	85,94
27,19	28,20	85,95
27,20	28,21	85,97
27,21	28,22	85,99
27,22	28,23	86,00
27,23	28,24	86,02
27,24	28,25	86,03
27,25	28,26	86,05
27,26	28,27	86,07
27,27	28,28	86,08
27,28	28,29	86,10
27,29	28,30	86,12
27,30	28,31	86,13
27,31	28,32	86,15
27,32	28,33	86,16
27,33	28,34	86,18
27,34	28,35	86,20
27,35	28,36	86,21
27,36	28,37	86,23
27,37	28,38	86,24
27,38	28,39	86,26
27,39	28,40	86,28
27,40	28,41	86,29
27,41	28,42	86,31
27,42	28,43	86,32
27,43	28,44	86,34
27,44	28,45	86,36



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	86,37
27,46	28,47	86,39
27,47	28,48	86,40
27,48	28,49	86,42
27,49	28,50	86,44
27,50	28,51	86,45
27,51	28,52	86,47
27,52	28,53	86,48
27,53	28,54	86,50
27,54	28,55	86,52
27,55	28,56	86,53
27,56	28,57	86,55
27,57	28,58	86,56
27,58	28,59	86,58
27,59	28,60	86,60
27,60	28,61	86,61
27,61	28,62	86,63
27,62	28,63	86,64
27,63	28,64	86,66
27,64	28,65	86,68
27,65	28,66	86,69
27,66	28,67	86,71
27,67	28,68	86,72
27,68	28,69	86,74
27,69	28,70	86,75
27,70	28,71	86,77
27,71	28,72	86,79
27,72	28,73	86,80
27,73	28,74	86,82
27,74	28,75	86,83
27,75	28,76	86,85
27,76	28,77	86,87
27,77	28,78	86,88
27,78	28,79	86,90
27,79	28,80	86,91
27,80	28,81	86,93
27,81	28,82	86,95
27,82	28,83	86,96
27,83	28,84	86,98
27,84	28,85	86,99
27,85	28,86	87,01
27,86	28,87	87,02
27,87	28,88	87,04
27,88	28,89	87,06



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	87,07
27,90	28,91	87,09
27,91	28,92	87,10
27,92	28,93	87,12
27,93	28,94	87,13
27,94	28,95	87,15
27,95	28,96	87,17
27,96	28,97	87,18
27,97	28,98	87,20
27,98	28,99	87,21
27,99	29,00	87,23
28,00	29,01	87,25
28,01	29,02	87,26
28,02	29,03	87,28
28,03	29,04	87,29
28,04	29,05	87,31
28,05	29,06	87,32
28,06	29,07	87,34
28,07	29,08	87,36
28,08	29,09	87,37
28,09	29,10	87,39
28,10	29,11	87,40
28,11	29,12	87,42
28,12	29,13	87,43
28,13	29,14	87,45
28,14	29,15	87,47
28,15	29,16	87,48
28,16	29,17	87,50
28,17	29,18	87,51
28,18	29,19	87,53
28,19	29,20	87,54
28,20	29,21	87,56
28,21	29,22	87,57
28,22	29,23	87,59
28,23	29,24	87,61
28,24	29,25	87,62
28,25	29,26	87,64
28,26	29,27	87,65
28,27	29,28	87,67
28,28	29,29	87,68
28,29	29,30	87,70
28,30	29,31	87,72
28,31	29,32	87,73
28,32	29,33	87,75



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	87,76
28,34	29,35	87,78
28,35	29,36	87,79
28,36	29,37	87,81
28,37	29,38	87,82
28,38	29,39	87,84
28,39	29,40	87,86
28,40	29,41	87,87
28,41	29,42	87,89
28,42	29,43	87,90
28,43	29,44	87,92
28,44	29,45	87,93
28,45	29,46	87,95
28,46	29,47	87,96
28,47	29,48	87,98
28,48	29,49	87,99
28,49	29,50	88,01
28,50	29,51	88,03
28,51	29,52	88,04
28,52	29,53	88,06
28,53	29,54	88,07
28,54	29,55	88,09
28,55	29,56	88,10
28,56	29,57	88,12
28,57	29,58	88,13
28,58	29,59	88,15
28,59	29,60	88,17
28,60	29,61	88,18
28,61	29,62	88,20
28,62	29,63	88,21
28,63	29,64	88,23
28,64	29,65	88,24
28,65	29,66	88,26
28,66	29,67	88,27
28,67	29,68	88,29
28,68	29,69	88,30
28,69	29,70	88,32
28,70	29,71	88,33
28,71	29,72	88,35
28,72	29,73	88,37
28,73	29,74	88,38
28,74	29,75	88,40
28,75	29,76	88,41
28,76	29,77	88,43



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
28,77	29,78	88,44
28,78	29,79	88,46
28,79	29,80	88,47
28,80	29,81	88,49
28,81	29,82	88,50
28,82	29,83	88,52
28,83	29,84	88,53
28,84	29,85	88,55
28,85	29,86	88,56
28,86	29,87	88,58
28,87	29,88	88,60
28,88	29,89	88,61
28,89	29,90	88,63
28,90	29,91	88,64
28,91	29,92	88,66
28,92	29,93	88,67
28,93	29,94	88,69
28,94	29,95	88,70
28,95	29,96	88,72
28,96	29,97	88,73
28,97	29,98	88,75
28,98	29,99	88,76
28,99	30,00	88,78
29,00	30,01	88,79
29,01	30,02	88,81
29,02	30,03	88,82
29,03	30,04	88,84
29,04	30,05	88,86
29,05	30,06	88,87
29,06	30,07	88,89
29,07	30,08	88,90
29,08	30,09	88,92
29,09	30,10	88,93
29,10	30,11	88,95
29,11	30,12	88,96
29,12	30,13	88,98
29,13	30,14	88,99
29,14	30,15	89,01
29,15	30,16	89,02
29,16	30,17	89,04
29,17	30,18	89,05
29,18	30,19	89,07
29,19	30,20	89,08
29,20	30,21	89,10



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	89,11
29,22	30,23	89,13
29,23	30,24	89,14
29,24	30,25	89,16
29,25	30,26	89,17
29,26	30,27	89,19
29,27	30,28	89,20
29,28	30,29	89,22
29,29	30,30	89,23
29,30	30,31	89,25
29,31	30,32	89,26
29,32	30,33	89,28
29,33	30,34	89,29
29,34	30,35	89,31
29,35	30,36	89,32
29,36	30,37	89,34
29,37	30,38	89,35
29,38	30,39	89,37
29,39	30,40	89,38
29,40	30,41	89,40
29,41	30,42	89,42
29,42	30,43	89,43
29,43	30,44	89,45
29,44	30,45	89,46
29,45	30,46	89,48
29,46	30,47	89,49
29,47	30,48	89,51
29,48	30,49	89,52
29,49	30,50	89,54
29,50	30,51	89,55
29,51	30,52	89,57
29,52	30,53	89,58
29,53	30,54	89,60
29,54	30,55	89,61
29,55	30,56	89,63
29,56	30,57	89,64
29,57	30,58	89,66
29,58	30,59	89,67
29,59	30,60	89,69
29,60	30,61	89,70
29,61	30,62	89,72
29,62	30,63	89,73
29,63	30,64	89,74
29,64	30,65	89,76



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,65	30,66	89,77
29,66	30,67	89,79
29,67	30,68	89,80
29,68	30,69	89,82
29,69	30,70	89,83
29,70	30,71	89,85
29,71	30,72	89,86
29,72	30,73	89,88
29,73	30,74	89,89
29,74	30,75	89,91
29,75	30,76	89,92
29,76	30,77	89,94
29,77	30,78	89,95
29,78	30,79	89,97
29,79	30,80	89,98
29,80	30,81	90,00
29,81	30,82	90,01
29,82	30,83	90,03
29,83	30,84	90,04
29,84	30,85	90,06
29,85	30,86	90,07
29,86	30,87	90,09
29,87	30,88	90,10
29,88	30,89	90,12
29,89	30,90	90,13
29,90	30,91	90,15
29,91	30,92	90,16
29,92	30,93	90,18
29,93	30,94	90,19
29,94	30,95	90,21
29,95	30,96	90,22
29,96	30,97	90,24
29,97	30,98	90,25
29,98	30,99	90,27
29,99	31,00	90,28
30,00	31,01	90,29
30,01	31,02	90,31
30,02	31,03	90,32
30,03	31,04	90,34
30,04	31,05	90,35
30,05	31,06	90,37
30,06	31,07	90,38
30,07	31,08	90,40
30,08	31,09	90,41



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,09	31,10	90,43
30,10	31,11	90,44
30,11	31,12	90,46
30,12	31,13	90,47
30,13	31,14	90,49
30,14	31,15	90,50
30,15	31,16	90,52
30,16	31,17	90,53
30,17	31,18	90,54
30,18	31,19	90,56
30,19	31,20	90,57
30,20	31,21	90,59
30,21	31,22	90,60
30,22	31,23	90,62
30,23	31,24	90,63
30,24	31,25	90,65
30,25	31,26	90,66
30,26	31,27	90,68
30,27	31,28	90,69
30,28	31,29	90,71
30,29	31,30	90,72
30,30	31,31	90,74
30,31	31,32	90,75
30,32	31,33	90,76
30,33	31,34	90,78
30,34	31,35	90,79
30,35	31,36	90,81
30,36	31,37	90,82
30,37	31,38	90,84
30,38	31,39	90,85
30,39	31,40	90,87
30,40	31,41	90,88
30,41	31,42	90,90
30,42	31,43	90,91
30,43	31,44	90,93
30,44	31,45	90,94
30,45	31,46	90,95
30,46	31,47	90,97
30,47	31,48	90,98
30,48	31,49	91,00
30,49	31,50	91,01
30,50	31,51	91,03
30,51	31,52	91,04
30,52	31,53	91,06



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	91,07
30,54	31,55	91,09
30,55	31,56	91,10
30,56	31,57	91,11
30,57	31,58	91,13
30,58	31,59	91,14
30,59	31,60	91,16
30,60	31,61	91,17
30,61	31,62	91,19
30,62	31,63	91,20
30,63	31,64	91,22
30,64	31,65	91,23
30,65	31,66	91,24
30,66	31,67	91,26
30,67	31,68	91,27
30,68	31,69	91,29
30,69	31,70	91,30
30,70	31,71	91,32
30,71	31,72	91,33
30,72	31,73	91,35
30,73	31,74	91,36
30,74	31,75	91,37
30,75	31,76	91,39
30,76	31,77	91,40
30,77	31,78	91,42
30,78	31,79	91,43
30,79	31,80	91,45
30,80	31,81	91,46
30,81	31,82	91,48
30,82	31,83	91,49
30,83	31,84	91,50
30,84	31,85	91,52
30,85	31,86	91,53
30,86	31,87	91,55
30,87	31,88	91,56
30,88	31,89	91,58
30,89	31,90	91,59
30,90	31,91	91,60
30,91	31,92	91,62
30,92	31,93	91,63
30,93	31,94	91,65
30,94	31,95	91,66
30,95	31,96	91,68
30,96	31,97	91,69



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
30,97	31,98	91,71
30,98	31,99	91,72
30,99	32,00	91,73
31,00	32,01	91,75
31,01	32,02	91,76
31,02	32,03	91,78
31,03	32,04	91,79
31,04	32,05	91,81
31,05	32,06	91,82
31,06	32,07	91,83
31,07	32,08	91,85
31,08	32,09	91,86
31,09	32,10	91,88
31,10	32,11	91,89
31,11	32,12	91,91
31,12	32,13	91,92
31,13	32,14	91,93
31,14	32,15	91,95
31,15	32,16	91,96
31,16	32,17	91,98
31,17	32,18	91,99
31,18	32,19	92,00
31,19	32,20	92,02
31,20	32,21	92,03
31,21	32,22	92,05
31,22	32,23	92,06
31,23	32,24	92,08
31,24	32,25	92,09
31,25	32,26	92,10
31,26	32,27	92,12
31,27	32,28	92,13
31,28	32,29	92,15
31,29	32,30	92,16
31,30	32,31	92,18
31,31	32,32	92,19
31,32	32,33	92,20
31,33	32,34	92,22
31,34	32,35	92,23
31,35	32,36	92,25
31,36	32,37	92,26
31,37	32,38	92,27
31,38	32,39	92,29
31,39	32,40	92,30
31,40	32,41	92,32



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
31,41	32,42	92,33
31,42	32,43	92,35
31,43	32,44	92,36
31,44	32,45	92,37
31,45	32,46	92,39
31,46	32,47	92,40
31,47	32,48	92,42
31,48	32,49	92,43
31,49	32,50	92,44
31,50	32,51	92,46
31,51	32,52	92,47
31,52	32,53	92,49
31,53	32,54	92,50
31,54	32,55	92,51
31,55	32,56	92,53
31,56	32,57	92,54
31,57	32,58	92,56
31,58	32,59	92,57
31,59	32,60	92,58
31,60	32,61	92,60
31,61	32,62	92,61
31,62	32,63	92,63
31,63	32,64	92,64
31,64	32,65	92,65
31,65	32,66	92,67
31,66	32,67	92,68
31,67	32,68	92,70
31,68	32,69	92,71
31,69	32,70	92,72
31,70	32,71	92,74
31,71	32,72	92,75
31,72	32,73	92,77
31,73	32,74	92,78
31,74	32,75	92,79
31,75	32,76	92,81
31,76	32,77	92,82
31,77	32,78	92,84
31,78	32,79	92,85
31,79	32,80	92,86
31,80	32,81	92,88
31,81	32,82	92,89
31,82	32,83	92,91
31,83	32,84	92,92
31,84	32,85	92,93



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	92,95
31,86	32,87	92,96
31,87	32,88	92,98
31,88	32,89	92,99
31,89	32,90	93,00
31,90	32,91	93,02
31,91	32,92	93,03
31,92	32,93	93,05
31,93	32,94	93,06
31,94	32,95	93,07
31,95	32,96	93,09
31,96	32,97	93,10
31,97	32,98	93,11
31,98	32,99	93,13
31,99	33,00	93,14
32,00	33,01	93,16
32,01	33,02	93,17
32,02	33,03	93,18
32,03	33,04	93,20
32,04	33,05	93,21
32,05	33,06	93,23
32,06	33,07	93,24
32,07	33,08	93,25
32,08	33,09	93,27
32,09	33,10	93,28
32,10	33,11	93,29
32,11	33,12	93,31
32,12	33,13	93,32
32,13	33,14	93,34
32,14	33,15	93,35
32,15	33,16	93,36
32,16	33,17	93,38
32,17	33,18	93,39
32,18	33,19	93,40
32,19	33,20	93,42
32,20	33,21	93,43
32,21	33,22	93,45
32,22	33,23	93,46
32,23	33,24	93,47
32,24	33,25	93,49
32,25	33,26	93,50
32,26	33,27	93,52
32,27	33,28	93,53
32,28	33,29	93,54



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	93,56
32,30	33,31	93,57
32,31	33,32	93,58
32,32	33,33	93,60
32,33	33,34	93,61
32,34	33,35	93,62
32,35	33,36	93,64
32,36	33,37	93,65
32,37	33,38	93,67
32,38	33,39	93,68
32,39	33,40	93,69
32,40	33,41	93,71
32,41	33,42	93,72
32,42	33,43	93,73
32,43	33,44	93,75
32,44	33,45	93,76
32,45	33,46	93,78
32,46	33,47	93,79
32,47	33,48	93,80
32,48	33,49	93,82
32,49	33,50	93,83
32,50	33,51	93,84
32,51	33,52	93,86
32,52	33,53	93,87
32,53	33,54	93,88
32,54	33,55	93,90
32,55	33,56	93,91
32,56	33,57	93,93
32,57	33,58	93,94
32,58	33,59	93,95
32,59	33,60	93,97
32,60	33,61	93,98
32,61	33,62	93,99
32,62	33,63	94,01
32,63	33,64	94,02
32,64	33,65	94,03
32,65	33,66	94,05
32,66	33,67	94,06
32,67	33,68	94,07
32,68	33,69	94,09
32,69	33,70	94,10
32,70	33,71	94,12
32,71	33,72	94,13
32,72	33,73	94,14



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
32,73	33,74	94,16
32,74	33,75	94,17
32,75	33,76	94,18
32,76	33,77	94,20
32,77	33,78	94,21
32,78	33,79	94,22
32,79	33,80	94,24
32,80	33,81	94,25
32,81	33,82	94,26
32,82	33,83	94,28
32,83	33,84	94,29
32,84	33,85	94,30
32,85	33,86	94,32
32,86	33,87	94,33
32,87	33,88	94,34
32,88	33,89	94,36
32,89	33,90	94,37
32,90	33,91	94,39
32,91	33,92	94,40
32,92	33,93	94,41
32,93	33,94	94,43
32,94	33,95	94,44
32,95	33,96	94,45
32,96	33,97	94,47
32,97	33,98	94,48
32,98	33,99	94,49
32,99	34,00	94,51
33,00	34,01	94,52
33,01	34,02	94,53
33,02	34,03	94,55
33,03	34,04	94,56
33,04	34,05	94,57
33,05	34,06	94,59
33,06	34,07	94,60
33,07	34,08	94,61
33,08	34,09	94,63
33,09	34,10	94,64
33,10	34,11	94,65
33,11	34,12	94,67
33,12	34,13	94,68
33,13	34,14	94,69
33,14	34,15	94,71
33,15	34,16	94,72
33,16	34,17	94,73



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,17	34,18	94,75
33,18	34,19	94,76
33,19	34,20	94,77
33,20	34,21	94,79
33,21	34,22	94,80
33,22	34,23	94,81
33,23	34,24	94,83
33,24	34,25	94,84
33,25	34,26	94,85
33,26	34,27	94,87
33,27	34,28	94,88
33,28	34,29	94,89
33,29	34,30	94,91
33,30	34,31	94,92
33,31	34,32	94,93
33,32	34,33	94,95
33,33	34,34	94,96
33,34	34,35	94,97
33,35	34,36	94,99
33,36	34,37	95,00
33,37	34,38	95,01
33,38	34,39	95,03
33,39	34,40	95,04
33,40	34,41	95,05
33,41	34,42	95,07
33,42	34,43	95,08
33,43	34,44	95,09
33,44	34,45	95,11
33,45	34,46	95,12
33,46	34,47	95,13
33,47	34,48	95,15
33,48	34,49	95,16
33,49	34,50	95,17
33,50	34,51	95,18
33,51	34,52	95,20
33,52	34,53	95,21
33,53	34,54	95,22
33,54	34,55	95,24
33,55	34,56	95,25
33,56	34,57	95,26
33,57	34,58	95,28
33,58	34,59	95,29
33,59	34,60	95,30
33,60	34,61	95,32



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
33,61	34,62	95,33
33,62	34,63	95,34
33,63	34,64	95,36
33,64	34,65	95,37
33,65	34,66	95,38
33,66	34,67	95,40
33,67	34,68	95,41
33,68	34,69	95,42
33,69	34,70	95,43
33,70	34,71	95,45
33,71	34,72	95,46
33,72	34,73	95,47
33,73	34,74	95,49
33,74	34,75	95,50
33,75	34,76	95,51
33,76	34,77	95,53
33,77	34,78	95,54
33,78	34,79	95,55
33,79	34,80	95,57
33,80	34,81	95,58
33,81	34,82	95,59
33,82	34,83	95,60
33,83	34,84	95,62
33,84	34,85	95,63
33,85	34,86	95,64
33,86	34,87	95,66
33,87	34,88	95,67
33,88	34,89	95,68
33,89	34,90	95,70
33,90	34,91	95,71
33,91	34,92	95,72
33,92	34,93	95,74
33,93	34,94	95,75
33,94	34,95	95,76
33,95	34,96	95,77
33,96	34,97	95,79
33,97	34,98	95,80
33,98	34,99	95,81
33,99	35,00	95,83
34,00	35,01	95,84
34,01	35,02	95,85
34,02	35,03	95,86
34,03	35,04	95,88
34,04	35,05	95,89



R445A		
V1.0_R445A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,05	35,06	95,90
34,06	35,07	95,92
34,07	35,08	95,93
34,08	35,09	95,94
34,09	35,10	95,96
34,10	35,11	95,97
34,11	35,12	95,98
34,12	35,13	95,99
34,13	35,14	96,01
34,14	35,15	96,02
34,15	35,16	96,03