



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-54,90
-0,70	0,31	-54,36
-0,69	0,32	-53,83
-0,68	0,33	-53,32
-0,67	0,34	-52,81
-0,66	0,35	-52,32
-0,65	0,36	-51,84
-0,64	0,37	-51,37
-0,63	0,38	-50,91
-0,62	0,39	-50,46
-0,61	0,40	-50,02
-0,60	0,41	-49,59
-0,59	0,42	-49,17
-0,58	0,43	-48,76
-0,57	0,44	-48,35
-0,56	0,45	-47,95
-0,55	0,46	-47,56
-0,54	0,47	-47,17
-0,53	0,48	-46,79
-0,52	0,49	-46,42
-0,51	0,50	-46,05
-0,50	0,51	-45,69
-0,49	0,52	-45,34
-0,48	0,53	-44,99
-0,47	0,54	-44,64
-0,46	0,55	-44,30
-0,45	0,56	-43,97
-0,44	0,57	-43,64
-0,43	0,58	-43,32
-0,42	0,59	-43,00
-0,41	0,60	-42,68
-0,40	0,61	-42,37
-0,39	0,62	-42,06
-0,38	0,63	-41,76
-0,37	0,64	-41,46
-0,36	0,65	-41,16
-0,35	0,66	-40,87
-0,34	0,67	-40,58
-0,33	0,68	-40,29
-0,32	0,69	-40,01
-0,31	0,70	-39,73
-0,30	0,71	-39,46
-0,29	0,72	-39,18
-0,28	0,73	-38,91



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-38,65
-0,26	0,75	-38,38
-0,25	0,76	-38,12
-0,24	0,77	-37,86
-0,23	0,78	-37,61
-0,22	0,79	-37,35
-0,21	0,80	-37,10
-0,20	0,81	-36,85
-0,19	0,82	-36,61
-0,18	0,83	-36,37
-0,17	0,84	-36,12
-0,16	0,85	-35,89
-0,15	0,86	-35,65
-0,14	0,87	-35,41
-0,13	0,88	-35,18
-0,12	0,89	-34,95
-0,11	0,90	-34,72
-0,10	0,91	-34,50
-0,09	0,92	-34,27
-0,08	0,93	-34,05
-0,07	0,94	-33,83
-0,06	0,95	-33,61
-0,05	0,96	-33,40
-0,04	0,97	-33,18
-0,03	0,98	-32,97
-0,02	0,99	-32,76
-0,01	1,00	-32,55
0,00	1,01	-32,34
0,01	1,02	-32,13
0,02	1,03	-31,93
0,03	1,04	-31,73
0,04	1,05	-31,52
0,05	1,06	-31,32
0,06	1,07	-31,13
0,07	1,08	-30,93
0,08	1,09	-30,73
0,09	1,10	-30,54
0,10	1,11	-30,34
0,11	1,12	-30,15
0,12	1,13	-29,96
0,13	1,14	-29,77
0,14	1,15	-29,59
0,15	1,16	-29,40
0,16	1,17	-29,22



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,17	1,18	-29,03
0,18	1,19	-28,85
0,19	1,20	-28,67
0,20	1,21	-28,49
0,21	1,22	-28,31
0,22	1,23	-28,13
0,23	1,24	-27,95
0,24	1,25	-27,78
0,25	1,26	-27,60
0,26	1,27	-27,43
0,27	1,28	-27,26
0,28	1,29	-27,09
0,29	1,30	-26,92
0,30	1,31	-26,75
0,31	1,32	-26,58
0,32	1,33	-26,41
0,33	1,34	-26,25
0,34	1,35	-26,08
0,35	1,36	-25,92
0,36	1,37	-25,75
0,37	1,38	-25,59
0,38	1,39	-25,43
0,39	1,40	-25,27
0,40	1,41	-25,11
0,41	1,42	-24,95
0,42	1,43	-24,79
0,43	1,44	-24,64
0,44	1,45	-24,48
0,45	1,46	-24,32
0,46	1,47	-24,17
0,47	1,48	-24,02
0,48	1,49	-23,86
0,49	1,50	-23,71
0,50	1,51	-23,56
0,51	1,52	-23,41
0,52	1,53	-23,26
0,53	1,54	-23,11
0,54	1,55	-22,96
0,55	1,56	-22,82
0,56	1,57	-22,67
0,57	1,58	-22,52
0,58	1,59	-22,38
0,59	1,60	-22,23
0,60	1,61	-22,09



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
0,61	1,62	-21,95
0,62	1,63	-21,80
0,63	1,64	-21,66
0,64	1,65	-21,52
0,65	1,66	-21,38
0,66	1,67	-21,24
0,67	1,68	-21,10
0,68	1,69	-20,96
0,69	1,70	-20,83
0,70	1,71	-20,69
0,71	1,72	-20,55
0,72	1,73	-20,42
0,73	1,74	-20,28
0,74	1,75	-20,15
0,75	1,76	-20,01
0,76	1,77	-19,88
0,77	1,78	-19,75
0,78	1,79	-19,61
0,79	1,80	-19,48
0,80	1,81	-19,35
0,81	1,82	-19,22
0,82	1,83	-19,09
0,83	1,84	-18,96
0,84	1,85	-18,83
0,85	1,86	-18,70
0,86	1,87	-18,58
0,87	1,88	-18,45
0,88	1,89	-18,32
0,89	1,90	-18,19
0,90	1,91	-18,07
0,91	1,92	-17,94
0,92	1,93	-17,82
0,93	1,94	-17,69
0,94	1,95	-17,57
0,95	1,96	-17,45
0,96	1,97	-17,33
0,97	1,98	-17,20
0,98	1,99	-17,08
0,99	2,00	-16,96
1,00	2,01	-16,84
1,01	2,02	-16,72
1,02	2,03	-16,60
1,03	2,04	-16,48
1,04	2,05	-16,36



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	-16,24
1,06	2,07	-16,12
1,07	2,08	-16,01
1,08	2,09	-15,89
1,09	2,10	-15,77
1,10	2,11	-15,66
1,11	2,12	-15,54
1,12	2,13	-15,42
1,13	2,14	-15,31
1,14	2,15	-15,19
1,15	2,16	-15,08
1,16	2,17	-14,97
1,17	2,18	-14,85
1,18	2,19	-14,74
1,19	2,20	-14,63
1,20	2,21	-14,52
1,21	2,22	-14,40
1,22	2,23	-14,29
1,23	2,24	-14,18
1,24	2,25	-14,07
1,25	2,26	-13,96
1,26	2,27	-13,85
1,27	2,28	-13,74
1,28	2,29	-13,63
1,29	2,30	-13,52
1,30	2,31	-13,41
1,31	2,32	-13,31
1,32	2,33	-13,20
1,33	2,34	-13,09
1,34	2,35	-12,98
1,35	2,36	-12,88
1,36	2,37	-12,77
1,37	2,38	-12,67
1,38	2,39	-12,56
1,39	2,40	-12,46
1,40	2,41	-12,35
1,41	2,42	-12,25
1,42	2,43	-12,14
1,43	2,44	-12,04
1,44	2,45	-11,93
1,45	2,46	-11,83
1,46	2,47	-11,73
1,47	2,48	-11,63
1,48	2,49	-11,52



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,49	2,50	-11,42
1,50	2,51	-11,32
1,51	2,52	-11,22
1,52	2,53	-11,12
1,53	2,54	-11,02
1,54	2,55	-10,92
1,55	2,56	-10,82
1,56	2,57	-10,72
1,57	2,58	-10,62
1,58	2,59	-10,52
1,59	2,60	-10,42
1,60	2,61	-10,32
1,61	2,62	-10,22
1,62	2,63	-10,12
1,63	2,64	-10,03
1,64	2,65	-9,93
1,65	2,66	-9,83
1,66	2,67	-9,74
1,67	2,68	-9,64
1,68	2,69	-9,54
1,69	2,70	-9,45
1,70	2,71	-9,35
1,71	2,72	-9,25
1,72	2,73	-9,16
1,73	2,74	-9,06
1,74	2,75	-8,97
1,75	2,76	-8,88
1,76	2,77	-8,78
1,77	2,78	-8,69
1,78	2,79	-8,59
1,79	2,80	-8,50
1,80	2,81	-8,41
1,81	2,82	-8,31
1,82	2,83	-8,22
1,83	2,84	-8,13
1,84	2,85	-8,04
1,85	2,86	-7,95
1,86	2,87	-7,85
1,87	2,88	-7,76
1,88	2,89	-7,67
1,89	2,90	-7,58
1,90	2,91	-7,49
1,91	2,92	-7,40
1,92	2,93	-7,31



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,93	2,94	-7,22
1,94	2,95	-7,13
1,95	2,96	-7,04
1,96	2,97	-6,95
1,97	2,98	-6,86
1,98	2,99	-6,77
1,99	3,00	-6,69
2,00	3,01	-6,60
2,01	3,02	-6,51
2,02	3,03	-6,42
2,03	3,04	-6,33
2,04	3,05	-6,25
2,05	3,06	-6,16
2,06	3,07	-6,07
2,07	3,08	-5,99
2,08	3,09	-5,90
2,09	3,10	-5,81
2,10	3,11	-5,73
2,11	3,12	-5,64
2,12	3,13	-5,56
2,13	3,14	-5,47
2,14	3,15	-5,38
2,15	3,16	-5,30
2,16	3,17	-5,22
2,17	3,18	-5,13
2,18	3,19	-5,05
2,19	3,20	-4,96
2,20	3,21	-4,88
2,21	3,22	-4,79
2,22	3,23	-4,71
2,23	3,24	-4,63
2,24	3,25	-4,54
2,25	3,26	-4,46
2,26	3,27	-4,38
2,27	3,28	-4,30
2,28	3,29	-4,21
2,29	3,30	-4,13
2,30	3,31	-4,05
2,31	3,32	-3,97
2,32	3,33	-3,89
2,33	3,34	-3,80
2,34	3,35	-3,72
2,35	3,36	-3,64
2,36	3,37	-3,56



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	-3,48
2,38	3,39	-3,40
2,39	3,40	-3,32
2,40	3,41	-3,24
2,41	3,42	-3,16
2,42	3,43	-3,08
2,43	3,44	-3,00
2,44	3,45	-2,92
2,45	3,46	-2,84
2,46	3,47	-2,76
2,47	3,48	-2,68
2,48	3,49	-2,60
2,49	3,50	-2,53
2,50	3,51	-2,45
2,51	3,52	-2,37
2,52	3,53	-2,29
2,53	3,54	-2,21
2,54	3,55	-2,14
2,55	3,56	-2,06
2,56	3,57	-1,98
2,57	3,58	-1,90
2,58	3,59	-1,83
2,59	3,60	-1,75
2,60	3,61	-1,67
2,61	3,62	-1,60
2,62	3,63	-1,52
2,63	3,64	-1,44
2,64	3,65	-1,37
2,65	3,66	-1,29
2,66	3,67	-1,22
2,67	3,68	-1,14
2,68	3,69	-1,06
2,69	3,70	-0,99
2,70	3,71	-0,91
2,71	3,72	-0,84
2,72	3,73	-0,76
2,73	3,74	-0,69
2,74	3,75	-0,62
2,75	3,76	-0,54
2,76	3,77	-0,47
2,77	3,78	-0,39
2,78	3,79	-0,32
2,79	3,80	-0,25
2,80	3,81	-0,17



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,81	3,82	-0,10
2,82	3,83	-0,02
2,83	3,84	0,05
2,84	3,85	0,12
2,85	3,86	0,19
2,86	3,87	0,27
2,87	3,88	0,34
2,88	3,89	0,41
2,89	3,90	0,48
2,90	3,91	0,56
2,91	3,92	0,63
2,92	3,93	0,70
2,93	3,94	0,77
2,94	3,95	0,84
2,95	3,96	0,91
2,96	3,97	0,99
2,97	3,98	1,06
2,98	3,99	1,13
2,99	4,00	1,20
3,00	4,01	1,27
3,01	4,02	1,34
3,02	4,03	1,41
3,03	4,04	1,48
3,04	4,05	1,55
3,05	4,06	1,62
3,06	4,07	1,69
3,07	4,08	1,76
3,08	4,09	1,83
3,09	4,10	1,90
3,10	4,11	1,97
3,11	4,12	2,04
3,12	4,13	2,11
3,13	4,14	2,18
3,14	4,15	2,25
3,15	4,16	2,32
3,16	4,17	2,38
3,17	4,18	2,45
3,18	4,19	2,52
3,19	4,20	2,59
3,20	4,21	2,66
3,21	4,22	2,73
3,22	4,23	2,79
3,23	4,24	2,86
3,24	4,25	2,93



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,25	4,26	3,00
3,26	4,27	3,06
3,27	4,28	3,13
3,28	4,29	3,20
3,29	4,30	3,27
3,30	4,31	3,33
3,31	4,32	3,40
3,32	4,33	3,47
3,33	4,34	3,53
3,34	4,35	3,60
3,35	4,36	3,67
3,36	4,37	3,73
3,37	4,38	3,80
3,38	4,39	3,86
3,39	4,40	3,93
3,40	4,41	4,00
3,41	4,42	4,06
3,42	4,43	4,13
3,43	4,44	4,19
3,44	4,45	4,26
3,45	4,46	4,32
3,46	4,47	4,39
3,47	4,48	4,45
3,48	4,49	4,52
3,49	4,50	4,58
3,50	4,51	4,65
3,51	4,52	4,71
3,52	4,53	4,78
3,53	4,54	4,84
3,54	4,55	4,90
3,55	4,56	4,97
3,56	4,57	5,03
3,57	4,58	5,10
3,58	4,59	5,16
3,59	4,60	5,22
3,60	4,61	5,29
3,61	4,62	5,35
3,62	4,63	5,41
3,63	4,64	5,48
3,64	4,65	5,54
3,65	4,66	5,60
3,66	4,67	5,67
3,67	4,68	5,73
3,68	4,69	5,79



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
3,69	4,70	5,85
3,70	4,71	5,92
3,71	4,72	5,98
3,72	4,73	6,04
3,73	4,74	6,10
3,74	4,75	6,17
3,75	4,76	6,23
3,76	4,77	6,29
3,77	4,78	6,35
3,78	4,79	6,41
3,79	4,80	6,48
3,80	4,81	6,54
3,81	4,82	6,60
3,82	4,83	6,66
3,83	4,84	6,72
3,84	4,85	6,78
3,85	4,86	6,84
3,86	4,87	6,90
3,87	4,88	6,97
3,88	4,89	7,03
3,89	4,90	7,09
3,90	4,91	7,15
3,91	4,92	7,21
3,92	4,93	7,27
3,93	4,94	7,33
3,94	4,95	7,39
3,95	4,96	7,45
3,96	4,97	7,51
3,97	4,98	7,57
3,98	4,99	7,63
3,99	5,00	7,69
4,00	5,01	7,75
4,01	5,02	7,81
4,02	5,03	7,87
4,03	5,04	7,93
4,04	5,05	7,99
4,05	5,06	8,05
4,06	5,07	8,10
4,07	5,08	8,16
4,08	5,09	8,22
4,09	5,10	8,28
4,10	5,11	8,34
4,11	5,12	8,40
4,12	5,13	8,46



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	8,52
4,14	5,15	8,57
4,15	5,16	8,63
4,16	5,17	8,69
4,17	5,18	8,75
4,18	5,19	8,81
4,19	5,20	8,86
4,20	5,21	8,92
4,21	5,22	8,98
4,22	5,23	9,04
4,23	5,24	9,10
4,24	5,25	9,15
4,25	5,26	9,21
4,26	5,27	9,27
4,27	5,28	9,33
4,28	5,29	9,38
4,29	5,30	9,44
4,30	5,31	9,50
4,31	5,32	9,55
4,32	5,33	9,61
4,33	5,34	9,67
4,34	5,35	9,72
4,35	5,36	9,78
4,36	5,37	9,84
4,37	5,38	9,89
4,38	5,39	9,95
4,39	5,40	10,01
4,40	5,41	10,06
4,41	5,42	10,12
4,42	5,43	10,18
4,43	5,44	10,23
4,44	5,45	10,29
4,45	5,46	10,34
4,46	5,47	10,40
4,47	5,48	10,45
4,48	5,49	10,51
4,49	5,50	10,57
4,50	5,51	10,62
4,51	5,52	10,68
4,52	5,53	10,73
4,53	5,54	10,79
4,54	5,55	10,84
4,55	5,56	10,90
4,56	5,57	10,95



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	11,01
4,58	5,59	11,06
4,59	5,60	11,12
4,60	5,61	11,17
4,61	5,62	11,23
4,62	5,63	11,28
4,63	5,64	11,34
4,64	5,65	11,39
4,65	5,66	11,44
4,66	5,67	11,50
4,67	5,68	11,55
4,68	5,69	11,61
4,69	5,70	11,66
4,70	5,71	11,71
4,71	5,72	11,77
4,72	5,73	11,82
4,73	5,74	11,88
4,74	5,75	11,93
4,75	5,76	11,98
4,76	5,77	12,04
4,77	5,78	12,09
4,78	5,79	12,14
4,79	5,80	12,20
4,80	5,81	12,25
4,81	5,82	12,30
4,82	5,83	12,36
4,83	5,84	12,41
4,84	5,85	12,46
4,85	5,86	12,52
4,86	5,87	12,57
4,87	5,88	12,62
4,88	5,89	12,67
4,89	5,90	12,73
4,90	5,91	12,78
4,91	5,92	12,83
4,92	5,93	12,88
4,93	5,94	12,94
4,94	5,95	12,99
4,95	5,96	13,04
4,96	5,97	13,09
4,97	5,98	13,15
4,98	5,99	13,20
4,99	6,00	13,25
5,00	6,01	13,30



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	13,35
5,02	6,03	13,41
5,03	6,04	13,46
5,04	6,05	13,51
5,05	6,06	13,56
5,06	6,07	13,61
5,07	6,08	13,66
5,08	6,09	13,71
5,09	6,10	13,77
5,10	6,11	13,82
5,11	6,12	13,87
5,12	6,13	13,92
5,13	6,14	13,97
5,14	6,15	14,02
5,15	6,16	14,07
5,16	6,17	14,12
5,17	6,18	14,17
5,18	6,19	14,23
5,19	6,20	14,28
5,20	6,21	14,33
5,21	6,22	14,38
5,22	6,23	14,43
5,23	6,24	14,48
5,24	6,25	14,53
5,25	6,26	14,58
5,26	6,27	14,63
5,27	6,28	14,68
5,28	6,29	14,73
5,29	6,30	14,78
5,30	6,31	14,83
5,31	6,32	14,88
5,32	6,33	14,93
5,33	6,34	14,98
5,34	6,35	15,03
5,35	6,36	15,08
5,36	6,37	15,13
5,37	6,38	15,18
5,38	6,39	15,23
5,39	6,40	15,28
5,40	6,41	15,33
5,41	6,42	15,38
5,42	6,43	15,42
5,43	6,44	15,47
5,44	6,45	15,52



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,45	6,46	15,57
5,46	6,47	15,62
5,47	6,48	15,67
5,48	6,49	15,72
5,49	6,50	15,77
5,50	6,51	15,82
5,51	6,52	15,87
5,52	6,53	15,91
5,53	6,54	15,96
5,54	6,55	16,01
5,55	6,56	16,06
5,56	6,57	16,11
5,57	6,58	16,16
5,58	6,59	16,21
5,59	6,60	16,25
5,60	6,61	16,30
5,61	6,62	16,35
5,62	6,63	16,40
5,63	6,64	16,45
5,64	6,65	16,50
5,65	6,66	16,54
5,66	6,67	16,59
5,67	6,68	16,64
5,68	6,69	16,69
5,69	6,70	16,73
5,70	6,71	16,78
5,71	6,72	16,83
5,72	6,73	16,88
5,73	6,74	16,93
5,74	6,75	16,97
5,75	6,76	17,02
5,76	6,77	17,07
5,77	6,78	17,11
5,78	6,79	17,16
5,79	6,80	17,21
5,80	6,81	17,26
5,81	6,82	17,30
5,82	6,83	17,35
5,83	6,84	17,40
5,84	6,85	17,45
5,85	6,86	17,49
5,86	6,87	17,54
5,87	6,88	17,59
5,88	6,89	17,63



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	17,68
5,90	6,91	17,73
5,91	6,92	17,77
5,92	6,93	17,82
5,93	6,94	17,87
5,94	6,95	17,91
5,95	6,96	17,96
5,96	6,97	18,00
5,97	6,98	18,05
5,98	6,99	18,10
5,99	7,00	18,14
6,00	7,01	18,19
6,01	7,02	18,24
6,02	7,03	18,28
6,03	7,04	18,33
6,04	7,05	18,37
6,05	7,06	18,42
6,06	7,07	18,47
6,07	7,08	18,51
6,08	7,09	18,56
6,09	7,10	18,60
6,10	7,11	18,65
6,11	7,12	18,69
6,12	7,13	18,74
6,13	7,14	18,79
6,14	7,15	18,83
6,15	7,16	18,88
6,16	7,17	18,92
6,17	7,18	18,97
6,18	7,19	19,01
6,19	7,20	19,06
6,20	7,21	19,10
6,21	7,22	19,15
6,22	7,23	19,19
6,23	7,24	19,24
6,24	7,25	19,28
6,25	7,26	19,33
6,26	7,27	19,37
6,27	7,28	19,42
6,28	7,29	19,46
6,29	7,30	19,51
6,30	7,31	19,55
6,31	7,32	19,60
6,32	7,33	19,64



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,33	7,34	19,69
6,34	7,35	19,73
6,35	7,36	19,78
6,36	7,37	19,82
6,37	7,38	19,86
6,38	7,39	19,91
6,39	7,40	19,95
6,40	7,41	20,00
6,41	7,42	20,04
6,42	7,43	20,09
6,43	7,44	20,13
6,44	7,45	20,17
6,45	7,46	20,22
6,46	7,47	20,26
6,47	7,48	20,31
6,48	7,49	20,35
6,49	7,50	20,39
6,50	7,51	20,44
6,51	7,52	20,48
6,52	7,53	20,52
6,53	7,54	20,57
6,54	7,55	20,61
6,55	7,56	20,66
6,56	7,57	20,70
6,57	7,58	20,74
6,58	7,59	20,79
6,59	7,60	20,83
6,60	7,61	20,87
6,61	7,62	20,92
6,62	7,63	20,96
6,63	7,64	21,00
6,64	7,65	21,05
6,65	7,66	21,09
6,66	7,67	21,13
6,67	7,68	21,18
6,68	7,69	21,22
6,69	7,70	21,26
6,70	7,71	21,30
6,71	7,72	21,35
6,72	7,73	21,39
6,73	7,74	21,43
6,74	7,75	21,48
6,75	7,76	21,52
6,76	7,77	21,56



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,77	7,78	21,60
6,78	7,79	21,65
6,79	7,80	21,69
6,80	7,81	21,73
6,81	7,82	21,77
6,82	7,83	21,82
6,83	7,84	21,86
6,84	7,85	21,90
6,85	7,86	21,94
6,86	7,87	21,99
6,87	7,88	22,03
6,88	7,89	22,07
6,89	7,90	22,11
6,90	7,91	22,15
6,91	7,92	22,20
6,92	7,93	22,24
6,93	7,94	22,28
6,94	7,95	22,32
6,95	7,96	22,36
6,96	7,97	22,41
6,97	7,98	22,45
6,98	7,99	22,49
6,99	8,00	22,53
7,00	8,01	22,57
7,01	8,02	22,61
7,02	8,03	22,66
7,03	8,04	22,70
7,04	8,05	22,74
7,05	8,06	22,78
7,06	8,07	22,82
7,07	8,08	22,86
7,08	8,09	22,91
7,09	8,10	22,95
7,10	8,11	22,99
7,11	8,12	23,03
7,12	8,13	23,07
7,13	8,14	23,11
7,14	8,15	23,15
7,15	8,16	23,19
7,16	8,17	23,24
7,17	8,18	23,28
7,18	8,19	23,32
7,19	8,20	23,36
7,20	8,21	23,40



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	23,44
7,22	8,23	23,48
7,23	8,24	23,52
7,24	8,25	23,56
7,25	8,26	23,60
7,26	8,27	23,64
7,27	8,28	23,68
7,28	8,29	23,73
7,29	8,30	23,77
7,30	8,31	23,81
7,31	8,32	23,85
7,32	8,33	23,89
7,33	8,34	23,93
7,34	8,35	23,97
7,35	8,36	24,01
7,36	8,37	24,05
7,37	8,38	24,09
7,38	8,39	24,13
7,39	8,40	24,17
7,40	8,41	24,21
7,41	8,42	24,25
7,42	8,43	24,29
7,43	8,44	24,33
7,44	8,45	24,37
7,45	8,46	24,41
7,46	8,47	24,45
7,47	8,48	24,49
7,48	8,49	24,53
7,49	8,50	24,57
7,50	8,51	24,61
7,51	8,52	24,65
7,52	8,53	24,69
7,53	8,54	24,73
7,54	8,55	24,77
7,55	8,56	24,81
7,56	8,57	24,85
7,57	8,58	24,89
7,58	8,59	24,93
7,59	8,60	24,97
7,60	8,61	25,01
7,61	8,62	25,05
7,62	8,63	25,09
7,63	8,64	25,12
7,64	8,65	25,16



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
7,65	8,66	25,20
7,66	8,67	25,24
7,67	8,68	25,28
7,68	8,69	25,32
7,69	8,70	25,36
7,70	8,71	25,40
7,71	8,72	25,44
7,72	8,73	25,48
7,73	8,74	25,52
7,74	8,75	25,56
7,75	8,76	25,59
7,76	8,77	25,63
7,77	8,78	25,67
7,78	8,79	25,71
7,79	8,80	25,75
7,80	8,81	25,79
7,81	8,82	25,83
7,82	8,83	25,87
7,83	8,84	25,91
7,84	8,85	25,94
7,85	8,86	25,98
7,86	8,87	26,02
7,87	8,88	26,06
7,88	8,89	26,10
7,89	8,90	26,14
7,90	8,91	26,18
7,91	8,92	26,21
7,92	8,93	26,25
7,93	8,94	26,29
7,94	8,95	26,33
7,95	8,96	26,37
7,96	8,97	26,41
7,97	8,98	26,44
7,98	8,99	26,48
7,99	9,00	26,52
8,00	9,01	26,56
8,01	9,02	26,60
8,02	9,03	26,63
8,03	9,04	26,67
8,04	9,05	26,71
8,05	9,06	26,75
8,06	9,07	26,79
8,07	9,08	26,82
8,08	9,09	26,86



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,09	9,10	26,90
8,10	9,11	26,94
8,11	9,12	26,98
8,12	9,13	27,01
8,13	9,14	27,05
8,14	9,15	27,09
8,15	9,16	27,13
8,16	9,17	27,16
8,17	9,18	27,20
8,18	9,19	27,24
8,19	9,20	27,28
8,20	9,21	27,31
8,21	9,22	27,35
8,22	9,23	27,39
8,23	9,24	27,43
8,24	9,25	27,46
8,25	9,26	27,50
8,26	9,27	27,54
8,27	9,28	27,58
8,28	9,29	27,61
8,29	9,30	27,65
8,30	9,31	27,69
8,31	9,32	27,73
8,32	9,33	27,76
8,33	9,34	27,80
8,34	9,35	27,84
8,35	9,36	27,87
8,36	9,37	27,91
8,37	9,38	27,95
8,38	9,39	27,98
8,39	9,40	28,02
8,40	9,41	28,06
8,41	9,42	28,10
8,42	9,43	28,13
8,43	9,44	28,17
8,44	9,45	28,21
8,45	9,46	28,24
8,46	9,47	28,28
8,47	9,48	28,32
8,48	9,49	28,35
8,49	9,50	28,39
8,50	9,51	28,43
8,51	9,52	28,46
8,52	9,53	28,50



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,53	9,54	28,54
8,54	9,55	28,57
8,55	9,56	28,61
8,56	9,57	28,65
8,57	9,58	28,68
8,58	9,59	28,72
8,59	9,60	28,75
8,60	9,61	28,79
8,61	9,62	28,83
8,62	9,63	28,86
8,63	9,64	28,90
8,64	9,65	28,94
8,65	9,66	28,97
8,66	9,67	29,01
8,67	9,68	29,04
8,68	9,69	29,08
8,69	9,70	29,12
8,70	9,71	29,15
8,71	9,72	29,19
8,72	9,73	29,22
8,73	9,74	29,26
8,74	9,75	29,30
8,75	9,76	29,33
8,76	9,77	29,37
8,77	9,78	29,40
8,78	9,79	29,44
8,79	9,80	29,48
8,80	9,81	29,51
8,81	9,82	29,55
8,82	9,83	29,58
8,83	9,84	29,62
8,84	9,85	29,65
8,85	9,86	29,69
8,86	9,87	29,73
8,87	9,88	29,76
8,88	9,89	29,80
8,89	9,90	29,83
8,90	9,91	29,87
8,91	9,92	29,90
8,92	9,93	29,94
8,93	9,94	29,97
8,94	9,95	30,01
8,95	9,96	30,04
8,96	9,97	30,08



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,97	9,98	30,11
8,98	9,99	30,15
8,99	10,00	30,19
9,00	10,01	30,22
9,01	10,02	30,26
9,02	10,03	30,29
9,03	10,04	30,33
9,04	10,05	30,36
9,05	10,06	30,40
9,06	10,07	30,43
9,07	10,08	30,47
9,08	10,09	30,50
9,09	10,10	30,54
9,10	10,11	30,57
9,11	10,12	30,61
9,12	10,13	30,64
9,13	10,14	30,68
9,14	10,15	30,71
9,15	10,16	30,75
9,16	10,17	30,78
9,17	10,18	30,82
9,18	10,19	30,85
9,19	10,20	30,88
9,20	10,21	30,92
9,21	10,22	30,95
9,22	10,23	30,99
9,23	10,24	31,02
9,24	10,25	31,06
9,25	10,26	31,09
9,26	10,27	31,13
9,27	10,28	31,16
9,28	10,29	31,20
9,29	10,30	31,23
9,30	10,31	31,26
9,31	10,32	31,30
9,32	10,33	31,33
9,33	10,34	31,37
9,34	10,35	31,40
9,35	10,36	31,44
9,36	10,37	31,47
9,37	10,38	31,51
9,38	10,39	31,54
9,39	10,40	31,57
9,40	10,41	31,61



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,41	10,42	31,64
9,42	10,43	31,68
9,43	10,44	31,71
9,44	10,45	31,74
9,45	10,46	31,78
9,46	10,47	31,81
9,47	10,48	31,85
9,48	10,49	31,88
9,49	10,50	31,91
9,50	10,51	31,95
9,51	10,52	31,98
9,52	10,53	32,02
9,53	10,54	32,05
9,54	10,55	32,08
9,55	10,56	32,12
9,56	10,57	32,15
9,57	10,58	32,19
9,58	10,59	32,22
9,59	10,60	32,25
9,60	10,61	32,29
9,61	10,62	32,32
9,62	10,63	32,35
9,63	10,64	32,39
9,64	10,65	32,42
9,65	10,66	32,45
9,66	10,67	32,49
9,67	10,68	32,52
9,68	10,69	32,55
9,69	10,70	32,59
9,70	10,71	32,62
9,71	10,72	32,66
9,72	10,73	32,69
9,73	10,74	32,72
9,74	10,75	32,76
9,75	10,76	32,79
9,76	10,77	32,82
9,77	10,78	32,86
9,78	10,79	32,89
9,79	10,80	32,92
9,80	10,81	32,96
9,81	10,82	32,99
9,82	10,83	33,02
9,83	10,84	33,05
9,84	10,85	33,09



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,85	10,86	33,12
9,86	10,87	33,15
9,87	10,88	33,19
9,88	10,89	33,22
9,89	10,90	33,25
9,90	10,91	33,29
9,91	10,92	33,32
9,92	10,93	33,35
9,93	10,94	33,38
9,94	10,95	33,42
9,95	10,96	33,45
9,96	10,97	33,48
9,97	10,98	33,52
9,98	10,99	33,55
9,99	11,00	33,58
10,00	11,01	33,61
10,01	11,02	33,65
10,02	11,03	33,68
10,03	11,04	33,71
10,04	11,05	33,75
10,05	11,06	33,78
10,06	11,07	33,81
10,07	11,08	33,84
10,08	11,09	33,88
10,09	11,10	33,91
10,10	11,11	33,94
10,11	11,12	33,97
10,12	11,13	34,01
10,13	11,14	34,04
10,14	11,15	34,07
10,15	11,16	34,10
10,16	11,17	34,14
10,17	11,18	34,17
10,18	11,19	34,20
10,19	11,20	34,23
10,20	11,21	34,26
10,21	11,22	34,30
10,22	11,23	34,33
10,23	11,24	34,36
10,24	11,25	34,39
10,25	11,26	34,43
10,26	11,27	34,46
10,27	11,28	34,49
10,28	11,29	34,52



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,29	11,30	34,55
10,30	11,31	34,59
10,31	11,32	34,62
10,32	11,33	34,65
10,33	11,34	34,68
10,34	11,35	34,72
10,35	11,36	34,75
10,36	11,37	34,78
10,37	11,38	34,81
10,38	11,39	34,84
10,39	11,40	34,87
10,40	11,41	34,91
10,41	11,42	34,94
10,42	11,43	34,97
10,43	11,44	35,00
10,44	11,45	35,03
10,45	11,46	35,07
10,46	11,47	35,10
10,47	11,48	35,13
10,48	11,49	35,16
10,49	11,50	35,19
10,50	11,51	35,22
10,51	11,52	35,26
10,52	11,53	35,29
10,53	11,54	35,32
10,54	11,55	35,35
10,55	11,56	35,38
10,56	11,57	35,41
10,57	11,58	35,45
10,58	11,59	35,48
10,59	11,60	35,51
10,60	11,61	35,54
10,61	11,62	35,57
10,62	11,63	35,60
10,63	11,64	35,63
10,64	11,65	35,67
10,65	11,66	35,70
10,66	11,67	35,73
10,67	11,68	35,76
10,68	11,69	35,79
10,69	11,70	35,82
10,70	11,71	35,85
10,71	11,72	35,88
10,72	11,73	35,92



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	35,95
10,74	11,75	35,98
10,75	11,76	36,01
10,76	11,77	36,04
10,77	11,78	36,07
10,78	11,79	36,10
10,79	11,80	36,13
10,80	11,81	36,16
10,81	11,82	36,20
10,82	11,83	36,23
10,83	11,84	36,26
10,84	11,85	36,29
10,85	11,86	36,32
10,86	11,87	36,35
10,87	11,88	36,38
10,88	11,89	36,41
10,89	11,90	36,44
10,90	11,91	36,47
10,91	11,92	36,51
10,92	11,93	36,54
10,93	11,94	36,57
10,94	11,95	36,60
10,95	11,96	36,63
10,96	11,97	36,66
10,97	11,98	36,69
10,98	11,99	36,72
10,99	12,00	36,75
11,00	12,01	36,78
11,01	12,02	36,81
11,02	12,03	36,84
11,03	12,04	36,87
11,04	12,05	36,90
11,05	12,06	36,93
11,06	12,07	36,97
11,07	12,08	37,00
11,08	12,09	37,03
11,09	12,10	37,06
11,10	12,11	37,09
11,11	12,12	37,12
11,12	12,13	37,15
11,13	12,14	37,18
11,14	12,15	37,21
11,15	12,16	37,24
11,16	12,17	37,27



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,17	12,18	37,30
11,18	12,19	37,33
11,19	12,20	37,36
11,20	12,21	37,39
11,21	12,22	37,42
11,22	12,23	37,45
11,23	12,24	37,48
11,24	12,25	37,51
11,25	12,26	37,54
11,26	12,27	37,57
11,27	12,28	37,60
11,28	12,29	37,63
11,29	12,30	37,66
11,30	12,31	37,69
11,31	12,32	37,72
11,32	12,33	37,75
11,33	12,34	37,78
11,34	12,35	37,81
11,35	12,36	37,84
11,36	12,37	37,87
11,37	12,38	37,90
11,38	12,39	37,93
11,39	12,40	37,96
11,40	12,41	37,99
11,41	12,42	38,02
11,42	12,43	38,05
11,43	12,44	38,08
11,44	12,45	38,11
11,45	12,46	38,14
11,46	12,47	38,17
11,47	12,48	38,20
11,48	12,49	38,23
11,49	12,50	38,26
11,50	12,51	38,29
11,51	12,52	38,32
11,52	12,53	38,35
11,53	12,54	38,38
11,54	12,55	38,41
11,55	12,56	38,44
11,56	12,57	38,47
11,57	12,58	38,50
11,58	12,59	38,53
11,59	12,60	38,56
11,60	12,61	38,59



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	38,62
11,62	12,63	38,65
11,63	12,64	38,68
11,64	12,65	38,70
11,65	12,66	38,73
11,66	12,67	38,76
11,67	12,68	38,79
11,68	12,69	38,82
11,69	12,70	38,85
11,70	12,71	38,88
11,71	12,72	38,91
11,72	12,73	38,94
11,73	12,74	38,97
11,74	12,75	39,00
11,75	12,76	39,03
11,76	12,77	39,06
11,77	12,78	39,09
11,78	12,79	39,12
11,79	12,80	39,14
11,80	12,81	39,17
11,81	12,82	39,20
11,82	12,83	39,23
11,83	12,84	39,26
11,84	12,85	39,29
11,85	12,86	39,32
11,86	12,87	39,35
11,87	12,88	39,38
11,88	12,89	39,41
11,89	12,90	39,44
11,90	12,91	39,46
11,91	12,92	39,49
11,92	12,93	39,52
11,93	12,94	39,55
11,94	12,95	39,58
11,95	12,96	39,61
11,96	12,97	39,64
11,97	12,98	39,67
11,98	12,99	39,70
11,99	13,00	39,73
12,00	13,01	39,75
12,01	13,02	39,78
12,02	13,03	39,81
12,03	13,04	39,84
12,04	13,05	39,87



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,05	13,06	39,90
12,06	13,07	39,93
12,07	13,08	39,96
12,08	13,09	39,98
12,09	13,10	40,01
12,10	13,11	40,04
12,11	13,12	40,07
12,12	13,13	40,10
12,13	13,14	40,13
12,14	13,15	40,16
12,15	13,16	40,18
12,16	13,17	40,21
12,17	13,18	40,24
12,18	13,19	40,27
12,19	13,20	40,30
12,20	13,21	40,33
12,21	13,22	40,36
12,22	13,23	40,38
12,23	13,24	40,41
12,24	13,25	40,44
12,25	13,26	40,47
12,26	13,27	40,50
12,27	13,28	40,53
12,28	13,29	40,56
12,29	13,30	40,58
12,30	13,31	40,61
12,31	13,32	40,64
12,32	13,33	40,67
12,33	13,34	40,70
12,34	13,35	40,73
12,35	13,36	40,75
12,36	13,37	40,78
12,37	13,38	40,81
12,38	13,39	40,84
12,39	13,40	40,87
12,40	13,41	40,89
12,41	13,42	40,92
12,42	13,43	40,95
12,43	13,44	40,98
12,44	13,45	41,01
12,45	13,46	41,04
12,46	13,47	41,06
12,47	13,48	41,09
12,48	13,49	41,12



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	41,15
12,50	13,51	41,18
12,51	13,52	41,20
12,52	13,53	41,23
12,53	13,54	41,26
12,54	13,55	41,29
12,55	13,56	41,32
12,56	13,57	41,34
12,57	13,58	41,37
12,58	13,59	41,40
12,59	13,60	41,43
12,60	13,61	41,45
12,61	13,62	41,48
12,62	13,63	41,51
12,63	13,64	41,54
12,64	13,65	41,57
12,65	13,66	41,59
12,66	13,67	41,62
12,67	13,68	41,65
12,68	13,69	41,68
12,69	13,70	41,71
12,70	13,71	41,73
12,71	13,72	41,76
12,72	13,73	41,79
12,73	13,74	41,82
12,74	13,75	41,84
12,75	13,76	41,87
12,76	13,77	41,90
12,77	13,78	41,93
12,78	13,79	41,95
12,79	13,80	41,98
12,80	13,81	42,01
12,81	13,82	42,04
12,82	13,83	42,06
12,83	13,84	42,09
12,84	13,85	42,12
12,85	13,86	42,15
12,86	13,87	42,17
12,87	13,88	42,20
12,88	13,89	42,23
12,89	13,90	42,26
12,90	13,91	42,28
12,91	13,92	42,31
12,92	13,93	42,34



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,93	13,94	42,37
12,94	13,95	42,39
12,95	13,96	42,42
12,96	13,97	42,45
12,97	13,98	42,48
12,98	13,99	42,50
12,99	14,00	42,53
13,00	14,01	42,56
13,01	14,02	42,58
13,02	14,03	42,61
13,03	14,04	42,64
13,04	14,05	42,67
13,05	14,06	42,69
13,06	14,07	42,72
13,07	14,08	42,75
13,08	14,09	42,77
13,09	14,10	42,80
13,10	14,11	42,83
13,11	14,12	42,86
13,12	14,13	42,88
13,13	14,14	42,91
13,14	14,15	42,94
13,15	14,16	42,96
13,16	14,17	42,99
13,17	14,18	43,02
13,18	14,19	43,05
13,19	14,20	43,07
13,20	14,21	43,10
13,21	14,22	43,13
13,22	14,23	43,15
13,23	14,24	43,18
13,24	14,25	43,21
13,25	14,26	43,23
13,26	14,27	43,26
13,27	14,28	43,29
13,28	14,29	43,31
13,29	14,30	43,34
13,30	14,31	43,37
13,31	14,32	43,40
13,32	14,33	43,42
13,33	14,34	43,45
13,34	14,35	43,48
13,35	14,36	43,50
13,36	14,37	43,53



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,37	14,38	43,56
13,38	14,39	43,58
13,39	14,40	43,61
13,40	14,41	43,64
13,41	14,42	43,66
13,42	14,43	43,69
13,43	14,44	43,72
13,44	14,45	43,74
13,45	14,46	43,77
13,46	14,47	43,80
13,47	14,48	43,82
13,48	14,49	43,85
13,49	14,50	43,88
13,50	14,51	43,90
13,51	14,52	43,93
13,52	14,53	43,95
13,53	14,54	43,98
13,54	14,55	44,01
13,55	14,56	44,03
13,56	14,57	44,06
13,57	14,58	44,09
13,58	14,59	44,11
13,59	14,60	44,14
13,60	14,61	44,17
13,61	14,62	44,19
13,62	14,63	44,22
13,63	14,64	44,25
13,64	14,65	44,27
13,65	14,66	44,30
13,66	14,67	44,32
13,67	14,68	44,35
13,68	14,69	44,38
13,69	14,70	44,40
13,70	14,71	44,43
13,71	14,72	44,46
13,72	14,73	44,48
13,73	14,74	44,51
13,74	14,75	44,53
13,75	14,76	44,56
13,76	14,77	44,59
13,77	14,78	44,61
13,78	14,79	44,64
13,79	14,80	44,67
13,80	14,81	44,69



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,81	14,82	44,72
13,82	14,83	44,74
13,83	14,84	44,77
13,84	14,85	44,80
13,85	14,86	44,82
13,86	14,87	44,85
13,87	14,88	44,87
13,88	14,89	44,90
13,89	14,90	44,93
13,90	14,91	44,95
13,91	14,92	44,98
13,92	14,93	45,00
13,93	14,94	45,03
13,94	14,95	45,06
13,95	14,96	45,08
13,96	14,97	45,11
13,97	14,98	45,13
13,98	14,99	45,16
13,99	15,00	45,19
14,00	15,01	45,21
14,01	15,02	45,24
14,02	15,03	45,26
14,03	15,04	45,29
14,04	15,05	45,31
14,05	15,06	45,34
14,06	15,07	45,37
14,07	15,08	45,39
14,08	15,09	45,42
14,09	15,10	45,44
14,10	15,11	45,47
14,11	15,12	45,49
14,12	15,13	45,52
14,13	15,14	45,55
14,14	15,15	45,57
14,15	15,16	45,60
14,16	15,17	45,62
14,17	15,18	45,65
14,18	15,19	45,67
14,19	15,20	45,70
14,20	15,21	45,73
14,21	15,22	45,75
14,22	15,23	45,78
14,23	15,24	45,80
14,24	15,25	45,83



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
14,25	15,26	45,85
14,26	15,27	45,88
14,27	15,28	45,90
14,28	15,29	45,93
14,29	15,30	45,96
14,30	15,31	45,98
14,31	15,32	46,01
14,32	15,33	46,03
14,33	15,34	46,06
14,34	15,35	46,08
14,35	15,36	46,11
14,36	15,37	46,13
14,37	15,38	46,16
14,38	15,39	46,18
14,39	15,40	46,21
14,40	15,41	46,24
14,41	15,42	46,26
14,42	15,43	46,29
14,43	15,44	46,31
14,44	15,45	46,34
14,45	15,46	46,36
14,46	15,47	46,39
14,47	15,48	46,41
14,48	15,49	46,44
14,49	15,50	46,46
14,50	15,51	46,49
14,51	15,52	46,51
14,52	15,53	46,54
14,53	15,54	46,56
14,54	15,55	46,59
14,55	15,56	46,61
14,56	15,57	46,64
14,57	15,58	46,66
14,58	15,59	46,69
14,59	15,60	46,71
14,60	15,61	46,74
14,61	15,62	46,76
14,62	15,63	46,79
14,63	15,64	46,81
14,64	15,65	46,84
14,65	15,66	46,86
14,66	15,67	46,89
14,67	15,68	46,91
14,68	15,69	46,94



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	46,96
14,70	15,71	46,99
14,71	15,72	47,01
14,72	15,73	47,04
14,73	15,74	47,06
14,74	15,75	47,09
14,75	15,76	47,11
14,76	15,77	47,14
14,77	15,78	47,16
14,78	15,79	47,19
14,79	15,80	47,21
14,80	15,81	47,24
14,81	15,82	47,26
14,82	15,83	47,29
14,83	15,84	47,31
14,84	15,85	47,34
14,85	15,86	47,36
14,86	15,87	47,39
14,87	15,88	47,41
14,88	15,89	47,44
14,89	15,90	47,46
14,90	15,91	47,49
14,91	15,92	47,51
14,92	15,93	47,54
14,93	15,94	47,56
14,94	15,95	47,59
14,95	15,96	47,61
14,96	15,97	47,63
14,97	15,98	47,66
14,98	15,99	47,68
14,99	16,00	47,71
15,00	16,01	47,73
15,01	16,02	47,76
15,02	16,03	47,78
15,03	16,04	47,81
15,04	16,05	47,83
15,05	16,06	47,86
15,06	16,07	47,88
15,07	16,08	47,91
15,08	16,09	47,93
15,09	16,10	47,95
15,10	16,11	47,98
15,11	16,12	48,00
15,12	16,13	48,03



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	48,05
15,14	16,15	48,08
15,15	16,16	48,10
15,16	16,17	48,13
15,17	16,18	48,15
15,18	16,19	48,17
15,19	16,20	48,20
15,20	16,21	48,22
15,21	16,22	48,25
15,22	16,23	48,27
15,23	16,24	48,30
15,24	16,25	48,32
15,25	16,26	48,34
15,26	16,27	48,37
15,27	16,28	48,39
15,28	16,29	48,42
15,29	16,30	48,44
15,30	16,31	48,47
15,31	16,32	48,49
15,32	16,33	48,51
15,33	16,34	48,54
15,34	16,35	48,56
15,35	16,36	48,59
15,36	16,37	48,61
15,37	16,38	48,64
15,38	16,39	48,66
15,39	16,40	48,68
15,40	16,41	48,71
15,41	16,42	48,73
15,42	16,43	48,76
15,43	16,44	48,78
15,44	16,45	48,80
15,45	16,46	48,83
15,46	16,47	48,85
15,47	16,48	48,88
15,48	16,49	48,90
15,49	16,50	48,93
15,50	16,51	48,95
15,51	16,52	48,97
15,52	16,53	49,00
15,53	16,54	49,02
15,54	16,55	49,05
15,55	16,56	49,07
15,56	16,57	49,09



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
15,57	16,58	49,12
15,58	16,59	49,14
15,59	16,60	49,16
15,60	16,61	49,19
15,61	16,62	49,21
15,62	16,63	49,24
15,63	16,64	49,26
15,64	16,65	49,28
15,65	16,66	49,31
15,66	16,67	49,33
15,67	16,68	49,36
15,68	16,69	49,38
15,69	16,70	49,40
15,70	16,71	49,43
15,71	16,72	49,45
15,72	16,73	49,48
15,73	16,74	49,50
15,74	16,75	49,52
15,75	16,76	49,55
15,76	16,77	49,57
15,77	16,78	49,59
15,78	16,79	49,62
15,79	16,80	49,64
15,80	16,81	49,67
15,81	16,82	49,69
15,82	16,83	49,71
15,83	16,84	49,74
15,84	16,85	49,76
15,85	16,86	49,78
15,86	16,87	49,81
15,87	16,88	49,83
15,88	16,89	49,85
15,89	16,90	49,88
15,90	16,91	49,90
15,91	16,92	49,93
15,92	16,93	49,95
15,93	16,94	49,97
15,94	16,95	50,00
15,95	16,96	50,02
15,96	16,97	50,04
15,97	16,98	50,07
15,98	16,99	50,09
15,99	17,00	50,11
16,00	17,01	50,14



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	50,16
16,02	17,03	50,18
16,03	17,04	50,21
16,04	17,05	50,23
16,05	17,06	50,25
16,06	17,07	50,28
16,07	17,08	50,30
16,08	17,09	50,32
16,09	17,10	50,35
16,10	17,11	50,37
16,11	17,12	50,39
16,12	17,13	50,42
16,13	17,14	50,44
16,14	17,15	50,46
16,15	17,16	50,49
16,16	17,17	50,51
16,17	17,18	50,53
16,18	17,19	50,56
16,19	17,20	50,58
16,20	17,21	50,60
16,21	17,22	50,63
16,22	17,23	50,65
16,23	17,24	50,67
16,24	17,25	50,70
16,25	17,26	50,72
16,26	17,27	50,74
16,27	17,28	50,77
16,28	17,29	50,79
16,29	17,30	50,81
16,30	17,31	50,84
16,31	17,32	50,86
16,32	17,33	50,88
16,33	17,34	50,91
16,34	17,35	50,93
16,35	17,36	50,95
16,36	17,37	50,98
16,37	17,38	51,00
16,38	17,39	51,02
16,39	17,40	51,04
16,40	17,41	51,07
16,41	17,42	51,09
16,42	17,43	51,11
16,43	17,44	51,14
16,44	17,45	51,16



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,45	17,46	51,18
16,46	17,47	51,21
16,47	17,48	51,23
16,48	17,49	51,25
16,49	17,50	51,28
16,50	17,51	51,30
16,51	17,52	51,32
16,52	17,53	51,34
16,53	17,54	51,37
16,54	17,55	51,39
16,55	17,56	51,41
16,56	17,57	51,44
16,57	17,58	51,46
16,58	17,59	51,48
16,59	17,60	51,50
16,60	17,61	51,53
16,61	17,62	51,55
16,62	17,63	51,57
16,63	17,64	51,60
16,64	17,65	51,62
16,65	17,66	51,64
16,66	17,67	51,66
16,67	17,68	51,69
16,68	17,69	51,71
16,69	17,70	51,73
16,70	17,71	51,76
16,71	17,72	51,78
16,72	17,73	51,80
16,73	17,74	51,82
16,74	17,75	51,85
16,75	17,76	51,87
16,76	17,77	51,89
16,77	17,78	51,91
16,78	17,79	51,94
16,79	17,80	51,96
16,80	17,81	51,98
16,81	17,82	52,01
16,82	17,83	52,03
16,83	17,84	52,05
16,84	17,85	52,07
16,85	17,86	52,10
16,86	17,87	52,12
16,87	17,88	52,14
16,88	17,89	52,16



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	52,19
16,90	17,91	52,21
16,91	17,92	52,23
16,92	17,93	52,25
16,93	17,94	52,28
16,94	17,95	52,30
16,95	17,96	52,32
16,96	17,97	52,34
16,97	17,98	52,37
16,98	17,99	52,39
16,99	18,00	52,41
17,00	18,01	52,43
17,01	18,02	52,46
17,02	18,03	52,48
17,03	18,04	52,50
17,04	18,05	52,52
17,05	18,06	52,55
17,06	18,07	52,57
17,07	18,08	52,59
17,08	18,09	52,61
17,09	18,10	52,64
17,10	18,11	52,66
17,11	18,12	52,68
17,12	18,13	52,70
17,13	18,14	52,73
17,14	18,15	52,75
17,15	18,16	52,77
17,16	18,17	52,79
17,17	18,18	52,81
17,18	18,19	52,84
17,19	18,20	52,86
17,20	18,21	52,88
17,21	18,22	52,90
17,22	18,23	52,93
17,23	18,24	52,95
17,24	18,25	52,97
17,25	18,26	52,99
17,26	18,27	53,02
17,27	18,28	53,04
17,28	18,29	53,06
17,29	18,30	53,08
17,30	18,31	53,10
17,31	18,32	53,13
17,32	18,33	53,15



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	53,17
17,34	18,35	53,19
17,35	18,36	53,21
17,36	18,37	53,24
17,37	18,38	53,26
17,38	18,39	53,28
17,39	18,40	53,30
17,40	18,41	53,33
17,41	18,42	53,35
17,42	18,43	53,37
17,43	18,44	53,39
17,44	18,45	53,41
17,45	18,46	53,44
17,46	18,47	53,46
17,47	18,48	53,48
17,48	18,49	53,50
17,49	18,50	53,52
17,50	18,51	53,55
17,51	18,52	53,57
17,52	18,53	53,59
17,53	18,54	53,61
17,54	18,55	53,63
17,55	18,56	53,66
17,56	18,57	53,68
17,57	18,58	53,70
17,58	18,59	53,72
17,59	18,60	53,74
17,60	18,61	53,77
17,61	18,62	53,79
17,62	18,63	53,81
17,63	18,64	53,83
17,64	18,65	53,85
17,65	18,66	53,87
17,66	18,67	53,90
17,67	18,68	53,92
17,68	18,69	53,94
17,69	18,70	53,96
17,70	18,71	53,98
17,71	18,72	54,01
17,72	18,73	54,03
17,73	18,74	54,05
17,74	18,75	54,07
17,75	18,76	54,09
17,76	18,77	54,11



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,77	18,78	54,14
17,78	18,79	54,16
17,79	18,80	54,18
17,80	18,81	54,20
17,81	18,82	54,22
17,82	18,83	54,25
17,83	18,84	54,27
17,84	18,85	54,29
17,85	18,86	54,31
17,86	18,87	54,33
17,87	18,88	54,35
17,88	18,89	54,38
17,89	18,90	54,40
17,90	18,91	54,42
17,91	18,92	54,44
17,92	18,93	54,46
17,93	18,94	54,48
17,94	18,95	54,50
17,95	18,96	54,53
17,96	18,97	54,55
17,97	18,98	54,57
17,98	18,99	54,59
17,99	19,00	54,61
18,00	19,01	54,63
18,01	19,02	54,66
18,02	19,03	54,68
18,03	19,04	54,70
18,04	19,05	54,72
18,05	19,06	54,74
18,06	19,07	54,76
18,07	19,08	54,78
18,08	19,09	54,81
18,09	19,10	54,83
18,10	19,11	54,85
18,11	19,12	54,87
18,12	19,13	54,89
18,13	19,14	54,91
18,14	19,15	54,94
18,15	19,16	54,96
18,16	19,17	54,98
18,17	19,18	55,00
18,18	19,19	55,02
18,19	19,20	55,04
18,20	19,21	55,06



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,21	19,22	55,08
18,22	19,23	55,11
18,23	19,24	55,13
18,24	19,25	55,15
18,25	19,26	55,17
18,26	19,27	55,19
18,27	19,28	55,21
18,28	19,29	55,23
18,29	19,30	55,26
18,30	19,31	55,28
18,31	19,32	55,30
18,32	19,33	55,32
18,33	19,34	55,34
18,34	19,35	55,36
18,35	19,36	55,38
18,36	19,37	55,40
18,37	19,38	55,43
18,38	19,39	55,45
18,39	19,40	55,47
18,40	19,41	55,49
18,41	19,42	55,51
18,42	19,43	55,53
18,43	19,44	55,55
18,44	19,45	55,57
18,45	19,46	55,60
18,46	19,47	55,62
18,47	19,48	55,64
18,48	19,49	55,66
18,49	19,50	55,68
18,50	19,51	55,70
18,51	19,52	55,72
18,52	19,53	55,74
18,53	19,54	55,76
18,54	19,55	55,79
18,55	19,56	55,81
18,56	19,57	55,83
18,57	19,58	55,85
18,58	19,59	55,87
18,59	19,60	55,89
18,60	19,61	55,91
18,61	19,62	55,93
18,62	19,63	55,95
18,63	19,64	55,97
18,64	19,65	56,00



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
18,65	19,66	56,02
18,66	19,67	56,04
18,67	19,68	56,06
18,68	19,69	56,08
18,69	19,70	56,10
18,70	19,71	56,12
18,71	19,72	56,14
18,72	19,73	56,16
18,73	19,74	56,18
18,74	19,75	56,21
18,75	19,76	56,23
18,76	19,77	56,25
18,77	19,78	56,27
18,78	19,79	56,29
18,79	19,80	56,31
18,80	19,81	56,33
18,81	19,82	56,35
18,82	19,83	56,37
18,83	19,84	56,39
18,84	19,85	56,41
18,85	19,86	56,44
18,86	19,87	56,46
18,87	19,88	56,48
18,88	19,89	56,50
18,89	19,90	56,52
18,90	19,91	56,54
18,91	19,92	56,56
18,92	19,93	56,58
18,93	19,94	56,60
18,94	19,95	56,62
18,95	19,96	56,64
18,96	19,97	56,66
18,97	19,98	56,68
18,98	19,99	56,71
18,99	20,00	56,73
19,00	20,01	56,75
19,01	20,02	56,77
19,02	20,03	56,79
19,03	20,04	56,81
19,04	20,05	56,83
19,05	20,06	56,85
19,06	20,07	56,87
19,07	20,08	56,89
19,08	20,09	56,91



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	56,93
19,10	20,11	56,95
19,11	20,12	56,97
19,12	20,13	56,99
19,13	20,14	57,01
19,14	20,15	57,04
19,15	20,16	57,06
19,16	20,17	57,08
19,17	20,18	57,10
19,18	20,19	57,12
19,19	20,20	57,14
19,20	20,21	57,16
19,21	20,22	57,18
19,22	20,23	57,20
19,23	20,24	57,22
19,24	20,25	57,24
19,25	20,26	57,26
19,26	20,27	57,28
19,27	20,28	57,30
19,28	20,29	57,32
19,29	20,30	57,34
19,30	20,31	57,36
19,31	20,32	57,38
19,32	20,33	57,40
19,33	20,34	57,43
19,34	20,35	57,45
19,35	20,36	57,47
19,36	20,37	57,49
19,37	20,38	57,51
19,38	20,39	57,53
19,39	20,40	57,55
19,40	20,41	57,57
19,41	20,42	57,59
19,42	20,43	57,61
19,43	20,44	57,63
19,44	20,45	57,65
19,45	20,46	57,67
19,46	20,47	57,69
19,47	20,48	57,71
19,48	20,49	57,73
19,49	20,50	57,75
19,50	20,51	57,77
19,51	20,52	57,79
19,52	20,53	57,81



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	57,83
19,54	20,55	57,85
19,55	20,56	57,87
19,56	20,57	57,89
19,57	20,58	57,91
19,58	20,59	57,93
19,59	20,60	57,95
19,60	20,61	57,97
19,61	20,62	57,99
19,62	20,63	58,01
19,63	20,64	58,04
19,64	20,65	58,06
19,65	20,66	58,08
19,66	20,67	58,10
19,67	20,68	58,12
19,68	20,69	58,14
19,69	20,70	58,16
19,70	20,71	58,18
19,71	20,72	58,20
19,72	20,73	58,22
19,73	20,74	58,24
19,74	20,75	58,26
19,75	20,76	58,28
19,76	20,77	58,30
19,77	20,78	58,32
19,78	20,79	58,34
19,79	20,80	58,36
19,80	20,81	58,38
19,81	20,82	58,40
19,82	20,83	58,42
19,83	20,84	58,44
19,84	20,85	58,46
19,85	20,86	58,48
19,86	20,87	58,50
19,87	20,88	58,52
19,88	20,89	58,54
19,89	20,90	58,56
19,90	20,91	58,58
19,91	20,92	58,60
19,92	20,93	58,62
19,93	20,94	58,64
19,94	20,95	58,66
19,95	20,96	58,68
19,96	20,97	58,70



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,97	20,98	58,72
19,98	20,99	58,74
19,99	21,00	58,76
20,00	21,01	58,78
20,01	21,02	58,80
20,02	21,03	58,82
20,03	21,04	58,84
20,04	21,05	58,86
20,05	21,06	58,88
20,06	21,07	58,90
20,07	21,08	58,92
20,08	21,09	58,94
20,09	21,10	58,96
20,10	21,11	58,98
20,11	21,12	59,00
20,12	21,13	59,02
20,13	21,14	59,04
20,14	21,15	59,06
20,15	21,16	59,08
20,16	21,17	59,10
20,17	21,18	59,12
20,18	21,19	59,14
20,19	21,20	59,16
20,20	21,21	59,17
20,21	21,22	59,19
20,22	21,23	59,21
20,23	21,24	59,23
20,24	21,25	59,25
20,25	21,26	59,27
20,26	21,27	59,29
20,27	21,28	59,31
20,28	21,29	59,33
20,29	21,30	59,35
20,30	21,31	59,37
20,31	21,32	59,39
20,32	21,33	59,41
20,33	21,34	59,43
20,34	21,35	59,45
20,35	21,36	59,47
20,36	21,37	59,49
20,37	21,38	59,51
20,38	21,39	59,53
20,39	21,40	59,55
20,40	21,41	59,57



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,41	21,42	59,59
20,42	21,43	59,61
20,43	21,44	59,63
20,44	21,45	59,65
20,45	21,46	59,67
20,46	21,47	59,69
20,47	21,48	59,71
20,48	21,49	59,73
20,49	21,50	59,75
20,50	21,51	59,76
20,51	21,52	59,78
20,52	21,53	59,80
20,53	21,54	59,82
20,54	21,55	59,84
20,55	21,56	59,86
20,56	21,57	59,88
20,57	21,58	59,90
20,58	21,59	59,92
20,59	21,60	59,94
20,60	21,61	59,96
20,61	21,62	59,98
20,62	21,63	60,00
20,63	21,64	60,02
20,64	21,65	60,04
20,65	21,66	60,06
20,66	21,67	60,08
20,67	21,68	60,10
20,68	21,69	60,12
20,69	21,70	60,14
20,70	21,71	60,15
20,71	21,72	60,17
20,72	21,73	60,19
20,73	21,74	60,21
20,74	21,75	60,23
20,75	21,76	60,25
20,76	21,77	60,27
20,77	21,78	60,29
20,78	21,79	60,31
20,79	21,80	60,33
20,80	21,81	60,35
20,81	21,82	60,37
20,82	21,83	60,39
20,83	21,84	60,41
20,84	21,85	60,43



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
20,85	21,86	60,45
20,86	21,87	60,46
20,87	21,88	60,48
20,88	21,89	60,50
20,89	21,90	60,52
20,90	21,91	60,54
20,91	21,92	60,56
20,92	21,93	60,58
20,93	21,94	60,60
20,94	21,95	60,62
20,95	21,96	60,64
20,96	21,97	60,66
20,97	21,98	60,68
20,98	21,99	60,70
20,99	22,00	60,72
21,00	22,01	60,73
21,01	22,02	60,75
21,02	22,03	60,77
21,03	22,04	60,79
21,04	22,05	60,81
21,05	22,06	60,83
21,06	22,07	60,85
21,07	22,08	60,87
21,08	22,09	60,89
21,09	22,10	60,91
21,10	22,11	60,93
21,11	22,12	60,95
21,12	22,13	60,96
21,13	22,14	60,98
21,14	22,15	61,00
21,15	22,16	61,02
21,16	22,17	61,04
21,17	22,18	61,06
21,18	22,19	61,08
21,19	22,20	61,10
21,20	22,21	61,12
21,21	22,22	61,14
21,22	22,23	61,16
21,23	22,24	61,17
21,24	22,25	61,19
21,25	22,26	61,21
21,26	22,27	61,23
21,27	22,28	61,25
21,28	22,29	61,27



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,29	22,30	61,29
21,30	22,31	61,31
21,31	22,32	61,33
21,32	22,33	61,35
21,33	22,34	61,36
21,34	22,35	61,38
21,35	22,36	61,40
21,36	22,37	61,42
21,37	22,38	61,44
21,38	22,39	61,46
21,39	22,40	61,48
21,40	22,41	61,50
21,41	22,42	61,52
21,42	22,43	61,54
21,43	22,44	61,55
21,44	22,45	61,57
21,45	22,46	61,59
21,46	22,47	61,61
21,47	22,48	61,63
21,48	22,49	61,65
21,49	22,50	61,67
21,50	22,51	61,69
21,51	22,52	61,71
21,52	22,53	61,72
21,53	22,54	61,74
21,54	22,55	61,76
21,55	22,56	61,78
21,56	22,57	61,80
21,57	22,58	61,82
21,58	22,59	61,84
21,59	22,60	61,86
21,60	22,61	61,87
21,61	22,62	61,89
21,62	22,63	61,91
21,63	22,64	61,93
21,64	22,65	61,95
21,65	22,66	61,97
21,66	22,67	61,99
21,67	22,68	62,01
21,68	22,69	62,02
21,69	22,70	62,04
21,70	22,71	62,06
21,71	22,72	62,08
21,72	22,73	62,10



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	62,12
21,74	22,75	62,14
21,75	22,76	62,16
21,76	22,77	62,17
21,77	22,78	62,19
21,78	22,79	62,21
21,79	22,80	62,23
21,80	22,81	62,25
21,81	22,82	62,27
21,82	22,83	62,29
21,83	22,84	62,31
21,84	22,85	62,32
21,85	22,86	62,34
21,86	22,87	62,36
21,87	22,88	62,38
21,88	22,89	62,40
21,89	22,90	62,42
21,90	22,91	62,44
21,91	22,92	62,45
21,92	22,93	62,47
21,93	22,94	62,49
21,94	22,95	62,51
21,95	22,96	62,53
21,96	22,97	62,55
21,97	22,98	62,57
21,98	22,99	62,58
21,99	23,00	62,60
22,00	23,01	62,62
22,01	23,02	62,64
22,02	23,03	62,66
22,03	23,04	62,68
22,04	23,05	62,70
22,05	23,06	62,71
22,06	23,07	62,73
22,07	23,08	62,75
22,08	23,09	62,77
22,09	23,10	62,79
22,10	23,11	62,81
22,11	23,12	62,83
22,12	23,13	62,84
22,13	23,14	62,86
22,14	23,15	62,88
22,15	23,16	62,90
22,16	23,17	62,92



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
22,17	23,18	62,94
22,18	23,19	62,95
22,19	23,20	62,97
22,20	23,21	62,99
22,21	23,22	63,01
22,22	23,23	63,03
22,23	23,24	63,05
22,24	23,25	63,07
22,25	23,26	63,08
22,26	23,27	63,10
22,27	23,28	63,12
22,28	23,29	63,14
22,29	23,30	63,16
22,30	23,31	63,18
22,31	23,32	63,19
22,32	23,33	63,21
22,33	23,34	63,23
22,34	23,35	63,25
22,35	23,36	63,27
22,36	23,37	63,29
22,37	23,38	63,30
22,38	23,39	63,32
22,39	23,40	63,34
22,40	23,41	63,36
22,41	23,42	63,38
22,42	23,43	63,40
22,43	23,44	63,41
22,44	23,45	63,43
22,45	23,46	63,45
22,46	23,47	63,47
22,47	23,48	63,49
22,48	23,49	63,50
22,49	23,50	63,52
22,50	23,51	63,54
22,51	23,52	63,56
22,52	23,53	63,58
22,53	23,54	63,60
22,54	23,55	63,61
22,55	23,56	63,63
22,56	23,57	63,65
22,57	23,58	63,67
22,58	23,59	63,69
22,59	23,60	63,70
22,60	23,61	63,72



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	63,74
22,62	23,63	63,76
22,63	23,64	63,78
22,64	23,65	63,80
22,65	23,66	63,81
22,66	23,67	63,83
22,67	23,68	63,85
22,68	23,69	63,87
22,69	23,70	63,89
22,70	23,71	63,90
22,71	23,72	63,92
22,72	23,73	63,94
22,73	23,74	63,96
22,74	23,75	63,98
22,75	23,76	63,99
22,76	23,77	64,01
22,77	23,78	64,03
22,78	23,79	64,05
22,79	23,80	64,07
22,80	23,81	64,09
22,81	23,82	64,10
22,82	23,83	64,12
22,83	23,84	64,14
22,84	23,85	64,16
22,85	23,86	64,18
22,86	23,87	64,19
22,87	23,88	64,21
22,88	23,89	64,23
22,89	23,90	64,25
22,90	23,91	64,27
22,91	23,92	64,28
22,92	23,93	64,30
22,93	23,94	64,32
22,94	23,95	64,34
22,95	23,96	64,36
22,96	23,97	64,37
22,97	23,98	64,39
22,98	23,99	64,41
22,99	24,00	64,43
23,00	24,01	64,44
23,01	24,02	64,46
23,02	24,03	64,48
23,03	24,04	64,50
23,04	24,05	64,52



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,05	24,06	64,53
23,06	24,07	64,55
23,07	24,08	64,57
23,08	24,09	64,59
23,09	24,10	64,61
23,10	24,11	64,62
23,11	24,12	64,64
23,12	24,13	64,66
23,13	24,14	64,68
23,14	24,15	64,70
23,15	24,16	64,71
23,16	24,17	64,73
23,17	24,18	64,75
23,18	24,19	64,77
23,19	24,20	64,78
23,20	24,21	64,80
23,21	24,22	64,82
23,22	24,23	64,84
23,23	24,24	64,86
23,24	24,25	64,87
23,25	24,26	64,89
23,26	24,27	64,91
23,27	24,28	64,93
23,28	24,29	64,94
23,29	24,30	64,96
23,30	24,31	64,98
23,31	24,32	65,00
23,32	24,33	65,02
23,33	24,34	65,03
23,34	24,35	65,05
23,35	24,36	65,07
23,36	24,37	65,09
23,37	24,38	65,10
23,38	24,39	65,12
23,39	24,40	65,14
23,40	24,41	65,16
23,41	24,42	65,17
23,42	24,43	65,19
23,43	24,44	65,21
23,44	24,45	65,23
23,45	24,46	65,25
23,46	24,47	65,26
23,47	24,48	65,28
23,48	24,49	65,30



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,49	24,50	65,32
23,50	24,51	65,33
23,51	24,52	65,35
23,52	24,53	65,37
23,53	24,54	65,39
23,54	24,55	65,40
23,55	24,56	65,42
23,56	24,57	65,44
23,57	24,58	65,46
23,58	24,59	65,47
23,59	24,60	65,49
23,60	24,61	65,51
23,61	24,62	65,53
23,62	24,63	65,54
23,63	24,64	65,56
23,64	24,65	65,58
23,65	24,66	65,60
23,66	24,67	65,62
23,67	24,68	65,63
23,68	24,69	65,65
23,69	24,70	65,67
23,70	24,71	65,69
23,71	24,72	65,70
23,72	24,73	65,72
23,73	24,74	65,74
23,74	24,75	65,76
23,75	24,76	65,77
23,76	24,77	65,79
23,77	24,78	65,81
23,78	24,79	65,83
23,79	24,80	65,84
23,80	24,81	65,86
23,81	24,82	65,88
23,82	24,83	65,90
23,83	24,84	65,91
23,84	24,85	65,93
23,85	24,86	65,95
23,86	24,87	65,96
23,87	24,88	65,98
23,88	24,89	66,00
23,89	24,90	66,02
23,90	24,91	66,03
23,91	24,92	66,05
23,92	24,93	66,07



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,93	24,94	66,09
23,94	24,95	66,10
23,95	24,96	66,12
23,96	24,97	66,14
23,97	24,98	66,16
23,98	24,99	66,17
23,99	25,00	66,19
24,00	25,01	66,21
24,01	25,02	66,23
24,02	25,03	66,24
24,03	25,04	66,26
24,04	25,05	66,28
24,05	25,06	66,29
24,06	25,07	66,31
24,07	25,08	66,33
24,08	25,09	66,35
24,09	25,10	66,36
24,10	25,11	66,38
24,11	25,12	66,40
24,12	25,13	66,42
24,13	25,14	66,43
24,14	25,15	66,45
24,15	25,16	66,47
24,16	25,17	66,49
24,17	25,18	66,50
24,18	25,19	66,52
24,19	25,20	66,54
24,20	25,21	66,55
24,21	25,22	66,57
24,22	25,23	66,59
24,23	25,24	66,61
24,24	25,25	66,62
24,25	25,26	66,64
24,26	25,27	66,66
24,27	25,28	66,67
24,28	25,29	66,69
24,29	25,30	66,71
24,30	25,31	66,73
24,31	25,32	66,74
24,32	25,33	66,76
24,33	25,34	66,78
24,34	25,35	66,79
24,35	25,36	66,81
24,36	25,37	66,83



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,37	25,38	66,85
24,38	25,39	66,86
24,39	25,40	66,88
24,40	25,41	66,90
24,41	25,42	66,91
24,42	25,43	66,93
24,43	25,44	66,95
24,44	25,45	66,97
24,45	25,46	66,98
24,46	25,47	67,00
24,47	25,48	67,02
24,48	25,49	67,03
24,49	25,50	67,05
24,50	25,51	67,07
24,51	25,52	67,09
24,52	25,53	67,10
24,53	25,54	67,12
24,54	25,55	67,14
24,55	25,56	67,15
24,56	25,57	67,17
24,57	25,58	67,19
24,58	25,59	67,20
24,59	25,60	67,22
24,60	25,61	67,24
24,61	25,62	67,26
24,62	25,63	67,27
24,63	25,64	67,29
24,64	25,65	67,31
24,65	25,66	67,32
24,66	25,67	67,34
24,67	25,68	67,36
24,68	25,69	67,37
24,69	25,70	67,39
24,70	25,71	67,41
24,71	25,72	67,43
24,72	25,73	67,44
24,73	25,74	67,46
24,74	25,75	67,48
24,75	25,76	67,49
24,76	25,77	67,51
24,77	25,78	67,53
24,78	25,79	67,54
24,79	25,80	67,56
24,80	25,81	67,58



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	67,60
24,82	25,83	67,61
24,83	25,84	67,63
24,84	25,85	67,65
24,85	25,86	67,66
24,86	25,87	67,68
24,87	25,88	67,70
24,88	25,89	67,71
24,89	25,90	67,73
24,90	25,91	67,75
24,91	25,92	67,76
24,92	25,93	67,78
24,93	25,94	67,80
24,94	25,95	67,81
24,95	25,96	67,83
24,96	25,97	67,85
24,97	25,98	67,86
24,98	25,99	67,88
24,99	26,00	67,90
25,00	26,01	67,92
25,01	26,02	67,93
25,02	26,03	67,95
25,03	26,04	67,97
25,04	26,05	67,98
25,05	26,06	68,00
25,06	26,07	68,02
25,07	26,08	68,03
25,08	26,09	68,05
25,09	26,10	68,07
25,10	26,11	68,08
25,11	26,12	68,10
25,12	26,13	68,12
25,13	26,14	68,13
25,14	26,15	68,15
25,15	26,16	68,17
25,16	26,17	68,18
25,17	26,18	68,20
25,18	26,19	68,22
25,19	26,20	68,23
25,20	26,21	68,25
25,21	26,22	68,27
25,22	26,23	68,28
25,23	26,24	68,30
25,24	26,25	68,32



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	68,33
25,26	26,27	68,35
25,27	26,28	68,37
25,28	26,29	68,38
25,29	26,30	68,40
25,30	26,31	68,42
25,31	26,32	68,43
25,32	26,33	68,45
25,33	26,34	68,47
25,34	26,35	68,48
25,35	26,36	68,50
25,36	26,37	68,52
25,37	26,38	68,53
25,38	26,39	68,55
25,39	26,40	68,57
25,40	26,41	68,58
25,41	26,42	68,60
25,42	26,43	68,62
25,43	26,44	68,63
25,44	26,45	68,65
25,45	26,46	68,67
25,46	26,47	68,68
25,47	26,48	68,70
25,48	26,49	68,72
25,49	26,50	68,73
25,50	26,51	68,75
25,51	26,52	68,77
25,52	26,53	68,78
25,53	26,54	68,80
25,54	26,55	68,81
25,55	26,56	68,83
25,56	26,57	68,85
25,57	26,58	68,86
25,58	26,59	68,88
25,59	26,60	68,90
25,60	26,61	68,91
25,61	26,62	68,93
25,62	26,63	68,95
25,63	26,64	68,96
25,64	26,65	68,98
25,65	26,66	69,00
25,66	26,67	69,01
25,67	26,68	69,03
25,68	26,69	69,05



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
25,69	26,70	69,06
25,70	26,71	69,08
25,71	26,72	69,10
25,72	26,73	69,11
25,73	26,74	69,13
25,74	26,75	69,14
25,75	26,76	69,16
25,76	26,77	69,18
25,77	26,78	69,19
25,78	26,79	69,21
25,79	26,80	69,23
25,80	26,81	69,24
25,81	26,82	69,26
25,82	26,83	69,28
25,83	26,84	69,29
25,84	26,85	69,31
25,85	26,86	69,32
25,86	26,87	69,34
25,87	26,88	69,36
25,88	26,89	69,37
25,89	26,90	69,39
25,90	26,91	69,41
25,91	26,92	69,42
25,92	26,93	69,44
25,93	26,94	69,46
25,94	26,95	69,47
25,95	26,96	69,49
25,96	26,97	69,50
25,97	26,98	69,52
25,98	26,99	69,54
25,99	27,00	69,55
26,00	27,01	69,57
26,01	27,02	69,59
26,02	27,03	69,60
26,03	27,04	69,62
26,04	27,05	69,63
26,05	27,06	69,65
26,06	27,07	69,67
26,07	27,08	69,68
26,08	27,09	69,70
26,09	27,10	69,72
26,10	27,11	69,73
26,11	27,12	69,75
26,12	27,13	69,76



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	69,78
26,14	27,15	69,80
26,15	27,16	69,81
26,16	27,17	69,83
26,17	27,18	69,85
26,18	27,19	69,86
26,19	27,20	69,88
26,20	27,21	69,89
26,21	27,22	69,91
26,22	27,23	69,93
26,23	27,24	69,94
26,24	27,25	69,96
26,25	27,26	69,98
26,26	27,27	69,99
26,27	27,28	70,01
26,28	27,29	70,02
26,29	27,30	70,04
26,30	27,31	70,06
26,31	27,32	70,07
26,32	27,33	70,09
26,33	27,34	70,10
26,34	27,35	70,12
26,35	27,36	70,14
26,36	27,37	70,15
26,37	27,38	70,17
26,38	27,39	70,18
26,39	27,40	70,20
26,40	27,41	70,22
26,41	27,42	70,23
26,42	27,43	70,25
26,43	27,44	70,27
26,44	27,45	70,28
26,45	27,46	70,30
26,46	27,47	70,31
26,47	27,48	70,33
26,48	27,49	70,35
26,49	27,50	70,36
26,50	27,51	70,38
26,51	27,52	70,39
26,52	27,53	70,41
26,53	27,54	70,43
26,54	27,55	70,44
26,55	27,56	70,46
26,56	27,57	70,47



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,57	27,58	70,49
26,58	27,59	70,51
26,59	27,60	70,52
26,60	27,61	70,54
26,61	27,62	70,55
26,62	27,63	70,57
26,63	27,64	70,59
26,64	27,65	70,60
26,65	27,66	70,62
26,66	27,67	70,63
26,67	27,68	70,65
26,68	27,69	70,67
26,69	27,70	70,68
26,70	27,71	70,70
26,71	27,72	70,71
26,72	27,73	70,73
26,73	27,74	70,75
26,74	27,75	70,76
26,75	27,76	70,78
26,76	27,77	70,79
26,77	27,78	70,81
26,78	27,79	70,83
26,79	27,80	70,84
26,80	27,81	70,86
26,81	27,82	70,87
26,82	27,83	70,89
26,83	27,84	70,90
26,84	27,85	70,92
26,85	27,86	70,94
26,86	27,87	70,95
26,87	27,88	70,97
26,88	27,89	70,98
26,89	27,90	71,00
26,90	27,91	71,02
26,91	27,92	71,03
26,92	27,93	71,05
26,93	27,94	71,06
26,94	27,95	71,08
26,95	27,96	71,09
26,96	27,97	71,11
26,97	27,98	71,13
26,98	27,99	71,14
26,99	28,00	71,16
27,00	28,01	71,17



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	71,19
27,02	28,03	71,21
27,03	28,04	71,22
27,04	28,05	71,24
27,05	28,06	71,25
27,06	28,07	71,27
27,07	28,08	71,28
27,08	28,09	71,30
27,09	28,10	71,32
27,10	28,11	71,33
27,11	28,12	71,35
27,12	28,13	71,36
27,13	28,14	71,38
27,14	28,15	71,39
27,15	28,16	71,41
27,16	28,17	71,43
27,17	28,18	71,44
27,18	28,19	71,46
27,19	28,20	71,47
27,20	28,21	71,49
27,21	28,22	71,50
27,22	28,23	71,52
27,23	28,24	71,54
27,24	28,25	71,55
27,25	28,26	71,57
27,26	28,27	71,58
27,27	28,28	71,60
27,28	28,29	71,61
27,29	28,30	71,63
27,30	28,31	71,65
27,31	28,32	71,66
27,32	28,33	71,68
27,33	28,34	71,69
27,34	28,35	71,71
27,35	28,36	71,72
27,36	28,37	71,74
27,37	28,38	71,76
27,38	28,39	71,77
27,39	28,40	71,79
27,40	28,41	71,80
27,41	28,42	71,82
27,42	28,43	71,83
27,43	28,44	71,85
27,44	28,45	71,86



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	71,88
27,46	28,47	71,90
27,47	28,48	71,91
27,48	28,49	71,93
27,49	28,50	71,94
27,50	28,51	71,96
27,51	28,52	71,97
27,52	28,53	71,99
27,53	28,54	72,00
27,54	28,55	72,02
27,55	28,56	72,04
27,56	28,57	72,05
27,57	28,58	72,07
27,58	28,59	72,08
27,59	28,60	72,10
27,60	28,61	72,11
27,61	28,62	72,13
27,62	28,63	72,14
27,63	28,64	72,16
27,64	28,65	72,18
27,65	28,66	72,19
27,66	28,67	72,21
27,67	28,68	72,22
27,68	28,69	72,24
27,69	28,70	72,25
27,70	28,71	72,27
27,71	28,72	72,28
27,72	28,73	72,30
27,73	28,74	72,32
27,74	28,75	72,33
27,75	28,76	72,35
27,76	28,77	72,36
27,77	28,78	72,38
27,78	28,79	72,39
27,79	28,80	72,41
27,80	28,81	72,42
27,81	28,82	72,44
27,82	28,83	72,45
27,83	28,84	72,47
27,84	28,85	72,48
27,85	28,86	72,50
27,86	28,87	72,52
27,87	28,88	72,53
27,88	28,89	72,55



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	72,56
27,90	28,91	72,58
27,91	28,92	72,59
27,92	28,93	72,61
27,93	28,94	72,62
27,94	28,95	72,64
27,95	28,96	72,65
27,96	28,97	72,67
27,97	28,98	72,68
27,98	28,99	72,70
27,99	29,00	72,72
28,00	29,01	72,73
28,01	29,02	72,75
28,02	29,03	72,76
28,03	29,04	72,78
28,04	29,05	72,79
28,05	29,06	72,81
28,06	29,07	72,82
28,07	29,08	72,84
28,08	29,09	72,85
28,09	29,10	72,87
28,10	29,11	72,88
28,11	29,12	72,90
28,12	29,13	72,91
28,13	29,14	72,93
28,14	29,15	72,95
28,15	29,16	72,96
28,16	29,17	72,98
28,17	29,18	72,99
28,18	29,19	73,01
28,19	29,20	73,02
28,20	29,21	73,04
28,21	29,22	73,05
28,22	29,23	73,07
28,23	29,24	73,08
28,24	29,25	73,10
28,25	29,26	73,11
28,26	29,27	73,13
28,27	29,28	73,14
28,28	29,29	73,16
28,29	29,30	73,17
28,30	29,31	73,19
28,31	29,32	73,20
28,32	29,33	73,22



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	73,23
28,34	29,35	73,25
28,35	29,36	73,27
28,36	29,37	73,28
28,37	29,38	73,30
28,38	29,39	73,31
28,39	29,40	73,33
28,40	29,41	73,34
28,41	29,42	73,36
28,42	29,43	73,37
28,43	29,44	73,39
28,44	29,45	73,40
28,45	29,46	73,42
28,46	29,47	73,43
28,47	29,48	73,45
28,48	29,49	73,46
28,49	29,50	73,48
28,50	29,51	73,49
28,51	29,52	73,51
28,52	29,53	73,52
28,53	29,54	73,54
28,54	29,55	73,55
28,55	29,56	73,57
28,56	29,57	73,58
28,57	29,58	73,60
28,58	29,59	73,61
28,59	29,60	73,63
28,60	29,61	73,64
28,61	29,62	73,66
28,62	29,63	73,67
28,63	29,64	73,69
28,64	29,65	73,70
28,65	29,66	73,72
28,66	29,67	73,73
28,67	29,68	73,75
28,68	29,69	73,76
28,69	29,70	73,78
28,70	29,71	73,79
28,71	29,72	73,81
28,72	29,73	73,82
28,73	29,74	73,84
28,74	29,75	73,85
28,75	29,76	73,87
28,76	29,77	73,88



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	73,90
28,78	29,79	73,91
28,79	29,80	73,93
28,80	29,81	73,94
28,81	29,82	73,96
28,82	29,83	73,97
28,83	29,84	73,99
28,84	29,85	74,00
28,85	29,86	74,02
28,86	29,87	74,03
28,87	29,88	74,05
28,88	29,89	74,06
28,89	29,90	74,08
28,90	29,91	74,09
28,91	29,92	74,11
28,92	29,93	74,12
28,93	29,94	74,14
28,94	29,95	74,15
28,95	29,96	74,17
28,96	29,97	74,18
28,97	29,98	74,20
28,98	29,99	74,21
28,99	30,00	74,23
29,00	30,01	74,24
29,01	30,02	74,26
29,02	30,03	74,27
29,03	30,04	74,29
29,04	30,05	74,30
29,05	30,06	74,32
29,06	30,07	74,33
29,07	30,08	74,35
29,08	30,09	74,36
29,09	30,10	74,38
29,10	30,11	74,39
29,11	30,12	74,41
29,12	30,13	74,42
29,13	30,14	74,44
29,14	30,15	74,45
29,15	30,16	74,47
29,16	30,17	74,48
29,17	30,18	74,50
29,18	30,19	74,51
29,19	30,20	74,53
29,20	30,21	74,54



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	74,56
29,22	30,23	74,57
29,23	30,24	74,59
29,24	30,25	74,60
29,25	30,26	74,61
29,26	30,27	74,63
29,27	30,28	74,64
29,28	30,29	74,66
29,29	30,30	74,67
29,30	30,31	74,69
29,31	30,32	74,70
29,32	30,33	74,72
29,33	30,34	74,73
29,34	30,35	74,75
29,35	30,36	74,76
29,36	30,37	74,78
29,37	30,38	74,79
29,38	30,39	74,81
29,39	30,40	74,82
29,40	30,41	74,84
29,41	30,42	74,85
29,42	30,43	74,87
29,43	30,44	74,88
29,44	30,45	74,90
29,45	30,46	74,91
29,46	30,47	74,92
29,47	30,48	74,94
29,48	30,49	74,95
29,49	30,50	74,97
29,50	30,51	74,98
29,51	30,52	75,00
29,52	30,53	75,01
29,53	30,54	75,03
29,54	30,55	75,04
29,55	30,56	75,06
29,56	30,57	75,07
29,57	30,58	75,09
29,58	30,59	75,10
29,59	30,60	75,12
29,60	30,61	75,13
29,61	30,62	75,14
29,62	30,63	75,16
29,63	30,64	75,17
29,64	30,65	75,19



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
29,65	30,66	75,20
29,66	30,67	75,22
29,67	30,68	75,23
29,68	30,69	75,25
29,69	30,70	75,26
29,70	30,71	75,28
29,71	30,72	75,29
29,72	30,73	75,31
29,73	30,74	75,32
29,74	30,75	75,33
29,75	30,76	75,35
29,76	30,77	75,36
29,77	30,78	75,38
29,78	30,79	75,39
29,79	30,80	75,41
29,80	30,81	75,42
29,81	30,82	75,44
29,82	30,83	75,45
29,83	30,84	75,47
29,84	30,85	75,48
29,85	30,86	75,50
29,86	30,87	75,51
29,87	30,88	75,52
29,88	30,89	75,54
29,89	30,90	75,55
29,90	30,91	75,57
29,91	30,92	75,58
29,92	30,93	75,60
29,93	30,94	75,61
29,94	30,95	75,63
29,95	30,96	75,64
29,96	30,97	75,65
29,97	30,98	75,67
29,98	30,99	75,68
29,99	31,00	75,70
30,00	31,01	75,71
30,01	31,02	75,73
30,02	31,03	75,74
30,03	31,04	75,76
30,04	31,05	75,77
30,05	31,06	75,79
30,06	31,07	75,80
30,07	31,08	75,81
30,08	31,09	75,83



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
30,09	31,10	75,84
30,10	31,11	75,86
30,11	31,12	75,87
30,12	31,13	75,89
30,13	31,14	75,90
30,14	31,15	75,92
30,15	31,16	75,93
30,16	31,17	75,94
30,17	31,18	75,96
30,18	31,19	75,97
30,19	31,20	75,99
30,20	31,21	76,00
30,21	31,22	76,02
30,22	31,23	76,03
30,23	31,24	76,04
30,24	31,25	76,06
30,25	31,26	76,07
30,26	31,27	76,09
30,27	31,28	76,10
30,28	31,29	76,12
30,29	31,30	76,13
30,30	31,31	76,15
30,31	31,32	76,16
30,32	31,33	76,17
30,33	31,34	76,19
30,34	31,35	76,20
30,35	31,36	76,22
30,36	31,37	76,23
30,37	31,38	76,25
30,38	31,39	76,26
30,39	31,40	76,27
30,40	31,41	76,29
30,41	31,42	76,30
30,42	31,43	76,32
30,43	31,44	76,33
30,44	31,45	76,35
30,45	31,46	76,36
30,46	31,47	76,37
30,47	31,48	76,39
30,48	31,49	76,40
30,49	31,50	76,42
30,50	31,51	76,43
30,51	31,52	76,45
30,52	31,53	76,46



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	76,47
30,54	31,55	76,49
30,55	31,56	76,50
30,56	31,57	76,52
30,57	31,58	76,53
30,58	31,59	76,55
30,59	31,60	76,56
30,60	31,61	76,57
30,61	31,62	76,59
30,62	31,63	76,60
30,63	31,64	76,62
30,64	31,65	76,63
30,65	31,66	76,65
30,66	31,67	76,66
30,67	31,68	76,67
30,68	31,69	76,69
30,69	31,70	76,70
30,70	31,71	76,72
30,71	31,72	76,73
30,72	31,73	76,75
30,73	31,74	76,76
30,74	31,75	76,77
30,75	31,76	76,79
30,76	31,77	76,80
30,77	31,78	76,82
30,78	31,79	76,83
30,79	31,80	76,84
30,80	31,81	76,86
30,81	31,82	76,87
30,82	31,83	76,89
30,83	31,84	76,90
30,84	31,85	76,92
30,85	31,86	76,93
30,86	31,87	76,94
30,87	31,88	76,96
30,88	31,89	76,97
30,89	31,90	76,99
30,90	31,91	77,00
30,91	31,92	77,01
30,92	31,93	77,03
30,93	31,94	77,04
30,94	31,95	77,06
30,95	31,96	77,07
30,96	31,97	77,09



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,97	31,98	77,10
30,98	31,99	77,11
30,99	32,00	77,13
31,00	32,01	77,14
31,01	32,02	77,16
31,02	32,03	77,17
31,03	32,04	77,18
31,04	32,05	77,20
31,05	32,06	77,21
31,06	32,07	77,23
31,07	32,08	77,24
31,08	32,09	77,25
31,09	32,10	77,27
31,10	32,11	77,28
31,11	32,12	77,30
31,12	32,13	77,31
31,13	32,14	77,32
31,14	32,15	77,34
31,15	32,16	77,35
31,16	32,17	77,37
31,17	32,18	77,38
31,18	32,19	77,39
31,19	32,20	77,41
31,20	32,21	77,42
31,21	32,22	77,44
31,22	32,23	77,45
31,23	32,24	77,46
31,24	32,25	77,48
31,25	32,26	77,49
31,26	32,27	77,51
31,27	32,28	77,52
31,28	32,29	77,53
31,29	32,30	77,55
31,30	32,31	77,56
31,31	32,32	77,58
31,32	32,33	77,59
31,33	32,34	77,60
31,34	32,35	77,62
31,35	32,36	77,63
31,36	32,37	77,65
31,37	32,38	77,66
31,38	32,39	77,67
31,39	32,40	77,69
31,40	32,41	77,70



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	77,72
31,42	32,43	77,73
31,43	32,44	77,74
31,44	32,45	77,76
31,45	32,46	77,77
31,46	32,47	77,79
31,47	32,48	77,80
31,48	32,49	77,81
31,49	32,50	77,83
31,50	32,51	77,84
31,51	32,52	77,85
31,52	32,53	77,87
31,53	32,54	77,88
31,54	32,55	77,90
31,55	32,56	77,91
31,56	32,57	77,92
31,57	32,58	77,94
31,58	32,59	77,95
31,59	32,60	77,97
31,60	32,61	77,98
31,61	32,62	77,99
31,62	32,63	78,01
31,63	32,64	78,02
31,64	32,65	78,03
31,65	32,66	78,05
31,66	32,67	78,06
31,67	32,68	78,08
31,68	32,69	78,09
31,69	32,70	78,10
31,70	32,71	78,12
31,71	32,72	78,13
31,72	32,73	78,15
31,73	32,74	78,16
31,74	32,75	78,17
31,75	32,76	78,19
31,76	32,77	78,20
31,77	32,78	78,21
31,78	32,79	78,23
31,79	32,80	78,24
31,80	32,81	78,26
31,81	32,82	78,27
31,82	32,83	78,28
31,83	32,84	78,30
31,84	32,85	78,31



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	78,32
31,86	32,87	78,34
31,87	32,88	78,35
31,88	32,89	78,37
31,89	32,90	78,38
31,90	32,91	78,39
31,91	32,92	78,41
31,92	32,93	78,42
31,93	32,94	78,43
31,94	32,95	78,45
31,95	32,96	78,46
31,96	32,97	78,48
31,97	32,98	78,49
31,98	32,99	78,50
31,99	33,00	78,52
32,00	33,01	78,53
32,01	33,02	78,54
32,02	33,03	78,56
32,03	33,04	78,57
32,04	33,05	78,59
32,05	33,06	78,60
32,06	33,07	78,61
32,07	33,08	78,63
32,08	33,09	78,64
32,09	33,10	78,65
32,10	33,11	78,67
32,11	33,12	78,68
32,12	33,13	78,69
32,13	33,14	78,71
32,14	33,15	78,72
32,15	33,16	78,74
32,16	33,17	78,75
32,17	33,18	78,76
32,18	33,19	78,78
32,19	33,20	78,79
32,20	33,21	78,80
32,21	33,22	78,82
32,22	33,23	78,83
32,23	33,24	78,84
32,24	33,25	78,86
32,25	33,26	78,87
32,26	33,27	78,89
32,27	33,28	78,90
32,28	33,29	78,91



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	78,93
32,30	33,31	78,94
32,31	33,32	78,95
32,32	33,33	78,97
32,33	33,34	78,98
32,34	33,35	78,99
32,35	33,36	79,01
32,36	33,37	79,02
32,37	33,38	79,04
32,38	33,39	79,05
32,39	33,40	79,06
32,40	33,41	79,08
32,41	33,42	79,09
32,42	33,43	79,10
32,43	33,44	79,12
32,44	33,45	79,13
32,45	33,46	79,14
32,46	33,47	79,16
32,47	33,48	79,17
32,48	33,49	79,18
32,49	33,50	79,20
32,50	33,51	79,21
32,51	33,52	79,22
32,52	33,53	79,24
32,53	33,54	79,25
32,54	33,55	79,27
32,55	33,56	79,28
32,56	33,57	79,29
32,57	33,58	79,31
32,58	33,59	79,32
32,59	33,60	79,33
32,60	33,61	79,35
32,61	33,62	79,36
32,62	33,63	79,37
32,63	33,64	79,39
32,64	33,65	79,40
32,65	33,66	79,41
32,66	33,67	79,43
32,67	33,68	79,44
32,68	33,69	79,45
32,69	33,70	79,47
32,70	33,71	79,48
32,71	33,72	79,49
32,72	33,73	79,51



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,73	33,74	79,52
32,74	33,75	79,53
32,75	33,76	79,55
32,76	33,77	79,56
32,77	33,78	79,57
32,78	33,79	79,59
32,79	33,80	79,60
32,80	33,81	79,61
32,81	33,82	79,63
32,82	33,83	79,64
32,83	33,84	79,65
32,84	33,85	79,67
32,85	33,86	79,68
32,86	33,87	79,70
32,87	33,88	79,71
32,88	33,89	79,72
32,89	33,90	79,74
32,90	33,91	79,75
32,91	33,92	79,76
32,92	33,93	79,78
32,93	33,94	79,79
32,94	33,95	79,80
32,95	33,96	79,82
32,96	33,97	79,83
32,97	33,98	79,84
32,98	33,99	79,86
32,99	34,00	79,87
33,00	34,01	79,88
33,01	34,02	79,90
33,02	34,03	79,91
33,03	34,04	79,92
33,04	34,05	79,94
33,05	34,06	79,95
33,06	34,07	79,96
33,07	34,08	79,98
33,08	34,09	79,99
33,09	34,10	80,00
33,10	34,11	80,02
33,11	34,12	80,03
33,12	34,13	80,04
33,13	34,14	80,05
33,14	34,15	80,07
33,15	34,16	80,08
33,16	34,17	80,09



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,17	34,18	80,11
33,18	34,19	80,12
33,19	34,20	80,13
33,20	34,21	80,15
33,21	34,22	80,16
33,22	34,23	80,17
33,23	34,24	80,19
33,24	34,25	80,20
33,25	34,26	80,21
33,26	34,27	80,23
33,27	34,28	80,24
33,28	34,29	80,25
33,29	34,30	80,27
33,30	34,31	80,28
33,31	34,32	80,29
33,32	34,33	80,31
33,33	34,34	80,32
33,34	34,35	80,33
33,35	34,36	80,35
33,36	34,37	80,36
33,37	34,38	80,37
33,38	34,39	80,39
33,39	34,40	80,40
33,40	34,41	80,41
33,41	34,42	80,43
33,42	34,43	80,44
33,43	34,44	80,45
33,44	34,45	80,46
33,45	34,46	80,48
33,46	34,47	80,49
33,47	34,48	80,50
33,48	34,49	80,52
33,49	34,50	80,53
33,50	34,51	80,54
33,51	34,52	80,56
33,52	34,53	80,57
33,53	34,54	80,58
33,54	34,55	80,60
33,55	34,56	80,61
33,56	34,57	80,62
33,57	34,58	80,64
33,58	34,59	80,65
33,59	34,60	80,66
33,60	34,61	80,68



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
33,61	34,62	80,69
33,62	34,63	80,70
33,63	34,64	80,71
33,64	34,65	80,73
33,65	34,66	80,74
33,66	34,67	80,75
33,67	34,68	80,77
33,68	34,69	80,78
33,69	34,70	80,79
33,70	34,71	80,81
33,71	34,72	80,82
33,72	34,73	80,83
33,73	34,74	80,85
33,74	34,75	80,86
33,75	34,76	80,87
33,76	34,77	80,88
33,77	34,78	80,90
33,78	34,79	80,91
33,79	34,80	80,92
33,80	34,81	80,94
33,81	34,82	80,95
33,82	34,83	80,96
33,83	34,84	80,98
33,84	34,85	80,99
33,85	34,86	81,00
33,86	34,87	81,01
33,87	34,88	81,03
33,88	34,89	81,04
33,89	34,90	81,05
33,90	34,91	81,07
33,91	34,92	81,08
33,92	34,93	81,09
33,93	34,94	81,11
33,94	34,95	81,12
33,95	34,96	81,13
33,96	34,97	81,14
33,97	34,98	81,16
33,98	34,99	81,17
33,99	35,00	81,18
34,00	35,01	81,20
34,01	35,02	81,21
34,02	35,03	81,22
34,03	35,04	81,24
34,04	35,05	81,25



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,05	35,06	81,26
34,06	35,07	81,27
34,07	35,08	81,29
34,08	35,09	81,30
34,09	35,10	81,31
34,10	35,11	81,33
34,11	35,12	81,34
34,12	35,13	81,35
34,13	35,14	81,36
34,14	35,15	81,38
34,15	35,16	81,39
34,16	35,17	81,40
34,17	35,18	81,42
34,18	35,19	81,43
34,19	35,20	81,44
34,20	35,21	81,46
34,21	35,22	81,47
34,22	35,23	81,48
34,23	35,24	81,49
34,24	35,25	81,51
34,25	35,26	81,52
34,26	35,27	81,53
34,27	35,28	81,55
34,28	35,29	81,56
34,29	35,30	81,57
34,30	35,31	81,58
34,31	35,32	81,60
34,32	35,33	81,61
34,33	35,34	81,62
34,34	35,35	81,64
34,35	35,36	81,65
34,36	35,37	81,66
34,37	35,38	81,67
34,38	35,39	81,69
34,39	35,40	81,70
34,40	35,41	81,71
34,41	35,42	81,73
34,42	35,43	81,74
34,43	35,44	81,75
34,44	35,45	81,76
34,45	35,46	81,78
34,46	35,47	81,79
34,47	35,48	81,80
34,48	35,49	81,81



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,49	35,50	81,83
34,50	35,51	81,84
34,51	35,52	81,85
34,52	35,53	81,87
34,53	35,54	81,88
34,54	35,55	81,89
34,55	35,56	81,90
34,56	35,57	81,92
34,57	35,58	81,93
34,58	35,59	81,94
34,59	35,60	81,96
34,60	35,61	81,97
34,61	35,62	81,98
34,62	35,63	81,99
34,63	35,64	82,01
34,64	35,65	82,02
34,65	35,66	82,03
34,66	35,67	82,04
34,67	35,68	82,06
34,68	35,69	82,07
34,69	35,70	82,08
34,70	35,71	82,10
34,71	35,72	82,11
34,72	35,73	82,12
34,73	35,74	82,13
34,74	35,75	82,15
34,75	35,76	82,16
34,76	35,77	82,17
34,77	35,78	82,18
34,78	35,79	82,20
34,79	35,80	82,21
34,80	35,81	82,22
34,81	35,82	82,23
34,82	35,83	82,25
34,83	35,84	82,26
34,84	35,85	82,27
34,85	35,86	82,29
34,86	35,87	82,30
34,87	35,88	82,31
34,88	35,89	82,32
34,89	35,90	82,34
34,90	35,91	82,35
34,91	35,92	82,36
34,92	35,93	82,37



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,93	35,94	82,39
34,94	35,95	82,40
34,95	35,96	82,41
34,96	35,97	82,42
34,97	35,98	82,44
34,98	35,99	82,45
34,99	36,00	82,46
35,00	36,01	82,48
35,01	36,02	82,49
35,02	36,03	82,50
35,03	36,04	82,51
35,04	36,05	82,53
35,05	36,06	82,54
35,06	36,07	82,55
35,07	36,08	82,56
35,08	36,09	82,58
35,09	36,10	82,59
35,10	36,11	82,60
35,11	36,12	82,61
35,12	36,13	82,63
35,13	36,14	82,64
35,14	36,15	82,65
35,15	36,16	82,66
35,16	36,17	82,68
35,17	36,18	82,69
35,18	36,19	82,70
35,19	36,20	82,71
35,20	36,21	82,73
35,21	36,22	82,74
35,22	36,23	82,75
35,23	36,24	82,76
35,24	36,25	82,78
35,25	36,26	82,79
35,26	36,27	82,80
35,27	36,28	82,81
35,28	36,29	82,83
35,29	36,30	82,84
35,30	36,31	82,85
35,31	36,32	82,86
35,32	36,33	82,88
35,33	36,34	82,89
35,34	36,35	82,90
35,35	36,36	82,91
35,36	36,37	82,93



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
35,37	36,38	82,94
35,38	36,39	82,95
35,39	36,40	82,96
35,40	36,41	82,98
35,41	36,42	82,99
35,42	36,43	83,00
35,43	36,44	83,01
35,44	36,45	83,03
35,45	36,46	83,04
35,46	36,47	83,05
35,47	36,48	83,06
35,48	36,49	83,08
35,49	36,50	83,09
35,50	36,51	83,10
35,51	36,52	83,11
35,52	36,53	83,13
35,53	36,54	83,14
35,54	36,55	83,15
35,55	36,56	83,16
35,56	36,57	83,18
35,57	36,58	83,19
35,58	36,59	83,20
35,59	36,60	83,21
35,60	36,61	83,23
35,61	36,62	83,24
35,62	36,63	83,25
35,63	36,64	83,26
35,64	36,65	83,27
35,65	36,66	83,29
35,66	36,67	83,30
35,67	36,68	83,31
35,68	36,69	83,32
35,69	36,70	83,34
35,70	36,71	83,35
35,71	36,72	83,36
35,72	36,73	83,37
35,73	36,74	83,39
35,74	36,75	83,40
35,75	36,76	83,41
35,76	36,77	83,42
35,77	36,78	83,44
35,78	36,79	83,45
35,79	36,80	83,46
35,80	36,81	83,47



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
35,81	36,82	83,48
35,82	36,83	83,50
35,83	36,84	83,51
35,84	36,85	83,52
35,85	36,86	83,53
35,86	36,87	83,55
35,87	36,88	83,56
35,88	36,89	83,57
35,89	36,90	83,58
35,90	36,91	83,60
35,91	36,92	83,61
35,92	36,93	83,62
35,93	36,94	83,63
35,94	36,95	83,64
35,95	36,96	83,66
35,96	36,97	83,67
35,97	36,98	83,68
35,98	36,99	83,69
35,99	37,00	83,71
36,00	37,01	83,72
36,01	37,02	83,73
36,02	37,03	83,74
36,03	37,04	83,76
36,04	37,05	83,77
36,05	37,06	83,78
36,06	37,07	83,79
36,07	37,08	83,80
36,08	37,09	83,82
36,09	37,10	83,83
36,10	37,11	83,84
36,11	37,12	83,85
36,12	37,13	83,87
36,13	37,14	83,88
36,14	37,15	83,89
36,15	37,16	83,90
36,16	37,17	83,91
36,17	37,18	83,93
36,18	37,19	83,94
36,19	37,20	83,95
36,20	37,21	83,96
36,21	37,22	83,97
36,22	37,23	83,99
36,23	37,24	84,00
36,24	37,25	84,01



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
36,25	37,26	84,02
36,26	37,27	84,04
36,27	37,28	84,05
36,28	37,29	84,06
36,29	37,30	84,07
36,30	37,31	84,08
36,31	37,32	84,10
36,32	37,33	84,11
36,33	37,34	84,12
36,34	37,35	84,13
36,35	37,36	84,15
36,36	37,37	84,16
36,37	37,38	84,17
36,38	37,39	84,18
36,39	37,40	84,19
36,40	37,41	84,21
36,41	37,42	84,22
36,42	37,43	84,23
36,43	37,44	84,24
36,44	37,45	84,25
36,45	37,46	84,27
36,46	37,47	84,28
36,47	37,48	84,29
36,48	37,49	84,30
36,49	37,50	84,31
36,50	37,51	84,33
36,51	37,52	84,34
36,52	37,53	84,35
36,53	37,54	84,36
36,54	37,55	84,38
36,55	37,56	84,39
36,56	37,57	84,40
36,57	37,58	84,41
36,58	37,59	84,42
36,59	37,60	84,44
36,60	37,61	84,45
36,61	37,62	84,46
36,62	37,63	84,47
36,63	37,64	84,48
36,64	37,65	84,50
36,65	37,66	84,51
36,66	37,67	84,52
36,67	37,68	84,53
36,68	37,69	84,54



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
36,69	37,70	84,56
36,70	37,71	84,57
36,71	37,72	84,58
36,72	37,73	84,59
36,73	37,74	84,60
36,74	37,75	84,62
36,75	37,76	84,63
36,76	37,77	84,64
36,77	37,78	84,65
36,78	37,79	84,66
36,79	37,80	84,68
36,80	37,81	84,69
36,81	37,82	84,70
36,82	37,83	84,71
36,83	37,84	84,72
36,84	37,85	84,74
36,85	37,86	84,75
36,86	37,87	84,76
36,87	37,88	84,77
36,88	37,89	84,78
36,89	37,90	84,80
36,90	37,91	84,81
36,91	37,92	84,82
36,92	37,93	84,83
36,93	37,94	84,84
36,94	37,95	84,86
36,95	37,96	84,87
36,96	37,97	84,88
36,97	37,98	84,89
36,98	37,99	84,90
36,99	38,00	84,91
37,00	38,01	84,93
37,01	38,02	84,94
37,02	38,03	84,95
37,03	38,04	84,96
37,04	38,05	84,97
37,05	38,06	84,99
37,06	38,07	85,00
37,07	38,08	85,01
37,08	38,09	85,02
37,09	38,10	85,03
37,10	38,11	85,05
37,11	38,12	85,06
37,12	38,13	85,07



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
37,13	38,14	85,08
37,14	38,15	85,09
37,15	38,16	85,10
37,16	38,17	85,12
37,17	38,18	85,13
37,18	38,19	85,14
37,19	38,20	85,15
37,20	38,21	85,16
37,21	38,22	85,18
37,22	38,23	85,19
37,23	38,24	85,20
37,24	38,25	85,21
37,25	38,26	85,22
37,26	38,27	85,24
37,27	38,28	85,25
37,28	38,29	85,26
37,29	38,30	85,27
37,30	38,31	85,28
37,31	38,32	85,29
37,32	38,33	85,31
37,33	38,34	85,32
37,34	38,35	85,33
37,35	38,36	85,34
37,36	38,37	85,35
37,37	38,38	85,36
37,38	38,39	85,38
37,39	38,40	85,39
37,40	38,41	85,40
37,41	38,42	85,41
37,42	38,43	85,42
37,43	38,44	85,44
37,44	38,45	85,45
37,45	38,46	85,46
37,46	38,47	85,47
37,47	38,48	85,48
37,48	38,49	85,49
37,49	38,50	85,51
37,50	38,51	85,52
37,51	38,52	85,53
37,52	38,53	85,54
37,53	38,54	85,55
37,54	38,55	85,56
37,55	38,56	85,58
37,56	38,57	85,59



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
37,57	38,58	85,60
37,58	38,59	85,61
37,59	38,60	85,62
37,60	38,61	85,63
37,61	38,62	85,65
37,62	38,63	85,66
37,63	38,64	85,67
37,64	38,65	85,68
37,65	38,66	85,69
37,66	38,67	85,71
37,67	38,68	85,72
37,68	38,69	85,73
37,69	38,70	85,74
37,70	38,71	85,75
37,71	38,72	85,76
37,72	38,73	85,78
37,73	38,74	85,79
37,74	38,75	85,80
37,75	38,76	85,81
37,76	38,77	85,82
37,77	38,78	85,83
37,78	38,79	85,84
37,79	38,80	85,86
37,80	38,81	85,87
37,81	38,82	85,88
37,82	38,83	85,89
37,83	38,84	85,90
37,84	38,85	85,91
37,85	38,86	85,93
37,86	38,87	85,94
37,87	38,88	85,95
37,88	38,89	85,96
37,89	38,90	85,97
37,90	38,91	85,98
37,91	38,92	86,00
37,92	38,93	86,01
37,93	38,94	86,02
37,94	38,95	86,03
37,95	38,96	86,04
37,96	38,97	86,05
37,97	38,98	86,07
37,98	38,99	86,08
37,99	39,00	86,09
38,00	39,01	86,10



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
38,01	39,02	86,11
38,02	39,03	86,12
38,03	39,04	86,13
38,04	39,05	86,15
38,05	39,06	86,16
38,06	39,07	86,17
38,07	39,08	86,18
38,08	39,09	86,19
38,09	39,10	86,20
38,10	39,11	86,22
38,11	39,12	86,23
38,12	39,13	86,24
38,13	39,14	86,25
38,14	39,15	86,26
38,15	39,16	86,27
38,16	39,17	86,28
38,17	39,18	86,30
38,18	39,19	86,31
38,19	39,20	86,32
38,20	39,21	86,33
38,21	39,22	86,34
38,22	39,23	86,35
38,23	39,24	86,36
38,24	39,25	86,38
38,25	39,26	86,39
38,26	39,27	86,40
38,27	39,28	86,41
38,28	39,29	86,42
38,29	39,30	86,43
38,30	39,31	86,45
38,31	39,32	86,46
38,32	39,33	86,47
38,33	39,34	86,48
38,34	39,35	86,49
38,35	39,36	86,50
38,36	39,37	86,51
38,37	39,38	86,53
38,38	39,39	86,54
38,39	39,40	86,55
38,40	39,41	86,56
38,41	39,42	86,57
38,42	39,43	86,58
38,43	39,44	86,59
38,44	39,45	86,61



R458A		
V1.0_R458A		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
38,45	39,46	86,62
38,46	39,47	86,63
38,47	39,48	86,64
38,48	39,49	86,65
38,49	39,50	86,66
38,50	39,51	86,67
38,51	39,52	86,68
38,52	39,53	86,70
38,53	39,54	86,71
38,54	39,55	86,72
38,55	39,56	86,73
38,56	39,57	86,74
38,57	39,58	86,75
38,58	39,59	86,76
38,59	39,60	86,78
38,60	39,61	86,79
38,61	39,62	86,80
38,62	39,63	86,81
38,63	39,64	86,82
38,64	39,65	86,83
38,65	39,66	86,84
38,66	39,67	86,86
38,67	39,68	86,87
38,68	39,69	86,88
38,69	39,70	86,89
38,70	39,71	86,90
38,71	39,72	86,91
38,72	39,73	86,92
38,73	39,74	86,93
38,74	39,75	86,95
38,75	39,76	86,96
38,76	39,77	86,97
38,77	39,78	86,98
38,78	39,79	86,99
38,79	39,80	87,00
38,80	39,81	87,01
38,81	39,82	87,02
38,82	39,83	87,04
38,83	39,84	87,05
38,84	39,85	87,06
38,85	39,86	87,07