



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-68,03
-0,70	0,31	-67,48
-0,69	0,32	-66,95
-0,68	0,33	-66,43
-0,67	0,34	-65,92
-0,66	0,35	-65,42
-0,65	0,36	-64,94
-0,64	0,37	-64,47
-0,63	0,38	-64,00
-0,62	0,39	-63,55
-0,61	0,40	-63,10
-0,60	0,41	-62,67
-0,59	0,42	-62,24
-0,58	0,43	-61,82
-0,57	0,44	-61,41
-0,56	0,45	-61,01
-0,55	0,46	-60,61
-0,54	0,47	-60,22
-0,53	0,48	-59,84
-0,52	0,49	-59,46
-0,51	0,50	-59,09
-0,50	0,51	-58,72
-0,49	0,52	-58,36
-0,48	0,53	-58,01
-0,47	0,54	-57,66
-0,46	0,55	-57,32
-0,45	0,56	-56,98
-0,44	0,57	-56,64
-0,43	0,58	-56,31
-0,42	0,59	-55,99
-0,41	0,60	-55,67
-0,40	0,61	-55,35
-0,39	0,62	-55,04
-0,38	0,63	-54,73
-0,37	0,64	-54,43
-0,36	0,65	-54,13
-0,35	0,66	-53,83
-0,34	0,67	-53,53
-0,33	0,68	-53,24
-0,32	0,69	-52,96
-0,31	0,70	-52,67
-0,30	0,71	-52,39
-0,29	0,72	-52,12
-0,28	0,73	-51,84



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-51,57
-0,26	0,75	-51,30
-0,25	0,76	-51,04
-0,24	0,77	-50,77
-0,23	0,78	-50,51
-0,22	0,79	-50,26
-0,21	0,80	-50,00
-0,20	0,81	-49,75
-0,19	0,82	-49,50
-0,18	0,83	-49,25
-0,17	0,84	-49,01
-0,16	0,85	-48,76
-0,15	0,86	-48,52
-0,14	0,87	-48,28
-0,13	0,88	-48,05
-0,12	0,89	-47,81
-0,11	0,90	-47,58
-0,10	0,91	-47,35
-0,09	0,92	-47,12
-0,08	0,93	-46,89
-0,07	0,94	-46,67
-0,06	0,95	-46,45
-0,05	0,96	-46,23
-0,04	0,97	-46,01
-0,03	0,98	-45,79
-0,02	0,99	-45,57
-0,01	1,00	-45,36
0,00	1,01	-45,15
0,01	1,02	-44,94
0,02	1,03	-44,73
0,03	1,04	-44,52
0,04	1,05	-44,32
0,05	1,06	-44,11
0,06	1,07	-43,91
0,07	1,08	-43,71
0,08	1,09	-43,51
0,09	1,10	-43,31
0,10	1,11	-43,11
0,11	1,12	-42,92
0,12	1,13	-42,72
0,13	1,14	-42,53
0,14	1,15	-42,34
0,15	1,16	-42,15
0,16	1,17	-41,96



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,17	1,18	-41,77
0,18	1,19	-41,58
0,19	1,20	-41,40
0,20	1,21	-41,21
0,21	1,22	-41,03
0,22	1,23	-40,85
0,23	1,24	-40,67
0,24	1,25	-40,49
0,25	1,26	-40,31
0,26	1,27	-40,13
0,27	1,28	-39,96
0,28	1,29	-39,78
0,29	1,30	-39,61
0,30	1,31	-39,43
0,31	1,32	-39,26
0,32	1,33	-39,09
0,33	1,34	-38,92
0,34	1,35	-38,75
0,35	1,36	-38,58
0,36	1,37	-38,42
0,37	1,38	-38,25
0,38	1,39	-38,08
0,39	1,40	-37,92
0,40	1,41	-37,76
0,41	1,42	-37,59
0,42	1,43	-37,43
0,43	1,44	-37,27
0,44	1,45	-37,11
0,45	1,46	-36,95
0,46	1,47	-36,79
0,47	1,48	-36,64
0,48	1,49	-36,48
0,49	1,50	-36,32
0,50	1,51	-36,17
0,51	1,52	-36,01
0,52	1,53	-35,86
0,53	1,54	-35,71
0,54	1,55	-35,56
0,55	1,56	-35,41
0,56	1,57	-35,26
0,57	1,58	-35,11
0,58	1,59	-34,96
0,59	1,60	-34,81
0,60	1,61	-34,66



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,61	1,62	-34,51
0,62	1,63	-34,37
0,63	1,64	-34,22
0,64	1,65	-34,08
0,65	1,66	-33,93
0,66	1,67	-33,79
0,67	1,68	-33,65
0,68	1,69	-33,51
0,69	1,70	-33,36
0,70	1,71	-33,22
0,71	1,72	-33,08
0,72	1,73	-32,94
0,73	1,74	-32,80
0,74	1,75	-32,67
0,75	1,76	-32,53
0,76	1,77	-32,39
0,77	1,78	-32,26
0,78	1,79	-32,12
0,79	1,80	-31,98
0,80	1,81	-31,85
0,81	1,82	-31,72
0,82	1,83	-31,58
0,83	1,84	-31,45
0,84	1,85	-31,32
0,85	1,86	-31,18
0,86	1,87	-31,05
0,87	1,88	-30,92
0,88	1,89	-30,79
0,89	1,90	-30,66
0,90	1,91	-30,53
0,91	1,92	-30,40
0,92	1,93	-30,28
0,93	1,94	-30,15
0,94	1,95	-30,02
0,95	1,96	-29,89
0,96	1,97	-29,77
0,97	1,98	-29,64
0,98	1,99	-29,52
0,99	2,00	-29,39
1,00	2,01	-29,27
1,01	2,02	-29,14
1,02	2,03	-29,02
1,03	2,04	-28,90
1,04	2,05	-28,77



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	-28,65
1,06	2,07	-28,53
1,07	2,08	-28,41
1,08	2,09	-28,29
1,09	2,10	-28,17
1,10	2,11	-28,05
1,11	2,12	-27,93
1,12	2,13	-27,81
1,13	2,14	-27,69
1,14	2,15	-27,57
1,15	2,16	-27,46
1,16	2,17	-27,34
1,17	2,18	-27,22
1,18	2,19	-27,11
1,19	2,20	-26,99
1,20	2,21	-26,88
1,21	2,22	-26,76
1,22	2,23	-26,65
1,23	2,24	-26,53
1,24	2,25	-26,42
1,25	2,26	-26,30
1,26	2,27	-26,19
1,27	2,28	-26,08
1,28	2,29	-25,96
1,29	2,30	-25,85
1,30	2,31	-25,74
1,31	2,32	-25,63
1,32	2,33	-25,52
1,33	2,34	-25,41
1,34	2,35	-25,30
1,35	2,36	-25,19
1,36	2,37	-25,08
1,37	2,38	-24,97
1,38	2,39	-24,86
1,39	2,40	-24,75
1,40	2,41	-24,64
1,41	2,42	-24,54
1,42	2,43	-24,43
1,43	2,44	-24,32
1,44	2,45	-24,21
1,45	2,46	-24,11
1,46	2,47	-24,00
1,47	2,48	-23,90
1,48	2,49	-23,79



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,49	2,50	-23,69
1,50	2,51	-23,58
1,51	2,52	-23,48
1,52	2,53	-23,37
1,53	2,54	-23,27
1,54	2,55	-23,16
1,55	2,56	-23,06
1,56	2,57	-22,96
1,57	2,58	-22,86
1,58	2,59	-22,75
1,59	2,60	-22,65
1,60	2,61	-22,55
1,61	2,62	-22,45
1,62	2,63	-22,35
1,63	2,64	-22,25
1,64	2,65	-22,15
1,65	2,66	-22,04
1,66	2,67	-21,94
1,67	2,68	-21,85
1,68	2,69	-21,75
1,69	2,70	-21,65
1,70	2,71	-21,55
1,71	2,72	-21,45
1,72	2,73	-21,35
1,73	2,74	-21,25
1,74	2,75	-21,15
1,75	2,76	-21,06
1,76	2,77	-20,96
1,77	2,78	-20,86
1,78	2,79	-20,77
1,79	2,80	-20,67
1,80	2,81	-20,57
1,81	2,82	-20,48
1,82	2,83	-20,38
1,83	2,84	-20,29
1,84	2,85	-20,19
1,85	2,86	-20,10
1,86	2,87	-20,00
1,87	2,88	-19,91
1,88	2,89	-19,81
1,89	2,90	-19,72
1,90	2,91	-19,63
1,91	2,92	-19,53
1,92	2,93	-19,44



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,93	2,94	-19,35
1,94	2,95	-19,25
1,95	2,96	-19,16
1,96	2,97	-19,07
1,97	2,98	-18,98
1,98	2,99	-18,88
1,99	3,00	-18,79
2,00	3,01	-18,70
2,01	3,02	-18,61
2,02	3,03	-18,52
2,03	3,04	-18,43
2,04	3,05	-18,34
2,05	3,06	-18,25
2,06	3,07	-18,16
2,07	3,08	-18,07
2,08	3,09	-17,98
2,09	3,10	-17,89
2,10	3,11	-17,80
2,11	3,12	-17,71
2,12	3,13	-17,62
2,13	3,14	-17,54
2,14	3,15	-17,45
2,15	3,16	-17,36
2,16	3,17	-17,27
2,17	3,18	-17,18
2,18	3,19	-17,10
2,19	3,20	-17,01
2,20	3,21	-16,92
2,21	3,22	-16,84
2,22	3,23	-16,75
2,23	3,24	-16,66
2,24	3,25	-16,58
2,25	3,26	-16,49
2,26	3,27	-16,40
2,27	3,28	-16,32
2,28	3,29	-16,23
2,29	3,30	-16,15
2,30	3,31	-16,06
2,31	3,32	-15,98
2,32	3,33	-15,89
2,33	3,34	-15,81
2,34	3,35	-15,73
2,35	3,36	-15,64
2,36	3,37	-15,56



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	-15,47
2,38	3,39	-15,39
2,39	3,40	-15,31
2,40	3,41	-15,22
2,41	3,42	-15,14
2,42	3,43	-15,06
2,43	3,44	-14,98
2,44	3,45	-14,89
2,45	3,46	-14,81
2,46	3,47	-14,73
2,47	3,48	-14,65
2,48	3,49	-14,57
2,49	3,50	-14,48
2,50	3,51	-14,40
2,51	3,52	-14,32
2,52	3,53	-14,24
2,53	3,54	-14,16
2,54	3,55	-14,08
2,55	3,56	-14,00
2,56	3,57	-13,92
2,57	3,58	-13,84
2,58	3,59	-13,76
2,59	3,60	-13,68
2,60	3,61	-13,60
2,61	3,62	-13,52
2,62	3,63	-13,44
2,63	3,64	-13,36
2,64	3,65	-13,28
2,65	3,66	-13,21
2,66	3,67	-13,13
2,67	3,68	-13,05
2,68	3,69	-12,97
2,69	3,70	-12,89
2,70	3,71	-12,81
2,71	3,72	-12,74
2,72	3,73	-12,66
2,73	3,74	-12,58
2,74	3,75	-12,50
2,75	3,76	-12,43
2,76	3,77	-12,35
2,77	3,78	-12,27
2,78	3,79	-12,20
2,79	3,80	-12,12
2,80	3,81	-12,04



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,81	3,82	-11,97
2,82	3,83	-11,89
2,83	3,84	-11,81
2,84	3,85	-11,74
2,85	3,86	-11,66
2,86	3,87	-11,59
2,87	3,88	-11,51
2,88	3,89	-11,44
2,89	3,90	-11,36
2,90	3,91	-11,29
2,91	3,92	-11,21
2,92	3,93	-11,14
2,93	3,94	-11,06
2,94	3,95	-10,99
2,95	3,96	-10,91
2,96	3,97	-10,84
2,97	3,98	-10,77
2,98	3,99	-10,69
2,99	4,00	-10,62
3,00	4,01	-10,55
3,01	4,02	-10,47
3,02	4,03	-10,40
3,03	4,04	-10,33
3,04	4,05	-10,25
3,05	4,06	-10,18
3,06	4,07	-10,11
3,07	4,08	-10,03
3,08	4,09	-9,96
3,09	4,10	-9,89
3,10	4,11	-9,82
3,11	4,12	-9,75
3,12	4,13	-9,67
3,13	4,14	-9,60
3,14	4,15	-9,53
3,15	4,16	-9,46
3,16	4,17	-9,39
3,17	4,18	-9,32
3,18	4,19	-9,25
3,19	4,20	-9,17
3,20	4,21	-9,10
3,21	4,22	-9,03
3,22	4,23	-8,96
3,23	4,24	-8,89
3,24	4,25	-8,82



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
3,25	4,26	-8,75
3,26	4,27	-8,68
3,27	4,28	-8,61
3,28	4,29	-8,54
3,29	4,30	-8,47
3,30	4,31	-8,40
3,31	4,32	-8,33
3,32	4,33	-8,26
3,33	4,34	-8,19
3,34	4,35	-8,12
3,35	4,36	-8,06
3,36	4,37	-7,99
3,37	4,38	-7,92
3,38	4,39	-7,85
3,39	4,40	-7,78
3,40	4,41	-7,71
3,41	4,42	-7,64
3,42	4,43	-7,58
3,43	4,44	-7,51
3,44	4,45	-7,44
3,45	4,46	-7,37
3,46	4,47	-7,30
3,47	4,48	-7,24
3,48	4,49	-7,17
3,49	4,50	-7,10
3,50	4,51	-7,03
3,51	4,52	-6,97
3,52	4,53	-6,90
3,53	4,54	-6,83
3,54	4,55	-6,77
3,55	4,56	-6,70
3,56	4,57	-6,63
3,57	4,58	-6,57
3,58	4,59	-6,50
3,59	4,60	-6,43
3,60	4,61	-6,37
3,61	4,62	-6,30
3,62	4,63	-6,23
3,63	4,64	-6,17
3,64	4,65	-6,10
3,65	4,66	-6,04
3,66	4,67	-5,97
3,67	4,68	-5,91
3,68	4,69	-5,84



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
3,69	4,70	-5,78
3,70	4,71	-5,71
3,71	4,72	-5,65
3,72	4,73	-5,58
3,73	4,74	-5,52
3,74	4,75	-5,45
3,75	4,76	-5,39
3,76	4,77	-5,32
3,77	4,78	-5,26
3,78	4,79	-5,19
3,79	4,80	-5,13
3,80	4,81	-5,06
3,81	4,82	-5,00
3,82	4,83	-4,94
3,83	4,84	-4,87
3,84	4,85	-4,81
3,85	4,86	-4,75
3,86	4,87	-4,68
3,87	4,88	-4,62
3,88	4,89	-4,56
3,89	4,90	-4,49
3,90	4,91	-4,43
3,91	4,92	-4,37
3,92	4,93	-4,30
3,93	4,94	-4,24
3,94	4,95	-4,18
3,95	4,96	-4,11
3,96	4,97	-4,05
3,97	4,98	-3,99
3,98	4,99	-3,93
3,99	5,00	-3,87
4,00	5,01	-3,80
4,01	5,02	-3,74
4,02	5,03	-3,68
4,03	5,04	-3,62
4,04	5,05	-3,56
4,05	5,06	-3,49
4,06	5,07	-3,43
4,07	5,08	-3,37
4,08	5,09	-3,31
4,09	5,10	-3,25
4,10	5,11	-3,19
4,11	5,12	-3,12
4,12	5,13	-3,06



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	-3,00
4,14	5,15	-2,94
4,15	5,16	-2,88
4,16	5,17	-2,82
4,17	5,18	-2,76
4,18	5,19	-2,70
4,19	5,20	-2,64
4,20	5,21	-2,58
4,21	5,22	-2,52
4,22	5,23	-2,46
4,23	5,24	-2,40
4,24	5,25	-2,34
4,25	5,26	-2,28
4,26	5,27	-2,22
4,27	5,28	-2,16
4,28	5,29	-2,10
4,29	5,30	-2,04
4,30	5,31	-1,98
4,31	5,32	-1,92
4,32	5,33	-1,86
4,33	5,34	-1,80
4,34	5,35	-1,74
4,35	5,36	-1,68
4,36	5,37	-1,62
4,37	5,38	-1,56
4,38	5,39	-1,51
4,39	5,40	-1,45
4,40	5,41	-1,39
4,41	5,42	-1,33
4,42	5,43	-1,27
4,43	5,44	-1,21
4,44	5,45	-1,15
4,45	5,46	-1,10
4,46	5,47	-1,04
4,47	5,48	-0,98
4,48	5,49	-0,92
4,49	5,50	-0,86
4,50	5,51	-0,80
4,51	5,52	-0,75
4,52	5,53	-0,69
4,53	5,54	-0,63
4,54	5,55	-0,57
4,55	5,56	-0,52
4,56	5,57	-0,46



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	-0,40
4,58	5,59	-0,34
4,59	5,60	-0,29
4,60	5,61	-0,23
4,61	5,62	-0,17
4,62	5,63	-0,12
4,63	5,64	-0,06
4,64	5,65	0,00
4,65	5,66	0,06
4,66	5,67	0,11
4,67	5,68	0,17
4,68	5,69	0,23
4,69	5,70	0,28
4,70	5,71	0,34
4,71	5,72	0,39
4,72	5,73	0,45
4,73	5,74	0,51
4,74	5,75	0,56
4,75	5,76	0,62
4,76	5,77	0,67
4,77	5,78	0,73
4,78	5,79	0,79
4,79	5,80	0,84
4,80	5,81	0,90
4,81	5,82	0,95
4,82	5,83	1,01
4,83	5,84	1,06
4,84	5,85	1,12
4,85	5,86	1,18
4,86	5,87	1,23
4,87	5,88	1,29
4,88	5,89	1,34
4,89	5,90	1,40
4,90	5,91	1,45
4,91	5,92	1,51
4,92	5,93	1,56
4,93	5,94	1,62
4,94	5,95	1,67
4,95	5,96	1,72
4,96	5,97	1,78
4,97	5,98	1,83
4,98	5,99	1,89
4,99	6,00	1,94
5,00	6,01	2,00



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	2,05
5,02	6,03	2,11
5,03	6,04	2,16
5,04	6,05	2,21
5,05	6,06	2,27
5,06	6,07	2,32
5,07	6,08	2,38
5,08	6,09	2,43
5,09	6,10	2,48
5,10	6,11	2,54
5,11	6,12	2,59
5,12	6,13	2,64
5,13	6,14	2,70
5,14	6,15	2,75
5,15	6,16	2,80
5,16	6,17	2,86
5,17	6,18	2,91
5,18	6,19	2,96
5,19	6,20	3,02
5,20	6,21	3,07
5,21	6,22	3,12
5,22	6,23	3,18
5,23	6,24	3,23
5,24	6,25	3,28
5,25	6,26	3,33
5,26	6,27	3,39
5,27	6,28	3,44
5,28	6,29	3,49
5,29	6,30	3,54
5,30	6,31	3,60
5,31	6,32	3,65
5,32	6,33	3,70
5,33	6,34	3,75
5,34	6,35	3,80
5,35	6,36	3,86
5,36	6,37	3,91
5,37	6,38	3,96
5,38	6,39	4,01
5,39	6,40	4,06
5,40	6,41	4,12
5,41	6,42	4,17
5,42	6,43	4,22
5,43	6,44	4,27
5,44	6,45	4,32



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,45	6,46	4,37
5,46	6,47	4,43
5,47	6,48	4,48
5,48	6,49	4,53
5,49	6,50	4,58
5,50	6,51	4,63
5,51	6,52	4,68
5,52	6,53	4,73
5,53	6,54	4,78
5,54	6,55	4,83
5,55	6,56	4,89
5,56	6,57	4,94
5,57	6,58	4,99
5,58	6,59	5,04
5,59	6,60	5,09
5,60	6,61	5,14
5,61	6,62	5,19
5,62	6,63	5,24
5,63	6,64	5,29
5,64	6,65	5,34
5,65	6,66	5,39
5,66	6,67	5,44
5,67	6,68	5,49
5,68	6,69	5,54
5,69	6,70	5,59
5,70	6,71	5,64
5,71	6,72	5,69
5,72	6,73	5,74
5,73	6,74	5,79
5,74	6,75	5,84
5,75	6,76	5,89
5,76	6,77	5,94
5,77	6,78	5,99
5,78	6,79	6,04
5,79	6,80	6,09
5,80	6,81	6,14
5,81	6,82	6,19
5,82	6,83	6,24
5,83	6,84	6,29
5,84	6,85	6,34
5,85	6,86	6,39
5,86	6,87	6,43
5,87	6,88	6,48
5,88	6,89	6,53



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	6,58
5,90	6,91	6,63
5,91	6,92	6,68
5,92	6,93	6,73
5,93	6,94	6,78
5,94	6,95	6,83
5,95	6,96	6,88
5,96	6,97	6,92
5,97	6,98	6,97
5,98	6,99	7,02
5,99	7,00	7,07
6,00	7,01	7,12
6,01	7,02	7,17
6,02	7,03	7,21
6,03	7,04	7,26
6,04	7,05	7,31
6,05	7,06	7,36
6,06	7,07	7,41
6,07	7,08	7,46
6,08	7,09	7,50
6,09	7,10	7,55
6,10	7,11	7,60
6,11	7,12	7,65
6,12	7,13	7,69
6,13	7,14	7,74
6,14	7,15	7,79
6,15	7,16	7,84
6,16	7,17	7,89
6,17	7,18	7,93
6,18	7,19	7,98
6,19	7,20	8,03
6,20	7,21	8,08
6,21	7,22	8,12
6,22	7,23	8,17
6,23	7,24	8,22
6,24	7,25	8,27
6,25	7,26	8,31
6,26	7,27	8,36
6,27	7,28	8,41
6,28	7,29	8,45
6,29	7,30	8,50
6,30	7,31	8,55
6,31	7,32	8,59
6,32	7,33	8,64



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,33	7,34	8,69
6,34	7,35	8,73
6,35	7,36	8,78
6,36	7,37	8,83
6,37	7,38	8,87
6,38	7,39	8,92
6,39	7,40	8,97
6,40	7,41	9,01
6,41	7,42	9,06
6,42	7,43	9,11
6,43	7,44	9,15
6,44	7,45	9,20
6,45	7,46	9,25
6,46	7,47	9,29
6,47	7,48	9,34
6,48	7,49	9,38
6,49	7,50	9,43
6,50	7,51	9,48
6,51	7,52	9,52
6,52	7,53	9,57
6,53	7,54	9,61
6,54	7,55	9,66
6,55	7,56	9,71
6,56	7,57	9,75
6,57	7,58	9,80
6,58	7,59	9,84
6,59	7,60	9,89
6,60	7,61	9,93
6,61	7,62	9,98
6,62	7,63	10,03
6,63	7,64	10,07
6,64	7,65	10,12
6,65	7,66	10,16
6,66	7,67	10,21
6,67	7,68	10,25
6,68	7,69	10,30
6,69	7,70	10,34
6,70	7,71	10,39
6,71	7,72	10,43
6,72	7,73	10,48
6,73	7,74	10,52
6,74	7,75	10,57
6,75	7,76	10,61
6,76	7,77	10,66



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,77	7,78	10,70
6,78	7,79	10,75
6,79	7,80	10,79
6,80	7,81	10,84
6,81	7,82	10,88
6,82	7,83	10,93
6,83	7,84	10,97
6,84	7,85	11,02
6,85	7,86	11,06
6,86	7,87	11,10
6,87	7,88	11,15
6,88	7,89	11,19
6,89	7,90	11,24
6,90	7,91	11,28
6,91	7,92	11,33
6,92	7,93	11,37
6,93	7,94	11,41
6,94	7,95	11,46
6,95	7,96	11,50
6,96	7,97	11,55
6,97	7,98	11,59
6,98	7,99	11,63
6,99	8,00	11,68
7,00	8,01	11,72
7,01	8,02	11,77
7,02	8,03	11,81
7,03	8,04	11,85
7,04	8,05	11,90
7,05	8,06	11,94
7,06	8,07	11,98
7,07	8,08	12,03
7,08	8,09	12,07
7,09	8,10	12,12
7,10	8,11	12,16
7,11	8,12	12,20
7,12	8,13	12,25
7,13	8,14	12,29
7,14	8,15	12,33
7,15	8,16	12,38
7,16	8,17	12,42
7,17	8,18	12,46
7,18	8,19	12,50
7,19	8,20	12,55
7,20	8,21	12,59



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	12,63
7,22	8,23	12,68
7,23	8,24	12,72
7,24	8,25	12,76
7,25	8,26	12,81
7,26	8,27	12,85
7,27	8,28	12,89
7,28	8,29	12,93
7,29	8,30	12,98
7,30	8,31	13,02
7,31	8,32	13,06
7,32	8,33	13,11
7,33	8,34	13,15
7,34	8,35	13,19
7,35	8,36	13,23
7,36	8,37	13,28
7,37	8,38	13,32
7,38	8,39	13,36
7,39	8,40	13,40
7,40	8,41	13,44
7,41	8,42	13,49
7,42	8,43	13,53
7,43	8,44	13,57
7,44	8,45	13,61
7,45	8,46	13,66
7,46	8,47	13,70
7,47	8,48	13,74
7,48	8,49	13,78
7,49	8,50	13,82
7,50	8,51	13,87
7,51	8,52	13,91
7,52	8,53	13,95
7,53	8,54	13,99
7,54	8,55	14,03
7,55	8,56	14,08
7,56	8,57	14,12
7,57	8,58	14,16
7,58	8,59	14,20
7,59	8,60	14,24
7,60	8,61	14,28
7,61	8,62	14,33
7,62	8,63	14,37
7,63	8,64	14,41
7,64	8,65	14,45



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,65	8,66	14,49
7,66	8,67	14,53
7,67	8,68	14,57
7,68	8,69	14,61
7,69	8,70	14,66
7,70	8,71	14,70
7,71	8,72	14,74
7,72	8,73	14,78
7,73	8,74	14,82
7,74	8,75	14,86
7,75	8,76	14,90
7,76	8,77	14,94
7,77	8,78	14,99
7,78	8,79	15,03
7,79	8,80	15,07
7,80	8,81	15,11
7,81	8,82	15,15
7,82	8,83	15,19
7,83	8,84	15,23
7,84	8,85	15,27
7,85	8,86	15,31
7,86	8,87	15,35
7,87	8,88	15,39
7,88	8,89	15,43
7,89	8,90	15,47
7,90	8,91	15,51
7,91	8,92	15,56
7,92	8,93	15,60
7,93	8,94	15,64
7,94	8,95	15,68
7,95	8,96	15,72
7,96	8,97	15,76
7,97	8,98	15,80
7,98	8,99	15,84
7,99	9,00	15,88
8,00	9,01	15,92
8,01	9,02	15,96
8,02	9,03	16,00
8,03	9,04	16,04
8,04	9,05	16,08
8,05	9,06	16,12
8,06	9,07	16,16
8,07	9,08	16,20
8,08	9,09	16,24



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,09	9,10	16,28
8,10	9,11	16,32
8,11	9,12	16,36
8,12	9,13	16,40
8,13	9,14	16,44
8,14	9,15	16,48
8,15	9,16	16,52
8,16	9,17	16,56
8,17	9,18	16,60
8,18	9,19	16,64
8,19	9,20	16,68
8,20	9,21	16,72
8,21	9,22	16,76
8,22	9,23	16,80
8,23	9,24	16,83
8,24	9,25	16,87
8,25	9,26	16,91
8,26	9,27	16,95
8,27	9,28	16,99
8,28	9,29	17,03
8,29	9,30	17,07
8,30	9,31	17,11
8,31	9,32	17,15
8,32	9,33	17,19
8,33	9,34	17,23
8,34	9,35	17,27
8,35	9,36	17,31
8,36	9,37	17,35
8,37	9,38	17,38
8,38	9,39	17,42
8,39	9,40	17,46
8,40	9,41	17,50
8,41	9,42	17,54
8,42	9,43	17,58
8,43	9,44	17,62
8,44	9,45	17,66
8,45	9,46	17,70
8,46	9,47	17,73
8,47	9,48	17,77
8,48	9,49	17,81
8,49	9,50	17,85
8,50	9,51	17,89
8,51	9,52	17,93
8,52	9,53	17,97



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,53	9,54	18,00
8,54	9,55	18,04
8,55	9,56	18,08
8,56	9,57	18,12
8,57	9,58	18,16
8,58	9,59	18,20
8,59	9,60	18,24
8,60	9,61	18,27
8,61	9,62	18,31
8,62	9,63	18,35
8,63	9,64	18,39
8,64	9,65	18,43
8,65	9,66	18,47
8,66	9,67	18,50
8,67	9,68	18,54
8,68	9,69	18,58
8,69	9,70	18,62
8,70	9,71	18,66
8,71	9,72	18,69
8,72	9,73	18,73
8,73	9,74	18,77
8,74	9,75	18,81
8,75	9,76	18,85
8,76	9,77	18,88
8,77	9,78	18,92
8,78	9,79	18,96
8,79	9,80	19,00
8,80	9,81	19,03
8,81	9,82	19,07
8,82	9,83	19,11
8,83	9,84	19,15
8,84	9,85	19,19
8,85	9,86	19,22
8,86	9,87	19,26
8,87	9,88	19,30
8,88	9,89	19,34
8,89	9,90	19,37
8,90	9,91	19,41
8,91	9,92	19,45
8,92	9,93	19,49
8,93	9,94	19,52
8,94	9,95	19,56
8,95	9,96	19,60
8,96	9,97	19,64



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,97	9,98	19,67
8,98	9,99	19,71
8,99	10,00	19,75
9,00	10,01	19,78
9,01	10,02	19,82
9,02	10,03	19,86
9,03	10,04	19,90
9,04	10,05	19,93
9,05	10,06	19,97
9,06	10,07	20,01
9,07	10,08	20,04
9,08	10,09	20,08
9,09	10,10	20,12
9,10	10,11	20,15
9,11	10,12	20,19
9,12	10,13	20,23
9,13	10,14	20,27
9,14	10,15	20,30
9,15	10,16	20,34
9,16	10,17	20,38
9,17	10,18	20,41
9,18	10,19	20,45
9,19	10,20	20,49
9,20	10,21	20,52
9,21	10,22	20,56
9,22	10,23	20,60
9,23	10,24	20,63
9,24	10,25	20,67
9,25	10,26	20,71
9,26	10,27	20,74
9,27	10,28	20,78
9,28	10,29	20,82
9,29	10,30	20,85
9,30	10,31	20,89
9,31	10,32	20,92
9,32	10,33	20,96
9,33	10,34	21,00
9,34	10,35	21,03
9,35	10,36	21,07
9,36	10,37	21,11
9,37	10,38	21,14
9,38	10,39	21,18
9,39	10,40	21,21
9,40	10,41	21,25



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,41	10,42	21,29
9,42	10,43	21,32
9,43	10,44	21,36
9,44	10,45	21,40
9,45	10,46	21,43
9,46	10,47	21,47
9,47	10,48	21,50
9,48	10,49	21,54
9,49	10,50	21,57
9,50	10,51	21,61
9,51	10,52	21,65
9,52	10,53	21,68
9,53	10,54	21,72
9,54	10,55	21,75
9,55	10,56	21,79
9,56	10,57	21,83
9,57	10,58	21,86
9,58	10,59	21,90
9,59	10,60	21,93
9,60	10,61	21,97
9,61	10,62	22,00
9,62	10,63	22,04
9,63	10,64	22,08
9,64	10,65	22,11
9,65	10,66	22,15
9,66	10,67	22,18
9,67	10,68	22,22
9,68	10,69	22,25
9,69	10,70	22,29
9,70	10,71	22,32
9,71	10,72	22,36
9,72	10,73	22,39
9,73	10,74	22,43
9,74	10,75	22,46
9,75	10,76	22,50
9,76	10,77	22,54
9,77	10,78	22,57
9,78	10,79	22,61
9,79	10,80	22,64
9,80	10,81	22,68
9,81	10,82	22,71
9,82	10,83	22,75
9,83	10,84	22,78
9,84	10,85	22,82



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,85	10,86	22,85
9,86	10,87	22,89
9,87	10,88	22,92
9,88	10,89	22,96
9,89	10,90	22,99
9,90	10,91	23,03
9,91	10,92	23,06
9,92	10,93	23,10
9,93	10,94	23,13
9,94	10,95	23,17
9,95	10,96	23,20
9,96	10,97	23,24
9,97	10,98	23,27
9,98	10,99	23,31
9,99	11,00	23,34
10,00	11,01	23,37
10,01	11,02	23,41
10,02	11,03	23,44
10,03	11,04	23,48
10,04	11,05	23,51
10,05	11,06	23,55
10,06	11,07	23,58
10,07	11,08	23,62
10,08	11,09	23,65
10,09	11,10	23,69
10,10	11,11	23,72
10,11	11,12	23,75
10,12	11,13	23,79
10,13	11,14	23,82
10,14	11,15	23,86
10,15	11,16	23,89
10,16	11,17	23,93
10,17	11,18	23,96
10,18	11,19	23,99
10,19	11,20	24,03
10,20	11,21	24,06
10,21	11,22	24,10
10,22	11,23	24,13
10,23	11,24	24,17
10,24	11,25	24,20
10,25	11,26	24,23
10,26	11,27	24,27
10,27	11,28	24,30
10,28	11,29	24,34



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
10,29	11,30	24,37
10,30	11,31	24,40
10,31	11,32	24,44
10,32	11,33	24,47
10,33	11,34	24,51
10,34	11,35	24,54
10,35	11,36	24,57
10,36	11,37	24,61
10,37	11,38	24,64
10,38	11,39	24,68
10,39	11,40	24,71
10,40	11,41	24,74
10,41	11,42	24,78
10,42	11,43	24,81
10,43	11,44	24,84
10,44	11,45	24,88
10,45	11,46	24,91
10,46	11,47	24,95
10,47	11,48	24,98
10,48	11,49	25,01
10,49	11,50	25,05
10,50	11,51	25,08
10,51	11,52	25,11
10,52	11,53	25,15
10,53	11,54	25,18
10,54	11,55	25,21
10,55	11,56	25,25
10,56	11,57	25,28
10,57	11,58	25,31
10,58	11,59	25,35
10,59	11,60	25,38
10,60	11,61	25,41
10,61	11,62	25,45
10,62	11,63	25,48
10,63	11,64	25,51
10,64	11,65	25,55
10,65	11,66	25,58
10,66	11,67	25,61
10,67	11,68	25,65
10,68	11,69	25,68
10,69	11,70	25,71
10,70	11,71	25,75
10,71	11,72	25,78
10,72	11,73	25,81



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
10,73	11,74	25,85
10,74	11,75	25,88
10,75	11,76	25,91
10,76	11,77	25,95
10,77	11,78	25,98
10,78	11,79	26,01
10,79	11,80	26,04
10,80	11,81	26,08
10,81	11,82	26,11
10,82	11,83	26,14
10,83	11,84	26,18
10,84	11,85	26,21
10,85	11,86	26,24
10,86	11,87	26,27
10,87	11,88	26,31
10,88	11,89	26,34
10,89	11,90	26,37
10,90	11,91	26,41
10,91	11,92	26,44
10,92	11,93	26,47
10,93	11,94	26,50
10,94	11,95	26,54
10,95	11,96	26,57
10,96	11,97	26,60
10,97	11,98	26,63
10,98	11,99	26,67
10,99	12,00	26,70
11,00	12,01	26,73
11,01	12,02	26,76
11,02	12,03	26,80
11,03	12,04	26,83
11,04	12,05	26,86
11,05	12,06	26,89
11,06	12,07	26,93
11,07	12,08	26,96
11,08	12,09	26,99
11,09	12,10	27,02
11,10	12,11	27,06
11,11	12,12	27,09
11,12	12,13	27,12
11,13	12,14	27,15
11,14	12,15	27,19
11,15	12,16	27,22
11,16	12,17	27,25



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,17	12,18	27,28
11,18	12,19	27,31
11,19	12,20	27,35
11,20	12,21	27,38
11,21	12,22	27,41
11,22	12,23	27,44
11,23	12,24	27,47
11,24	12,25	27,51
11,25	12,26	27,54
11,26	12,27	27,57
11,27	12,28	27,60
11,28	12,29	27,63
11,29	12,30	27,67
11,30	12,31	27,70
11,31	12,32	27,73
11,32	12,33	27,76
11,33	12,34	27,79
11,34	12,35	27,83
11,35	12,36	27,86
11,36	12,37	27,89
11,37	12,38	27,92
11,38	12,39	27,95
11,39	12,40	27,99
11,40	12,41	28,02
11,41	12,42	28,05
11,42	12,43	28,08
11,43	12,44	28,11
11,44	12,45	28,14
11,45	12,46	28,18
11,46	12,47	28,21
11,47	12,48	28,24
11,48	12,49	28,27
11,49	12,50	28,30
11,50	12,51	28,33
11,51	12,52	28,37
11,52	12,53	28,40
11,53	12,54	28,43
11,54	12,55	28,46
11,55	12,56	28,49
11,56	12,57	28,52
11,57	12,58	28,55
11,58	12,59	28,59
11,59	12,60	28,62
11,60	12,61	28,65



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	28,68
11,62	12,63	28,71
11,63	12,64	28,74
11,64	12,65	28,77
11,65	12,66	28,80
11,66	12,67	28,84
11,67	12,68	28,87
11,68	12,69	28,90
11,69	12,70	28,93
11,70	12,71	28,96
11,71	12,72	28,99
11,72	12,73	29,02
11,73	12,74	29,05
11,74	12,75	29,09
11,75	12,76	29,12
11,76	12,77	29,15
11,77	12,78	29,18
11,78	12,79	29,21
11,79	12,80	29,24
11,80	12,81	29,27
11,81	12,82	29,30
11,82	12,83	29,33
11,83	12,84	29,37
11,84	12,85	29,40
11,85	12,86	29,43
11,86	12,87	29,46
11,87	12,88	29,49
11,88	12,89	29,52
11,89	12,90	29,55
11,90	12,91	29,58
11,91	12,92	29,61
11,92	12,93	29,64
11,93	12,94	29,67
11,94	12,95	29,70
11,95	12,96	29,74
11,96	12,97	29,77
11,97	12,98	29,80
11,98	12,99	29,83
11,99	13,00	29,86
12,00	13,01	29,89
12,01	13,02	29,92
12,02	13,03	29,95
12,03	13,04	29,98
12,04	13,05	30,01



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,05	13,06	30,04
12,06	13,07	30,07
12,07	13,08	30,10
12,08	13,09	30,13
12,09	13,10	30,16
12,10	13,11	30,19
12,11	13,12	30,23
12,12	13,13	30,26
12,13	13,14	30,29
12,14	13,15	30,32
12,15	13,16	30,35
12,16	13,17	30,38
12,17	13,18	30,41
12,18	13,19	30,44
12,19	13,20	30,47
12,20	13,21	30,50
12,21	13,22	30,53
12,22	13,23	30,56
12,23	13,24	30,59
12,24	13,25	30,62
12,25	13,26	30,65
12,26	13,27	30,68
12,27	13,28	30,71
12,28	13,29	30,74
12,29	13,30	30,77
12,30	13,31	30,80
12,31	13,32	30,83
12,32	13,33	30,86
12,33	13,34	30,89
12,34	13,35	30,92
12,35	13,36	30,95
12,36	13,37	30,98
12,37	13,38	31,01
12,38	13,39	31,04
12,39	13,40	31,07
12,40	13,41	31,10
12,41	13,42	31,13
12,42	13,43	31,16
12,43	13,44	31,19
12,44	13,45	31,22
12,45	13,46	31,25
12,46	13,47	31,28
12,47	13,48	31,31
12,48	13,49	31,34



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	31,37
12,50	13,51	31,40
12,51	13,52	31,43
12,52	13,53	31,46
12,53	13,54	31,49
12,54	13,55	31,52
12,55	13,56	31,55
12,56	13,57	31,58
12,57	13,58	31,61
12,58	13,59	31,64
12,59	13,60	31,67
12,60	13,61	31,70
12,61	13,62	31,73
12,62	13,63	31,76
12,63	13,64	31,79
12,64	13,65	31,82
12,65	13,66	31,85
12,66	13,67	31,88
12,67	13,68	31,91
12,68	13,69	31,93
12,69	13,70	31,96
12,70	13,71	31,99
12,71	13,72	32,02
12,72	13,73	32,05
12,73	13,74	32,08
12,74	13,75	32,11
12,75	13,76	32,14
12,76	13,77	32,17
12,77	13,78	32,20
12,78	13,79	32,23
12,79	13,80	32,26
12,80	13,81	32,29
12,81	13,82	32,32
12,82	13,83	32,35
12,83	13,84	32,38
12,84	13,85	32,41
12,85	13,86	32,43
12,86	13,87	32,46
12,87	13,88	32,49
12,88	13,89	32,52
12,89	13,90	32,55
12,90	13,91	32,58
12,91	13,92	32,61
12,92	13,93	32,64



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	32,67
12,94	13,95	32,70
12,95	13,96	32,73
12,96	13,97	32,76
12,97	13,98	32,78
12,98	13,99	32,81
12,99	14,00	32,84
13,00	14,01	32,87
13,01	14,02	32,90
13,02	14,03	32,93
13,03	14,04	32,96
13,04	14,05	32,99
13,05	14,06	33,02
13,06	14,07	33,05
13,07	14,08	33,07
13,08	14,09	33,10
13,09	14,10	33,13
13,10	14,11	33,16
13,11	14,12	33,19
13,12	14,13	33,22
13,13	14,14	33,25
13,14	14,15	33,28
13,15	14,16	33,31
13,16	14,17	33,33
13,17	14,18	33,36
13,18	14,19	33,39
13,19	14,20	33,42
13,20	14,21	33,45
13,21	14,22	33,48
13,22	14,23	33,51
13,23	14,24	33,54
13,24	14,25	33,56
13,25	14,26	33,59
13,26	14,27	33,62
13,27	14,28	33,65
13,28	14,29	33,68
13,29	14,30	33,71
13,30	14,31	33,74
13,31	14,32	33,76
13,32	14,33	33,79
13,33	14,34	33,82
13,34	14,35	33,85
13,35	14,36	33,88
13,36	14,37	33,91



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,37	14,38	33,94
13,38	14,39	33,96
13,39	14,40	33,99
13,40	14,41	34,02
13,41	14,42	34,05
13,42	14,43	34,08
13,43	14,44	34,11
13,44	14,45	34,13
13,45	14,46	34,16
13,46	14,47	34,19
13,47	14,48	34,22
13,48	14,49	34,25
13,49	14,50	34,28
13,50	14,51	34,30
13,51	14,52	34,33
13,52	14,53	34,36
13,53	14,54	34,39
13,54	14,55	34,42
13,55	14,56	34,45
13,56	14,57	34,47
13,57	14,58	34,50
13,58	14,59	34,53
13,59	14,60	34,56
13,60	14,61	34,59
13,61	14,62	34,61
13,62	14,63	34,64
13,63	14,64	34,67
13,64	14,65	34,70
13,65	14,66	34,73
13,66	14,67	34,75
13,67	14,68	34,78
13,68	14,69	34,81
13,69	14,70	34,84
13,70	14,71	34,87
13,71	14,72	34,90
13,72	14,73	34,92
13,73	14,74	34,95
13,74	14,75	34,98
13,75	14,76	35,01
13,76	14,77	35,03
13,77	14,78	35,06
13,78	14,79	35,09
13,79	14,80	35,12
13,80	14,81	35,15



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,81	14,82	35,17
13,82	14,83	35,20
13,83	14,84	35,23
13,84	14,85	35,26
13,85	14,86	35,29
13,86	14,87	35,31
13,87	14,88	35,34
13,88	14,89	35,37
13,89	14,90	35,40
13,90	14,91	35,42
13,91	14,92	35,45
13,92	14,93	35,48
13,93	14,94	35,51
13,94	14,95	35,54
13,95	14,96	35,56
13,96	14,97	35,59
13,97	14,98	35,62
13,98	14,99	35,65
13,99	15,00	35,67
14,00	15,01	35,70
14,01	15,02	35,73
14,02	15,03	35,76
14,03	15,04	35,78
14,04	15,05	35,81
14,05	15,06	35,84
14,06	15,07	35,87
14,07	15,08	35,89
14,08	15,09	35,92
14,09	15,10	35,95
14,10	15,11	35,98
14,11	15,12	36,00
14,12	15,13	36,03
14,13	15,14	36,06
14,14	15,15	36,09
14,15	15,16	36,11
14,16	15,17	36,14
14,17	15,18	36,17
14,18	15,19	36,20
14,19	15,20	36,22
14,20	15,21	36,25
14,21	15,22	36,28
14,22	15,23	36,30
14,23	15,24	36,33
14,24	15,25	36,36



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
14,25	15,26	36,39
14,26	15,27	36,41
14,27	15,28	36,44
14,28	15,29	36,47
14,29	15,30	36,50
14,30	15,31	36,52
14,31	15,32	36,55
14,32	15,33	36,58
14,33	15,34	36,60
14,34	15,35	36,63
14,35	15,36	36,66
14,36	15,37	36,69
14,37	15,38	36,71
14,38	15,39	36,74
14,39	15,40	36,77
14,40	15,41	36,79
14,41	15,42	36,82
14,42	15,43	36,85
14,43	15,44	36,87
14,44	15,45	36,90
14,45	15,46	36,93
14,46	15,47	36,96
14,47	15,48	36,98
14,48	15,49	37,01
14,49	15,50	37,04
14,50	15,51	37,06
14,51	15,52	37,09
14,52	15,53	37,12
14,53	15,54	37,14
14,54	15,55	37,17
14,55	15,56	37,20
14,56	15,57	37,22
14,57	15,58	37,25
14,58	15,59	37,28
14,59	15,60	37,31
14,60	15,61	37,33
14,61	15,62	37,36
14,62	15,63	37,39
14,63	15,64	37,41
14,64	15,65	37,44
14,65	15,66	37,47
14,66	15,67	37,49
14,67	15,68	37,52
14,68	15,69	37,55



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	37,57
14,70	15,71	37,60
14,71	15,72	37,63
14,72	15,73	37,65
14,73	15,74	37,68
14,74	15,75	37,71
14,75	15,76	37,73
14,76	15,77	37,76
14,77	15,78	37,79
14,78	15,79	37,81
14,79	15,80	37,84
14,80	15,81	37,87
14,81	15,82	37,89
14,82	15,83	37,92
14,83	15,84	37,95
14,84	15,85	37,97
14,85	15,86	38,00
14,86	15,87	38,02
14,87	15,88	38,05
14,88	15,89	38,08
14,89	15,90	38,10
14,90	15,91	38,13
14,91	15,92	38,16
14,92	15,93	38,18
14,93	15,94	38,21
14,94	15,95	38,24
14,95	15,96	38,26
14,96	15,97	38,29
14,97	15,98	38,32
14,98	15,99	38,34
14,99	16,00	38,37
15,00	16,01	38,39
15,01	16,02	38,42
15,02	16,03	38,45
15,03	16,04	38,47
15,04	16,05	38,50
15,05	16,06	38,53
15,06	16,07	38,55
15,07	16,08	38,58
15,08	16,09	38,60
15,09	16,10	38,63
15,10	16,11	38,66
15,11	16,12	38,68
15,12	16,13	38,71



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	38,73
15,14	16,15	38,76
15,15	16,16	38,79
15,16	16,17	38,81
15,17	16,18	38,84
15,18	16,19	38,87
15,19	16,20	38,89
15,20	16,21	38,92
15,21	16,22	38,94
15,22	16,23	38,97
15,23	16,24	39,00
15,24	16,25	39,02
15,25	16,26	39,05
15,26	16,27	39,07
15,27	16,28	39,10
15,28	16,29	39,13
15,29	16,30	39,15
15,30	16,31	39,18
15,31	16,32	39,20
15,32	16,33	39,23
15,33	16,34	39,26
15,34	16,35	39,28
15,35	16,36	39,31
15,36	16,37	39,33
15,37	16,38	39,36
15,38	16,39	39,38
15,39	16,40	39,41
15,40	16,41	39,44
15,41	16,42	39,46
15,42	16,43	39,49
15,43	16,44	39,51
15,44	16,45	39,54
15,45	16,46	39,57
15,46	16,47	39,59
15,47	16,48	39,62
15,48	16,49	39,64
15,49	16,50	39,67
15,50	16,51	39,69
15,51	16,52	39,72
15,52	16,53	39,75
15,53	16,54	39,77
15,54	16,55	39,80
15,55	16,56	39,82
15,56	16,57	39,85



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,57	16,58	39,87
15,58	16,59	39,90
15,59	16,60	39,93
15,60	16,61	39,95
15,61	16,62	39,98
15,62	16,63	40,00
15,63	16,64	40,03
15,64	16,65	40,05
15,65	16,66	40,08
15,66	16,67	40,10
15,67	16,68	40,13
15,68	16,69	40,16
15,69	16,70	40,18
15,70	16,71	40,21
15,71	16,72	40,23
15,72	16,73	40,26
15,73	16,74	40,28
15,74	16,75	40,31
15,75	16,76	40,33
15,76	16,77	40,36
15,77	16,78	40,38
15,78	16,79	40,41
15,79	16,80	40,43
15,80	16,81	40,46
15,81	16,82	40,49
15,82	16,83	40,51
15,83	16,84	40,54
15,84	16,85	40,56
15,85	16,86	40,59
15,86	16,87	40,61
15,87	16,88	40,64
15,88	16,89	40,66
15,89	16,90	40,69
15,90	16,91	40,71
15,91	16,92	40,74
15,92	16,93	40,76
15,93	16,94	40,79
15,94	16,95	40,81
15,95	16,96	40,84
15,96	16,97	40,86
15,97	16,98	40,89
15,98	16,99	40,92
15,99	17,00	40,94
16,00	17,01	40,97



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
16,01	17,02	40,99
16,02	17,03	41,02
16,03	17,04	41,04
16,04	17,05	41,07
16,05	17,06	41,09
16,06	17,07	41,12
16,07	17,08	41,14
16,08	17,09	41,17
16,09	17,10	41,19
16,10	17,11	41,22
16,11	17,12	41,24
16,12	17,13	41,27
16,13	17,14	41,29
16,14	17,15	41,32
16,15	17,16	41,34
16,16	17,17	41,37
16,17	17,18	41,39
16,18	17,19	41,42
16,19	17,20	41,44
16,20	17,21	41,47
16,21	17,22	41,49
16,22	17,23	41,52
16,23	17,24	41,54
16,24	17,25	41,57
16,25	17,26	41,59
16,26	17,27	41,62
16,27	17,28	41,64
16,28	17,29	41,67
16,29	17,30	41,69
16,30	17,31	41,71
16,31	17,32	41,74
16,32	17,33	41,76
16,33	17,34	41,79
16,34	17,35	41,81
16,35	17,36	41,84
16,36	17,37	41,86
16,37	17,38	41,89
16,38	17,39	41,91
16,39	17,40	41,94
16,40	17,41	41,96
16,41	17,42	41,99
16,42	17,43	42,01
16,43	17,44	42,04
16,44	17,45	42,06



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,45	17,46	42,09
16,46	17,47	42,11
16,47	17,48	42,14
16,48	17,49	42,16
16,49	17,50	42,18
16,50	17,51	42,21
16,51	17,52	42,23
16,52	17,53	42,26
16,53	17,54	42,28
16,54	17,55	42,31
16,55	17,56	42,33
16,56	17,57	42,36
16,57	17,58	42,38
16,58	17,59	42,41
16,59	17,60	42,43
16,60	17,61	42,45
16,61	17,62	42,48
16,62	17,63	42,50
16,63	17,64	42,53
16,64	17,65	42,55
16,65	17,66	42,58
16,66	17,67	42,60
16,67	17,68	42,63
16,68	17,69	42,65
16,69	17,70	42,67
16,70	17,71	42,70
16,71	17,72	42,72
16,72	17,73	42,75
16,73	17,74	42,77
16,74	17,75	42,80
16,75	17,76	42,82
16,76	17,77	42,85
16,77	17,78	42,87
16,78	17,79	42,89
16,79	17,80	42,92
16,80	17,81	42,94
16,81	17,82	42,97
16,82	17,83	42,99
16,83	17,84	43,02
16,84	17,85	43,04
16,85	17,86	43,06
16,86	17,87	43,09
16,87	17,88	43,11
16,88	17,89	43,14



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	43,16
16,90	17,91	43,19
16,91	17,92	43,21
16,92	17,93	43,23
16,93	17,94	43,26
16,94	17,95	43,28
16,95	17,96	43,31
16,96	17,97	43,33
16,97	17,98	43,35
16,98	17,99	43,38
16,99	18,00	43,40
17,00	18,01	43,43
17,01	18,02	43,45
17,02	18,03	43,47
17,03	18,04	43,50
17,04	18,05	43,52
17,05	18,06	43,55
17,06	18,07	43,57
17,07	18,08	43,60
17,08	18,09	43,62
17,09	18,10	43,64
17,10	18,11	43,67
17,11	18,12	43,69
17,12	18,13	43,72
17,13	18,14	43,74
17,14	18,15	43,76
17,15	18,16	43,79
17,16	18,17	43,81
17,17	18,18	43,83
17,18	18,19	43,86
17,19	18,20	43,88
17,20	18,21	43,91
17,21	18,22	43,93
17,22	18,23	43,95
17,23	18,24	43,98
17,24	18,25	44,00
17,25	18,26	44,03
17,26	18,27	44,05
17,27	18,28	44,07
17,28	18,29	44,10
17,29	18,30	44,12
17,30	18,31	44,15
17,31	18,32	44,17
17,32	18,33	44,19



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	44,22
17,34	18,35	44,24
17,35	18,36	44,26
17,36	18,37	44,29
17,37	18,38	44,31
17,38	18,39	44,34
17,39	18,40	44,36
17,40	18,41	44,38
17,41	18,42	44,41
17,42	18,43	44,43
17,43	18,44	44,45
17,44	18,45	44,48
17,45	18,46	44,50
17,46	18,47	44,52
17,47	18,48	44,55
17,48	18,49	44,57
17,49	18,50	44,60
17,50	18,51	44,62
17,51	18,52	44,64
17,52	18,53	44,67
17,53	18,54	44,69
17,54	18,55	44,71
17,55	18,56	44,74
17,56	18,57	44,76
17,57	18,58	44,78
17,58	18,59	44,81
17,59	18,60	44,83
17,60	18,61	44,85
17,61	18,62	44,88
17,62	18,63	44,90
17,63	18,64	44,93
17,64	18,65	44,95
17,65	18,66	44,97
17,66	18,67	45,00
17,67	18,68	45,02
17,68	18,69	45,04
17,69	18,70	45,07
17,70	18,71	45,09
17,71	18,72	45,11
17,72	18,73	45,14
17,73	18,74	45,16
17,74	18,75	45,18
17,75	18,76	45,21
17,76	18,77	45,23



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
17,77	18,78	45,25
17,78	18,79	45,28
17,79	18,80	45,30
17,80	18,81	45,32
17,81	18,82	45,35
17,82	18,83	45,37
17,83	18,84	45,39
17,84	18,85	45,42
17,85	18,86	45,44
17,86	18,87	45,46
17,87	18,88	45,49
17,88	18,89	45,51
17,89	18,90	45,53
17,90	18,91	45,56
17,91	18,92	45,58
17,92	18,93	45,60
17,93	18,94	45,63
17,94	18,95	45,65
17,95	18,96	45,67
17,96	18,97	45,70
17,97	18,98	45,72
17,98	18,99	45,74
17,99	19,00	45,76
18,00	19,01	45,79
18,01	19,02	45,81
18,02	19,03	45,83
18,03	19,04	45,86
18,04	19,05	45,88
18,05	19,06	45,90
18,06	19,07	45,93
18,07	19,08	45,95
18,08	19,09	45,97
18,09	19,10	46,00
18,10	19,11	46,02
18,11	19,12	46,04
18,12	19,13	46,07
18,13	19,14	46,09
18,14	19,15	46,11
18,15	19,16	46,13
18,16	19,17	46,16
18,17	19,18	46,18
18,18	19,19	46,20
18,19	19,20	46,23
18,20	19,21	46,25



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,21	19,22	46,27
18,22	19,23	46,29
18,23	19,24	46,32
18,24	19,25	46,34
18,25	19,26	46,36
18,26	19,27	46,39
18,27	19,28	46,41
18,28	19,29	46,43
18,29	19,30	46,46
18,30	19,31	46,48
18,31	19,32	46,50
18,32	19,33	46,52
18,33	19,34	46,55
18,34	19,35	46,57
18,35	19,36	46,59
18,36	19,37	46,62
18,37	19,38	46,64
18,38	19,39	46,66
18,39	19,40	46,68
18,40	19,41	46,71
18,41	19,42	46,73
18,42	19,43	46,75
18,43	19,44	46,77
18,44	19,45	46,80
18,45	19,46	46,82
18,46	19,47	46,84
18,47	19,48	46,87
18,48	19,49	46,89
18,49	19,50	46,91
18,50	19,51	46,93
18,51	19,52	46,96
18,52	19,53	46,98
18,53	19,54	47,00
18,54	19,55	47,02
18,55	19,56	47,05
18,56	19,57	47,07
18,57	19,58	47,09
18,58	19,59	47,12
18,59	19,60	47,14
18,60	19,61	47,16
18,61	19,62	47,18
18,62	19,63	47,21
18,63	19,64	47,23
18,64	19,65	47,25



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
18,65	19,66	47,27
18,66	19,67	47,30
18,67	19,68	47,32
18,68	19,69	47,34
18,69	19,70	47,36
18,70	19,71	47,39
18,71	19,72	47,41
18,72	19,73	47,43
18,73	19,74	47,45
18,74	19,75	47,48
18,75	19,76	47,50
18,76	19,77	47,52
18,77	19,78	47,54
18,78	19,79	47,57
18,79	19,80	47,59
18,80	19,81	47,61
18,81	19,82	47,63
18,82	19,83	47,66
18,83	19,84	47,68
18,84	19,85	47,70
18,85	19,86	47,72
18,86	19,87	47,75
18,87	19,88	47,77
18,88	19,89	47,79
18,89	19,90	47,81
18,90	19,91	47,84
18,91	19,92	47,86
18,92	19,93	47,88
18,93	19,94	47,90
18,94	19,95	47,92
18,95	19,96	47,95
18,96	19,97	47,97
18,97	19,98	47,99
18,98	19,99	48,01
18,99	20,00	48,04
19,00	20,01	48,06
19,01	20,02	48,08
19,02	20,03	48,10
19,03	20,04	48,13
19,04	20,05	48,15
19,05	20,06	48,17
19,06	20,07	48,19
19,07	20,08	48,21
19,08	20,09	48,24



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	48,26
19,10	20,11	48,28
19,11	20,12	48,30
19,12	20,13	48,32
19,13	20,14	48,35
19,14	20,15	48,37
19,15	20,16	48,39
19,16	20,17	48,41
19,17	20,18	48,44
19,18	20,19	48,46
19,19	20,20	48,48
19,20	20,21	48,50
19,21	20,22	48,52
19,22	20,23	48,55
19,23	20,24	48,57
19,24	20,25	48,59
19,25	20,26	48,61
19,26	20,27	48,63
19,27	20,28	48,66
19,28	20,29	48,68
19,29	20,30	48,70
19,30	20,31	48,72
19,31	20,32	48,74
19,32	20,33	48,77
19,33	20,34	48,79
19,34	20,35	48,81
19,35	20,36	48,83
19,36	20,37	48,85
19,37	20,38	48,88
19,38	20,39	48,90
19,39	20,40	48,92
19,40	20,41	48,94
19,41	20,42	48,96
19,42	20,43	48,99
19,43	20,44	49,01
19,44	20,45	49,03
19,45	20,46	49,05
19,46	20,47	49,07
19,47	20,48	49,10
19,48	20,49	49,12
19,49	20,50	49,14
19,50	20,51	49,16
19,51	20,52	49,18
19,52	20,53	49,21



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	49,23
19,54	20,55	49,25
19,55	20,56	49,27
19,56	20,57	49,29
19,57	20,58	49,31
19,58	20,59	49,34
19,59	20,60	49,36
19,60	20,61	49,38
19,61	20,62	49,40
19,62	20,63	49,42
19,63	20,64	49,45
19,64	20,65	49,47
19,65	20,66	49,49
19,66	20,67	49,51
19,67	20,68	49,53
19,68	20,69	49,55
19,69	20,70	49,58
19,70	20,71	49,60
19,71	20,72	49,62
19,72	20,73	49,64
19,73	20,74	49,66
19,74	20,75	49,68
19,75	20,76	49,71
19,76	20,77	49,73
19,77	20,78	49,75
19,78	20,79	49,77
19,79	20,80	49,79
19,80	20,81	49,81
19,81	20,82	49,84
19,82	20,83	49,86
19,83	20,84	49,88
19,84	20,85	49,90
19,85	20,86	49,92
19,86	20,87	49,94
19,87	20,88	49,97
19,88	20,89	49,99
19,89	20,90	50,01
19,90	20,91	50,03
19,91	20,92	50,05
19,92	20,93	50,07
19,93	20,94	50,09
19,94	20,95	50,12
19,95	20,96	50,14
19,96	20,97	50,16



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,97	20,98	50,18
19,98	20,99	50,20
19,99	21,00	50,22
20,00	21,01	50,24
20,01	21,02	50,27
20,02	21,03	50,29
20,03	21,04	50,31
20,04	21,05	50,33
20,05	21,06	50,35
20,06	21,07	50,37
20,07	21,08	50,39
20,08	21,09	50,42
20,09	21,10	50,44
20,10	21,11	50,46
20,11	21,12	50,48
20,12	21,13	50,50
20,13	21,14	50,52
20,14	21,15	50,54
20,15	21,16	50,57
20,16	21,17	50,59
20,17	21,18	50,61
20,18	21,19	50,63
20,19	21,20	50,65
20,20	21,21	50,67
20,21	21,22	50,69
20,22	21,23	50,72
20,23	21,24	50,74
20,24	21,25	50,76
20,25	21,26	50,78
20,26	21,27	50,80
20,27	21,28	50,82
20,28	21,29	50,84
20,29	21,30	50,86
20,30	21,31	50,89
20,31	21,32	50,91
20,32	21,33	50,93
20,33	21,34	50,95
20,34	21,35	50,97
20,35	21,36	50,99
20,36	21,37	51,01
20,37	21,38	51,03
20,38	21,39	51,06
20,39	21,40	51,08
20,40	21,41	51,10



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,41	21,42	51,12
20,42	21,43	51,14
20,43	21,44	51,16
20,44	21,45	51,18
20,45	21,46	51,20
20,46	21,47	51,22
20,47	21,48	51,25
20,48	21,49	51,27
20,49	21,50	51,29
20,50	21,51	51,31
20,51	21,52	51,33
20,52	21,53	51,35
20,53	21,54	51,37
20,54	21,55	51,39
20,55	21,56	51,41
20,56	21,57	51,44
20,57	21,58	51,46
20,58	21,59	51,48
20,59	21,60	51,50
20,60	21,61	51,52
20,61	21,62	51,54
20,62	21,63	51,56
20,63	21,64	51,58
20,64	21,65	51,60
20,65	21,66	51,62
20,66	21,67	51,65
20,67	21,68	51,67
20,68	21,69	51,69
20,69	21,70	51,71
20,70	21,71	51,73
20,71	21,72	51,75
20,72	21,73	51,77
20,73	21,74	51,79
20,74	21,75	51,81
20,75	21,76	51,83
20,76	21,77	51,85
20,77	21,78	51,88
20,78	21,79	51,90
20,79	21,80	51,92
20,80	21,81	51,94
20,81	21,82	51,96
20,82	21,83	51,98
20,83	21,84	52,00
20,84	21,85	52,02



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
20,85	21,86	52,04
20,86	21,87	52,06
20,87	21,88	52,08
20,88	21,89	52,11
20,89	21,90	52,13
20,90	21,91	52,15
20,91	21,92	52,17
20,92	21,93	52,19
20,93	21,94	52,21
20,94	21,95	52,23
20,95	21,96	52,25
20,96	21,97	52,27
20,97	21,98	52,29
20,98	21,99	52,31
20,99	22,00	52,33
21,00	22,01	52,35
21,01	22,02	52,38
21,02	22,03	52,40
21,03	22,04	52,42
21,04	22,05	52,44
21,05	22,06	52,46
21,06	22,07	52,48
21,07	22,08	52,50
21,08	22,09	52,52
21,09	22,10	52,54
21,10	22,11	52,56
21,11	22,12	52,58
21,12	22,13	52,60
21,13	22,14	52,62
21,14	22,15	52,64
21,15	22,16	52,66
21,16	22,17	52,69
21,17	22,18	52,71
21,18	22,19	52,73
21,19	22,20	52,75
21,20	22,21	52,77
21,21	22,22	52,79
21,22	22,23	52,81
21,23	22,24	52,83
21,24	22,25	52,85
21,25	22,26	52,87
21,26	22,27	52,89
21,27	22,28	52,91
21,28	22,29	52,93



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
21,29	22,30	52,95
21,30	22,31	52,97
21,31	22,32	52,99
21,32	22,33	53,01
21,33	22,34	53,03
21,34	22,35	53,06
21,35	22,36	53,08
21,36	22,37	53,10
21,37	22,38	53,12
21,38	22,39	53,14
21,39	22,40	53,16
21,40	22,41	53,18
21,41	22,42	53,20
21,42	22,43	53,22
21,43	22,44	53,24
21,44	22,45	53,26
21,45	22,46	53,28
21,46	22,47	53,30
21,47	22,48	53,32
21,48	22,49	53,34
21,49	22,50	53,36
21,50	22,51	53,38
21,51	22,52	53,40
21,52	22,53	53,42
21,53	22,54	53,44
21,54	22,55	53,46
21,55	22,56	53,48
21,56	22,57	53,50
21,57	22,58	53,52
21,58	22,59	53,54
21,59	22,60	53,57
21,60	22,61	53,59
21,61	22,62	53,61
21,62	22,63	53,63
21,63	22,64	53,65
21,64	22,65	53,67
21,65	22,66	53,69
21,66	22,67	53,71
21,67	22,68	53,73
21,68	22,69	53,75
21,69	22,70	53,77
21,70	22,71	53,79
21,71	22,72	53,81
21,72	22,73	53,83



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
21,73	22,74	53,85
21,74	22,75	53,87
21,75	22,76	53,89
21,76	22,77	53,91
21,77	22,78	53,93
21,78	22,79	53,95
21,79	22,80	53,97
21,80	22,81	53,99
21,81	22,82	54,01
21,82	22,83	54,03
21,83	22,84	54,05
21,84	22,85	54,07
21,85	22,86	54,09
21,86	22,87	54,11
21,87	22,88	54,13
21,88	22,89	54,15
21,89	22,90	54,17
21,90	22,91	54,19
21,91	22,92	54,21
21,92	22,93	54,23
21,93	22,94	54,25
21,94	22,95	54,27
21,95	22,96	54,29
21,96	22,97	54,31
21,97	22,98	54,33
21,98	22,99	54,35
21,99	23,00	54,37
22,00	23,01	54,39
22,01	23,02	54,41
22,02	23,03	54,43
22,03	23,04	54,45
22,04	23,05	54,47
22,05	23,06	54,49
22,06	23,07	54,51
22,07	23,08	54,53
22,08	23,09	54,55
22,09	23,10	54,57
22,10	23,11	54,59
22,11	23,12	54,61
22,12	23,13	54,63
22,13	23,14	54,65
22,14	23,15	54,67
22,15	23,16	54,69
22,16	23,17	54,71



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
22,17	23,18	54,73
22,18	23,19	54,75
22,19	23,20	54,77
22,20	23,21	54,79
22,21	23,22	54,81
22,22	23,23	54,83
22,23	23,24	54,85
22,24	23,25	54,87
22,25	23,26	54,89
22,26	23,27	54,91
22,27	23,28	54,93
22,28	23,29	54,95
22,29	23,30	54,97
22,30	23,31	54,99
22,31	23,32	55,01
22,32	23,33	55,03
22,33	23,34	55,05
22,34	23,35	55,07
22,35	23,36	55,09
22,36	23,37	55,11
22,37	23,38	55,13
22,38	23,39	55,15
22,39	23,40	55,17
22,40	23,41	55,19
22,41	23,42	55,21
22,42	23,43	55,23
22,43	23,44	55,25
22,44	23,45	55,27
22,45	23,46	55,29
22,46	23,47	55,31
22,47	23,48	55,33
22,48	23,49	55,35
22,49	23,50	55,37
22,50	23,51	55,39
22,51	23,52	55,41
22,52	23,53	55,43
22,53	23,54	55,45
22,54	23,55	55,47
22,55	23,56	55,48
22,56	23,57	55,50
22,57	23,58	55,52
22,58	23,59	55,54
22,59	23,60	55,56
22,60	23,61	55,58



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
22,61	23,62	55,60
22,62	23,63	55,62
22,63	23,64	55,64
22,64	23,65	55,66
22,65	23,66	55,68
22,66	23,67	55,70
22,67	23,68	55,72
22,68	23,69	55,74
22,69	23,70	55,76
22,70	23,71	55,78
22,71	23,72	55,80
22,72	23,73	55,82
22,73	23,74	55,84
22,74	23,75	55,86
22,75	23,76	55,88
22,76	23,77	55,90
22,77	23,78	55,92
22,78	23,79	55,94
22,79	23,80	55,96
22,80	23,81	55,97
22,81	23,82	55,99
22,82	23,83	56,01
22,83	23,84	56,03
22,84	23,85	56,05
22,85	23,86	56,07
22,86	23,87	56,09
22,87	23,88	56,11
22,88	23,89	56,13
22,89	23,90	56,15
22,90	23,91	56,17
22,91	23,92	56,19
22,92	23,93	56,21
22,93	23,94	56,23
22,94	23,95	56,25
22,95	23,96	56,27
22,96	23,97	56,29
22,97	23,98	56,31
22,98	23,99	56,33
22,99	24,00	56,34
23,00	24,01	56,36
23,01	24,02	56,38
23,02	24,03	56,40
23,03	24,04	56,42
23,04	24,05	56,44



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,05	24,06	56,46
23,06	24,07	56,48
23,07	24,08	56,50
23,08	24,09	56,52
23,09	24,10	56,54
23,10	24,11	56,56
23,11	24,12	56,58
23,12	24,13	56,60
23,13	24,14	56,62
23,14	24,15	56,64
23,15	24,16	56,65
23,16	24,17	56,67
23,17	24,18	56,69
23,18	24,19	56,71
23,19	24,20	56,73
23,20	24,21	56,75
23,21	24,22	56,77
23,22	24,23	56,79
23,23	24,24	56,81
23,24	24,25	56,83
23,25	24,26	56,85
23,26	24,27	56,87
23,27	24,28	56,89
23,28	24,29	56,90
23,29	24,30	56,92
23,30	24,31	56,94
23,31	24,32	56,96
23,32	24,33	56,98
23,33	24,34	57,00
23,34	24,35	57,02
23,35	24,36	57,04
23,36	24,37	57,06
23,37	24,38	57,08
23,38	24,39	57,10
23,39	24,40	57,12
23,40	24,41	57,14
23,41	24,42	57,15
23,42	24,43	57,17
23,43	24,44	57,19
23,44	24,45	57,21
23,45	24,46	57,23
23,46	24,47	57,25
23,47	24,48	57,27
23,48	24,49	57,29



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,49	24,50	57,31
23,50	24,51	57,33
23,51	24,52	57,35
23,52	24,53	57,36
23,53	24,54	57,38
23,54	24,55	57,40
23,55	24,56	57,42
23,56	24,57	57,44
23,57	24,58	57,46
23,58	24,59	57,48
23,59	24,60	57,50
23,60	24,61	57,52
23,61	24,62	57,54
23,62	24,63	57,56
23,63	24,64	57,57
23,64	24,65	57,59
23,65	24,66	57,61
23,66	24,67	57,63
23,67	24,68	57,65
23,68	24,69	57,67
23,69	24,70	57,69
23,70	24,71	57,71
23,71	24,72	57,73
23,72	24,73	57,74
23,73	24,74	57,76
23,74	24,75	57,78
23,75	24,76	57,80
23,76	24,77	57,82
23,77	24,78	57,84
23,78	24,79	57,86
23,79	24,80	57,88
23,80	24,81	57,90
23,81	24,82	57,92
23,82	24,83	57,93
23,83	24,84	57,95
23,84	24,85	57,97
23,85	24,86	57,99
23,86	24,87	58,01
23,87	24,88	58,03
23,88	24,89	58,05
23,89	24,90	58,07
23,90	24,91	58,09
23,91	24,92	58,10
23,92	24,93	58,12



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,93	24,94	58,14
23,94	24,95	58,16
23,95	24,96	58,18
23,96	24,97	58,20
23,97	24,98	58,22
23,98	24,99	58,24
23,99	25,00	58,25
24,00	25,01	58,27
24,01	25,02	58,29
24,02	25,03	58,31
24,03	25,04	58,33
24,04	25,05	58,35
24,05	25,06	58,37
24,06	25,07	58,39
24,07	25,08	58,41
24,08	25,09	58,42
24,09	25,10	58,44
24,10	25,11	58,46
24,11	25,12	58,48
24,12	25,13	58,50
24,13	25,14	58,52
24,14	25,15	58,54
24,15	25,16	58,55
24,16	25,17	58,57
24,17	25,18	58,59
24,18	25,19	58,61
24,19	25,20	58,63
24,20	25,21	58,65
24,21	25,22	58,67
24,22	25,23	58,69
24,23	25,24	58,70
24,24	25,25	58,72
24,25	25,26	58,74
24,26	25,27	58,76
24,27	25,28	58,78
24,28	25,29	58,80
24,29	25,30	58,82
24,30	25,31	58,84
24,31	25,32	58,85
24,32	25,33	58,87
24,33	25,34	58,89
24,34	25,35	58,91
24,35	25,36	58,93
24,36	25,37	58,95



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,37	25,38	58,97
24,38	25,39	58,98
24,39	25,40	59,00
24,40	25,41	59,02
24,41	25,42	59,04
24,42	25,43	59,06
24,43	25,44	59,08
24,44	25,45	59,10
24,45	25,46	59,11
24,46	25,47	59,13
24,47	25,48	59,15
24,48	25,49	59,17
24,49	25,50	59,19
24,50	25,51	59,21
24,51	25,52	59,22
24,52	25,53	59,24
24,53	25,54	59,26
24,54	25,55	59,28
24,55	25,56	59,30
24,56	25,57	59,32
24,57	25,58	59,34
24,58	25,59	59,35
24,59	25,60	59,37
24,60	25,61	59,39
24,61	25,62	59,41
24,62	25,63	59,43
24,63	25,64	59,45
24,64	25,65	59,47
24,65	25,66	59,48
24,66	25,67	59,50
24,67	25,68	59,52
24,68	25,69	59,54
24,69	25,70	59,56
24,70	25,71	59,58
24,71	25,72	59,59
24,72	25,73	59,61
24,73	25,74	59,63
24,74	25,75	59,65
24,75	25,76	59,67
24,76	25,77	59,69
24,77	25,78	59,70
24,78	25,79	59,72
24,79	25,80	59,74
24,80	25,81	59,76



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	59,78
24,82	25,83	59,80
24,83	25,84	59,81
24,84	25,85	59,83
24,85	25,86	59,85
24,86	25,87	59,87
24,87	25,88	59,89
24,88	25,89	59,91
24,89	25,90	59,92
24,90	25,91	59,94
24,91	25,92	59,96
24,92	25,93	59,98
24,93	25,94	60,00
24,94	25,95	60,02
24,95	25,96	60,03
24,96	25,97	60,05
24,97	25,98	60,07
24,98	25,99	60,09
24,99	26,00	60,11
25,00	26,01	60,13
25,01	26,02	60,14
25,02	26,03	60,16
25,03	26,04	60,18
25,04	26,05	60,20
25,05	26,06	60,22
25,06	26,07	60,23
25,07	26,08	60,25
25,08	26,09	60,27
25,09	26,10	60,29
25,10	26,11	60,31
25,11	26,12	60,33
25,12	26,13	60,34
25,13	26,14	60,36
25,14	26,15	60,38
25,15	26,16	60,40
25,16	26,17	60,42
25,17	26,18	60,43
25,18	26,19	60,45
25,19	26,20	60,47
25,20	26,21	60,49
25,21	26,22	60,51
25,22	26,23	60,52
25,23	26,24	60,54
25,24	26,25	60,56



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	60,58
25,26	26,27	60,60
25,27	26,28	60,62
25,28	26,29	60,63
25,29	26,30	60,65
25,30	26,31	60,67
25,31	26,32	60,69
25,32	26,33	60,71
25,33	26,34	60,72
25,34	26,35	60,74
25,35	26,36	60,76
25,36	26,37	60,78
25,37	26,38	60,80
25,38	26,39	60,81
25,39	26,40	60,83
25,40	26,41	60,85
25,41	26,42	60,87
25,42	26,43	60,89
25,43	26,44	60,90
25,44	26,45	60,92
25,45	26,46	60,94
25,46	26,47	60,96
25,47	26,48	60,98
25,48	26,49	60,99
25,49	26,50	61,01
25,50	26,51	61,03
25,51	26,52	61,05
25,52	26,53	61,07
25,53	26,54	61,08
25,54	26,55	61,10
25,55	26,56	61,12
25,56	26,57	61,14
25,57	26,58	61,16
25,58	26,59	61,17
25,59	26,60	61,19
25,60	26,61	61,21
25,61	26,62	61,23
25,62	26,63	61,25
25,63	26,64	61,26
25,64	26,65	61,28
25,65	26,66	61,30
25,66	26,67	61,32
25,67	26,68	61,33
25,68	26,69	61,35



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
25,69	26,70	61,37
25,70	26,71	61,39
25,71	26,72	61,41
25,72	26,73	61,42
25,73	26,74	61,44
25,74	26,75	61,46
25,75	26,76	61,48
25,76	26,77	61,50
25,77	26,78	61,51
25,78	26,79	61,53
25,79	26,80	61,55
25,80	26,81	61,57
25,81	26,82	61,58
25,82	26,83	61,60
25,83	26,84	61,62
25,84	26,85	61,64
25,85	26,86	61,66
25,86	26,87	61,67
25,87	26,88	61,69
25,88	26,89	61,71
25,89	26,90	61,73
25,90	26,91	61,74
25,91	26,92	61,76
25,92	26,93	61,78
25,93	26,94	61,80
25,94	26,95	61,82
25,95	26,96	61,83
25,96	26,97	61,85
25,97	26,98	61,87
25,98	26,99	61,89
25,99	27,00	61,90
26,00	27,01	61,92
26,01	27,02	61,94
26,02	27,03	61,96
26,03	27,04	61,98
26,04	27,05	61,99
26,05	27,06	62,01
26,06	27,07	62,03
26,07	27,08	62,05
26,08	27,09	62,06
26,09	27,10	62,08
26,10	27,11	62,10
26,11	27,12	62,12
26,12	27,13	62,13



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	62,15
26,14	27,15	62,17
26,15	27,16	62,19
26,16	27,17	62,20
26,17	27,18	62,22
26,18	27,19	62,24
26,19	27,20	62,26
26,20	27,21	62,28
26,21	27,22	62,29
26,22	27,23	62,31
26,23	27,24	62,33
26,24	27,25	62,35
26,25	27,26	62,36
26,26	27,27	62,38
26,27	27,28	62,40
26,28	27,29	62,42
26,29	27,30	62,43
26,30	27,31	62,45
26,31	27,32	62,47
26,32	27,33	62,49
26,33	27,34	62,50
26,34	27,35	62,52
26,35	27,36	62,54
26,36	27,37	62,56
26,37	27,38	62,57
26,38	27,39	62,59
26,39	27,40	62,61
26,40	27,41	62,63
26,41	27,42	62,64
26,42	27,43	62,66
26,43	27,44	62,68
26,44	27,45	62,70
26,45	27,46	62,71
26,46	27,47	62,73
26,47	27,48	62,75
26,48	27,49	62,77
26,49	27,50	62,78
26,50	27,51	62,80
26,51	27,52	62,82
26,52	27,53	62,84
26,53	27,54	62,85
26,54	27,55	62,87
26,55	27,56	62,89
26,56	27,57	62,91



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
26,57	27,58	62,92
26,58	27,59	62,94
26,59	27,60	62,96
26,60	27,61	62,98
26,61	27,62	62,99
26,62	27,63	63,01
26,63	27,64	63,03
26,64	27,65	63,04
26,65	27,66	63,06
26,66	27,67	63,08
26,67	27,68	63,10
26,68	27,69	63,11
26,69	27,70	63,13
26,70	27,71	63,15
26,71	27,72	63,17
26,72	27,73	63,18
26,73	27,74	63,20
26,74	27,75	63,22
26,75	27,76	63,24
26,76	27,77	63,25
26,77	27,78	63,27
26,78	27,79	63,29
26,79	27,80	63,30
26,80	27,81	63,32
26,81	27,82	63,34
26,82	27,83	63,36
26,83	27,84	63,37
26,84	27,85	63,39
26,85	27,86	63,41
26,86	27,87	63,43
26,87	27,88	63,44
26,88	27,89	63,46
26,89	27,90	63,48
26,90	27,91	63,49
26,91	27,92	63,51
26,92	27,93	63,53
26,93	27,94	63,55
26,94	27,95	63,56
26,95	27,96	63,58
26,96	27,97	63,60
26,97	27,98	63,62
26,98	27,99	63,63
26,99	28,00	63,65
27,00	28,01	63,67



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	63,68
27,02	28,03	63,70
27,03	28,04	63,72
27,04	28,05	63,74
27,05	28,06	63,75
27,06	28,07	63,77
27,07	28,08	63,79
27,08	28,09	63,80
27,09	28,10	63,82
27,10	28,11	63,84
27,11	28,12	63,86
27,12	28,13	63,87
27,13	28,14	63,89
27,14	28,15	63,91
27,15	28,16	63,92
27,16	28,17	63,94
27,17	28,18	63,96
27,18	28,19	63,98
27,19	28,20	63,99
27,20	28,21	64,01
27,21	28,22	64,03
27,22	28,23	64,04
27,23	28,24	64,06
27,24	28,25	64,08
27,25	28,26	64,10
27,26	28,27	64,11
27,27	28,28	64,13
27,28	28,29	64,15
27,29	28,30	64,16
27,30	28,31	64,18
27,31	28,32	64,20
27,32	28,33	64,22
27,33	28,34	64,23
27,34	28,35	64,25
27,35	28,36	64,27
27,36	28,37	64,28
27,37	28,38	64,30
27,38	28,39	64,32
27,39	28,40	64,33
27,40	28,41	64,35
27,41	28,42	64,37
27,42	28,43	64,39
27,43	28,44	64,40
27,44	28,45	64,42



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	64,44
27,46	28,47	64,45
27,47	28,48	64,47
27,48	28,49	64,49
27,49	28,50	64,50
27,50	28,51	64,52
27,51	28,52	64,54
27,52	28,53	64,56
27,53	28,54	64,57
27,54	28,55	64,59
27,55	28,56	64,61
27,56	28,57	64,62
27,57	28,58	64,64
27,58	28,59	64,66
27,59	28,60	64,67
27,60	28,61	64,69
27,61	28,62	64,71
27,62	28,63	64,72
27,63	28,64	64,74
27,64	28,65	64,76
27,65	28,66	64,78
27,66	28,67	64,79
27,67	28,68	64,81
27,68	28,69	64,83
27,69	28,70	64,84
27,70	28,71	64,86
27,71	28,72	64,88
27,72	28,73	64,89
27,73	28,74	64,91
27,74	28,75	64,93
27,75	28,76	64,94
27,76	28,77	64,96
27,77	28,78	64,98
27,78	28,79	64,99
27,79	28,80	65,01
27,80	28,81	65,03
27,81	28,82	65,05
27,82	28,83	65,06
27,83	28,84	65,08
27,84	28,85	65,10
27,85	28,86	65,11
27,86	28,87	65,13
27,87	28,88	65,15
27,88	28,89	65,16



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	65,18
27,90	28,91	65,20
27,91	28,92	65,21
27,92	28,93	65,23
27,93	28,94	65,25
27,94	28,95	65,26
27,95	28,96	65,28
27,96	28,97	65,30
27,97	28,98	65,31
27,98	28,99	65,33
27,99	29,00	65,35
28,00	29,01	65,36
28,01	29,02	65,38
28,02	29,03	65,40
28,03	29,04	65,41
28,04	29,05	65,43
28,05	29,06	65,45
28,06	29,07	65,46
28,07	29,08	65,48
28,08	29,09	65,50
28,09	29,10	65,51
28,10	29,11	65,53
28,11	29,12	65,55
28,12	29,13	65,56
28,13	29,14	65,58
28,14	29,15	65,60
28,15	29,16	65,61
28,16	29,17	65,63
28,17	29,18	65,65
28,18	29,19	65,66
28,19	29,20	65,68
28,20	29,21	65,70
28,21	29,22	65,71
28,22	29,23	65,73
28,23	29,24	65,75
28,24	29,25	65,76
28,25	29,26	65,78
28,26	29,27	65,80
28,27	29,28	65,81
28,28	29,29	65,83
28,29	29,30	65,85
28,30	29,31	65,86
28,31	29,32	65,88
28,32	29,33	65,90



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	65,91
28,34	29,35	65,93
28,35	29,36	65,95
28,36	29,37	65,96
28,37	29,38	65,98
28,38	29,39	66,00
28,39	29,40	66,01
28,40	29,41	66,03
28,41	29,42	66,05
28,42	29,43	66,06
28,43	29,44	66,08
28,44	29,45	66,10
28,45	29,46	66,11
28,46	29,47	66,13
28,47	29,48	66,15
28,48	29,49	66,16
28,49	29,50	66,18
28,50	29,51	66,19
28,51	29,52	66,21
28,52	29,53	66,23
28,53	29,54	66,24
28,54	29,55	66,26
28,55	29,56	66,28
28,56	29,57	66,29
28,57	29,58	66,31
28,58	29,59	66,33
28,59	29,60	66,34
28,60	29,61	66,36
28,61	29,62	66,38
28,62	29,63	66,39
28,63	29,64	66,41
28,64	29,65	66,43
28,65	29,66	66,44
28,66	29,67	66,46
28,67	29,68	66,47
28,68	29,69	66,49
28,69	29,70	66,51
28,70	29,71	66,52
28,71	29,72	66,54
28,72	29,73	66,56
28,73	29,74	66,57
28,74	29,75	66,59
28,75	29,76	66,61
28,76	29,77	66,62



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	66,64
28,78	29,79	66,65
28,79	29,80	66,67
28,80	29,81	66,69
28,81	29,82	66,70
28,82	29,83	66,72
28,83	29,84	66,74
28,84	29,85	66,75
28,85	29,86	66,77
28,86	29,87	66,79
28,87	29,88	66,80
28,88	29,89	66,82
28,89	29,90	66,83
28,90	29,91	66,85
28,91	29,92	66,87
28,92	29,93	66,88
28,93	29,94	66,90
28,94	29,95	66,92
28,95	29,96	66,93
28,96	29,97	66,95
28,97	29,98	66,97
28,98	29,99	66,98
28,99	30,00	67,00
29,00	30,01	67,01
29,01	30,02	67,03
29,02	30,03	67,05
29,03	30,04	67,06
29,04	30,05	67,08
29,05	30,06	67,10
29,06	30,07	67,11
29,07	30,08	67,13
29,08	30,09	67,14
29,09	30,10	67,16
29,10	30,11	67,18
29,11	30,12	67,19
29,12	30,13	67,21
29,13	30,14	67,23
29,14	30,15	67,24
29,15	30,16	67,26
29,16	30,17	67,27
29,17	30,18	67,29
29,18	30,19	67,31
29,19	30,20	67,32
29,20	30,21	67,34



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	67,35
29,22	30,23	67,37
29,23	30,24	67,39
29,24	30,25	67,40
29,25	30,26	67,42
29,26	30,27	67,44
29,27	30,28	67,45
29,28	30,29	67,47
29,29	30,30	67,48
29,30	30,31	67,50
29,31	30,32	67,52
29,32	30,33	67,53
29,33	30,34	67,55
29,34	30,35	67,56
29,35	30,36	67,58
29,36	30,37	67,60
29,37	30,38	67,61
29,38	30,39	67,63
29,39	30,40	67,65
29,40	30,41	67,66
29,41	30,42	67,68
29,42	30,43	67,69
29,43	30,44	67,71
29,44	30,45	67,73
29,45	30,46	67,74
29,46	30,47	67,76
29,47	30,48	67,77
29,48	30,49	67,79
29,49	30,50	67,81
29,50	30,51	67,82
29,51	30,52	67,84
29,52	30,53	67,85
29,53	30,54	67,87
29,54	30,55	67,89
29,55	30,56	67,90
29,56	30,57	67,92
29,57	30,58	67,93
29,58	30,59	67,95
29,59	30,60	67,97
29,60	30,61	67,98
29,61	30,62	68,00
29,62	30,63	68,01
29,63	30,64	68,03
29,64	30,65	68,05



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,65	30,66	68,06
29,66	30,67	68,08
29,67	30,68	68,09
29,68	30,69	68,11
29,69	30,70	68,13
29,70	30,71	68,14
29,71	30,72	68,16
29,72	30,73	68,17
29,73	30,74	68,19
29,74	30,75	68,21
29,75	30,76	68,22
29,76	30,77	68,24
29,77	30,78	68,25
29,78	30,79	68,27
29,79	30,80	68,29
29,80	30,81	68,30
29,81	30,82	68,32
29,82	30,83	68,33
29,83	30,84	68,35
29,84	30,85	68,37
29,85	30,86	68,38
29,86	30,87	68,40
29,87	30,88	68,41
29,88	30,89	68,43
29,89	30,90	68,45
29,90	30,91	68,46
29,91	30,92	68,48
29,92	30,93	68,49
29,93	30,94	68,51
29,94	30,95	68,52
29,95	30,96	68,54
29,96	30,97	68,56
29,97	30,98	68,57
29,98	30,99	68,59
29,99	31,00	68,60
30,00	31,01	68,62
30,01	31,02	68,64
30,02	31,03	68,65
30,03	31,04	68,67
30,04	31,05	68,68
30,05	31,06	68,70
30,06	31,07	68,72
30,07	31,08	68,73
30,08	31,09	68,75



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
30,09	31,10	68,76
30,10	31,11	68,78
30,11	31,12	68,79
30,12	31,13	68,81
30,13	31,14	68,83
30,14	31,15	68,84
30,15	31,16	68,86
30,16	31,17	68,87
30,17	31,18	68,89
30,18	31,19	68,90
30,19	31,20	68,92
30,20	31,21	68,94
30,21	31,22	68,95
30,22	31,23	68,97
30,23	31,24	68,98
30,24	31,25	69,00
30,25	31,26	69,01
30,26	31,27	69,03
30,27	31,28	69,05
30,28	31,29	69,06
30,29	31,30	69,08
30,30	31,31	69,09
30,31	31,32	69,11
30,32	31,33	69,13
30,33	31,34	69,14
30,34	31,35	69,16
30,35	31,36	69,17
30,36	31,37	69,19
30,37	31,38	69,20
30,38	31,39	69,22
30,39	31,40	69,23
30,40	31,41	69,25
30,41	31,42	69,27
30,42	31,43	69,28
30,43	31,44	69,30
30,44	31,45	69,31
30,45	31,46	69,33
30,46	31,47	69,34
30,47	31,48	69,36
30,48	31,49	69,38
30,49	31,50	69,39
30,50	31,51	69,41
30,51	31,52	69,42
30,52	31,53	69,44



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	69,45
30,54	31,55	69,47
30,55	31,56	69,49
30,56	31,57	69,50
30,57	31,58	69,52
30,58	31,59	69,53
30,59	31,60	69,55
30,60	31,61	69,56
30,61	31,62	69,58
30,62	31,63	69,59
30,63	31,64	69,61
30,64	31,65	69,63
30,65	31,66	69,64
30,66	31,67	69,66
30,67	31,68	69,67
30,68	31,69	69,69
30,69	31,70	69,70
30,70	31,71	69,72
30,71	31,72	69,73
30,72	31,73	69,75
30,73	31,74	69,77
30,74	31,75	69,78
30,75	31,76	69,80
30,76	31,77	69,81
30,77	31,78	69,83
30,78	31,79	69,84
30,79	31,80	69,86
30,80	31,81	69,87
30,81	31,82	69,89
30,82	31,83	69,91
30,83	31,84	69,92
30,84	31,85	69,94
30,85	31,86	69,95
30,86	31,87	69,97
30,87	31,88	69,98
30,88	31,89	70,00
30,89	31,90	70,01
30,90	31,91	70,03
30,91	31,92	70,04
30,92	31,93	70,06
30,93	31,94	70,08
30,94	31,95	70,09
30,95	31,96	70,11
30,96	31,97	70,12



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,97	31,98	70,14
30,98	31,99	70,15
30,99	32,00	70,17
31,00	32,01	70,18
31,01	32,02	70,20
31,02	32,03	70,21
31,03	32,04	70,23
31,04	32,05	70,25
31,05	32,06	70,26
31,06	32,07	70,28
31,07	32,08	70,29
31,08	32,09	70,31
31,09	32,10	70,32
31,10	32,11	70,34
31,11	32,12	70,35
31,12	32,13	70,37
31,13	32,14	70,38
31,14	32,15	70,40
31,15	32,16	70,42
31,16	32,17	70,43
31,17	32,18	70,45
31,18	32,19	70,46
31,19	32,20	70,48
31,20	32,21	70,49
31,21	32,22	70,51
31,22	32,23	70,52
31,23	32,24	70,54
31,24	32,25	70,55
31,25	32,26	70,57
31,26	32,27	70,58
31,27	32,28	70,60
31,28	32,29	70,61
31,29	32,30	70,63
31,30	32,31	70,65
31,31	32,32	70,66
31,32	32,33	70,68
31,33	32,34	70,69
31,34	32,35	70,71
31,35	32,36	70,72
31,36	32,37	70,74
31,37	32,38	70,75
31,38	32,39	70,77
31,39	32,40	70,78
31,40	32,41	70,80



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	70,81
31,42	32,43	70,83
31,43	32,44	70,84
31,44	32,45	70,86
31,45	32,46	70,87
31,46	32,47	70,89
31,47	32,48	70,90
31,48	32,49	70,92
31,49	32,50	70,94
31,50	32,51	70,95
31,51	32,52	70,97
31,52	32,53	70,98
31,53	32,54	71,00
31,54	32,55	71,01
31,55	32,56	71,03
31,56	32,57	71,04
31,57	32,58	71,06
31,58	32,59	71,07
31,59	32,60	71,09
31,60	32,61	71,10
31,61	32,62	71,12
31,62	32,63	71,13
31,63	32,64	71,15
31,64	32,65	71,16
31,65	32,66	71,18
31,66	32,67	71,19
31,67	32,68	71,21
31,68	32,69	71,22
31,69	32,70	71,24
31,70	32,71	71,25
31,71	32,72	71,27
31,72	32,73	71,28
31,73	32,74	71,30
31,74	32,75	71,32
31,75	32,76	71,33
31,76	32,77	71,35
31,77	32,78	71,36
31,78	32,79	71,38
31,79	32,80	71,39
31,80	32,81	71,41
31,81	32,82	71,42
31,82	32,83	71,44
31,83	32,84	71,45
31,84	32,85	71,47



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	71,48
31,86	32,87	71,50
31,87	32,88	71,51
31,88	32,89	71,53
31,89	32,90	71,54
31,90	32,91	71,56
31,91	32,92	71,57
31,92	32,93	71,59
31,93	32,94	71,60
31,94	32,95	71,62
31,95	32,96	71,63
31,96	32,97	71,65
31,97	32,98	71,66
31,98	32,99	71,68
31,99	33,00	71,69
32,00	33,01	71,71
32,01	33,02	71,72
32,02	33,03	71,74
32,03	33,04	71,75
32,04	33,05	71,77
32,05	33,06	71,78
32,06	33,07	71,80
32,07	33,08	71,81
32,08	33,09	71,83
32,09	33,10	71,84
32,10	33,11	71,86
32,11	33,12	71,87
32,12	33,13	71,89
32,13	33,14	71,90
32,14	33,15	71,92
32,15	33,16	71,93
32,16	33,17	71,95
32,17	33,18	71,96
32,18	33,19	71,98
32,19	33,20	71,99
32,20	33,21	72,01
32,21	33,22	72,02
32,22	33,23	72,04
32,23	33,24	72,05
32,24	33,25	72,07
32,25	33,26	72,08
32,26	33,27	72,10
32,27	33,28	72,11
32,28	33,29	72,13



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,29	33,30	72,14
32,30	33,31	72,16
32,31	33,32	72,17
32,32	33,33	72,19
32,33	33,34	72,20
32,34	33,35	72,22
32,35	33,36	72,23
32,36	33,37	72,25
32,37	33,38	72,26
32,38	33,39	72,28
32,39	33,40	72,29
32,40	33,41	72,31
32,41	33,42	72,32
32,42	33,43	72,34
32,43	33,44	72,35
32,44	33,45	72,37
32,45	33,46	72,38
32,46	33,47	72,40
32,47	33,48	72,41
32,48	33,49	72,42
32,49	33,50	72,44
32,50	33,51	72,45
32,51	33,52	72,47
32,52	33,53	72,48
32,53	33,54	72,50
32,54	33,55	72,51
32,55	33,56	72,53
32,56	33,57	72,54
32,57	33,58	72,56
32,58	33,59	72,57
32,59	33,60	72,59
32,60	33,61	72,60
32,61	33,62	72,62
32,62	33,63	72,63
32,63	33,64	72,65
32,64	33,65	72,66
32,65	33,66	72,68
32,66	33,67	72,69
32,67	33,68	72,71
32,68	33,69	72,72
32,69	33,70	72,74
32,70	33,71	72,75
32,71	33,72	72,77
32,72	33,73	72,78



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
32,73	33,74	72,79
32,74	33,75	72,81
32,75	33,76	72,82
32,76	33,77	72,84
32,77	33,78	72,85
32,78	33,79	72,87
32,79	33,80	72,88
32,80	33,81	72,90
32,81	33,82	72,91
32,82	33,83	72,93
32,83	33,84	72,94
32,84	33,85	72,96
32,85	33,86	72,97
32,86	33,87	72,99
32,87	33,88	73,00
32,88	33,89	73,02
32,89	33,90	73,03
32,90	33,91	73,05
32,91	33,92	73,06
32,92	33,93	73,07
32,93	33,94	73,09
32,94	33,95	73,10
32,95	33,96	73,12
32,96	33,97	73,13
32,97	33,98	73,15
32,98	33,99	73,16
32,99	34,00	73,18
33,00	34,01	73,19
33,01	34,02	73,21
33,02	34,03	73,22
33,03	34,04	73,24
33,04	34,05	73,25
33,05	34,06	73,27
33,06	34,07	73,28
33,07	34,08	73,29
33,08	34,09	73,31
33,09	34,10	73,32
33,10	34,11	73,34
33,11	34,12	73,35
33,12	34,13	73,37
33,13	34,14	73,38
33,14	34,15	73,40
33,15	34,16	73,41
33,16	34,17	73,43



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
33,17	34,18	73,44
33,18	34,19	73,46
33,19	34,20	73,47
33,20	34,21	73,48
33,21	34,22	73,50
33,22	34,23	73,51
33,23	34,24	73,53
33,24	34,25	73,54
33,25	34,26	73,56
33,26	34,27	73,57
33,27	34,28	73,59
33,28	34,29	73,60
33,29	34,30	73,62
33,30	34,31	73,63
33,31	34,32	73,64
33,32	34,33	73,66
33,33	34,34	73,67
33,34	34,35	73,69
33,35	34,36	73,70
33,36	34,37	73,72
33,37	34,38	73,73
33,38	34,39	73,75
33,39	34,40	73,76
33,40	34,41	73,78
33,41	34,42	73,79
33,42	34,43	73,80
33,43	34,44	73,82
33,44	34,45	73,83
33,45	34,46	73,85
33,46	34,47	73,86
33,47	34,48	73,88
33,48	34,49	73,89
33,49	34,50	73,91
33,50	34,51	73,92
33,51	34,52	73,93
33,52	34,53	73,95
33,53	34,54	73,96
33,54	34,55	73,98
33,55	34,56	73,99
33,56	34,57	74,01
33,57	34,58	74,02
33,58	34,59	74,04
33,59	34,60	74,05
33,60	34,61	74,06



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
33,61	34,62	74,08
33,62	34,63	74,09
33,63	34,64	74,11
33,64	34,65	74,12
33,65	34,66	74,14
33,66	34,67	74,15
33,67	34,68	74,17
33,68	34,69	74,18
33,69	34,70	74,19
33,70	34,71	74,21
33,71	34,72	74,22
33,72	34,73	74,24
33,73	34,74	74,25
33,74	34,75	74,27
33,75	34,76	74,28
33,76	34,77	74,29
33,77	34,78	74,31
33,78	34,79	74,32
33,79	34,80	74,34
33,80	34,81	74,35
33,81	34,82	74,37
33,82	34,83	74,38
33,83	34,84	74,40
33,84	34,85	74,41
33,85	34,86	74,42
33,86	34,87	74,44
33,87	34,88	74,45
33,88	34,89	74,47
33,89	34,90	74,48
33,90	34,91	74,50
33,91	34,92	74,51
33,92	34,93	74,52
33,93	34,94	74,54
33,94	34,95	74,55
33,95	34,96	74,57
33,96	34,97	74,58
33,97	34,98	74,60
33,98	34,99	74,61
33,99	35,00	74,62
34,00	35,01	74,64
34,01	35,02	74,65
34,02	35,03	74,67
34,03	35,04	74,68
34,04	35,05	74,70



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,05	35,06	74,71
34,06	35,07	74,72
34,07	35,08	74,74
34,08	35,09	74,75
34,09	35,10	74,77
34,10	35,11	74,78
34,11	35,12	74,80
34,12	35,13	74,81
34,13	35,14	74,82
34,14	35,15	74,84
34,15	35,16	74,85
34,16	35,17	74,87
34,17	35,18	74,88
34,18	35,19	74,90
34,19	35,20	74,91
34,20	35,21	74,92
34,21	35,22	74,94
34,22	35,23	74,95
34,23	35,24	74,97
34,24	35,25	74,98
34,25	35,26	74,99
34,26	35,27	75,01
34,27	35,28	75,02
34,28	35,29	75,04
34,29	35,30	75,05
34,30	35,31	75,07
34,31	35,32	75,08
34,32	35,33	75,09
34,33	35,34	75,11
34,34	35,35	75,12
34,35	35,36	75,14
34,36	35,37	75,15
34,37	35,38	75,16
34,38	35,39	75,18
34,39	35,40	75,19
34,40	35,41	75,21
34,41	35,42	75,22
34,42	35,43	75,24
34,43	35,44	75,25
34,44	35,45	75,26
34,45	35,46	75,28
34,46	35,47	75,29
34,47	35,48	75,31
34,48	35,49	75,32



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,49	35,50	75,33
34,50	35,51	75,35
34,51	35,52	75,36
34,52	35,53	75,38
34,53	35,54	75,39
34,54	35,55	75,40
34,55	35,56	75,42
34,56	35,57	75,43
34,57	35,58	75,45
34,58	35,59	75,46
34,59	35,60	75,48
34,60	35,61	75,49
34,61	35,62	75,50
34,62	35,63	75,52
34,63	35,64	75,53
34,64	35,65	75,55
34,65	35,66	75,56
34,66	35,67	75,57
34,67	35,68	75,59
34,68	35,69	75,60
34,69	35,70	75,62
34,70	35,71	75,63
34,71	35,72	75,64
34,72	35,73	75,66
34,73	35,74	75,67
34,74	35,75	75,69
34,75	35,76	75,70
34,76	35,77	75,71
34,77	35,78	75,73
34,78	35,79	75,74
34,79	35,80	75,76
34,80	35,81	75,77
34,81	35,82	75,78
34,82	35,83	75,80
34,83	35,84	75,81
34,84	35,85	75,83
34,85	35,86	75,84
34,86	35,87	75,85
34,87	35,88	75,87
34,88	35,89	75,88
34,89	35,90	75,90
34,90	35,91	75,91
34,91	35,92	75,92
34,92	35,93	75,94



R502		
V1.0_R502		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
34,93	35,94	75,95
34,94	35,95	75,97
34,95	35,96	75,98
34,96	35,97	75,99
34,97	35,98	76,01
34,98	35,99	76,02
34,99	36,00	76,03
35,00	36,01	76,05
35,01	36,02	76,06
35,02	36,03	76,08
35,03	36,04	76,09
35,04	36,05	76,10
35,05	36,06	76,12
35,06	36,07	76,13
35,07	36,08	76,15
35,08	36,09	76,16
35,09	36,10	76,17
35,10	36,11	76,19
35,11	36,12	76,20
35,12	36,13	76,22
35,13	36,14	76,23
35,14	36,15	76,24
35,15	36,16	76,26
35,16	36,17	76,27
35,17	36,18	76,28
35,18	36,19	76,30
35,19	36,20	76,31
35,20	36,21	76,33
35,21	36,22	76,34
35,22	36,23	76,35
35,23	36,24	76,37
35,24	36,25	76,38
35,25	36,26	76,40
35,26	36,27	76,41
35,27	36,28	76,42
35,28	36,29	76,44
35,29	36,30	76,45
35,30	36,31	76,46
35,31	36,32	76,48
35,32	36,33	76,49
35,33	36,34	76,51