



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
-0,71	0,30	-39,13
-0,70	0,31	-38,48
-0,69	0,32	-37,84
-0,68	0,33	-37,22
-0,67	0,34	-36,62
-0,66	0,35	-36,03
-0,65	0,36	-35,45
-0,64	0,37	-34,89
-0,63	0,38	-34,33
-0,62	0,39	-33,79
-0,61	0,40	-33,26
-0,60	0,41	-32,74
-0,59	0,42	-32,24
-0,58	0,43	-31,74
-0,57	0,44	-31,25
-0,56	0,45	-30,76
-0,55	0,46	-30,29
-0,54	0,47	-29,83
-0,53	0,48	-29,37
-0,52	0,49	-28,92
-0,51	0,50	-28,48
-0,50	0,51	-28,04
-0,49	0,52	-27,61
-0,48	0,53	-27,19
-0,47	0,54	-26,77
-0,46	0,55	-26,36
-0,45	0,56	-25,96
-0,44	0,57	-25,56
-0,43	0,58	-25,17
-0,42	0,59	-24,78
-0,41	0,60	-24,40
-0,40	0,61	-24,02
-0,39	0,62	-23,65
-0,38	0,63	-23,28
-0,37	0,64	-22,91
-0,36	0,65	-22,56
-0,35	0,66	-22,20
-0,34	0,67	-21,85
-0,33	0,68	-21,50
-0,32	0,69	-21,16
-0,31	0,70	-20,82
-0,30	0,71	-20,49
-0,29	0,72	-20,16
-0,28	0,73	-19,83



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
-0,27	0,74	-19,51
-0,26	0,75	-19,18
-0,25	0,76	-18,87
-0,24	0,77	-18,55
-0,23	0,78	-18,24
-0,22	0,79	-17,94
-0,21	0,80	-17,63
-0,20	0,81	-17,33
-0,19	0,82	-17,03
-0,18	0,83	-16,73
-0,17	0,84	-16,44
-0,16	0,85	-16,15
-0,15	0,86	-15,86
-0,14	0,87	-15,58
-0,13	0,88	-15,29
-0,12	0,89	-15,01
-0,11	0,90	-14,74
-0,10	0,91	-14,46
-0,09	0,92	-14,19
-0,08	0,93	-13,92
-0,07	0,94	-13,65
-0,06	0,95	-13,38
-0,05	0,96	-13,12
-0,04	0,97	-12,86
-0,03	0,98	-12,60
-0,02	0,99	-12,34
-0,01	1,00	-12,08
0,00	1,01	-11,83
0,01	1,02	-11,58
0,02	1,03	-11,33
0,03	1,04	-11,08
0,04	1,05	-10,84
0,05	1,06	-10,59
0,06	1,07	-10,35
0,07	1,08	-10,11
0,08	1,09	-9,87
0,09	1,10	-9,63
0,10	1,11	-9,40
0,11	1,12	-9,16
0,12	1,13	-8,93
0,13	1,14	-8,70
0,14	1,15	-8,47
0,15	1,16	-8,24
0,16	1,17	-8,02



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,17	1,18	-7,79
0,18	1,19	-7,57
0,19	1,20	-7,35
0,20	1,21	-7,13
0,21	1,22	-6,91
0,22	1,23	-6,69
0,23	1,24	-6,47
0,24	1,25	-6,26
0,25	1,26	-6,04
0,26	1,27	-5,83
0,27	1,28	-5,62
0,28	1,29	-5,41
0,29	1,30	-5,20
0,30	1,31	-5,00
0,31	1,32	-4,79
0,32	1,33	-4,58
0,33	1,34	-4,38
0,34	1,35	-4,18
0,35	1,36	-3,98
0,36	1,37	-3,78
0,37	1,38	-3,58
0,38	1,39	-3,38
0,39	1,40	-3,18
0,40	1,41	-2,99
0,41	1,42	-2,79
0,42	1,43	-2,60
0,43	1,44	-2,41
0,44	1,45	-2,22
0,45	1,46	-2,02
0,46	1,47	-1,83
0,47	1,48	-1,65
0,48	1,49	-1,46
0,49	1,50	-1,27
0,50	1,51	-1,09
0,51	1,52	-0,90
0,52	1,53	-0,72
0,53	1,54	-0,54
0,54	1,55	-0,35
0,55	1,56	-0,17
0,56	1,57	0,01
0,57	1,58	0,19
0,58	1,59	0,37
0,59	1,60	0,54
0,60	1,61	0,72



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
0,61	1,62	0,90
0,62	1,63	1,07
0,63	1,64	1,25
0,64	1,65	1,42
0,65	1,66	1,59
0,66	1,67	1,76
0,67	1,68	1,93
0,68	1,69	2,10
0,69	1,70	2,27
0,70	1,71	2,44
0,71	1,72	2,61
0,72	1,73	2,78
0,73	1,74	2,94
0,74	1,75	3,11
0,75	1,76	3,27
0,76	1,77	3,44
0,77	1,78	3,60
0,78	1,79	3,77
0,79	1,80	3,93
0,80	1,81	4,09
0,81	1,82	4,25
0,82	1,83	4,41
0,83	1,84	4,57
0,84	1,85	4,73
0,85	1,86	4,89
0,86	1,87	5,04
0,87	1,88	5,20
0,88	1,89	5,36
0,89	1,90	5,51
0,90	1,91	5,67
0,91	1,92	5,82
0,92	1,93	5,98
0,93	1,94	6,13
0,94	1,95	6,28
0,95	1,96	6,43
0,96	1,97	6,58
0,97	1,98	6,74
0,98	1,99	6,89
0,99	2,00	7,04
1,00	2,01	7,18
1,01	2,02	7,33
1,02	2,03	7,48
1,03	2,04	7,63
1,04	2,05	7,78



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	7,92
1,06	2,07	8,07
1,07	2,08	8,21
1,08	2,09	8,36
1,09	2,10	8,50
1,10	2,11	8,64
1,11	2,12	8,79
1,12	2,13	8,93
1,13	2,14	9,07
1,14	2,15	9,21
1,15	2,16	9,36
1,16	2,17	9,50
1,17	2,18	9,64
1,18	2,19	9,78
1,19	2,20	9,91
1,20	2,21	10,05
1,21	2,22	10,19
1,22	2,23	10,33
1,23	2,24	10,47
1,24	2,25	10,60
1,25	2,26	10,74
1,26	2,27	10,88
1,27	2,28	11,01
1,28	2,29	11,15
1,29	2,30	11,28
1,30	2,31	11,41
1,31	2,32	11,55
1,32	2,33	11,68
1,33	2,34	11,81
1,34	2,35	11,95
1,35	2,36	12,08
1,36	2,37	12,21
1,37	2,38	12,34
1,38	2,39	12,47
1,39	2,40	12,60
1,40	2,41	12,73
1,41	2,42	12,86
1,42	2,43	12,99
1,43	2,44	13,12
1,44	2,45	13,25
1,45	2,46	13,37
1,46	2,47	13,50
1,47	2,48	13,63
1,48	2,49	13,76



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,49	2,50	13,88
1,50	2,51	14,01
1,51	2,52	14,13
1,52	2,53	14,26
1,53	2,54	14,38
1,54	2,55	14,51
1,55	2,56	14,63
1,56	2,57	14,75
1,57	2,58	14,88
1,58	2,59	15,00
1,59	2,60	15,12
1,60	2,61	15,25
1,61	2,62	15,37
1,62	2,63	15,49
1,63	2,64	15,61
1,64	2,65	15,73
1,65	2,66	15,85
1,66	2,67	15,97
1,67	2,68	16,09
1,68	2,69	16,21
1,69	2,70	16,33
1,70	2,71	16,45
1,71	2,72	16,57
1,72	2,73	16,68
1,73	2,74	16,80
1,74	2,75	16,92
1,75	2,76	17,04
1,76	2,77	17,15
1,77	2,78	17,27
1,78	2,79	17,39
1,79	2,80	17,50
1,80	2,81	17,62
1,81	2,82	17,73
1,82	2,83	17,85
1,83	2,84	17,96
1,84	2,85	18,08
1,85	2,86	18,19
1,86	2,87	18,31
1,87	2,88	18,42
1,88	2,89	18,53
1,89	2,90	18,64
1,90	2,91	18,76
1,91	2,92	18,87
1,92	2,93	18,98



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,93	2,94	19,09
1,94	2,95	19,20
1,95	2,96	19,32
1,96	2,97	19,43
1,97	2,98	19,54
1,98	2,99	19,65
1,99	3,00	19,76
2,00	3,01	19,87
2,01	3,02	19,98
2,02	3,03	20,09
2,03	3,04	20,19
2,04	3,05	20,30
2,05	3,06	20,41
2,06	3,07	20,52
2,07	3,08	20,63
2,08	3,09	20,73
2,09	3,10	20,84
2,10	3,11	20,95
2,11	3,12	21,06
2,12	3,13	21,16
2,13	3,14	21,27
2,14	3,15	21,37
2,15	3,16	21,48
2,16	3,17	21,59
2,17	3,18	21,69
2,18	3,19	21,80
2,19	3,20	21,90
2,20	3,21	22,01
2,21	3,22	22,11
2,22	3,23	22,21
2,23	3,24	22,32
2,24	3,25	22,42
2,25	3,26	22,52
2,26	3,27	22,63
2,27	3,28	22,73
2,28	3,29	22,83
2,29	3,30	22,93
2,30	3,31	23,04
2,31	3,32	23,14
2,32	3,33	23,24
2,33	3,34	23,34
2,34	3,35	23,44
2,35	3,36	23,54
2,36	3,37	23,64



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	23,75
2,38	3,39	23,85
2,39	3,40	23,95
2,40	3,41	24,05
2,41	3,42	24,15
2,42	3,43	24,24
2,43	3,44	24,34
2,44	3,45	24,44
2,45	3,46	24,54
2,46	3,47	24,64
2,47	3,48	24,74
2,48	3,49	24,84
2,49	3,50	24,93
2,50	3,51	25,03
2,51	3,52	25,13
2,52	3,53	25,23
2,53	3,54	25,32
2,54	3,55	25,42
2,55	3,56	25,52
2,56	3,57	25,61
2,57	3,58	25,71
2,58	3,59	25,81
2,59	3,60	25,90
2,60	3,61	26,00
2,61	3,62	26,09
2,62	3,63	26,19
2,63	3,64	26,28
2,64	3,65	26,38
2,65	3,66	26,47
2,66	3,67	26,57
2,67	3,68	26,66
2,68	3,69	26,76
2,69	3,70	26,85
2,70	3,71	26,94
2,71	3,72	27,04
2,72	3,73	27,13
2,73	3,74	27,22
2,74	3,75	27,32
2,75	3,76	27,41
2,76	3,77	27,50
2,77	3,78	27,60
2,78	3,79	27,69
2,79	3,80	27,78
2,80	3,81	27,87



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,81	3,82	27,96
2,82	3,83	28,05
2,83	3,84	28,15
2,84	3,85	28,24
2,85	3,86	28,33
2,86	3,87	28,42
2,87	3,88	28,51
2,88	3,89	28,60
2,89	3,90	28,69
2,90	3,91	28,78
2,91	3,92	28,87
2,92	3,93	28,96
2,93	3,94	29,05
2,94	3,95	29,14
2,95	3,96	29,23
2,96	3,97	29,32
2,97	3,98	29,41
2,98	3,99	29,50
2,99	4,00	29,58
3,00	4,01	29,67
3,01	4,02	29,76
3,02	4,03	29,85
3,03	4,04	29,94
3,04	4,05	30,02
3,05	4,06	30,11
3,06	4,07	30,20
3,07	4,08	30,29
3,08	4,09	30,37
3,09	4,10	30,46
3,10	4,11	30,55
3,11	4,12	30,63
3,12	4,13	30,72
3,13	4,14	30,81
3,14	4,15	30,89
3,15	4,16	30,98
3,16	4,17	31,07
3,17	4,18	31,15
3,18	4,19	31,24
3,19	4,20	31,32
3,20	4,21	31,41
3,21	4,22	31,49
3,22	4,23	31,58
3,23	4,24	31,66
3,24	4,25	31,75



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
3,25	4,26	31,83
3,26	4,27	31,92
3,27	4,28	32,00
3,28	4,29	32,08
3,29	4,30	32,17
3,30	4,31	32,25
3,31	4,32	32,34
3,32	4,33	32,42
3,33	4,34	32,50
3,34	4,35	32,59
3,35	4,36	32,67
3,36	4,37	32,75
3,37	4,38	32,83
3,38	4,39	32,92
3,39	4,40	33,00
3,40	4,41	33,08
3,41	4,42	33,16
3,42	4,43	33,25
3,43	4,44	33,33
3,44	4,45	33,41
3,45	4,46	33,49
3,46	4,47	33,57
3,47	4,48	33,65
3,48	4,49	33,74
3,49	4,50	33,82
3,50	4,51	33,90
3,51	4,52	33,98
3,52	4,53	34,06
3,53	4,54	34,14
3,54	4,55	34,22
3,55	4,56	34,30
3,56	4,57	34,38
3,57	4,58	34,46
3,58	4,59	34,54
3,59	4,60	34,62
3,60	4,61	34,70
3,61	4,62	34,78
3,62	4,63	34,86
3,63	4,64	34,94
3,64	4,65	35,02
3,65	4,66	35,10
3,66	4,67	35,18
3,67	4,68	35,26
3,68	4,69	35,33



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,69	4,70	35,41
3,70	4,71	35,49
3,71	4,72	35,57
3,72	4,73	35,65
3,73	4,74	35,73
3,74	4,75	35,80
3,75	4,76	35,88
3,76	4,77	35,96
3,77	4,78	36,04
3,78	4,79	36,11
3,79	4,80	36,19
3,80	4,81	36,27
3,81	4,82	36,35
3,82	4,83	36,42
3,83	4,84	36,50
3,84	4,85	36,58
3,85	4,86	36,65
3,86	4,87	36,73
3,87	4,88	36,81
3,88	4,89	36,88
3,89	4,90	36,96
3,90	4,91	37,03
3,91	4,92	37,11
3,92	4,93	37,19
3,93	4,94	37,26
3,94	4,95	37,34
3,95	4,96	37,41
3,96	4,97	37,49
3,97	4,98	37,56
3,98	4,99	37,64
3,99	5,00	37,71
4,00	5,01	37,79
4,01	5,02	37,86
4,02	5,03	37,94
4,03	5,04	38,01
4,04	5,05	38,09
4,05	5,06	38,16
4,06	5,07	38,24
4,07	5,08	38,31
4,08	5,09	38,38
4,09	5,10	38,46
4,10	5,11	38,53
4,11	5,12	38,60
4,12	5,13	38,68



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,13	5,14	38,75
4,14	5,15	38,83
4,15	5,16	38,90
4,16	5,17	38,97
4,17	5,18	39,04
4,18	5,19	39,12
4,19	5,20	39,19
4,20	5,21	39,26
4,21	5,22	39,34
4,22	5,23	39,41
4,23	5,24	39,48
4,24	5,25	39,55
4,25	5,26	39,63
4,26	5,27	39,70
4,27	5,28	39,77
4,28	5,29	39,84
4,29	5,30	39,91
4,30	5,31	39,99
4,31	5,32	40,06
4,32	5,33	40,13
4,33	5,34	40,20
4,34	5,35	40,27
4,35	5,36	40,34
4,36	5,37	40,41
4,37	5,38	40,48
4,38	5,39	40,56
4,39	5,40	40,63
4,40	5,41	40,70
4,41	5,42	40,77
4,42	5,43	40,84
4,43	5,44	40,91
4,44	5,45	40,98
4,45	5,46	41,05
4,46	5,47	41,12
4,47	5,48	41,19
4,48	5,49	41,26
4,49	5,50	41,33
4,50	5,51	41,40
4,51	5,52	41,47
4,52	5,53	41,54
4,53	5,54	41,61
4,54	5,55	41,68
4,55	5,56	41,75
4,56	5,57	41,82



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	41,89
4,58	5,59	41,95
4,59	5,60	42,02
4,60	5,61	42,09
4,61	5,62	42,16
4,62	5,63	42,23
4,63	5,64	42,30
4,64	5,65	42,37
4,65	5,66	42,44
4,66	5,67	42,50
4,67	5,68	42,57
4,68	5,69	42,64
4,69	5,70	42,71
4,70	5,71	42,78
4,71	5,72	42,84
4,72	5,73	42,91
4,73	5,74	42,98
4,74	5,75	43,05
4,75	5,76	43,11
4,76	5,77	43,18
4,77	5,78	43,25
4,78	5,79	43,32
4,79	5,80	43,38
4,80	5,81	43,45
4,81	5,82	43,52
4,82	5,83	43,58
4,83	5,84	43,65
4,84	5,85	43,72
4,85	5,86	43,78
4,86	5,87	43,85
4,87	5,88	43,92
4,88	5,89	43,98
4,89	5,90	44,05
4,90	5,91	44,12
4,91	5,92	44,18
4,92	5,93	44,25
4,93	5,94	44,32
4,94	5,95	44,38
4,95	5,96	44,45
4,96	5,97	44,51
4,97	5,98	44,58
4,98	5,99	44,64
4,99	6,00	44,71
5,00	6,01	44,78



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	44,84
5,02	6,03	44,91
5,03	6,04	44,97
5,04	6,05	45,04
5,05	6,06	45,10
5,06	6,07	45,17
5,07	6,08	45,23
5,08	6,09	45,30
5,09	6,10	45,36
5,10	6,11	45,43
5,11	6,12	45,49
5,12	6,13	45,55
5,13	6,14	45,62
5,14	6,15	45,68
5,15	6,16	45,75
5,16	6,17	45,81
5,17	6,18	45,88
5,18	6,19	45,94
5,19	6,20	46,00
5,20	6,21	46,07
5,21	6,22	46,13
5,22	6,23	46,19
5,23	6,24	46,26
5,24	6,25	46,32
5,25	6,26	46,39
5,26	6,27	46,45
5,27	6,28	46,51
5,28	6,29	46,58
5,29	6,30	46,64
5,30	6,31	46,70
5,31	6,32	46,77
5,32	6,33	46,83
5,33	6,34	46,89
5,34	6,35	46,95
5,35	6,36	47,02
5,36	6,37	47,08
5,37	6,38	47,14
5,38	6,39	47,20
5,39	6,40	47,27
5,40	6,41	47,33
5,41	6,42	47,39
5,42	6,43	47,45
5,43	6,44	47,52
5,44	6,45	47,58



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,45	6,46	47,64
5,46	6,47	47,70
5,47	6,48	47,76
5,48	6,49	47,83
5,49	6,50	47,89
5,50	6,51	47,95
5,51	6,52	48,01
5,52	6,53	48,07
5,53	6,54	48,13
5,54	6,55	48,20
5,55	6,56	48,26
5,56	6,57	48,32
5,57	6,58	48,38
5,58	6,59	48,44
5,59	6,60	48,50
5,60	6,61	48,56
5,61	6,62	48,62
5,62	6,63	48,68
5,63	6,64	48,74
5,64	6,65	48,81
5,65	6,66	48,87
5,66	6,67	48,93
5,67	6,68	48,99
5,68	6,69	49,05
5,69	6,70	49,11
5,70	6,71	49,17
5,71	6,72	49,23
5,72	6,73	49,29
5,73	6,74	49,35
5,74	6,75	49,41
5,75	6,76	49,47
5,76	6,77	49,53
5,77	6,78	49,59
5,78	6,79	49,65
5,79	6,80	49,71
5,80	6,81	49,77
5,81	6,82	49,83
5,82	6,83	49,89
5,83	6,84	49,95
5,84	6,85	50,01
5,85	6,86	50,07
5,86	6,87	50,12
5,87	6,88	50,18
5,88	6,89	50,24



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,89	6,90	50,30
5,90	6,91	50,36
5,91	6,92	50,42
5,92	6,93	50,48
5,93	6,94	50,54
5,94	6,95	50,60
5,95	6,96	50,66
5,96	6,97	50,71
5,97	6,98	50,77
5,98	6,99	50,83
5,99	7,00	50,89
6,00	7,01	50,95
6,01	7,02	51,01
6,02	7,03	51,06
6,03	7,04	51,12
6,04	7,05	51,18
6,05	7,06	51,24
6,06	7,07	51,30
6,07	7,08	51,36
6,08	7,09	51,41
6,09	7,10	51,47
6,10	7,11	51,53
6,11	7,12	51,59
6,12	7,13	51,64
6,13	7,14	51,70
6,14	7,15	51,76
6,15	7,16	51,82
6,16	7,17	51,87
6,17	7,18	51,93
6,18	7,19	51,99
6,19	7,20	52,05
6,20	7,21	52,10
6,21	7,22	52,16
6,22	7,23	52,22
6,23	7,24	52,27
6,24	7,25	52,33
6,25	7,26	52,39
6,26	7,27	52,45
6,27	7,28	52,50
6,28	7,29	52,56
6,29	7,30	52,62
6,30	7,31	52,67
6,31	7,32	52,73
6,32	7,33	52,79



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,33	7,34	52,84
6,34	7,35	52,90
6,35	7,36	52,95
6,36	7,37	53,01
6,37	7,38	53,07
6,38	7,39	53,12
6,39	7,40	53,18
6,40	7,41	53,24
6,41	7,42	53,29
6,42	7,43	53,35
6,43	7,44	53,40
6,44	7,45	53,46
6,45	7,46	53,51
6,46	7,47	53,57
6,47	7,48	53,63
6,48	7,49	53,68
6,49	7,50	53,74
6,50	7,51	53,79
6,51	7,52	53,85
6,52	7,53	53,90
6,53	7,54	53,96
6,54	7,55	54,01
6,55	7,56	54,07
6,56	7,57	54,12
6,57	7,58	54,18
6,58	7,59	54,24
6,59	7,60	54,29
6,60	7,61	54,35
6,61	7,62	54,40
6,62	7,63	54,45
6,63	7,64	54,51
6,64	7,65	54,56
6,65	7,66	54,62
6,66	7,67	54,67
6,67	7,68	54,73
6,68	7,69	54,78
6,69	7,70	54,84
6,70	7,71	54,89
6,71	7,72	54,95
6,72	7,73	55,00
6,73	7,74	55,05
6,74	7,75	55,11
6,75	7,76	55,16
6,76	7,77	55,22



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
6,77	7,78	55,27
6,78	7,79	55,33
6,79	7,80	55,38
6,80	7,81	55,43
6,81	7,82	55,49
6,82	7,83	55,54
6,83	7,84	55,59
6,84	7,85	55,65
6,85	7,86	55,70
6,86	7,87	55,76
6,87	7,88	55,81
6,88	7,89	55,86
6,89	7,90	55,92
6,90	7,91	55,97
6,91	7,92	56,02
6,92	7,93	56,08
6,93	7,94	56,13
6,94	7,95	56,18
6,95	7,96	56,24
6,96	7,97	56,29
6,97	7,98	56,34
6,98	7,99	56,40
6,99	8,00	56,45
7,00	8,01	56,50
7,01	8,02	56,55
7,02	8,03	56,61
7,03	8,04	56,66
7,04	8,05	56,71
7,05	8,06	56,77
7,06	8,07	56,82
7,07	8,08	56,87
7,08	8,09	56,92
7,09	8,10	56,98
7,10	8,11	57,03
7,11	8,12	57,08
7,12	8,13	57,13
7,13	8,14	57,19
7,14	8,15	57,24
7,15	8,16	57,29
7,16	8,17	57,34
7,17	8,18	57,39
7,18	8,19	57,45
7,19	8,20	57,50
7,20	8,21	57,55



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	57,60
7,22	8,23	57,65
7,23	8,24	57,71
7,24	8,25	57,76
7,25	8,26	57,81
7,26	8,27	57,86
7,27	8,28	57,91
7,28	8,29	57,96
7,29	8,30	58,02
7,30	8,31	58,07
7,31	8,32	58,12
7,32	8,33	58,17
7,33	8,34	58,22
7,34	8,35	58,27
7,35	8,36	58,32
7,36	8,37	58,38
7,37	8,38	58,43
7,38	8,39	58,48
7,39	8,40	58,53
7,40	8,41	58,58
7,41	8,42	58,63
7,42	8,43	58,68
7,43	8,44	58,73
7,44	8,45	58,78
7,45	8,46	58,83
7,46	8,47	58,89
7,47	8,48	58,94
7,48	8,49	58,99
7,49	8,50	59,04
7,50	8,51	59,09
7,51	8,52	59,14
7,52	8,53	59,19
7,53	8,54	59,24
7,54	8,55	59,29
7,55	8,56	59,34
7,56	8,57	59,39
7,57	8,58	59,44
7,58	8,59	59,49
7,59	8,60	59,54
7,60	8,61	59,59
7,61	8,62	59,64
7,62	8,63	59,69
7,63	8,64	59,74
7,64	8,65	59,79



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,65	8,66	59,84
7,66	8,67	59,89
7,67	8,68	59,94
7,68	8,69	59,99
7,69	8,70	60,04
7,70	8,71	60,09
7,71	8,72	60,14
7,72	8,73	60,19
7,73	8,74	60,24
7,74	8,75	60,29
7,75	8,76	60,34
7,76	8,77	60,39
7,77	8,78	60,44
7,78	8,79	60,49
7,79	8,80	60,54
7,80	8,81	60,59
7,81	8,82	60,64
7,82	8,83	60,69
7,83	8,84	60,73
7,84	8,85	60,78
7,85	8,86	60,83
7,86	8,87	60,88
7,87	8,88	60,93
7,88	8,89	60,98
7,89	8,90	61,03
7,90	8,91	61,08
7,91	8,92	61,13
7,92	8,93	61,18
7,93	8,94	61,22
7,94	8,95	61,27
7,95	8,96	61,32
7,96	8,97	61,37
7,97	8,98	61,42
7,98	8,99	61,47
7,99	9,00	61,52
8,00	9,01	61,57
8,01	9,02	61,61
8,02	9,03	61,66
8,03	9,04	61,71
8,04	9,05	61,76
8,05	9,06	61,81
8,06	9,07	61,86
8,07	9,08	61,90
8,08	9,09	61,95



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,09	9,10	62,00
8,10	9,11	62,05
8,11	9,12	62,10
8,12	9,13	62,14
8,13	9,14	62,19
8,14	9,15	62,24
8,15	9,16	62,29
8,16	9,17	62,34
8,17	9,18	62,38
8,18	9,19	62,43
8,19	9,20	62,48
8,20	9,21	62,53
8,21	9,22	62,58
8,22	9,23	62,62
8,23	9,24	62,67
8,24	9,25	62,72
8,25	9,26	62,77
8,26	9,27	62,81
8,27	9,28	62,86
8,28	9,29	62,91
8,29	9,30	62,96
8,30	9,31	63,00
8,31	9,32	63,05
8,32	9,33	63,10
8,33	9,34	63,15
8,34	9,35	63,19
8,35	9,36	63,24
8,36	9,37	63,29
8,37	9,38	63,33
8,38	9,39	63,38
8,39	9,40	63,43
8,40	9,41	63,48
8,41	9,42	63,52
8,42	9,43	63,57
8,43	9,44	63,62
8,44	9,45	63,66
8,45	9,46	63,71
8,46	9,47	63,76
8,47	9,48	63,80
8,48	9,49	63,85
8,49	9,50	63,90
8,50	9,51	63,94
8,51	9,52	63,99
8,52	9,53	64,04



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,53	9,54	64,08
8,54	9,55	64,13
8,55	9,56	64,18
8,56	9,57	64,22
8,57	9,58	64,27
8,58	9,59	64,32
8,59	9,60	64,36
8,60	9,61	64,41
8,61	9,62	64,45
8,62	9,63	64,50
8,63	9,64	64,55
8,64	9,65	64,59
8,65	9,66	64,64
8,66	9,67	64,69
8,67	9,68	64,73
8,68	9,69	64,78
8,69	9,70	64,82
8,70	9,71	64,87
8,71	9,72	64,91
8,72	9,73	64,96
8,73	9,74	65,01
8,74	9,75	65,05
8,75	9,76	65,10
8,76	9,77	65,14
8,77	9,78	65,19
8,78	9,79	65,24
8,79	9,80	65,28
8,80	9,81	65,33
8,81	9,82	65,37
8,82	9,83	65,42
8,83	9,84	65,46
8,84	9,85	65,51
8,85	9,86	65,55
8,86	9,87	65,60
8,87	9,88	65,64
8,88	9,89	65,69
8,89	9,90	65,74
8,90	9,91	65,78
8,91	9,92	65,83
8,92	9,93	65,87
8,93	9,94	65,92
8,94	9,95	65,96
8,95	9,96	66,01
8,96	9,97	66,05



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,97	9,98	66,10
8,98	9,99	66,14
8,99	10,00	66,19
9,00	10,01	66,23
9,01	10,02	66,28
9,02	10,03	66,32
9,03	10,04	66,37
9,04	10,05	66,41
9,05	10,06	66,46
9,06	10,07	66,50
9,07	10,08	66,54
9,08	10,09	66,59
9,09	10,10	66,63
9,10	10,11	66,68
9,11	10,12	66,72
9,12	10,13	66,77
9,13	10,14	66,81
9,14	10,15	66,86
9,15	10,16	66,90
9,16	10,17	66,95
9,17	10,18	66,99
9,18	10,19	67,03
9,19	10,20	67,08
9,20	10,21	67,12
9,21	10,22	67,17
9,22	10,23	67,21
9,23	10,24	67,26
9,24	10,25	67,30
9,25	10,26	67,34
9,26	10,27	67,39
9,27	10,28	67,43
9,28	10,29	67,48
9,29	10,30	67,52
9,30	10,31	67,56
9,31	10,32	67,61
9,32	10,33	67,65
9,33	10,34	67,70
9,34	10,35	67,74
9,35	10,36	67,78
9,36	10,37	67,83
9,37	10,38	67,87
9,38	10,39	67,91
9,39	10,40	67,96
9,40	10,41	68,00



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
9,41	10,42	68,05
9,42	10,43	68,09
9,43	10,44	68,13
9,44	10,45	68,18
9,45	10,46	68,22
9,46	10,47	68,26
9,47	10,48	68,31
9,48	10,49	68,35
9,49	10,50	68,39
9,50	10,51	68,44
9,51	10,52	68,48
9,52	10,53	68,52
9,53	10,54	68,57
9,54	10,55	68,61
9,55	10,56	68,65
9,56	10,57	68,70
9,57	10,58	68,74
9,58	10,59	68,78
9,59	10,60	68,83
9,60	10,61	68,87
9,61	10,62	68,91
9,62	10,63	68,95
9,63	10,64	69,00
9,64	10,65	69,04
9,65	10,66	69,08
9,66	10,67	69,13
9,67	10,68	69,17
9,68	10,69	69,21
9,69	10,70	69,25
9,70	10,71	69,30
9,71	10,72	69,34
9,72	10,73	69,38
9,73	10,74	69,43
9,74	10,75	69,47
9,75	10,76	69,51
9,76	10,77	69,55
9,77	10,78	69,60
9,78	10,79	69,64
9,79	10,80	69,68
9,80	10,81	69,72
9,81	10,82	69,77
9,82	10,83	69,81
9,83	10,84	69,85
9,84	10,85	69,89



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,85	10,86	69,94
9,86	10,87	69,98
9,87	10,88	70,02
9,88	10,89	70,06
9,89	10,90	70,10
9,90	10,91	70,15
9,91	10,92	70,19
9,92	10,93	70,23
9,93	10,94	70,27
9,94	10,95	70,31
9,95	10,96	70,36
9,96	10,97	70,40
9,97	10,98	70,44
9,98	10,99	70,48
9,99	11,00	70,52
10,00	11,01	70,57
10,01	11,02	70,61
10,02	11,03	70,65
10,03	11,04	70,69
10,04	11,05	70,73
10,05	11,06	70,78
10,06	11,07	70,82
10,07	11,08	70,86
10,08	11,09	70,90
10,09	11,10	70,94
10,10	11,11	70,98
10,11	11,12	71,03
10,12	11,13	71,07
10,13	11,14	71,11
10,14	11,15	71,15
10,15	11,16	71,19
10,16	11,17	71,23
10,17	11,18	71,27
10,18	11,19	71,32
10,19	11,20	71,36
10,20	11,21	71,40
10,21	11,22	71,44
10,22	11,23	71,48
10,23	11,24	71,52
10,24	11,25	71,56
10,25	11,26	71,60
10,26	11,27	71,65
10,27	11,28	71,69
10,28	11,29	71,73



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
10,29	11,30	71,77
10,30	11,31	71,81
10,31	11,32	71,85
10,32	11,33	71,89
10,33	11,34	71,93
10,34	11,35	71,97
10,35	11,36	72,02
10,36	11,37	72,06
10,37	11,38	72,10
10,38	11,39	72,14
10,39	11,40	72,18
10,40	11,41	72,22
10,41	11,42	72,26
10,42	11,43	72,30
10,43	11,44	72,34
10,44	11,45	72,38
10,45	11,46	72,42
10,46	11,47	72,46
10,47	11,48	72,50
10,48	11,49	72,54
10,49	11,50	72,59
10,50	11,51	72,63
10,51	11,52	72,67
10,52	11,53	72,71
10,53	11,54	72,75
10,54	11,55	72,79
10,55	11,56	72,83
10,56	11,57	72,87
10,57	11,58	72,91
10,58	11,59	72,95
10,59	11,60	72,99
10,60	11,61	73,03
10,61	11,62	73,07
10,62	11,63	73,11
10,63	11,64	73,15
10,64	11,65	73,19
10,65	11,66	73,23
10,66	11,67	73,27
10,67	11,68	73,31
10,68	11,69	73,35
10,69	11,70	73,39
10,70	11,71	73,43
10,71	11,72	73,47
10,72	11,73	73,51



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	73,55
10,74	11,75	73,59
10,75	11,76	73,63
10,76	11,77	73,67
10,77	11,78	73,71
10,78	11,79	73,75
10,79	11,80	73,79
10,80	11,81	73,83
10,81	11,82	73,87
10,82	11,83	73,91
10,83	11,84	73,95
10,84	11,85	73,99
10,85	11,86	74,03
10,86	11,87	74,07
10,87	11,88	74,11
10,88	11,89	74,15
10,89	11,90	74,19
10,90	11,91	74,23
10,91	11,92	74,27
10,92	11,93	74,31
10,93	11,94	74,35
10,94	11,95	74,38
10,95	11,96	74,42
10,96	11,97	74,46
10,97	11,98	74,50
10,98	11,99	74,54
10,99	12,00	74,58
11,00	12,01	74,62
11,01	12,02	74,66
11,02	12,03	74,70
11,03	12,04	74,74
11,04	12,05	74,78
11,05	12,06	74,82
11,06	12,07	74,86
11,07	12,08	74,90
11,08	12,09	74,93
11,09	12,10	74,97
11,10	12,11	75,01
11,11	12,12	75,05
11,12	12,13	75,09
11,13	12,14	75,13
11,14	12,15	75,17
11,15	12,16	75,21
11,16	12,17	75,25



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,17	12,18	75,29
11,18	12,19	75,32
11,19	12,20	75,36
11,20	12,21	75,40
11,21	12,22	75,44
11,22	12,23	75,48
11,23	12,24	75,52
11,24	12,25	75,56
11,25	12,26	75,60
11,26	12,27	75,63
11,27	12,28	75,67
11,28	12,29	75,71
11,29	12,30	75,75
11,30	12,31	75,79
11,31	12,32	75,83
11,32	12,33	75,87
11,33	12,34	75,90
11,34	12,35	75,94
11,35	12,36	75,98
11,36	12,37	76,02
11,37	12,38	76,06
11,38	12,39	76,10
11,39	12,40	76,13
11,40	12,41	76,17
11,41	12,42	76,21
11,42	12,43	76,25
11,43	12,44	76,29
11,44	12,45	76,33
11,45	12,46	76,36
11,46	12,47	76,40
11,47	12,48	76,44
11,48	12,49	76,48
11,49	12,50	76,52
11,50	12,51	76,56
11,51	12,52	76,59
11,52	12,53	76,63
11,53	12,54	76,67
11,54	12,55	76,71
11,55	12,56	76,75
11,56	12,57	76,78
11,57	12,58	76,82
11,58	12,59	76,86
11,59	12,60	76,90
11,60	12,61	76,94



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	76,97
11,62	12,63	77,01
11,63	12,64	77,05
11,64	12,65	77,09
11,65	12,66	77,12
11,66	12,67	77,16
11,67	12,68	77,20
11,68	12,69	77,24
11,69	12,70	77,28
11,70	12,71	77,31
11,71	12,72	77,35
11,72	12,73	77,39
11,73	12,74	77,43
11,74	12,75	77,46
11,75	12,76	77,50
11,76	12,77	77,54
11,77	12,78	77,58
11,78	12,79	77,61
11,79	12,80	77,65
11,80	12,81	77,69
11,81	12,82	77,73
11,82	12,83	77,76
11,83	12,84	77,80
11,84	12,85	77,84
11,85	12,86	77,88
11,86	12,87	77,91
11,87	12,88	77,95
11,88	12,89	77,99
11,89	12,90	78,03
11,90	12,91	78,06
11,91	12,92	78,10
11,92	12,93	78,14
11,93	12,94	78,17
11,94	12,95	78,21
11,95	12,96	78,25
11,96	12,97	78,29
11,97	12,98	78,32
11,98	12,99	78,36
11,99	13,00	78,40
12,00	13,01	78,43
12,01	13,02	78,47
12,02	13,03	78,51
12,03	13,04	78,55
12,04	13,05	78,58



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,05	13,06	78,62
12,06	13,07	78,66
12,07	13,08	78,69
12,08	13,09	78,73
12,09	13,10	78,77
12,10	13,11	78,80
12,11	13,12	78,84
12,12	13,13	78,88
12,13	13,14	78,91
12,14	13,15	78,95
12,15	13,16	78,99
12,16	13,17	79,02
12,17	13,18	79,06
12,18	13,19	79,10
12,19	13,20	79,13
12,20	13,21	79,17
12,21	13,22	79,21
12,22	13,23	79,24
12,23	13,24	79,28
12,24	13,25	79,32
12,25	13,26	79,35
12,26	13,27	79,39
12,27	13,28	79,43
12,28	13,29	79,46
12,29	13,30	79,50
12,30	13,31	79,54
12,31	13,32	79,57
12,32	13,33	79,61
12,33	13,34	79,65
12,34	13,35	79,68
12,35	13,36	79,72
12,36	13,37	79,75
12,37	13,38	79,79
12,38	13,39	79,83
12,39	13,40	79,86
12,40	13,41	79,90
12,41	13,42	79,94
12,42	13,43	79,97
12,43	13,44	80,01
12,44	13,45	80,04
12,45	13,46	80,08
12,46	13,47	80,12
12,47	13,48	80,15
12,48	13,49	80,19



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	80,22
12,50	13,51	80,26
12,51	13,52	80,30
12,52	13,53	80,33
12,53	13,54	80,37
12,54	13,55	80,40
12,55	13,56	80,44
12,56	13,57	80,48
12,57	13,58	80,51
12,58	13,59	80,55
12,59	13,60	80,58
12,60	13,61	80,62
12,61	13,62	80,66
12,62	13,63	80,69
12,63	13,64	80,73
12,64	13,65	80,76
12,65	13,66	80,80
12,66	13,67	80,83
12,67	13,68	80,87
12,68	13,69	80,91
12,69	13,70	80,94
12,70	13,71	80,98
12,71	13,72	81,01
12,72	13,73	81,05
12,73	13,74	81,08
12,74	13,75	81,12
12,75	13,76	81,15
12,76	13,77	81,19
12,77	13,78	81,23
12,78	13,79	81,26
12,79	13,80	81,30
12,80	13,81	81,33
12,81	13,82	81,37
12,82	13,83	81,40
12,83	13,84	81,44
12,84	13,85	81,47
12,85	13,86	81,51
12,86	13,87	81,54
12,87	13,88	81,58
12,88	13,89	81,62
12,89	13,90	81,65
12,90	13,91	81,69
12,91	13,92	81,72
12,92	13,93	81,76



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,93	13,94	81,79
12,94	13,95	81,83
12,95	13,96	81,86
12,96	13,97	81,90
12,97	13,98	81,93
12,98	13,99	81,97
12,99	14,00	82,00
13,00	14,01	82,04
13,01	14,02	82,07
13,02	14,03	82,11
13,03	14,04	82,14
13,04	14,05	82,18
13,05	14,06	82,21
13,06	14,07	82,25
13,07	14,08	82,28
13,08	14,09	82,32
13,09	14,10	82,35
13,10	14,11	82,39
13,11	14,12	82,42
13,12	14,13	82,46
13,13	14,14	82,49
13,14	14,15	82,53
13,15	14,16	82,56
13,16	14,17	82,60
13,17	14,18	82,63
13,18	14,19	82,67
13,19	14,20	82,70
13,20	14,21	82,74
13,21	14,22	82,77
13,22	14,23	82,80
13,23	14,24	82,84
13,24	14,25	82,87
13,25	14,26	82,91
13,26	14,27	82,94
13,27	14,28	82,98
13,28	14,29	83,01
13,29	14,30	83,05
13,30	14,31	83,08
13,31	14,32	83,12
13,32	14,33	83,15
13,33	14,34	83,18
13,34	14,35	83,22
13,35	14,36	83,25
13,36	14,37	83,29



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,37	14,38	83,32
13,38	14,39	83,36
13,39	14,40	83,39
13,40	14,41	83,43
13,41	14,42	83,46
13,42	14,43	83,49
13,43	14,44	83,53
13,44	14,45	83,56
13,45	14,46	83,60
13,46	14,47	83,63
13,47	14,48	83,67
13,48	14,49	83,70
13,49	14,50	83,73
13,50	14,51	83,77
13,51	14,52	83,80
13,52	14,53	83,84
13,53	14,54	83,87
13,54	14,55	83,91
13,55	14,56	83,94
13,56	14,57	83,97
13,57	14,58	84,01
13,58	14,59	84,04
13,59	14,60	84,08
13,60	14,61	84,11
13,61	14,62	84,14
13,62	14,63	84,18
13,63	14,64	84,21
13,64	14,65	84,25
13,65	14,66	84,28
13,66	14,67	84,31
13,67	14,68	84,35
13,68	14,69	84,38
13,69	14,70	84,41
13,70	14,71	84,45
13,71	14,72	84,48
13,72	14,73	84,52
13,73	14,74	84,55
13,74	14,75	84,58
13,75	14,76	84,62
13,76	14,77	84,65
13,77	14,78	84,69
13,78	14,79	84,72
13,79	14,80	84,75
13,80	14,81	84,79



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
13,81	14,82	84,82
13,82	14,83	84,85
13,83	14,84	84,89
13,84	14,85	84,92
13,85	14,86	84,95
13,86	14,87	84,99
13,87	14,88	85,02
13,88	14,89	85,05
13,89	14,90	85,09
13,90	14,91	85,12
13,91	14,92	85,16
13,92	14,93	85,19
13,93	14,94	85,22
13,94	14,95	85,26
13,95	14,96	85,29
13,96	14,97	85,32
13,97	14,98	85,36
13,98	14,99	85,39
13,99	15,00	85,42
14,00	15,01	85,46
14,01	15,02	85,49
14,02	15,03	85,52
14,03	15,04	85,56
14,04	15,05	85,59
14,05	15,06	85,62
14,06	15,07	85,66
14,07	15,08	85,69
14,08	15,09	85,72
14,09	15,10	85,76
14,10	15,11	85,79
14,11	15,12	85,82
14,12	15,13	85,85
14,13	15,14	85,89
14,14	15,15	85,92
14,15	15,16	85,95
14,16	15,17	85,99
14,17	15,18	86,02
14,18	15,19	86,05
14,19	15,20	86,09
14,20	15,21	86,12
14,21	15,22	86,15
14,22	15,23	86,19
14,23	15,24	86,22
14,24	15,25	86,25



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
14,25	15,26	86,28
14,26	15,27	86,32
14,27	15,28	86,35
14,28	15,29	86,38
14,29	15,30	86,42
14,30	15,31	86,45
14,31	15,32	86,48
14,32	15,33	86,51
14,33	15,34	86,55
14,34	15,35	86,58
14,35	15,36	86,61
14,36	15,37	86,65
14,37	15,38	86,68
14,38	15,39	86,71
14,39	15,40	86,74
14,40	15,41	86,78
14,41	15,42	86,81
14,42	15,43	86,84
14,43	15,44	86,87
14,44	15,45	86,91
14,45	15,46	86,94
14,46	15,47	86,97
14,47	15,48	87,00
14,48	15,49	87,04
14,49	15,50	87,07
14,50	15,51	87,10
14,51	15,52	87,14
14,52	15,53	87,17
14,53	15,54	87,20
14,54	15,55	87,23
14,55	15,56	87,27
14,56	15,57	87,30
14,57	15,58	87,33
14,58	15,59	87,36
14,59	15,60	87,39
14,60	15,61	87,43
14,61	15,62	87,46
14,62	15,63	87,49
14,63	15,64	87,52
14,64	15,65	87,56
14,65	15,66	87,59
14,66	15,67	87,62
14,67	15,68	87,65
14,68	15,69	87,69



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	87,72
14,70	15,71	87,75
14,71	15,72	87,78
14,72	15,73	87,81
14,73	15,74	87,85
14,74	15,75	87,88
14,75	15,76	87,91
14,76	15,77	87,94
14,77	15,78	87,98
14,78	15,79	88,01
14,79	15,80	88,04
14,80	15,81	88,07
14,81	15,82	88,10
14,82	15,83	88,14
14,83	15,84	88,17
14,84	15,85	88,20
14,85	15,86	88,23
14,86	15,87	88,26
14,87	15,88	88,30
14,88	15,89	88,33
14,89	15,90	88,36
14,90	15,91	88,39
14,91	15,92	88,42
14,92	15,93	88,46
14,93	15,94	88,49
14,94	15,95	88,52
14,95	15,96	88,55
14,96	15,97	88,58
14,97	15,98	88,61
14,98	15,99	88,65
14,99	16,00	88,68
15,00	16,01	88,71
15,01	16,02	88,74
15,02	16,03	88,77
15,03	16,04	88,81
15,04	16,05	88,84
15,05	16,06	88,87
15,06	16,07	88,90
15,07	16,08	88,93
15,08	16,09	88,96
15,09	16,10	89,00
15,10	16,11	89,03
15,11	16,12	89,06
15,12	16,13	89,09



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	89,12
15,14	16,15	89,15
15,15	16,16	89,19
15,16	16,17	89,22
15,17	16,18	89,25
15,18	16,19	89,28
15,19	16,20	89,31
15,20	16,21	89,34
15,21	16,22	89,37
15,22	16,23	89,41
15,23	16,24	89,44
15,24	16,25	89,47
15,25	16,26	89,50
15,26	16,27	89,53
15,27	16,28	89,56
15,28	16,29	89,59
15,29	16,30	89,63
15,30	16,31	89,66
15,31	16,32	89,69
15,32	16,33	89,72
15,33	16,34	89,75
15,34	16,35	89,78
15,35	16,36	89,81
15,36	16,37	89,85
15,37	16,38	89,88
15,38	16,39	89,91
15,39	16,40	89,94
15,40	16,41	89,97
15,41	16,42	90,00
15,42	16,43	90,03
15,43	16,44	90,06
15,44	16,45	90,09
15,45	16,46	90,13
15,46	16,47	90,16
15,47	16,48	90,19
15,48	16,49	90,22
15,49	16,50	90,25
15,50	16,51	90,28
15,51	16,52	90,31
15,52	16,53	90,34
15,53	16,54	90,37
15,54	16,55	90,41
15,55	16,56	90,44
15,56	16,57	90,47



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
15,57	16,58	90,50
15,58	16,59	90,53
15,59	16,60	90,56
15,60	16,61	90,59
15,61	16,62	90,62
15,62	16,63	90,65
15,63	16,64	90,68
15,64	16,65	90,72
15,65	16,66	90,75
15,66	16,67	90,78
15,67	16,68	90,81
15,68	16,69	90,84
15,69	16,70	90,87
15,70	16,71	90,90
15,71	16,72	90,93
15,72	16,73	90,96
15,73	16,74	90,99
15,74	16,75	91,02
15,75	16,76	91,05
15,76	16,77	91,08
15,77	16,78	91,12
15,78	16,79	91,15
15,79	16,80	91,18
15,80	16,81	91,21
15,81	16,82	91,24
15,82	16,83	91,27
15,83	16,84	91,30
15,84	16,85	91,33
15,85	16,86	91,36
15,86	16,87	91,39
15,87	16,88	91,42
15,88	16,89	91,45
15,89	16,90	91,48
15,90	16,91	91,51
15,91	16,92	91,54
15,92	16,93	91,57
15,93	16,94	91,60
15,94	16,95	91,64
15,95	16,96	91,67
15,96	16,97	91,70
15,97	16,98	91,73
15,98	16,99	91,76
15,99	17,00	91,79
16,00	17,01	91,82



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	91,85
16,02	17,03	91,88
16,03	17,04	91,91
16,04	17,05	91,94
16,05	17,06	91,97
16,06	17,07	92,00
16,07	17,08	92,03
16,08	17,09	92,06
16,09	17,10	92,09
16,10	17,11	92,12
16,11	17,12	92,15
16,12	17,13	92,18
16,13	17,14	92,21
16,14	17,15	92,24
16,15	17,16	92,27
16,16	17,17	92,30
16,17	17,18	92,33
16,18	17,19	92,36
16,19	17,20	92,39
16,20	17,21	92,42
16,21	17,22	92,45
16,22	17,23	92,48
16,23	17,24	92,51
16,24	17,25	92,54
16,25	17,26	92,57
16,26	17,27	92,60
16,27	17,28	92,63
16,28	17,29	92,66
16,29	17,30	92,69
16,30	17,31	92,72
16,31	17,32	92,75
16,32	17,33	92,78
16,33	17,34	92,81
16,34	17,35	92,84
16,35	17,36	92,87
16,36	17,37	92,90
16,37	17,38	92,93
16,38	17,39	92,96
16,39	17,40	92,99
16,40	17,41	93,02
16,41	17,42	93,05
16,42	17,43	93,08
16,43	17,44	93,11
16,44	17,45	93,14



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,45	17,46	93,17
16,46	17,47	93,20
16,47	17,48	93,23
16,48	17,49	93,26
16,49	17,50	93,29
16,50	17,51	93,32
16,51	17,52	93,35
16,52	17,53	93,38
16,53	17,54	93,41
16,54	17,55	93,44
16,55	17,56	93,47
16,56	17,57	93,50
16,57	17,58	93,53
16,58	17,59	93,56
16,59	17,60	93,59
16,60	17,61	93,62
16,61	17,62	93,65
16,62	17,63	93,68
16,63	17,64	93,71
16,64	17,65	93,74
16,65	17,66	93,77
16,66	17,67	93,80
16,67	17,68	93,82
16,68	17,69	93,85
16,69	17,70	93,88
16,70	17,71	93,91
16,71	17,72	93,94
16,72	17,73	93,97
16,73	17,74	94,00
16,74	17,75	94,03
16,75	17,76	94,06
16,76	17,77	94,09
16,77	17,78	94,12
16,78	17,79	94,15
16,79	17,80	94,18
16,80	17,81	94,21
16,81	17,82	94,24
16,82	17,83	94,27
16,83	17,84	94,30
16,84	17,85	94,32
16,85	17,86	94,35
16,86	17,87	94,38
16,87	17,88	94,41
16,88	17,89	94,44



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	94,47
16,90	17,91	94,50
16,91	17,92	94,53
16,92	17,93	94,56
16,93	17,94	94,59
16,94	17,95	94,62
16,95	17,96	94,65
16,96	17,97	94,68
16,97	17,98	94,70
16,98	17,99	94,73
16,99	18,00	94,76
17,00	18,01	94,79
17,01	18,02	94,82
17,02	18,03	94,85
17,03	18,04	94,88
17,04	18,05	94,91
17,05	18,06	94,94
17,06	18,07	94,97
17,07	18,08	95,00
17,08	18,09	95,03
17,09	18,10	95,05
17,10	18,11	95,08
17,11	18,12	95,11
17,12	18,13	95,14
17,13	18,14	95,17
17,14	18,15	95,20
17,15	18,16	95,23
17,16	18,17	95,26
17,17	18,18	95,29
17,18	18,19	95,31
17,19	18,20	95,34
17,20	18,21	95,37
17,21	18,22	95,40
17,22	18,23	95,43
17,23	18,24	95,46
17,24	18,25	95,49
17,25	18,26	95,52
17,26	18,27	95,55
17,27	18,28	95,57
17,28	18,29	95,60
17,29	18,30	95,63
17,30	18,31	95,66
17,31	18,32	95,69
17,32	18,33	95,72



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,33	18,34	95,75
17,34	18,35	95,78
17,35	18,36	95,80
17,36	18,37	95,83
17,37	18,38	95,86
17,38	18,39	95,89
17,39	18,40	95,92
17,40	18,41	95,95
17,41	18,42	95,98
17,42	18,43	96,01
17,43	18,44	96,03
17,44	18,45	96,06
17,45	18,46	96,09
17,46	18,47	96,12
17,47	18,48	96,15
17,48	18,49	96,18
17,49	18,50	96,21
17,50	18,51	96,23
17,51	18,52	96,26
17,52	18,53	96,29
17,53	18,54	96,32
17,54	18,55	96,35
17,55	18,56	96,38
17,56	18,57	96,40
17,57	18,58	96,43
17,58	18,59	96,46
17,59	18,60	96,49
17,60	18,61	96,52
17,61	18,62	96,55
17,62	18,63	96,58
17,63	18,64	96,60
17,64	18,65	96,63
17,65	18,66	96,66
17,66	18,67	96,69
17,67	18,68	96,72
17,68	18,69	96,75
17,69	18,70	96,77
17,70	18,71	96,80
17,71	18,72	96,83
17,72	18,73	96,86
17,73	18,74	96,89
17,74	18,75	96,92
17,75	18,76	96,94
17,76	18,77	96,97



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
17,77	18,78	97,00
17,78	18,79	97,03
17,79	18,80	97,06
17,80	18,81	97,08
17,81	18,82	97,11
17,82	18,83	97,14
17,83	18,84	97,17
17,84	18,85	97,20
17,85	18,86	97,23
17,86	18,87	97,25
17,87	18,88	97,28
17,88	18,89	97,31
17,89	18,90	97,34
17,90	18,91	97,37
17,91	18,92	97,39
17,92	18,93	97,42
17,93	18,94	97,45
17,94	18,95	97,48
17,95	18,96	97,51
17,96	18,97	97,53
17,97	18,98	97,56
17,98	18,99	97,59
17,99	19,00	97,62
18,00	19,01	97,65
18,01	19,02	97,67
18,02	19,03	97,70
18,03	19,04	97,73
18,04	19,05	97,76
18,05	19,06	97,79
18,06	19,07	97,81
18,07	19,08	97,84
18,08	19,09	97,87
18,09	19,10	97,90
18,10	19,11	97,93
18,11	19,12	97,95
18,12	19,13	97,98
18,13	19,14	98,01
18,14	19,15	98,04
18,15	19,16	98,07
18,16	19,17	98,09
18,17	19,18	98,12
18,18	19,19	98,15
18,19	19,20	98,18
18,20	19,21	98,20



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,21	19,22	98,23
18,22	19,23	98,26
18,23	19,24	98,29
18,24	19,25	98,31
18,25	19,26	98,34
18,26	19,27	98,37
18,27	19,28	98,40
18,28	19,29	98,43
18,29	19,30	98,45
18,30	19,31	98,48
18,31	19,32	98,51
18,32	19,33	98,54
18,33	19,34	98,56
18,34	19,35	98,59
18,35	19,36	98,62
18,36	19,37	98,65
18,37	19,38	98,67
18,38	19,39	98,70
18,39	19,40	98,73
18,40	19,41	98,76
18,41	19,42	98,78
18,42	19,43	98,81
18,43	19,44	98,84
18,44	19,45	98,87
18,45	19,46	98,89
18,46	19,47	98,92
18,47	19,48	98,95
18,48	19,49	98,98
18,49	19,50	99,00
18,50	19,51	99,03
18,51	19,52	99,06
18,52	19,53	99,09
18,53	19,54	99,11
18,54	19,55	99,14
18,55	19,56	99,17
18,56	19,57	99,20
18,57	19,58	99,22
18,58	19,59	99,25
18,59	19,60	99,28
18,60	19,61	99,31
18,61	19,62	99,33
18,62	19,63	99,36
18,63	19,64	99,39
18,64	19,65	99,42



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
18,65	19,66	99,44
18,66	19,67	99,47
18,67	19,68	99,50
18,68	19,69	99,52
18,69	19,70	99,55
18,70	19,71	99,58
18,71	19,72	99,61
18,72	19,73	99,63
18,73	19,74	99,66
18,74	19,75	99,69
18,75	19,76	99,71
18,76	19,77	99,74
18,77	19,78	99,77
18,78	19,79	99,80
18,79	19,80	99,82
18,80	19,81	99,85
18,81	19,82	99,88
18,82	19,83	99,90
18,83	19,84	99,93
18,84	19,85	99,96
18,85	19,86	99,99
18,86	19,87	100,01
18,87	19,88	100,04
18,88	19,89	100,07
18,89	19,90	100,09
18,90	19,91	100,12
18,91	19,92	100,15
18,92	19,93	100,18
18,93	19,94	100,20
18,94	19,95	100,23
18,95	19,96	100,26
18,96	19,97	100,28
18,97	19,98	100,31
18,98	19,99	100,34
18,99	20,00	100,36
19,00	20,01	100,39
19,01	20,02	100,42
19,02	20,03	100,44
19,03	20,04	100,47
19,04	20,05	100,50
19,05	20,06	100,53
19,06	20,07	100,55
19,07	20,08	100,58
19,08	20,09	100,61



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	100,63
19,10	20,11	100,66
19,11	20,12	100,69
19,12	20,13	100,71
19,13	20,14	100,74
19,14	20,15	100,77
19,15	20,16	100,79
19,16	20,17	100,82
19,17	20,18	100,85
19,18	20,19	100,87
19,19	20,20	100,90
19,20	20,21	100,93
19,21	20,22	100,95
19,22	20,23	100,98
19,23	20,24	101,01
19,24	20,25	101,03
19,25	20,26	101,06
19,26	20,27	101,09
19,27	20,28	101,11
19,28	20,29	101,14
19,29	20,30	101,17
19,30	20,31	101,19
19,31	20,32	101,22
19,32	20,33	101,25
19,33	20,34	101,27
19,34	20,35	101,30
19,35	20,36	101,33
19,36	20,37	101,35
19,37	20,38	101,38
19,38	20,39	101,41
19,39	20,40	101,43
19,40	20,41	101,46
19,41	20,42	101,49
19,42	20,43	101,51
19,43	20,44	101,54
19,44	20,45	101,57
19,45	20,46	101,59
19,46	20,47	101,62
19,47	20,48	101,65
19,48	20,49	101,67
19,49	20,50	101,70
19,50	20,51	101,72
19,51	20,52	101,75
19,52	20,53	101,78



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,53	20,54	101,80
19,54	20,55	101,83
19,55	20,56	101,86
19,56	20,57	101,88
19,57	20,58	101,91
19,58	20,59	101,94
19,59	20,60	101,96
19,60	20,61	101,99
19,61	20,62	102,01
19,62	20,63	102,04
19,63	20,64	102,07
19,64	20,65	102,09
19,65	20,66	102,12
19,66	20,67	102,15
19,67	20,68	102,17
19,68	20,69	102,20
19,69	20,70	102,23
19,70	20,71	102,25
19,71	20,72	102,28
19,72	20,73	102,30
19,73	20,74	102,33
19,74	20,75	102,36
19,75	20,76	102,38
19,76	20,77	102,41
19,77	20,78	102,43
19,78	20,79	102,46
19,79	20,80	102,49
19,80	20,81	102,51
19,81	20,82	102,54
19,82	20,83	102,57
19,83	20,84	102,59
19,84	20,85	102,62
19,85	20,86	102,64
19,86	20,87	102,67
19,87	20,88	102,70
19,88	20,89	102,72
19,89	20,90	102,75
19,90	20,91	102,77
19,91	20,92	102,80
19,92	20,93	102,83
19,93	20,94	102,85
19,94	20,95	102,88
19,95	20,96	102,90
19,96	20,97	102,93



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,97	20,98	102,96
19,98	20,99	102,98
19,99	21,00	103,01
20,00	21,01	103,03
20,01	21,02	103,06
20,02	21,03	103,09
20,03	21,04	103,11
20,04	21,05	103,14
20,05	21,06	103,16
20,06	21,07	103,19
20,07	21,08	103,22
20,08	21,09	103,24
20,09	21,10	103,27
20,10	21,11	103,29
20,11	21,12	103,32
20,12	21,13	103,35
20,13	21,14	103,37
20,14	21,15	103,40
20,15	21,16	103,42
20,16	21,17	103,45
20,17	21,18	103,47
20,18	21,19	103,50
20,19	21,20	103,53
20,20	21,21	103,55
20,21	21,22	103,58
20,22	21,23	103,60
20,23	21,24	103,63
20,24	21,25	103,65
20,25	21,26	103,68
20,26	21,27	103,71
20,27	21,28	103,73
20,28	21,29	103,76
20,29	21,30	103,78
20,30	21,31	103,81
20,31	21,32	103,83
20,32	21,33	103,86
20,33	21,34	103,89
20,34	21,35	103,91
20,35	21,36	103,94
20,36	21,37	103,96
20,37	21,38	103,99
20,38	21,39	104,01
20,39	21,40	104,04
20,40	21,41	104,07



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,41	21,42	104,09
20,42	21,43	104,12
20,43	21,44	104,14
20,44	21,45	104,17
20,45	21,46	104,19
20,46	21,47	104,22
20,47	21,48	104,24
20,48	21,49	104,27
20,49	21,50	104,30
20,50	21,51	104,32
20,51	21,52	104,35
20,52	21,53	104,37
20,53	21,54	104,40
20,54	21,55	104,42
20,55	21,56	104,45
20,56	21,57	104,47
20,57	21,58	104,50
20,58	21,59	104,52
20,59	21,60	104,55
20,60	21,61	104,58
20,61	21,62	104,60
20,62	21,63	104,63
20,63	21,64	104,65
20,64	21,65	104,68
20,65	21,66	104,70
20,66	21,67	104,73
20,67	21,68	104,75
20,68	21,69	104,78
20,69	21,70	104,80
20,70	21,71	104,83
20,71	21,72	104,85
20,72	21,73	104,88
20,73	21,74	104,90
20,74	21,75	104,93
20,75	21,76	104,96
20,76	21,77	104,98
20,77	21,78	105,01
20,78	21,79	105,03
20,79	21,80	105,06
20,80	21,81	105,08
20,81	21,82	105,11
20,82	21,83	105,13
20,83	21,84	105,16
20,84	21,85	105,18



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
20,85	21,86	105,21
20,86	21,87	105,23
20,87	21,88	105,26
20,88	21,89	105,28
20,89	21,90	105,31
20,90	21,91	105,33
20,91	21,92	105,36
20,92	21,93	105,38
20,93	21,94	105,41
20,94	21,95	105,43
20,95	21,96	105,46
20,96	21,97	105,48
20,97	21,98	105,51
20,98	21,99	105,53
20,99	22,00	105,56
21,00	22,01	105,58
21,01	22,02	105,61
21,02	22,03	105,63
21,03	22,04	105,66
21,04	22,05	105,68
21,05	22,06	105,71
21,06	22,07	105,73
21,07	22,08	105,76
21,08	22,09	105,78
21,09	22,10	105,81
21,10	22,11	105,83
21,11	22,12	105,86
21,12	22,13	105,88
21,13	22,14	105,91
21,14	22,15	105,93
21,15	22,16	105,96
21,16	22,17	105,98
21,17	22,18	106,01
21,18	22,19	106,03
21,19	22,20	106,06
21,20	22,21	106,08
21,21	22,22	106,11
21,22	22,23	106,13
21,23	22,24	106,16
21,24	22,25	106,18
21,25	22,26	106,21
21,26	22,27	106,23
21,27	22,28	106,26
21,28	22,29	106,28



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,29	22,30	106,31
21,30	22,31	106,33
21,31	22,32	106,36
21,32	22,33	106,38
21,33	22,34	106,41
21,34	22,35	106,43
21,35	22,36	106,46
21,36	22,37	106,48
21,37	22,38	106,51
21,38	22,39	106,53
21,39	22,40	106,56
21,40	22,41	106,58
21,41	22,42	106,60
21,42	22,43	106,63
21,43	22,44	106,65
21,44	22,45	106,68
21,45	22,46	106,70
21,46	22,47	106,73
21,47	22,48	106,75
21,48	22,49	106,78
21,49	22,50	106,80
21,50	22,51	106,83
21,51	22,52	106,85
21,52	22,53	106,88
21,53	22,54	106,90
21,54	22,55	106,93
21,55	22,56	106,95
21,56	22,57	106,97
21,57	22,58	107,00
21,58	22,59	107,02
21,59	22,60	107,05
21,60	22,61	107,07
21,61	22,62	107,10
21,62	22,63	107,12
21,63	22,64	107,15
21,64	22,65	107,17
21,65	22,66	107,20
21,66	22,67	107,22
21,67	22,68	107,24
21,68	22,69	107,27
21,69	22,70	107,29
21,70	22,71	107,32
21,71	22,72	107,34
21,72	22,73	107,37



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	107,39
21,74	22,75	107,42
21,75	22,76	107,44
21,76	22,77	107,46
21,77	22,78	107,49
21,78	22,79	107,51
21,79	22,80	107,54
21,80	22,81	107,56
21,81	22,82	107,59
21,82	22,83	107,61
21,83	22,84	107,64
21,84	22,85	107,66
21,85	22,86	107,68
21,86	22,87	107,71
21,87	22,88	107,73
21,88	22,89	107,76
21,89	22,90	107,78
21,90	22,91	107,81
21,91	22,92	107,83
21,92	22,93	107,85
21,93	22,94	107,88
21,94	22,95	107,90
21,95	22,96	107,93
21,96	22,97	107,95
21,97	22,98	107,98
21,98	22,99	108,00
21,99	23,00	108,02
22,00	23,01	108,05
22,01	23,02	108,07
22,02	23,03	108,10
22,03	23,04	108,12
22,04	23,05	108,15
22,05	23,06	108,17
22,06	23,07	108,19
22,07	23,08	108,22
22,08	23,09	108,24
22,09	23,10	108,27
22,10	23,11	108,29
22,11	23,12	108,31
22,12	23,13	108,34
22,13	23,14	108,36
22,14	23,15	108,39
22,15	23,16	108,41
22,16	23,17	108,44



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,17	23,18	108,46
22,18	23,19	108,48
22,19	23,20	108,51
22,20	23,21	108,53
22,21	23,22	108,56
22,22	23,23	108,58
22,23	23,24	108,60
22,24	23,25	108,63
22,25	23,26	108,65
22,26	23,27	108,68
22,27	23,28	108,70
22,28	23,29	108,72
22,29	23,30	108,75
22,30	23,31	108,77
22,31	23,32	108,80
22,32	23,33	108,82
22,33	23,34	108,84
22,34	23,35	108,87
22,35	23,36	108,89
22,36	23,37	108,92
22,37	23,38	108,94
22,38	23,39	108,96
22,39	23,40	108,99
22,40	23,41	109,01
22,41	23,42	109,04
22,42	23,43	109,06
22,43	23,44	109,08
22,44	23,45	109,11
22,45	23,46	109,13
22,46	23,47	109,15
22,47	23,48	109,18
22,48	23,49	109,20
22,49	23,50	109,23
22,50	23,51	109,25
22,51	23,52	109,27
22,52	23,53	109,30
22,53	23,54	109,32
22,54	23,55	109,35
22,55	23,56	109,37
22,56	23,57	109,39
22,57	23,58	109,42
22,58	23,59	109,44
22,59	23,60	109,46
22,60	23,61	109,49



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	109,51
22,62	23,63	109,54
22,63	23,64	109,56
22,64	23,65	109,58
22,65	23,66	109,61
22,66	23,67	109,63
22,67	23,68	109,65
22,68	23,69	109,68
22,69	23,70	109,70
22,70	23,71	109,73
22,71	23,72	109,75
22,72	23,73	109,77
22,73	23,74	109,80
22,74	23,75	109,82
22,75	23,76	109,84
22,76	23,77	109,87
22,77	23,78	109,89
22,78	23,79	109,91
22,79	23,80	109,94
22,80	23,81	109,96
22,81	23,82	109,99
22,82	23,83	110,01
22,83	23,84	110,03
22,84	23,85	110,06
22,85	23,86	110,08
22,86	23,87	110,10
22,87	23,88	110,13
22,88	23,89	110,15
22,89	23,90	110,17
22,90	23,91	110,20
22,91	23,92	110,22
22,92	23,93	110,24
22,93	23,94	110,27
22,94	23,95	110,29
22,95	23,96	110,32
22,96	23,97	110,34
22,97	23,98	110,36
22,98	23,99	110,39
22,99	24,00	110,41
23,00	24,01	110,43
23,01	24,02	110,46
23,02	24,03	110,48
23,03	24,04	110,50
23,04	24,05	110,53



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,05	24,06	110,55
23,06	24,07	110,57
23,07	24,08	110,60
23,08	24,09	110,62
23,09	24,10	110,64
23,10	24,11	110,67
23,11	24,12	110,69
23,12	24,13	110,71
23,13	24,14	110,74
23,14	24,15	110,76
23,15	24,16	110,78
23,16	24,17	110,81
23,17	24,18	110,83
23,18	24,19	110,85
23,19	24,20	110,88
23,20	24,21	110,90
23,21	24,22	110,92
23,22	24,23	110,95
23,23	24,24	110,97
23,24	24,25	110,99
23,25	24,26	111,02
23,26	24,27	111,04
23,27	24,28	111,06
23,28	24,29	111,09
23,29	24,30	111,11
23,30	24,31	111,13
23,31	24,32	111,16
23,32	24,33	111,18
23,33	24,34	111,20
23,34	24,35	111,23
23,35	24,36	111,25
23,36	24,37	111,27
23,37	24,38	111,30
23,38	24,39	111,32
23,39	24,40	111,34
23,40	24,41	111,36
23,41	24,42	111,39
23,42	24,43	111,41
23,43	24,44	111,43
23,44	24,45	111,46
23,45	24,46	111,48
23,46	24,47	111,50
23,47	24,48	111,53
23,48	24,49	111,55



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,49	24,50	111,57
23,50	24,51	111,60
23,51	24,52	111,62
23,52	24,53	111,64
23,53	24,54	111,67
23,54	24,55	111,69
23,55	24,56	111,71
23,56	24,57	111,73
23,57	24,58	111,76
23,58	24,59	111,78
23,59	24,60	111,80
23,60	24,61	111,83
23,61	24,62	111,85
23,62	24,63	111,87
23,63	24,64	111,90
23,64	24,65	111,92
23,65	24,66	111,94
23,66	24,67	111,96
23,67	24,68	111,99
23,68	24,69	112,01
23,69	24,70	112,03
23,70	24,71	112,06
23,71	24,72	112,08
23,72	24,73	112,10
23,73	24,74	112,13
23,74	24,75	112,15
23,75	24,76	112,17
23,76	24,77	112,19
23,77	24,78	112,22
23,78	24,79	112,24
23,79	24,80	112,26
23,80	24,81	112,29
23,81	24,82	112,31
23,82	24,83	112,33
23,83	24,84	112,35
23,84	24,85	112,38
23,85	24,86	112,40
23,86	24,87	112,42
23,87	24,88	112,45
23,88	24,89	112,47
23,89	24,90	112,49
23,90	24,91	112,51
23,91	24,92	112,54
23,92	24,93	112,56



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
23,93	24,94	112,58
23,94	24,95	112,60
23,95	24,96	112,63
23,96	24,97	112,65
23,97	24,98	112,67
23,98	24,99	112,70
23,99	25,00	112,72
24,00	25,01	112,74
24,01	25,02	112,76
24,02	25,03	112,79
24,03	25,04	112,81
24,04	25,05	112,83
24,05	25,06	112,85
24,06	25,07	112,88
24,07	25,08	112,90
24,08	25,09	112,92
24,09	25,10	112,95
24,10	25,11	112,97
24,11	25,12	112,99
24,12	25,13	113,01
24,13	25,14	113,04
24,14	25,15	113,06
24,15	25,16	113,08
24,16	25,17	113,10
24,17	25,18	113,13
24,18	25,19	113,15
24,19	25,20	113,17
24,20	25,21	113,19
24,21	25,22	113,22
24,22	25,23	113,24
24,23	25,24	113,26
24,24	25,25	113,28
24,25	25,26	113,31
24,26	25,27	113,33
24,27	25,28	113,35
24,28	25,29	113,38
24,29	25,30	113,40
24,30	25,31	113,42
24,31	25,32	113,44
24,32	25,33	113,47
24,33	25,34	113,49
24,34	25,35	113,51
24,35	25,36	113,53
24,36	25,37	113,56



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
24,37	25,38	113,58
24,38	25,39	113,60
24,39	25,40	113,62
24,40	25,41	113,65
24,41	25,42	113,67
24,42	25,43	113,69
24,43	25,44	113,71
24,44	25,45	113,73
24,45	25,46	113,76
24,46	25,47	113,78
24,47	25,48	113,80
24,48	25,49	113,82
24,49	25,50	113,85
24,50	25,51	113,87
24,51	25,52	113,89
24,52	25,53	113,91
24,53	25,54	113,94
24,54	25,55	113,96
24,55	25,56	113,98
24,56	25,57	114,00
24,57	25,58	114,03
24,58	25,59	114,05
24,59	25,60	114,07
24,60	25,61	114,09
24,61	25,62	114,12
24,62	25,63	114,14
24,63	25,64	114,16
24,64	25,65	114,18
24,65	25,66	114,20
24,66	25,67	114,23
24,67	25,68	114,25
24,68	25,69	114,27
24,69	25,70	114,29
24,70	25,71	114,32
24,71	25,72	114,34
24,72	25,73	114,36
24,73	25,74	114,38
24,74	25,75	114,40
24,75	25,76	114,43
24,76	25,77	114,45
24,77	25,78	114,47
24,78	25,79	114,49
24,79	25,80	114,52
24,80	25,81	114,54



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	114,56
24,82	25,83	114,58
24,83	25,84	114,60
24,84	25,85	114,63
24,85	25,86	114,65
24,86	25,87	114,67
24,87	25,88	114,69
24,88	25,89	114,71
24,89	25,90	114,74
24,90	25,91	114,76
24,91	25,92	114,78
24,92	25,93	114,80
24,93	25,94	114,83
24,94	25,95	114,85
24,95	25,96	114,87
24,96	25,97	114,89
24,97	25,98	114,91
24,98	25,99	114,94
24,99	26,00	114,96
25,00	26,01	114,98
25,01	26,02	115,00
25,02	26,03	115,02
25,03	26,04	115,05
25,04	26,05	115,07
25,05	26,06	115,09
25,06	26,07	115,11
25,07	26,08	115,13
25,08	26,09	115,16
25,09	26,10	115,18
25,10	26,11	115,20
25,11	26,12	115,22
25,12	26,13	115,24
25,13	26,14	115,27
25,14	26,15	115,29
25,15	26,16	115,31
25,16	26,17	115,33
25,17	26,18	115,35
25,18	26,19	115,38
25,19	26,20	115,40
25,20	26,21	115,42
25,21	26,22	115,44
25,22	26,23	115,46
25,23	26,24	115,49
25,24	26,25	115,51



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	115,53
25,26	26,27	115,55
25,27	26,28	115,57
25,28	26,29	115,59
25,29	26,30	115,62
25,30	26,31	115,64
25,31	26,32	115,66
25,32	26,33	115,68
25,33	26,34	115,70
25,34	26,35	115,73
25,35	26,36	115,75
25,36	26,37	115,77
25,37	26,38	115,79
25,38	26,39	115,81
25,39	26,40	115,83
25,40	26,41	115,86
25,41	26,42	115,88
25,42	26,43	115,90
25,43	26,44	115,92
25,44	26,45	115,94
25,45	26,46	115,97
25,46	26,47	115,99
25,47	26,48	116,01
25,48	26,49	116,03
25,49	26,50	116,05
25,50	26,51	116,07
25,51	26,52	116,10
25,52	26,53	116,12
25,53	26,54	116,14
25,54	26,55	116,16
25,55	26,56	116,18
25,56	26,57	116,20
25,57	26,58	116,23
25,58	26,59	116,25
25,59	26,60	116,27
25,60	26,61	116,29
25,61	26,62	116,31
25,62	26,63	116,33
25,63	26,64	116,36
25,64	26,65	116,38
25,65	26,66	116,40
25,66	26,67	116,42
25,67	26,68	116,44
25,68	26,69	116,46



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,69	26,70	116,49
25,70	26,71	116,51
25,71	26,72	116,53
25,72	26,73	116,55
25,73	26,74	116,57
25,74	26,75	116,59
25,75	26,76	116,62
25,76	26,77	116,64
25,77	26,78	116,66
25,78	26,79	116,68
25,79	26,80	116,70
25,80	26,81	116,72
25,81	26,82	116,74
25,82	26,83	116,77
25,83	26,84	116,79
25,84	26,85	116,81
25,85	26,86	116,83
25,86	26,87	116,85
25,87	26,88	116,87
25,88	26,89	116,90
25,89	26,90	116,92
25,90	26,91	116,94
25,91	26,92	116,96
25,92	26,93	116,98
25,93	26,94	117,00
25,94	26,95	117,02
25,95	26,96	117,05
25,96	26,97	117,07
25,97	26,98	117,09
25,98	26,99	117,11
25,99	27,00	117,13
26,00	27,01	117,15
26,01	27,02	117,17
26,02	27,03	117,20
26,03	27,04	117,22
26,04	27,05	117,24
26,05	27,06	117,26
26,06	27,07	117,28
26,07	27,08	117,30
26,08	27,09	117,32
26,09	27,10	117,34
26,10	27,11	117,37
26,11	27,12	117,39
26,12	27,13	117,41



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	117,43
26,14	27,15	117,45
26,15	27,16	117,47
26,16	27,17	117,49
26,17	27,18	117,52
26,18	27,19	117,54
26,19	27,20	117,56
26,20	27,21	117,58
26,21	27,22	117,60
26,22	27,23	117,62
26,23	27,24	117,64
26,24	27,25	117,66
26,25	27,26	117,69
26,26	27,27	117,71
26,27	27,28	117,73
26,28	27,29	117,75
26,29	27,30	117,77
26,30	27,31	117,79
26,31	27,32	117,81
26,32	27,33	117,83
26,33	27,34	117,86
26,34	27,35	117,88
26,35	27,36	117,90
26,36	27,37	117,92
26,37	27,38	117,94
26,38	27,39	117,96
26,39	27,40	117,98
26,40	27,41	118,00
26,41	27,42	118,02
26,42	27,43	118,05
26,43	27,44	118,07
26,44	27,45	118,09
26,45	27,46	118,11
26,46	27,47	118,13
26,47	27,48	118,15
26,48	27,49	118,17
26,49	27,50	118,19
26,50	27,51	118,22
26,51	27,52	118,24
26,52	27,53	118,26
26,53	27,54	118,28
26,54	27,55	118,30
26,55	27,56	118,32
26,56	27,57	118,34



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,57	27,58	118,36
26,58	27,59	118,38
26,59	27,60	118,40
26,60	27,61	118,43
26,61	27,62	118,45
26,62	27,63	118,47
26,63	27,64	118,49
26,64	27,65	118,51
26,65	27,66	118,53
26,66	27,67	118,55
26,67	27,68	118,57
26,68	27,69	118,59
26,69	27,70	118,61
26,70	27,71	118,64
26,71	27,72	118,66
26,72	27,73	118,68
26,73	27,74	118,70
26,74	27,75	118,72
26,75	27,76	118,74
26,76	27,77	118,76
26,77	27,78	118,78
26,78	27,79	118,80
26,79	27,80	118,82
26,80	27,81	118,85
26,81	27,82	118,87
26,82	27,83	118,89
26,83	27,84	118,91
26,84	27,85	118,93
26,85	27,86	118,95
26,86	27,87	118,97
26,87	27,88	118,99
26,88	27,89	119,01
26,89	27,90	119,03
26,90	27,91	119,05
26,91	27,92	119,08
26,92	27,93	119,10
26,93	27,94	119,12
26,94	27,95	119,14
26,95	27,96	119,16
26,96	27,97	119,18
26,97	27,98	119,20
26,98	27,99	119,22
26,99	28,00	119,24
27,00	28,01	119,26



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	119,28
27,02	28,03	119,30
27,03	28,04	119,32
27,04	28,05	119,35
27,05	28,06	119,37
27,06	28,07	119,39
27,07	28,08	119,41
27,08	28,09	119,43
27,09	28,10	119,45
27,10	28,11	119,47
27,11	28,12	119,49
27,12	28,13	119,51
27,13	28,14	119,53
27,14	28,15	119,55
27,15	28,16	119,57
27,16	28,17	119,59
27,17	28,18	119,62
27,18	28,19	119,64
27,19	28,20	119,66
27,20	28,21	119,68
27,21	28,22	119,70
27,22	28,23	119,72
27,23	28,24	119,74
27,24	28,25	119,76
27,25	28,26	119,78
27,26	28,27	119,80
27,27	28,28	119,82
27,28	28,29	119,84
27,29	28,30	119,86
27,30	28,31	119,88
27,31	28,32	119,90
27,32	28,33	119,93
27,33	28,34	119,95
27,34	28,35	119,97
27,35	28,36	119,99
27,36	28,37	120,01
27,37	28,38	120,03
27,38	28,39	120,05
27,39	28,40	120,07
27,40	28,41	120,09
27,41	28,42	120,11
27,42	28,43	120,13
27,43	28,44	120,15
27,44	28,45	120,17



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	120,19
27,46	28,47	120,21
27,47	28,48	120,23
27,48	28,49	120,25
27,49	28,50	120,27
27,50	28,51	120,30
27,51	28,52	120,32
27,52	28,53	120,34
27,53	28,54	120,36
27,54	28,55	120,38
27,55	28,56	120,40
27,56	28,57	120,42
27,57	28,58	120,44
27,58	28,59	120,46
27,59	28,60	120,48
27,60	28,61	120,50
27,61	28,62	120,52
27,62	28,63	120,54
27,63	28,64	120,56
27,64	28,65	120,58
27,65	28,66	120,60
27,66	28,67	120,62
27,67	28,68	120,64
27,68	28,69	120,66
27,69	28,70	120,68
27,70	28,71	120,70
27,71	28,72	120,72
27,72	28,73	120,75
27,73	28,74	120,77
27,74	28,75	120,79
27,75	28,76	120,81
27,76	28,77	120,83
27,77	28,78	120,85
27,78	28,79	120,87
27,79	28,80	120,89
27,80	28,81	120,91
27,81	28,82	120,93
27,82	28,83	120,95
27,83	28,84	120,97
27,84	28,85	120,99
27,85	28,86	121,01
27,86	28,87	121,03
27,87	28,88	121,05
27,88	28,89	121,07



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,89	28,90	121,09
27,90	28,91	121,11
27,91	28,92	121,13
27,92	28,93	121,15
27,93	28,94	121,17
27,94	28,95	121,19
27,95	28,96	121,21
27,96	28,97	121,23
27,97	28,98	121,25
27,98	28,99	121,27
27,99	29,00	121,29
28,00	29,01	121,31
28,01	29,02	121,33
28,02	29,03	121,35
28,03	29,04	121,37
28,04	29,05	121,39
28,05	29,06	121,41
28,06	29,07	121,43
28,07	29,08	121,45
28,08	29,09	121,48
28,09	29,10	121,50
28,10	29,11	121,52
28,11	29,12	121,54
28,12	29,13	121,56
28,13	29,14	121,58
28,14	29,15	121,60
28,15	29,16	121,62
28,16	29,17	121,64
28,17	29,18	121,66
28,18	29,19	121,68
28,19	29,20	121,70
28,20	29,21	121,72
28,21	29,22	121,74
28,22	29,23	121,76
28,23	29,24	121,78
28,24	29,25	121,80
28,25	29,26	121,82
28,26	29,27	121,84
28,27	29,28	121,86
28,28	29,29	121,88
28,29	29,30	121,90
28,30	29,31	121,92
28,31	29,32	121,94
28,32	29,33	121,96



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,33	29,34	121,98
28,34	29,35	122,00
28,35	29,36	122,02
28,36	29,37	122,04
28,37	29,38	122,06
28,38	29,39	122,08
28,39	29,40	122,10
28,40	29,41	122,12
28,41	29,42	122,14
28,42	29,43	122,16
28,43	29,44	122,18
28,44	29,45	122,20
28,45	29,46	122,22
28,46	29,47	122,24
28,47	29,48	122,26
28,48	29,49	122,28
28,49	29,50	122,30
28,50	29,51	122,32
28,51	29,52	122,34
28,52	29,53	122,36
28,53	29,54	122,38
28,54	29,55	122,40
28,55	29,56	122,42
28,56	29,57	122,44
28,57	29,58	122,46
28,58	29,59	122,48
28,59	29,60	122,50
28,60	29,61	122,52
28,61	29,62	122,54
28,62	29,63	122,56
28,63	29,64	122,58
28,64	29,65	122,60
28,65	29,66	122,62
28,66	29,67	122,64
28,67	29,68	122,66
28,68	29,69	122,68
28,69	29,70	122,70
28,70	29,71	122,72
28,71	29,72	122,74
28,72	29,73	122,76
28,73	29,74	122,77
28,74	29,75	122,79
28,75	29,76	122,81
28,76	29,77	122,83



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
28,77	29,78	122,85
28,78	29,79	122,87
28,79	29,80	122,89
28,80	29,81	122,91
28,81	29,82	122,93
28,82	29,83	122,95
28,83	29,84	122,97
28,84	29,85	122,99
28,85	29,86	123,01
28,86	29,87	123,03
28,87	29,88	123,05
28,88	29,89	123,07
28,89	29,90	123,09
28,90	29,91	123,11
28,91	29,92	123,13
28,92	29,93	123,15
28,93	29,94	123,17
28,94	29,95	123,19
28,95	29,96	123,21
28,96	29,97	123,23
28,97	29,98	123,25
28,98	29,99	123,27
28,99	30,00	123,29
29,00	30,01	123,31
29,01	30,02	123,33
29,02	30,03	123,35
29,03	30,04	123,37
29,04	30,05	123,39
29,05	30,06	123,41
29,06	30,07	123,43
29,07	30,08	123,45
29,08	30,09	123,47
29,09	30,10	123,48
29,10	30,11	123,50
29,11	30,12	123,52
29,12	30,13	123,54
29,13	30,14	123,56
29,14	30,15	123,58
29,15	30,16	123,60
29,16	30,17	123,62
29,17	30,18	123,64
29,18	30,19	123,66
29,19	30,20	123,68
29,20	30,21	123,70



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,21	30,22	123,72
29,22	30,23	123,74
29,23	30,24	123,76
29,24	30,25	123,78
29,25	30,26	123,80
29,26	30,27	123,82
29,27	30,28	123,84
29,28	30,29	123,86
29,29	30,30	123,88
29,30	30,31	123,90
29,31	30,32	123,92
29,32	30,33	123,93
29,33	30,34	123,95
29,34	30,35	123,97
29,35	30,36	123,99
29,36	30,37	124,01
29,37	30,38	124,03
29,38	30,39	124,05
29,39	30,40	124,07
29,40	30,41	124,09
29,41	30,42	124,11
29,42	30,43	124,13
29,43	30,44	124,15
29,44	30,45	124,17
29,45	30,46	124,19
29,46	30,47	124,21
29,47	30,48	124,23
29,48	30,49	124,25
29,49	30,50	124,27
29,50	30,51	124,29
29,51	30,52	124,30
29,52	30,53	124,32
29,53	30,54	124,34
29,54	30,55	124,36
29,55	30,56	124,38
29,56	30,57	124,40
29,57	30,58	124,42
29,58	30,59	124,44
29,59	30,60	124,46
29,60	30,61	124,48
29,61	30,62	124,50
29,62	30,63	124,52
29,63	30,64	124,54
29,64	30,65	124,56



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
29,65	30,66	124,58
29,66	30,67	124,59
29,67	30,68	124,61
29,68	30,69	124,63
29,69	30,70	124,65
29,70	30,71	124,67
29,71	30,72	124,69
29,72	30,73	124,71
29,73	30,74	124,73
29,74	30,75	124,75
29,75	30,76	124,77
29,76	30,77	124,79
29,77	30,78	124,81
29,78	30,79	124,83
29,79	30,80	124,85
29,80	30,81	124,86
29,81	30,82	124,88
29,82	30,83	124,90
29,83	30,84	124,92
29,84	30,85	124,94
29,85	30,86	124,96
29,86	30,87	124,98
29,87	30,88	125,00
29,88	30,89	125,02
29,89	30,90	125,04
29,90	30,91	125,06
29,91	30,92	125,08
29,92	30,93	125,10
29,93	30,94	125,11
29,94	30,95	125,13
29,95	30,96	125,15
29,96	30,97	125,17
29,97	30,98	125,19
29,98	30,99	125,21
29,99	31,00	125,23
30,00	31,01	125,25
30,01	31,02	125,27
30,02	31,03	125,29
30,03	31,04	125,31
30,04	31,05	125,33
30,05	31,06	125,34
30,06	31,07	125,36
30,07	31,08	125,38
30,08	31,09	125,40



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,09	31,10	125,42
30,10	31,11	125,44
30,11	31,12	125,46
30,12	31,13	125,48
30,13	31,14	125,50
30,14	31,15	125,52
30,15	31,16	125,54
30,16	31,17	125,55
30,17	31,18	125,57
30,18	31,19	125,59
30,19	31,20	125,61
30,20	31,21	125,63
30,21	31,22	125,65
30,22	31,23	125,67
30,23	31,24	125,69
30,24	31,25	125,71
30,25	31,26	125,73
30,26	31,27	125,74
30,27	31,28	125,76
30,28	31,29	125,78
30,29	31,30	125,80
30,30	31,31	125,82
30,31	31,32	125,84
30,32	31,33	125,86
30,33	31,34	125,88
30,34	31,35	125,90
30,35	31,36	125,92
30,36	31,37	125,93
30,37	31,38	125,95
30,38	31,39	125,97
30,39	31,40	125,99
30,40	31,41	126,01
30,41	31,42	126,03
30,42	31,43	126,05
30,43	31,44	126,07
30,44	31,45	126,09
30,45	31,46	126,11
30,46	31,47	126,12
30,47	31,48	126,14
30,48	31,49	126,16
30,49	31,50	126,18
30,50	31,51	126,20
30,51	31,52	126,22
30,52	31,53	126,24



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
30,53	31,54	126,26
30,54	31,55	126,28
30,55	31,56	126,29
30,56	31,57	126,31
30,57	31,58	126,33
30,58	31,59	126,35
30,59	31,60	126,37
30,60	31,61	126,39
30,61	31,62	126,41
30,62	31,63	126,43
30,63	31,64	126,44
30,64	31,65	126,46
30,65	31,66	126,48
30,66	31,67	126,50
30,67	31,68	126,52
30,68	31,69	126,54
30,69	31,70	126,56
30,70	31,71	126,58
30,71	31,72	126,60
30,72	31,73	126,61
30,73	31,74	126,63
30,74	31,75	126,65
30,75	31,76	126,67
30,76	31,77	126,69
30,77	31,78	126,71
30,78	31,79	126,73
30,79	31,80	126,75
30,80	31,81	126,76
30,81	31,82	126,78
30,82	31,83	126,80
30,83	31,84	126,82
30,84	31,85	126,84
30,85	31,86	126,86
30,86	31,87	126,88
30,87	31,88	126,90
30,88	31,89	126,91
30,89	31,90	126,93
30,90	31,91	126,95
30,91	31,92	126,97
30,92	31,93	126,99
30,93	31,94	127,01
30,94	31,95	127,03
30,95	31,96	127,04
30,96	31,97	127,06



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
30,97	31,98	127,08
30,98	31,99	127,10
30,99	32,00	127,12
31,00	32,01	127,14
31,01	32,02	127,16
31,02	32,03	127,18
31,03	32,04	127,19
31,04	32,05	127,21
31,05	32,06	127,23
31,06	32,07	127,25
31,07	32,08	127,27
31,08	32,09	127,29
31,09	32,10	127,31
31,10	32,11	127,32
31,11	32,12	127,34
31,12	32,13	127,36
31,13	32,14	127,38
31,14	32,15	127,40
31,15	32,16	127,42
31,16	32,17	127,44
31,17	32,18	127,45
31,18	32,19	127,47
31,19	32,20	127,49
31,20	32,21	127,51
31,21	32,22	127,53
31,22	32,23	127,55
31,23	32,24	127,57
31,24	32,25	127,58
31,25	32,26	127,60
31,26	32,27	127,62
31,27	32,28	127,64
31,28	32,29	127,66
31,29	32,30	127,68
31,30	32,31	127,69
31,31	32,32	127,71
31,32	32,33	127,73
31,33	32,34	127,75
31,34	32,35	127,77
31,35	32,36	127,79
31,36	32,37	127,81
31,37	32,38	127,82
31,38	32,39	127,84
31,39	32,40	127,86
31,40	32,41	127,88



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,41	32,42	127,90
31,42	32,43	127,92
31,43	32,44	127,93
31,44	32,45	127,95
31,45	32,46	127,97
31,46	32,47	127,99
31,47	32,48	128,01
31,48	32,49	128,03
31,49	32,50	128,05
31,50	32,51	128,06
31,51	32,52	128,08
31,52	32,53	128,10
31,53	32,54	128,12
31,54	32,55	128,14
31,55	32,56	128,16
31,56	32,57	128,17
31,57	32,58	128,19
31,58	32,59	128,21
31,59	32,60	128,23
31,60	32,61	128,25
31,61	32,62	128,27
31,62	32,63	128,28
31,63	32,64	128,30
31,64	32,65	128,32
31,65	32,66	128,34
31,66	32,67	128,36
31,67	32,68	128,38
31,68	32,69	128,39
31,69	32,70	128,41
31,70	32,71	128,43
31,71	32,72	128,45
31,72	32,73	128,47
31,73	32,74	128,49
31,74	32,75	128,50
31,75	32,76	128,52
31,76	32,77	128,54
31,77	32,78	128,56
31,78	32,79	128,58
31,79	32,80	128,60
31,80	32,81	128,61
31,81	32,82	128,63
31,82	32,83	128,65
31,83	32,84	128,67
31,84	32,85	128,69



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
31,85	32,86	128,70
31,86	32,87	128,72
31,87	32,88	128,74
31,88	32,89	128,76
31,89	32,90	128,78
31,90	32,91	128,80
31,91	32,92	128,81
31,92	32,93	128,83
31,93	32,94	128,85
31,94	32,95	128,87
31,95	32,96	128,89
31,96	32,97	128,90
31,97	32,98	128,92
31,98	32,99	128,94
31,99	33,00	128,96
32,00	33,01	128,98
32,01	33,02	129,00
32,02	33,03	129,01
32,03	33,04	129,03
32,04	33,05	129,05
32,05	33,06	129,07
32,06	33,07	129,09
32,07	33,08	129,10
32,08	33,09	129,12
32,09	33,10	129,14
32,10	33,11	129,16
32,11	33,12	129,18
32,12	33,13	129,19
32,13	33,14	129,21
32,14	33,15	129,23
32,15	33,16	129,25
32,16	33,17	129,27
32,17	33,18	129,29
32,18	33,19	129,30
32,19	33,20	129,32
32,20	33,21	129,34
32,21	33,22	129,36
32,22	33,23	129,38
32,23	33,24	129,39
32,24	33,25	129,41
32,25	33,26	129,43
32,26	33,27	129,45
32,27	33,28	129,47
32,28	33,29	129,48



R600a		
V1.0_R600a		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
32,29	33,30	129,50
32,30	33,31	129,52
32,31	33,32	129,54
32,32	33,33	129,56
32,33	33,34	129,57
32,34	33,35	129,59
32,35	33,36	129,61
32,36	33,37	129,63
32,37	33,38	129,65
32,38	33,39	129,66
32,39	33,40	129,68
32,40	33,41	129,70