



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,71	0,30	-200,46
-0,70	0,31	-200,24
-0,69	0,32	-200,03
-0,68	0,33	-199,83
-0,67	0,34	-199,63
-0,66	0,35	-199,44
-0,65	0,36	-199,25
-0,64	0,37	-199,07
-0,63	0,38	-198,89
-0,62	0,39	-198,71
-0,61	0,40	-198,53
-0,60	0,41	-198,36
-0,59	0,42	-198,20
-0,58	0,43	-198,03
-0,57	0,44	-197,87
-0,56	0,45	-197,71
-0,55	0,46	-197,56
-0,54	0,47	-197,40
-0,53	0,48	-197,25
-0,52	0,49	-197,11
-0,51	0,50	-196,96
-0,50	0,51	-196,82
-0,49	0,52	-196,68
-0,48	0,53	-196,54
-0,47	0,54	-196,40
-0,46	0,55	-196,26
-0,45	0,56	-196,13
-0,44	0,57	-196,00
-0,43	0,58	-195,87
-0,42	0,59	-195,74
-0,41	0,60	-195,62
-0,40	0,61	-195,49
-0,39	0,62	-195,37
-0,38	0,63	-195,25
-0,37	0,64	-195,13
-0,36	0,65	-195,01
-0,35	0,66	-194,89
-0,34	0,67	-194,78
-0,33	0,68	-194,66
-0,32	0,69	-194,55
-0,31	0,70	-194,44
-0,30	0,71	-194,33
-0,29	0,72	-194,22
-0,28	0,73	-194,11



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
-0,27	0,74	-194,00
-0,26	0,75	-193,89
-0,25	0,76	-193,79
-0,24	0,77	-193,69
-0,23	0,78	-193,58
-0,22	0,79	-193,48
-0,21	0,80	-193,38
-0,20	0,81	-193,28
-0,19	0,82	-193,18
-0,18	0,83	-193,08
-0,17	0,84	-192,99
-0,16	0,85	-192,89
-0,15	0,86	-192,79
-0,14	0,87	-192,70
-0,13	0,88	-192,61
-0,12	0,89	-192,51
-0,11	0,90	-192,42
-0,10	0,91	-192,33
-0,09	0,92	-192,24
-0,08	0,93	-192,15
-0,07	0,94	-192,06
-0,06	0,95	-191,97
-0,05	0,96	-191,89
-0,04	0,97	-191,80
-0,03	0,98	-191,71
-0,02	0,99	-191,63
-0,01	1,00	-191,54
0,00	1,01	-191,46
0,01	1,02	-191,37
0,02	1,03	-191,29
0,03	1,04	-191,21
0,04	1,05	-191,13
0,05	1,06	-191,05
0,06	1,07	-190,96
0,07	1,08	-190,88
0,08	1,09	-190,81
0,09	1,10	-190,73
0,10	1,11	-190,65
0,11	1,12	-190,57
0,12	1,13	-190,49
0,13	1,14	-190,42
0,14	1,15	-190,34
0,15	1,16	-190,26
0,16	1,17	-190,19



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcalatrice.com		
0,17	1,18	-190,11
0,18	1,19	-190,04
0,19	1,20	-189,97
0,20	1,21	-189,89
0,21	1,22	-189,82
0,22	1,23	-189,75
0,23	1,24	-189,67
0,24	1,25	-189,60
0,25	1,26	-189,53
0,26	1,27	-189,46
0,27	1,28	-189,39
0,28	1,29	-189,32
0,29	1,30	-189,25
0,30	1,31	-189,18
0,31	1,32	-189,11
0,32	1,33	-189,05
0,33	1,34	-188,98
0,34	1,35	-188,91
0,35	1,36	-188,84
0,36	1,37	-188,78
0,37	1,38	-188,71
0,38	1,39	-188,64
0,39	1,40	-188,58
0,40	1,41	-188,51
0,41	1,42	-188,45
0,42	1,43	-188,38
0,43	1,44	-188,32
0,44	1,45	-188,26
0,45	1,46	-188,19
0,46	1,47	-188,13
0,47	1,48	-188,07
0,48	1,49	-188,00
0,49	1,50	-187,94
0,50	1,51	-187,88
0,51	1,52	-187,82
0,52	1,53	-187,76
0,53	1,54	-187,69
0,54	1,55	-187,63
0,55	1,56	-187,57
0,56	1,57	-187,51
0,57	1,58	-187,45
0,58	1,59	-187,39
0,59	1,60	-187,33
0,60	1,61	-187,27



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
0,61	1,62	-187,22
0,62	1,63	-187,16
0,63	1,64	-187,10
0,64	1,65	-187,04
0,65	1,66	-186,98
0,66	1,67	-186,93
0,67	1,68	-186,87
0,68	1,69	-186,81
0,69	1,70	-186,75
0,70	1,71	-186,70
0,71	1,72	-186,64
0,72	1,73	-186,59
0,73	1,74	-186,53
0,74	1,75	-186,47
0,75	1,76	-186,42
0,76	1,77	-186,36
0,77	1,78	-186,31
0,78	1,79	-186,26
0,79	1,80	-186,20
0,80	1,81	-186,15
0,81	1,82	-186,09
0,82	1,83	-186,04
0,83	1,84	-185,99
0,84	1,85	-185,93
0,85	1,86	-185,88
0,86	1,87	-185,83
0,87	1,88	-185,77
0,88	1,89	-185,72
0,89	1,90	-185,67
0,90	1,91	-185,62
0,91	1,92	-185,57
0,92	1,93	-185,51
0,93	1,94	-185,46
0,94	1,95	-185,41
0,95	1,96	-185,36
0,96	1,97	-185,31
0,97	1,98	-185,26
0,98	1,99	-185,21
0,99	2,00	-185,16
1,00	2,01	-185,11
1,01	2,02	-185,06
1,02	2,03	-185,01
1,03	2,04	-184,96
1,04	2,05	-184,91



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
1,05	2,06	-184,86
1,06	2,07	-184,81
1,07	2,08	-184,76
1,08	2,09	-184,72
1,09	2,10	-184,67
1,10	2,11	-184,62
1,11	2,12	-184,57
1,12	2,13	-184,52
1,13	2,14	-184,48
1,14	2,15	-184,43
1,15	2,16	-184,38
1,16	2,17	-184,33
1,17	2,18	-184,29
1,18	2,19	-184,24
1,19	2,20	-184,19
1,20	2,21	-184,15
1,21	2,22	-184,10
1,22	2,23	-184,05
1,23	2,24	-184,01
1,24	2,25	-183,96
1,25	2,26	-183,92
1,26	2,27	-183,87
1,27	2,28	-183,82
1,28	2,29	-183,78
1,29	2,30	-183,73
1,30	2,31	-183,69
1,31	2,32	-183,64
1,32	2,33	-183,60
1,33	2,34	-183,55
1,34	2,35	-183,51
1,35	2,36	-183,47
1,36	2,37	-183,42
1,37	2,38	-183,38
1,38	2,39	-183,33
1,39	2,40	-183,29
1,40	2,41	-183,25
1,41	2,42	-183,20
1,42	2,43	-183,16
1,43	2,44	-183,12
1,44	2,45	-183,07
1,45	2,46	-183,03
1,46	2,47	-182,99
1,47	2,48	-182,94
1,48	2,49	-182,90



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,49	2,50	-182,86
1,50	2,51	-182,82
1,51	2,52	-182,77
1,52	2,53	-182,73
1,53	2,54	-182,69
1,54	2,55	-182,65
1,55	2,56	-182,61
1,56	2,57	-182,56
1,57	2,58	-182,52
1,58	2,59	-182,48
1,59	2,60	-182,44
1,60	2,61	-182,40
1,61	2,62	-182,36
1,62	2,63	-182,32
1,63	2,64	-182,28
1,64	2,65	-182,24
1,65	2,66	-182,20
1,66	2,67	-182,15
1,67	2,68	-182,11
1,68	2,69	-182,07
1,69	2,70	-182,03
1,70	2,71	-181,99
1,71	2,72	-181,95
1,72	2,73	-181,91
1,73	2,74	-181,87
1,74	2,75	-181,83
1,75	2,76	-181,80
1,76	2,77	-181,76
1,77	2,78	-181,72
1,78	2,79	-181,68
1,79	2,80	-181,64
1,80	2,81	-181,60
1,81	2,82	-181,56
1,82	2,83	-181,52
1,83	2,84	-181,48
1,84	2,85	-181,44
1,85	2,86	-181,41
1,86	2,87	-181,37
1,87	2,88	-181,33
1,88	2,89	-181,29
1,89	2,90	-181,25
1,90	2,91	-181,22
1,91	2,92	-181,18
1,92	2,93	-181,14



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
1,93	2,94	-181,10
1,94	2,95	-181,06
1,95	2,96	-181,03
1,96	2,97	-180,99
1,97	2,98	-180,95
1,98	2,99	-180,92
1,99	3,00	-180,88
2,00	3,01	-180,84
2,01	3,02	-180,80
2,02	3,03	-180,77
2,03	3,04	-180,73
2,04	3,05	-180,69
2,05	3,06	-180,66
2,06	3,07	-180,62
2,07	3,08	-180,58
2,08	3,09	-180,55
2,09	3,10	-180,51
2,10	3,11	-180,48
2,11	3,12	-180,44
2,12	3,13	-180,40
2,13	3,14	-180,37
2,14	3,15	-180,33
2,15	3,16	-180,30
2,16	3,17	-180,26
2,17	3,18	-180,22
2,18	3,19	-180,19
2,19	3,20	-180,15
2,20	3,21	-180,12
2,21	3,22	-180,08
2,22	3,23	-180,05
2,23	3,24	-180,01
2,24	3,25	-179,98
2,25	3,26	-179,94
2,26	3,27	-179,91
2,27	3,28	-179,87
2,28	3,29	-179,84
2,29	3,30	-179,80
2,30	3,31	-179,77
2,31	3,32	-179,74
2,32	3,33	-179,70
2,33	3,34	-179,67
2,34	3,35	-179,63
2,35	3,36	-179,60
2,36	3,37	-179,56



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
2,37	3,38	-179,53
2,38	3,39	-179,50
2,39	3,40	-179,46
2,40	3,41	-179,43
2,41	3,42	-179,40
2,42	3,43	-179,36
2,43	3,44	-179,33
2,44	3,45	-179,29
2,45	3,46	-179,26
2,46	3,47	-179,23
2,47	3,48	-179,19
2,48	3,49	-179,16
2,49	3,50	-179,13
2,50	3,51	-179,09
2,51	3,52	-179,06
2,52	3,53	-179,03
2,53	3,54	-179,00
2,54	3,55	-178,96
2,55	3,56	-178,93
2,56	3,57	-178,90
2,57	3,58	-178,87
2,58	3,59	-178,83
2,59	3,60	-178,80
2,60	3,61	-178,77
2,61	3,62	-178,74
2,62	3,63	-178,70
2,63	3,64	-178,67
2,64	3,65	-178,64
2,65	3,66	-178,61
2,66	3,67	-178,58
2,67	3,68	-178,54
2,68	3,69	-178,51
2,69	3,70	-178,48
2,70	3,71	-178,45
2,71	3,72	-178,42
2,72	3,73	-178,38
2,73	3,74	-178,35
2,74	3,75	-178,32
2,75	3,76	-178,29
2,76	3,77	-178,26
2,77	3,78	-178,23
2,78	3,79	-178,20
2,79	3,80	-178,16
2,80	3,81	-178,13



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
2,81	3,82	-178,10
2,82	3,83	-178,07
2,83	3,84	-178,04
2,84	3,85	-178,01
2,85	3,86	-177,98
2,86	3,87	-177,95
2,87	3,88	-177,92
2,88	3,89	-177,89
2,89	3,90	-177,86
2,90	3,91	-177,83
2,91	3,92	-177,79
2,92	3,93	-177,76
2,93	3,94	-177,73
2,94	3,95	-177,70
2,95	3,96	-177,67
2,96	3,97	-177,64
2,97	3,98	-177,61
2,98	3,99	-177,58
2,99	4,00	-177,55
3,00	4,01	-177,52
3,01	4,02	-177,49
3,02	4,03	-177,46
3,03	4,04	-177,43
3,04	4,05	-177,40
3,05	4,06	-177,37
3,06	4,07	-177,34
3,07	4,08	-177,31
3,08	4,09	-177,29
3,09	4,10	-177,26
3,10	4,11	-177,23
3,11	4,12	-177,20
3,12	4,13	-177,17
3,13	4,14	-177,14
3,14	4,15	-177,11
3,15	4,16	-177,08
3,16	4,17	-177,05
3,17	4,18	-177,02
3,18	4,19	-176,99
3,19	4,20	-176,96
3,20	4,21	-176,93
3,21	4,22	-176,91
3,22	4,23	-176,88
3,23	4,24	-176,85
3,24	4,25	-176,82



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,25	4,26	-176,79
3,26	4,27	-176,76
3,27	4,28	-176,73
3,28	4,29	-176,70
3,29	4,30	-176,68
3,30	4,31	-176,65
3,31	4,32	-176,62
3,32	4,33	-176,59
3,33	4,34	-176,56
3,34	4,35	-176,53
3,35	4,36	-176,51
3,36	4,37	-176,48
3,37	4,38	-176,45
3,38	4,39	-176,42
3,39	4,40	-176,39
3,40	4,41	-176,37
3,41	4,42	-176,34
3,42	4,43	-176,31
3,43	4,44	-176,28
3,44	4,45	-176,25
3,45	4,46	-176,23
3,46	4,47	-176,20
3,47	4,48	-176,17
3,48	4,49	-176,14
3,49	4,50	-176,12
3,50	4,51	-176,09
3,51	4,52	-176,06
3,52	4,53	-176,03
3,53	4,54	-176,01
3,54	4,55	-175,98
3,55	4,56	-175,95
3,56	4,57	-175,92
3,57	4,58	-175,90
3,58	4,59	-175,87
3,59	4,60	-175,84
3,60	4,61	-175,82
3,61	4,62	-175,79
3,62	4,63	-175,76
3,63	4,64	-175,73
3,64	4,65	-175,71
3,65	4,66	-175,68
3,66	4,67	-175,65
3,67	4,68	-175,63
3,68	4,69	-175,60



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
3,69	4,70	-175,57
3,70	4,71	-175,55
3,71	4,72	-175,52
3,72	4,73	-175,49
3,73	4,74	-175,47
3,74	4,75	-175,44
3,75	4,76	-175,41
3,76	4,77	-175,39
3,77	4,78	-175,36
3,78	4,79	-175,34
3,79	4,80	-175,31
3,80	4,81	-175,28
3,81	4,82	-175,26
3,82	4,83	-175,23
3,83	4,84	-175,20
3,84	4,85	-175,18
3,85	4,86	-175,15
3,86	4,87	-175,13
3,87	4,88	-175,10
3,88	4,89	-175,07
3,89	4,90	-175,05
3,90	4,91	-175,02
3,91	4,92	-175,00
3,92	4,93	-174,97
3,93	4,94	-174,95
3,94	4,95	-174,92
3,95	4,96	-174,89
3,96	4,97	-174,87
3,97	4,98	-174,84
3,98	4,99	-174,82
3,99	5,00	-174,79
4,00	5,01	-174,77
4,01	5,02	-174,74
4,02	5,03	-174,72
4,03	5,04	-174,69
4,04	5,05	-174,66
4,05	5,06	-174,64
4,06	5,07	-174,61
4,07	5,08	-174,59
4,08	5,09	-174,56
4,09	5,10	-174,54
4,10	5,11	-174,51
4,11	5,12	-174,49
4,12	5,13	-174,46



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
4,13	5,14	-174,44
4,14	5,15	-174,41
4,15	5,16	-174,39
4,16	5,17	-174,36
4,17	5,18	-174,34
4,18	5,19	-174,31
4,19	5,20	-174,29
4,20	5,21	-174,26
4,21	5,22	-174,24
4,22	5,23	-174,21
4,23	5,24	-174,19
4,24	5,25	-174,17
4,25	5,26	-174,14
4,26	5,27	-174,12
4,27	5,28	-174,09
4,28	5,29	-174,07
4,29	5,30	-174,04
4,30	5,31	-174,02
4,31	5,32	-173,99
4,32	5,33	-173,97
4,33	5,34	-173,94
4,34	5,35	-173,92
4,35	5,36	-173,90
4,36	5,37	-173,87
4,37	5,38	-173,85
4,38	5,39	-173,82
4,39	5,40	-173,80
4,40	5,41	-173,78
4,41	5,42	-173,75
4,42	5,43	-173,73
4,43	5,44	-173,70
4,44	5,45	-173,68
4,45	5,46	-173,66
4,46	5,47	-173,63
4,47	5,48	-173,61
4,48	5,49	-173,58
4,49	5,50	-173,56
4,50	5,51	-173,54
4,51	5,52	-173,51
4,52	5,53	-173,49
4,53	5,54	-173,47
4,54	5,55	-173,44
4,55	5,56	-173,42
4,56	5,57	-173,39



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
4,57	5,58	-173,37
4,58	5,59	-173,35
4,59	5,60	-173,32
4,60	5,61	-173,30
4,61	5,62	-173,28
4,62	5,63	-173,25
4,63	5,64	-173,23
4,64	5,65	-173,21
4,65	5,66	-173,18
4,66	5,67	-173,16
4,67	5,68	-173,14
4,68	5,69	-173,11
4,69	5,70	-173,09
4,70	5,71	-173,07
4,71	5,72	-173,04
4,72	5,73	-173,02
4,73	5,74	-173,00
4,74	5,75	-172,97
4,75	5,76	-172,95
4,76	5,77	-172,93
4,77	5,78	-172,91
4,78	5,79	-172,88
4,79	5,80	-172,86
4,80	5,81	-172,84
4,81	5,82	-172,81
4,82	5,83	-172,79
4,83	5,84	-172,77
4,84	5,85	-172,75
4,85	5,86	-172,72
4,86	5,87	-172,70
4,87	5,88	-172,68
4,88	5,89	-172,65
4,89	5,90	-172,63
4,90	5,91	-172,61
4,91	5,92	-172,59
4,92	5,93	-172,56
4,93	5,94	-172,54
4,94	5,95	-172,52
4,95	5,96	-172,50
4,96	5,97	-172,47
4,97	5,98	-172,45
4,98	5,99	-172,43
4,99	6,00	-172,41
5,00	6,01	-172,38



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
5,01	6,02	-172,36
5,02	6,03	-172,34
5,03	6,04	-172,32
5,04	6,05	-172,30
5,05	6,06	-172,27
5,06	6,07	-172,25
5,07	6,08	-172,23
5,08	6,09	-172,21
5,09	6,10	-172,19
5,10	6,11	-172,16
5,11	6,12	-172,14
5,12	6,13	-172,12
5,13	6,14	-172,10
5,14	6,15	-172,08
5,15	6,16	-172,05
5,16	6,17	-172,03
5,17	6,18	-172,01
5,18	6,19	-171,99
5,19	6,20	-171,97
5,20	6,21	-171,94
5,21	6,22	-171,92
5,22	6,23	-171,90
5,23	6,24	-171,88
5,24	6,25	-171,86
5,25	6,26	-171,84
5,26	6,27	-171,81
5,27	6,28	-171,79
5,28	6,29	-171,77
5,29	6,30	-171,75
5,30	6,31	-171,73
5,31	6,32	-171,71
5,32	6,33	-171,68
5,33	6,34	-171,66
5,34	6,35	-171,64
5,35	6,36	-171,62
5,36	6,37	-171,60
5,37	6,38	-171,58
5,38	6,39	-171,56
5,39	6,40	-171,53
5,40	6,41	-171,51
5,41	6,42	-171,49
5,42	6,43	-171,47
5,43	6,44	-171,45
5,44	6,45	-171,43



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
5,45	6,46	-171,41
5,46	6,47	-171,39
5,47	6,48	-171,36
5,48	6,49	-171,34
5,49	6,50	-171,32
5,50	6,51	-171,30
5,51	6,52	-171,28
5,52	6,53	-171,26
5,53	6,54	-171,24
5,54	6,55	-171,22
5,55	6,56	-171,20
5,56	6,57	-171,18
5,57	6,58	-171,15
5,58	6,59	-171,13
5,59	6,60	-171,11
5,60	6,61	-171,09
5,61	6,62	-171,07
5,62	6,63	-171,05
5,63	6,64	-171,03
5,64	6,65	-171,01
5,65	6,66	-170,99
5,66	6,67	-170,97
5,67	6,68	-170,95
5,68	6,69	-170,93
5,69	6,70	-170,90
5,70	6,71	-170,88
5,71	6,72	-170,86
5,72	6,73	-170,84
5,73	6,74	-170,82
5,74	6,75	-170,80
5,75	6,76	-170,78
5,76	6,77	-170,76
5,77	6,78	-170,74
5,78	6,79	-170,72
5,79	6,80	-170,70
5,80	6,81	-170,68
5,81	6,82	-170,66
5,82	6,83	-170,64
5,83	6,84	-170,62
5,84	6,85	-170,60
5,85	6,86	-170,58
5,86	6,87	-170,56
5,87	6,88	-170,54
5,88	6,89	-170,52



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
5,89	6,90	-170,50
5,90	6,91	-170,48
5,91	6,92	-170,46
5,92	6,93	-170,44
5,93	6,94	-170,42
5,94	6,95	-170,40
5,95	6,96	-170,38
5,96	6,97	-170,36
5,97	6,98	-170,34
5,98	6,99	-170,32
5,99	7,00	-170,30
6,00	7,01	-170,28
6,01	7,02	-170,26
6,02	7,03	-170,24
6,03	7,04	-170,22
6,04	7,05	-170,20
6,05	7,06	-170,18
6,06	7,07	-170,16
6,07	7,08	-170,14
6,08	7,09	-170,12
6,09	7,10	-170,10
6,10	7,11	-170,08
6,11	7,12	-170,06
6,12	7,13	-170,04
6,13	7,14	-170,02
6,14	7,15	-170,00
6,15	7,16	-169,98
6,16	7,17	-169,96
6,17	7,18	-169,94
6,18	7,19	-169,92
6,19	7,20	-169,90
6,20	7,21	-169,88
6,21	7,22	-169,86
6,22	7,23	-169,84
6,23	7,24	-169,82
6,24	7,25	-169,80
6,25	7,26	-169,78
6,26	7,27	-169,76
6,27	7,28	-169,74
6,28	7,29	-169,72
6,29	7,30	-169,71
6,30	7,31	-169,69
6,31	7,32	-169,67
6,32	7,33	-169,65



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,33	7,34	-169,63
6,34	7,35	-169,61
6,35	7,36	-169,59
6,36	7,37	-169,57
6,37	7,38	-169,55
6,38	7,39	-169,53
6,39	7,40	-169,51
6,40	7,41	-169,49
6,41	7,42	-169,47
6,42	7,43	-169,45
6,43	7,44	-169,44
6,44	7,45	-169,42
6,45	7,46	-169,40
6,46	7,47	-169,38
6,47	7,48	-169,36
6,48	7,49	-169,34
6,49	7,50	-169,32
6,50	7,51	-169,30
6,51	7,52	-169,28
6,52	7,53	-169,26
6,53	7,54	-169,25
6,54	7,55	-169,23
6,55	7,56	-169,21
6,56	7,57	-169,19
6,57	7,58	-169,17
6,58	7,59	-169,15
6,59	7,60	-169,13
6,60	7,61	-169,11
6,61	7,62	-169,09
6,62	7,63	-169,08
6,63	7,64	-169,06
6,64	7,65	-169,04
6,65	7,66	-169,02
6,66	7,67	-169,00
6,67	7,68	-168,98
6,68	7,69	-168,96
6,69	7,70	-168,94
6,70	7,71	-168,93
6,71	7,72	-168,91
6,72	7,73	-168,89
6,73	7,74	-168,87
6,74	7,75	-168,85
6,75	7,76	-168,83
6,76	7,77	-168,81



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
6,77	7,78	-168,80
6,78	7,79	-168,78
6,79	7,80	-168,76
6,80	7,81	-168,74
6,81	7,82	-168,72
6,82	7,83	-168,70
6,83	7,84	-168,68
6,84	7,85	-168,67
6,85	7,86	-168,65
6,86	7,87	-168,63
6,87	7,88	-168,61
6,88	7,89	-168,59
6,89	7,90	-168,57
6,90	7,91	-168,56
6,91	7,92	-168,54
6,92	7,93	-168,52
6,93	7,94	-168,50
6,94	7,95	-168,48
6,95	7,96	-168,46
6,96	7,97	-168,45
6,97	7,98	-168,43
6,98	7,99	-168,41
6,99	8,00	-168,39
7,00	8,01	-168,37
7,01	8,02	-168,36
7,02	8,03	-168,34
7,03	8,04	-168,32
7,04	8,05	-168,30
7,05	8,06	-168,28
7,06	8,07	-168,27
7,07	8,08	-168,25
7,08	8,09	-168,23
7,09	8,10	-168,21
7,10	8,11	-168,19
7,11	8,12	-168,18
7,12	8,13	-168,16
7,13	8,14	-168,14
7,14	8,15	-168,12
7,15	8,16	-168,10
7,16	8,17	-168,09
7,17	8,18	-168,07
7,18	8,19	-168,05
7,19	8,20	-168,03
7,20	8,21	-168,01



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
7,21	8,22	-168,00
7,22	8,23	-167,98
7,23	8,24	-167,96
7,24	8,25	-167,94
7,25	8,26	-167,93
7,26	8,27	-167,91
7,27	8,28	-167,89
7,28	8,29	-167,87
7,29	8,30	-167,85
7,30	8,31	-167,84
7,31	8,32	-167,82
7,32	8,33	-167,80
7,33	8,34	-167,78
7,34	8,35	-167,77
7,35	8,36	-167,75
7,36	8,37	-167,73
7,37	8,38	-167,71
7,38	8,39	-167,70
7,39	8,40	-167,68
7,40	8,41	-167,66
7,41	8,42	-167,64
7,42	8,43	-167,63
7,43	8,44	-167,61
7,44	8,45	-167,59
7,45	8,46	-167,57
7,46	8,47	-167,56
7,47	8,48	-167,54
7,48	8,49	-167,52
7,49	8,50	-167,50
7,50	8,51	-167,49
7,51	8,52	-167,47
7,52	8,53	-167,45
7,53	8,54	-167,43
7,54	8,55	-167,42
7,55	8,56	-167,40
7,56	8,57	-167,38
7,57	8,58	-167,37
7,58	8,59	-167,35
7,59	8,60	-167,33
7,60	8,61	-167,31
7,61	8,62	-167,30
7,62	8,63	-167,28
7,63	8,64	-167,26
7,64	8,65	-167,25



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
7,65	8,66	-167,23
7,66	8,67	-167,21
7,67	8,68	-167,19
7,68	8,69	-167,18
7,69	8,70	-167,16
7,70	8,71	-167,14
7,71	8,72	-167,13
7,72	8,73	-167,11
7,73	8,74	-167,09
7,74	8,75	-167,07
7,75	8,76	-167,06
7,76	8,77	-167,04
7,77	8,78	-167,02
7,78	8,79	-167,01
7,79	8,80	-166,99
7,80	8,81	-166,97
7,81	8,82	-166,96
7,82	8,83	-166,94
7,83	8,84	-166,92
7,84	8,85	-166,90
7,85	8,86	-166,89
7,86	8,87	-166,87
7,87	8,88	-166,85
7,88	8,89	-166,84
7,89	8,90	-166,82
7,90	8,91	-166,80
7,91	8,92	-166,79
7,92	8,93	-166,77
7,93	8,94	-166,75
7,94	8,95	-166,74
7,95	8,96	-166,72
7,96	8,97	-166,70
7,97	8,98	-166,69
7,98	8,99	-166,67
7,99	9,00	-166,65
8,00	9,01	-166,64
8,01	9,02	-166,62
8,02	9,03	-166,60
8,03	9,04	-166,59
8,04	9,05	-166,57
8,05	9,06	-166,55
8,06	9,07	-166,54
8,07	9,08	-166,52
8,08	9,09	-166,50



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,09	9,10	-166,49
8,10	9,11	-166,47
8,11	9,12	-166,45
8,12	9,13	-166,44
8,13	9,14	-166,42
8,14	9,15	-166,40
8,15	9,16	-166,39
8,16	9,17	-166,37
8,17	9,18	-166,35
8,18	9,19	-166,34
8,19	9,20	-166,32
8,20	9,21	-166,31
8,21	9,22	-166,29
8,22	9,23	-166,27
8,23	9,24	-166,26
8,24	9,25	-166,24
8,25	9,26	-166,22
8,26	9,27	-166,21
8,27	9,28	-166,19
8,28	9,29	-166,17
8,29	9,30	-166,16
8,30	9,31	-166,14
8,31	9,32	-166,13
8,32	9,33	-166,11
8,33	9,34	-166,09
8,34	9,35	-166,08
8,35	9,36	-166,06
8,36	9,37	-166,04
8,37	9,38	-166,03
8,38	9,39	-166,01
8,39	9,40	-166,00
8,40	9,41	-165,98
8,41	9,42	-165,96
8,42	9,43	-165,95
8,43	9,44	-165,93
8,44	9,45	-165,92
8,45	9,46	-165,90
8,46	9,47	-165,88
8,47	9,48	-165,87
8,48	9,49	-165,85
8,49	9,50	-165,84
8,50	9,51	-165,82
8,51	9,52	-165,80
8,52	9,53	-165,79



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
8,53	9,54	-165,77
8,54	9,55	-165,76
8,55	9,56	-165,74
8,56	9,57	-165,72
8,57	9,58	-165,71
8,58	9,59	-165,69
8,59	9,60	-165,68
8,60	9,61	-165,66
8,61	9,62	-165,64
8,62	9,63	-165,63
8,63	9,64	-165,61
8,64	9,65	-165,60
8,65	9,66	-165,58
8,66	9,67	-165,56
8,67	9,68	-165,55
8,68	9,69	-165,53
8,69	9,70	-165,52
8,70	9,71	-165,50
8,71	9,72	-165,49
8,72	9,73	-165,47
8,73	9,74	-165,45
8,74	9,75	-165,44
8,75	9,76	-165,42
8,76	9,77	-165,41
8,77	9,78	-165,39
8,78	9,79	-165,37
8,79	9,80	-165,36
8,80	9,81	-165,34
8,81	9,82	-165,33
8,82	9,83	-165,31
8,83	9,84	-165,30
8,84	9,85	-165,28
8,85	9,86	-165,27
8,86	9,87	-165,25
8,87	9,88	-165,23
8,88	9,89	-165,22
8,89	9,90	-165,20
8,90	9,91	-165,19
8,91	9,92	-165,17
8,92	9,93	-165,16
8,93	9,94	-165,14
8,94	9,95	-165,13
8,95	9,96	-165,11
8,96	9,97	-165,09



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
8,97	9,98	-165,08
8,98	9,99	-165,06
8,99	10,00	-165,05
9,00	10,01	-165,03
9,01	10,02	-165,02
9,02	10,03	-165,00
9,03	10,04	-164,99
9,04	10,05	-164,97
9,05	10,06	-164,96
9,06	10,07	-164,94
9,07	10,08	-164,92
9,08	10,09	-164,91
9,09	10,10	-164,89
9,10	10,11	-164,88
9,11	10,12	-164,86
9,12	10,13	-164,85
9,13	10,14	-164,83
9,14	10,15	-164,82
9,15	10,16	-164,80
9,16	10,17	-164,79
9,17	10,18	-164,77
9,18	10,19	-164,76
9,19	10,20	-164,74
9,20	10,21	-164,73
9,21	10,22	-164,71
9,22	10,23	-164,70
9,23	10,24	-164,68
9,24	10,25	-164,66
9,25	10,26	-164,65
9,26	10,27	-164,63
9,27	10,28	-164,62
9,28	10,29	-164,60
9,29	10,30	-164,59
9,30	10,31	-164,57
9,31	10,32	-164,56
9,32	10,33	-164,54
9,33	10,34	-164,53
9,34	10,35	-164,51
9,35	10,36	-164,50
9,36	10,37	-164,48
9,37	10,38	-164,47
9,38	10,39	-164,45
9,39	10,40	-164,44
9,40	10,41	-164,42



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
9,41	10,42	-164,41
9,42	10,43	-164,39
9,43	10,44	-164,38
9,44	10,45	-164,36
9,45	10,46	-164,35
9,46	10,47	-164,33
9,47	10,48	-164,32
9,48	10,49	-164,30
9,49	10,50	-164,29
9,50	10,51	-164,27
9,51	10,52	-164,26
9,52	10,53	-164,24
9,53	10,54	-164,23
9,54	10,55	-164,21
9,55	10,56	-164,20
9,56	10,57	-164,18
9,57	10,58	-164,17
9,58	10,59	-164,15
9,59	10,60	-164,14
9,60	10,61	-164,12
9,61	10,62	-164,11
9,62	10,63	-164,09
9,63	10,64	-164,08
9,64	10,65	-164,07
9,65	10,66	-164,05
9,66	10,67	-164,04
9,67	10,68	-164,02
9,68	10,69	-164,01
9,69	10,70	-163,99
9,70	10,71	-163,98
9,71	10,72	-163,96
9,72	10,73	-163,95
9,73	10,74	-163,93
9,74	10,75	-163,92
9,75	10,76	-163,90
9,76	10,77	-163,89
9,77	10,78	-163,87
9,78	10,79	-163,86
9,79	10,80	-163,84
9,80	10,81	-163,83
9,81	10,82	-163,82
9,82	10,83	-163,80
9,83	10,84	-163,79
9,84	10,85	-163,77



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
9,85	10,86	-163,76
9,86	10,87	-163,74
9,87	10,88	-163,73
9,88	10,89	-163,71
9,89	10,90	-163,70
9,90	10,91	-163,68
9,91	10,92	-163,67
9,92	10,93	-163,66
9,93	10,94	-163,64
9,94	10,95	-163,63
9,95	10,96	-163,61
9,96	10,97	-163,60
9,97	10,98	-163,58
9,98	10,99	-163,57
9,99	11,00	-163,55
10,00	11,01	-163,54
10,01	11,02	-163,53
10,02	11,03	-163,51
10,03	11,04	-163,50
10,04	11,05	-163,48
10,05	11,06	-163,47
10,06	11,07	-163,45
10,07	11,08	-163,44
10,08	11,09	-163,42
10,09	11,10	-163,41
10,10	11,11	-163,40
10,11	11,12	-163,38
10,12	11,13	-163,37
10,13	11,14	-163,35
10,14	11,15	-163,34
10,15	11,16	-163,32
10,16	11,17	-163,31
10,17	11,18	-163,30
10,18	11,19	-163,28
10,19	11,20	-163,27
10,20	11,21	-163,25
10,21	11,22	-163,24
10,22	11,23	-163,22
10,23	11,24	-163,21
10,24	11,25	-163,20
10,25	11,26	-163,18
10,26	11,27	-163,17
10,27	11,28	-163,15
10,28	11,29	-163,14



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,29	11,30	-163,13
10,30	11,31	-163,11
10,31	11,32	-163,10
10,32	11,33	-163,08
10,33	11,34	-163,07
10,34	11,35	-163,05
10,35	11,36	-163,04
10,36	11,37	-163,03
10,37	11,38	-163,01
10,38	11,39	-163,00
10,39	11,40	-162,98
10,40	11,41	-162,97
10,41	11,42	-162,96
10,42	11,43	-162,94
10,43	11,44	-162,93
10,44	11,45	-162,91
10,45	11,46	-162,90
10,46	11,47	-162,89
10,47	11,48	-162,87
10,48	11,49	-162,86
10,49	11,50	-162,84
10,50	11,51	-162,83
10,51	11,52	-162,82
10,52	11,53	-162,80
10,53	11,54	-162,79
10,54	11,55	-162,77
10,55	11,56	-162,76
10,56	11,57	-162,75
10,57	11,58	-162,73
10,58	11,59	-162,72
10,59	11,60	-162,70
10,60	11,61	-162,69
10,61	11,62	-162,68
10,62	11,63	-162,66
10,63	11,64	-162,65
10,64	11,65	-162,63
10,65	11,66	-162,62
10,66	11,67	-162,61
10,67	11,68	-162,59
10,68	11,69	-162,58
10,69	11,70	-162,57
10,70	11,71	-162,55
10,71	11,72	-162,54
10,72	11,73	-162,52



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
10,73	11,74	-162,51
10,74	11,75	-162,50
10,75	11,76	-162,48
10,76	11,77	-162,47
10,77	11,78	-162,46
10,78	11,79	-162,44
10,79	11,80	-162,43
10,80	11,81	-162,41
10,81	11,82	-162,40
10,82	11,83	-162,39
10,83	11,84	-162,37
10,84	11,85	-162,36
10,85	11,86	-162,35
10,86	11,87	-162,33
10,87	11,88	-162,32
10,88	11,89	-162,30
10,89	11,90	-162,29
10,90	11,91	-162,28
10,91	11,92	-162,26
10,92	11,93	-162,25
10,93	11,94	-162,24
10,94	11,95	-162,22
10,95	11,96	-162,21
10,96	11,97	-162,20
10,97	11,98	-162,18
10,98	11,99	-162,17
10,99	12,00	-162,15
11,00	12,01	-162,14
11,01	12,02	-162,13
11,02	12,03	-162,11
11,03	12,04	-162,10
11,04	12,05	-162,09
11,05	12,06	-162,07
11,06	12,07	-162,06
11,07	12,08	-162,05
11,08	12,09	-162,03
11,09	12,10	-162,02
11,10	12,11	-162,01
11,11	12,12	-161,99
11,12	12,13	-161,98
11,13	12,14	-161,97
11,14	12,15	-161,95
11,15	12,16	-161,94
11,16	12,17	-161,93



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
11,17	12,18	-161,91
11,18	12,19	-161,90
11,19	12,20	-161,89
11,20	12,21	-161,87
11,21	12,22	-161,86
11,22	12,23	-161,85
11,23	12,24	-161,83
11,24	12,25	-161,82
11,25	12,26	-161,80
11,26	12,27	-161,79
11,27	12,28	-161,78
11,28	12,29	-161,76
11,29	12,30	-161,75
11,30	12,31	-161,74
11,31	12,32	-161,72
11,32	12,33	-161,71
11,33	12,34	-161,70
11,34	12,35	-161,69
11,35	12,36	-161,67
11,36	12,37	-161,66
11,37	12,38	-161,65
11,38	12,39	-161,63
11,39	12,40	-161,62
11,40	12,41	-161,61
11,41	12,42	-161,59
11,42	12,43	-161,58
11,43	12,44	-161,57
11,44	12,45	-161,55
11,45	12,46	-161,54
11,46	12,47	-161,53
11,47	12,48	-161,51
11,48	12,49	-161,50
11,49	12,50	-161,49
11,50	12,51	-161,47
11,51	12,52	-161,46
11,52	12,53	-161,45
11,53	12,54	-161,43
11,54	12,55	-161,42
11,55	12,56	-161,41
11,56	12,57	-161,39
11,57	12,58	-161,38
11,58	12,59	-161,37
11,59	12,60	-161,36
11,60	12,61	-161,34



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
11,61	12,62	-161,33
11,62	12,63	-161,32
11,63	12,64	-161,30
11,64	12,65	-161,29
11,65	12,66	-161,28
11,66	12,67	-161,26
11,67	12,68	-161,25
11,68	12,69	-161,24
11,69	12,70	-161,22
11,70	12,71	-161,21
11,71	12,72	-161,20
11,72	12,73	-161,19
11,73	12,74	-161,17
11,74	12,75	-161,16
11,75	12,76	-161,15
11,76	12,77	-161,13
11,77	12,78	-161,12
11,78	12,79	-161,11
11,79	12,80	-161,09
11,80	12,81	-161,08
11,81	12,82	-161,07
11,82	12,83	-161,06
11,83	12,84	-161,04
11,84	12,85	-161,03
11,85	12,86	-161,02
11,86	12,87	-161,00
11,87	12,88	-160,99
11,88	12,89	-160,98
11,89	12,90	-160,97
11,90	12,91	-160,95
11,91	12,92	-160,94
11,92	12,93	-160,93
11,93	12,94	-160,91
11,94	12,95	-160,90
11,95	12,96	-160,89
11,96	12,97	-160,88
11,97	12,98	-160,86
11,98	12,99	-160,85
11,99	13,00	-160,84
12,00	13,01	-160,82
12,01	13,02	-160,81
12,02	13,03	-160,80
12,03	13,04	-160,79
12,04	13,05	-160,77



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
12,05	13,06	-160,76
12,06	13,07	-160,75
12,07	13,08	-160,73
12,08	13,09	-160,72
12,09	13,10	-160,71
12,10	13,11	-160,70
12,11	13,12	-160,68
12,12	13,13	-160,67
12,13	13,14	-160,66
12,14	13,15	-160,65
12,15	13,16	-160,63
12,16	13,17	-160,62
12,17	13,18	-160,61
12,18	13,19	-160,60
12,19	13,20	-160,58
12,20	13,21	-160,57
12,21	13,22	-160,56
12,22	13,23	-160,54
12,23	13,24	-160,53
12,24	13,25	-160,52
12,25	13,26	-160,51
12,26	13,27	-160,49
12,27	13,28	-160,48
12,28	13,29	-160,47
12,29	13,30	-160,46
12,30	13,31	-160,44
12,31	13,32	-160,43
12,32	13,33	-160,42
12,33	13,34	-160,41
12,34	13,35	-160,39
12,35	13,36	-160,38
12,36	13,37	-160,37
12,37	13,38	-160,36
12,38	13,39	-160,34
12,39	13,40	-160,33
12,40	13,41	-160,32
12,41	13,42	-160,31
12,42	13,43	-160,29
12,43	13,44	-160,28
12,44	13,45	-160,27
12,45	13,46	-160,26
12,46	13,47	-160,24
12,47	13,48	-160,23
12,48	13,49	-160,22



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,49	13,50	-160,21
12,50	13,51	-160,19
12,51	13,52	-160,18
12,52	13,53	-160,17
12,53	13,54	-160,16
12,54	13,55	-160,14
12,55	13,56	-160,13
12,56	13,57	-160,12
12,57	13,58	-160,11
12,58	13,59	-160,09
12,59	13,60	-160,08
12,60	13,61	-160,07
12,61	13,62	-160,06
12,62	13,63	-160,04
12,63	13,64	-160,03
12,64	13,65	-160,02
12,65	13,66	-160,01
12,66	13,67	-159,99
12,67	13,68	-159,98
12,68	13,69	-159,97
12,69	13,70	-159,96
12,70	13,71	-159,95
12,71	13,72	-159,93
12,72	13,73	-159,92
12,73	13,74	-159,91
12,74	13,75	-159,90
12,75	13,76	-159,88
12,76	13,77	-159,87
12,77	13,78	-159,86
12,78	13,79	-159,85
12,79	13,80	-159,83
12,80	13,81	-159,82
12,81	13,82	-159,81
12,82	13,83	-159,80
12,83	13,84	-159,79
12,84	13,85	-159,77
12,85	13,86	-159,76
12,86	13,87	-159,75
12,87	13,88	-159,74
12,88	13,89	-159,72
12,89	13,90	-159,71
12,90	13,91	-159,70
12,91	13,92	-159,69
12,92	13,93	-159,68



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
12,93	13,94	-159,66
12,94	13,95	-159,65
12,95	13,96	-159,64
12,96	13,97	-159,63
12,97	13,98	-159,61
12,98	13,99	-159,60
12,99	14,00	-159,59
13,00	14,01	-159,58
13,01	14,02	-159,57
13,02	14,03	-159,55
13,03	14,04	-159,54
13,04	14,05	-159,53
13,05	14,06	-159,52
13,06	14,07	-159,51
13,07	14,08	-159,49
13,08	14,09	-159,48
13,09	14,10	-159,47
13,10	14,11	-159,46
13,11	14,12	-159,45
13,12	14,13	-159,43
13,13	14,14	-159,42
13,14	14,15	-159,41
13,15	14,16	-159,40
13,16	14,17	-159,38
13,17	14,18	-159,37
13,18	14,19	-159,36
13,19	14,20	-159,35
13,20	14,21	-159,34
13,21	14,22	-159,32
13,22	14,23	-159,31
13,23	14,24	-159,30
13,24	14,25	-159,29
13,25	14,26	-159,28
13,26	14,27	-159,26
13,27	14,28	-159,25
13,28	14,29	-159,24
13,29	14,30	-159,23
13,30	14,31	-159,22
13,31	14,32	-159,20
13,32	14,33	-159,19
13,33	14,34	-159,18
13,34	14,35	-159,17
13,35	14,36	-159,16
13,36	14,37	-159,15



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
13,37	14,38	-159,13
13,38	14,39	-159,12
13,39	14,40	-159,11
13,40	14,41	-159,10
13,41	14,42	-159,09
13,42	14,43	-159,07
13,43	14,44	-159,06
13,44	14,45	-159,05
13,45	14,46	-159,04
13,46	14,47	-159,03
13,47	14,48	-159,01
13,48	14,49	-159,00
13,49	14,50	-158,99
13,50	14,51	-158,98
13,51	14,52	-158,97
13,52	14,53	-158,96
13,53	14,54	-158,94
13,54	14,55	-158,93
13,55	14,56	-158,92
13,56	14,57	-158,91
13,57	14,58	-158,90
13,58	14,59	-158,88
13,59	14,60	-158,87
13,60	14,61	-158,86
13,61	14,62	-158,85
13,62	14,63	-158,84
13,63	14,64	-158,83
13,64	14,65	-158,81
13,65	14,66	-158,80
13,66	14,67	-158,79
13,67	14,68	-158,78
13,68	14,69	-158,77
13,69	14,70	-158,76
13,70	14,71	-158,74
13,71	14,72	-158,73
13,72	14,73	-158,72
13,73	14,74	-158,71
13,74	14,75	-158,70
13,75	14,76	-158,68
13,76	14,77	-158,67
13,77	14,78	-158,66
13,78	14,79	-158,65
13,79	14,80	-158,64
13,80	14,81	-158,63



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
13,81	14,82	-158,61
13,82	14,83	-158,60
13,83	14,84	-158,59
13,84	14,85	-158,58
13,85	14,86	-158,57
13,86	14,87	-158,56
13,87	14,88	-158,54
13,88	14,89	-158,53
13,89	14,90	-158,52
13,90	14,91	-158,51
13,91	14,92	-158,50
13,92	14,93	-158,49
13,93	14,94	-158,48
13,94	14,95	-158,46
13,95	14,96	-158,45
13,96	14,97	-158,44
13,97	14,98	-158,43
13,98	14,99	-158,42
13,99	15,00	-158,41
14,00	15,01	-158,39
14,01	15,02	-158,38
14,02	15,03	-158,37
14,03	15,04	-158,36
14,04	15,05	-158,35
14,05	15,06	-158,34
14,06	15,07	-158,33
14,07	15,08	-158,31
14,08	15,09	-158,30
14,09	15,10	-158,29
14,10	15,11	-158,28
14,11	15,12	-158,27
14,12	15,13	-158,26
14,13	15,14	-158,24
14,14	15,15	-158,23
14,15	15,16	-158,22
14,16	15,17	-158,21
14,17	15,18	-158,20
14,18	15,19	-158,19
14,19	15,20	-158,18
14,20	15,21	-158,16
14,21	15,22	-158,15
14,22	15,23	-158,14
14,23	15,24	-158,13
14,24	15,25	-158,12



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,25	15,26	-158,11
14,26	15,27	-158,10
14,27	15,28	-158,08
14,28	15,29	-158,07
14,29	15,30	-158,06
14,30	15,31	-158,05
14,31	15,32	-158,04
14,32	15,33	-158,03
14,33	15,34	-158,02
14,34	15,35	-158,00
14,35	15,36	-157,99
14,36	15,37	-157,98
14,37	15,38	-157,97
14,38	15,39	-157,96
14,39	15,40	-157,95
14,40	15,41	-157,94
14,41	15,42	-157,93
14,42	15,43	-157,91
14,43	15,44	-157,90
14,44	15,45	-157,89
14,45	15,46	-157,88
14,46	15,47	-157,87
14,47	15,48	-157,86
14,48	15,49	-157,85
14,49	15,50	-157,83
14,50	15,51	-157,82
14,51	15,52	-157,81
14,52	15,53	-157,80
14,53	15,54	-157,79
14,54	15,55	-157,78
14,55	15,56	-157,77
14,56	15,57	-157,76
14,57	15,58	-157,74
14,58	15,59	-157,73
14,59	15,60	-157,72
14,60	15,61	-157,71
14,61	15,62	-157,70
14,62	15,63	-157,69
14,63	15,64	-157,68
14,64	15,65	-157,67
14,65	15,66	-157,65
14,66	15,67	-157,64
14,67	15,68	-157,63
14,68	15,69	-157,62



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
14,69	15,70	-157,61
14,70	15,71	-157,60
14,71	15,72	-157,59
14,72	15,73	-157,58
14,73	15,74	-157,57
14,74	15,75	-157,55
14,75	15,76	-157,54
14,76	15,77	-157,53
14,77	15,78	-157,52
14,78	15,79	-157,51
14,79	15,80	-157,50
14,80	15,81	-157,49
14,81	15,82	-157,48
14,82	15,83	-157,47
14,83	15,84	-157,45
14,84	15,85	-157,44
14,85	15,86	-157,43
14,86	15,87	-157,42
14,87	15,88	-157,41
14,88	15,89	-157,40
14,89	15,90	-157,39
14,90	15,91	-157,38
14,91	15,92	-157,37
14,92	15,93	-157,35
14,93	15,94	-157,34
14,94	15,95	-157,33
14,95	15,96	-157,32
14,96	15,97	-157,31
14,97	15,98	-157,30
14,98	15,99	-157,29
14,99	16,00	-157,28
15,00	16,01	-157,27
15,01	16,02	-157,25
15,02	16,03	-157,24
15,03	16,04	-157,23
15,04	16,05	-157,22
15,05	16,06	-157,21
15,06	16,07	-157,20
15,07	16,08	-157,19
15,08	16,09	-157,18
15,09	16,10	-157,17
15,10	16,11	-157,16
15,11	16,12	-157,14
15,12	16,13	-157,13



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
15,13	16,14	-157,12
15,14	16,15	-157,11
15,15	16,16	-157,10
15,16	16,17	-157,09
15,17	16,18	-157,08
15,18	16,19	-157,07
15,19	16,20	-157,06
15,20	16,21	-157,05
15,21	16,22	-157,04
15,22	16,23	-157,02
15,23	16,24	-157,01
15,24	16,25	-157,00
15,25	16,26	-156,99
15,26	16,27	-156,98
15,27	16,28	-156,97
15,28	16,29	-156,96
15,29	16,30	-156,95
15,30	16,31	-156,94
15,31	16,32	-156,93
15,32	16,33	-156,92
15,33	16,34	-156,90
15,34	16,35	-156,89
15,35	16,36	-156,88
15,36	16,37	-156,87
15,37	16,38	-156,86
15,38	16,39	-156,85
15,39	16,40	-156,84
15,40	16,41	-156,83
15,41	16,42	-156,82
15,42	16,43	-156,81
15,43	16,44	-156,80
15,44	16,45	-156,79
15,45	16,46	-156,77
15,46	16,47	-156,76
15,47	16,48	-156,75
15,48	16,49	-156,74
15,49	16,50	-156,73
15,50	16,51	-156,72
15,51	16,52	-156,71
15,52	16,53	-156,70
15,53	16,54	-156,69
15,54	16,55	-156,68
15,55	16,56	-156,67
15,56	16,57	-156,66



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
15,57	16,58	-156,65
15,58	16,59	-156,63
15,59	16,60	-156,62
15,60	16,61	-156,61
15,61	16,62	-156,60
15,62	16,63	-156,59
15,63	16,64	-156,58
15,64	16,65	-156,57
15,65	16,66	-156,56
15,66	16,67	-156,55
15,67	16,68	-156,54
15,68	16,69	-156,53
15,69	16,70	-156,52
15,70	16,71	-156,51
15,71	16,72	-156,50
15,72	16,73	-156,48
15,73	16,74	-156,47
15,74	16,75	-156,46
15,75	16,76	-156,45
15,76	16,77	-156,44
15,77	16,78	-156,43
15,78	16,79	-156,42
15,79	16,80	-156,41
15,80	16,81	-156,40
15,81	16,82	-156,39
15,82	16,83	-156,38
15,83	16,84	-156,37
15,84	16,85	-156,36
15,85	16,86	-156,35
15,86	16,87	-156,34
15,87	16,88	-156,32
15,88	16,89	-156,31
15,89	16,90	-156,30
15,90	16,91	-156,29
15,91	16,92	-156,28
15,92	16,93	-156,27
15,93	16,94	-156,26
15,94	16,95	-156,25
15,95	16,96	-156,24
15,96	16,97	-156,23
15,97	16,98	-156,22
15,98	16,99	-156,21
15,99	17,00	-156,20
16,00	17,01	-156,19



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,01	17,02	-156,18
16,02	17,03	-156,17
16,03	17,04	-156,16
16,04	17,05	-156,14
16,05	17,06	-156,13
16,06	17,07	-156,12
16,07	17,08	-156,11
16,08	17,09	-156,10
16,09	17,10	-156,09
16,10	17,11	-156,08
16,11	17,12	-156,07
16,12	17,13	-156,06
16,13	17,14	-156,05
16,14	17,15	-156,04
16,15	17,16	-156,03
16,16	17,17	-156,02
16,17	17,18	-156,01
16,18	17,19	-156,00
16,19	17,20	-155,99
16,20	17,21	-155,98
16,21	17,22	-155,97
16,22	17,23	-155,96
16,23	17,24	-155,95
16,24	17,25	-155,94
16,25	17,26	-155,92
16,26	17,27	-155,91
16,27	17,28	-155,90
16,28	17,29	-155,89
16,29	17,30	-155,88
16,30	17,31	-155,87
16,31	17,32	-155,86
16,32	17,33	-155,85
16,33	17,34	-155,84
16,34	17,35	-155,83
16,35	17,36	-155,82
16,36	17,37	-155,81
16,37	17,38	-155,80
16,38	17,39	-155,79
16,39	17,40	-155,78
16,40	17,41	-155,77
16,41	17,42	-155,76
16,42	17,43	-155,75
16,43	17,44	-155,74
16,44	17,45	-155,73



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,45	17,46	-155,72
16,46	17,47	-155,71
16,47	17,48	-155,70
16,48	17,49	-155,69
16,49	17,50	-155,68
16,50	17,51	-155,66
16,51	17,52	-155,65
16,52	17,53	-155,64
16,53	17,54	-155,63
16,54	17,55	-155,62
16,55	17,56	-155,61
16,56	17,57	-155,60
16,57	17,58	-155,59
16,58	17,59	-155,58
16,59	17,60	-155,57
16,60	17,61	-155,56
16,61	17,62	-155,55
16,62	17,63	-155,54
16,63	17,64	-155,53
16,64	17,65	-155,52
16,65	17,66	-155,51
16,66	17,67	-155,50
16,67	17,68	-155,49
16,68	17,69	-155,48
16,69	17,70	-155,47
16,70	17,71	-155,46
16,71	17,72	-155,45
16,72	17,73	-155,44
16,73	17,74	-155,43
16,74	17,75	-155,42
16,75	17,76	-155,41
16,76	17,77	-155,40
16,77	17,78	-155,39
16,78	17,79	-155,38
16,79	17,80	-155,37
16,80	17,81	-155,36
16,81	17,82	-155,35
16,82	17,83	-155,34
16,83	17,84	-155,33
16,84	17,85	-155,32
16,85	17,86	-155,31
16,86	17,87	-155,30
16,87	17,88	-155,29
16,88	17,89	-155,28



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
16,89	17,90	-155,26
16,90	17,91	-155,25
16,91	17,92	-155,24
16,92	17,93	-155,23
16,93	17,94	-155,22
16,94	17,95	-155,21
16,95	17,96	-155,20
16,96	17,97	-155,19
16,97	17,98	-155,18
16,98	17,99	-155,17
16,99	18,00	-155,16
17,00	18,01	-155,15
17,01	18,02	-155,14
17,02	18,03	-155,13
17,03	18,04	-155,12
17,04	18,05	-155,11
17,05	18,06	-155,10
17,06	18,07	-155,09
17,07	18,08	-155,08
17,08	18,09	-155,07
17,09	18,10	-155,06
17,10	18,11	-155,05
17,11	18,12	-155,04
17,12	18,13	-155,03
17,13	18,14	-155,02
17,14	18,15	-155,01
17,15	18,16	-155,00
17,16	18,17	-154,99
17,17	18,18	-154,98
17,18	18,19	-154,97
17,19	18,20	-154,96
17,20	18,21	-154,95
17,21	18,22	-154,94
17,22	18,23	-154,93
17,23	18,24	-154,92
17,24	18,25	-154,91
17,25	18,26	-154,90
17,26	18,27	-154,89
17,27	18,28	-154,88
17,28	18,29	-154,87
17,29	18,30	-154,86
17,30	18,31	-154,85
17,31	18,32	-154,84
17,32	18,33	-154,83



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
17,33	18,34	-154,82
17,34	18,35	-154,81
17,35	18,36	-154,80
17,36	18,37	-154,79
17,37	18,38	-154,78
17,38	18,39	-154,77
17,39	18,40	-154,76
17,40	18,41	-154,75
17,41	18,42	-154,74
17,42	18,43	-154,73
17,43	18,44	-154,72
17,44	18,45	-154,71
17,45	18,46	-154,70
17,46	18,47	-154,69
17,47	18,48	-154,68
17,48	18,49	-154,67
17,49	18,50	-154,66
17,50	18,51	-154,65
17,51	18,52	-154,64
17,52	18,53	-154,63
17,53	18,54	-154,62
17,54	18,55	-154,61
17,55	18,56	-154,60
17,56	18,57	-154,59
17,57	18,58	-154,58
17,58	18,59	-154,57
17,59	18,60	-154,56
17,60	18,61	-154,55
17,61	18,62	-154,54
17,62	18,63	-154,53
17,63	18,64	-154,52
17,64	18,65	-154,51
17,65	18,66	-154,50
17,66	18,67	-154,49
17,67	18,68	-154,48
17,68	18,69	-154,47
17,69	18,70	-154,46
17,70	18,71	-154,45
17,71	18,72	-154,44
17,72	18,73	-154,43
17,73	18,74	-154,42
17,74	18,75	-154,41
17,75	18,76	-154,40
17,76	18,77	-154,39



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
17,77	18,78	-154,38
17,78	18,79	-154,38
17,79	18,80	-154,37
17,80	18,81	-154,36
17,81	18,82	-154,35
17,82	18,83	-154,34
17,83	18,84	-154,33
17,84	18,85	-154,32
17,85	18,86	-154,31
17,86	18,87	-154,30
17,87	18,88	-154,29
17,88	18,89	-154,28
17,89	18,90	-154,27
17,90	18,91	-154,26
17,91	18,92	-154,25
17,92	18,93	-154,24
17,93	18,94	-154,23
17,94	18,95	-154,22
17,95	18,96	-154,21
17,96	18,97	-154,20
17,97	18,98	-154,19
17,98	18,99	-154,18
17,99	19,00	-154,17
18,00	19,01	-154,16
18,01	19,02	-154,15
18,02	19,03	-154,14
18,03	19,04	-154,13
18,04	19,05	-154,12
18,05	19,06	-154,11
18,06	19,07	-154,10
18,07	19,08	-154,09
18,08	19,09	-154,08
18,09	19,10	-154,07
18,10	19,11	-154,06
18,11	19,12	-154,05
18,12	19,13	-154,04
18,13	19,14	-154,03
18,14	19,15	-154,02
18,15	19,16	-154,01
18,16	19,17	-154,00
18,17	19,18	-153,99
18,18	19,19	-153,99
18,19	19,20	-153,98
18,20	19,21	-153,97



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,21	19,22	-153,96
18,22	19,23	-153,95
18,23	19,24	-153,94
18,24	19,25	-153,93
18,25	19,26	-153,92
18,26	19,27	-153,91
18,27	19,28	-153,90
18,28	19,29	-153,89
18,29	19,30	-153,88
18,30	19,31	-153,87
18,31	19,32	-153,86
18,32	19,33	-153,85
18,33	19,34	-153,84
18,34	19,35	-153,83
18,35	19,36	-153,82
18,36	19,37	-153,81
18,37	19,38	-153,80
18,38	19,39	-153,79
18,39	19,40	-153,78
18,40	19,41	-153,77
18,41	19,42	-153,76
18,42	19,43	-153,75
18,43	19,44	-153,74
18,44	19,45	-153,73
18,45	19,46	-153,73
18,46	19,47	-153,72
18,47	19,48	-153,71
18,48	19,49	-153,70
18,49	19,50	-153,69
18,50	19,51	-153,68
18,51	19,52	-153,67
18,52	19,53	-153,66
18,53	19,54	-153,65
18,54	19,55	-153,64
18,55	19,56	-153,63
18,56	19,57	-153,62
18,57	19,58	-153,61
18,58	19,59	-153,60
18,59	19,60	-153,59
18,60	19,61	-153,58
18,61	19,62	-153,57
18,62	19,63	-153,56
18,63	19,64	-153,55
18,64	19,65	-153,54



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
18,65	19,66	-153,53
18,66	19,67	-153,52
18,67	19,68	-153,52
18,68	19,69	-153,51
18,69	19,70	-153,50
18,70	19,71	-153,49
18,71	19,72	-153,48
18,72	19,73	-153,47
18,73	19,74	-153,46
18,74	19,75	-153,45
18,75	19,76	-153,44
18,76	19,77	-153,43
18,77	19,78	-153,42
18,78	19,79	-153,41
18,79	19,80	-153,40
18,80	19,81	-153,39
18,81	19,82	-153,38
18,82	19,83	-153,37
18,83	19,84	-153,36
18,84	19,85	-153,35
18,85	19,86	-153,35
18,86	19,87	-153,34
18,87	19,88	-153,33
18,88	19,89	-153,32
18,89	19,90	-153,31
18,90	19,91	-153,30
18,91	19,92	-153,29
18,92	19,93	-153,28
18,93	19,94	-153,27
18,94	19,95	-153,26
18,95	19,96	-153,25
18,96	19,97	-153,24
18,97	19,98	-153,23
18,98	19,99	-153,22
18,99	20,00	-153,21
19,00	20,01	-153,20
19,01	20,02	-153,19
19,02	20,03	-153,19
19,03	20,04	-153,18
19,04	20,05	-153,17
19,05	20,06	-153,16
19,06	20,07	-153,15
19,07	20,08	-153,14
19,08	20,09	-153,13



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,09	20,10	-153,12
19,10	20,11	-153,11
19,11	20,12	-153,10
19,12	20,13	-153,09
19,13	20,14	-153,08
19,14	20,15	-153,07
19,15	20,16	-153,06
19,16	20,17	-153,05
19,17	20,18	-153,04
19,18	20,19	-153,04
19,19	20,20	-153,03
19,20	20,21	-153,02
19,21	20,22	-153,01
19,22	20,23	-153,00
19,23	20,24	-152,99
19,24	20,25	-152,98
19,25	20,26	-152,97
19,26	20,27	-152,96
19,27	20,28	-152,95
19,28	20,29	-152,94
19,29	20,30	-152,93
19,30	20,31	-152,92
19,31	20,32	-152,91
19,32	20,33	-152,91
19,33	20,34	-152,90
19,34	20,35	-152,89
19,35	20,36	-152,88
19,36	20,37	-152,87
19,37	20,38	-152,86
19,38	20,39	-152,85
19,39	20,40	-152,84
19,40	20,41	-152,83
19,41	20,42	-152,82
19,42	20,43	-152,81
19,43	20,44	-152,80
19,44	20,45	-152,79
19,45	20,46	-152,78
19,46	20,47	-152,78
19,47	20,48	-152,77
19,48	20,49	-152,76
19,49	20,50	-152,75
19,50	20,51	-152,74
19,51	20,52	-152,73
19,52	20,53	-152,72



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
19,53	20,54	-152,71
19,54	20,55	-152,70
19,55	20,56	-152,69
19,56	20,57	-152,68
19,57	20,58	-152,67
19,58	20,59	-152,67
19,59	20,60	-152,66
19,60	20,61	-152,65
19,61	20,62	-152,64
19,62	20,63	-152,63
19,63	20,64	-152,62
19,64	20,65	-152,61
19,65	20,66	-152,60
19,66	20,67	-152,59
19,67	20,68	-152,58
19,68	20,69	-152,57
19,69	20,70	-152,56
19,70	20,71	-152,56
19,71	20,72	-152,55
19,72	20,73	-152,54
19,73	20,74	-152,53
19,74	20,75	-152,52
19,75	20,76	-152,51
19,76	20,77	-152,50
19,77	20,78	-152,49
19,78	20,79	-152,48
19,79	20,80	-152,47
19,80	20,81	-152,46
19,81	20,82	-152,45
19,82	20,83	-152,45
19,83	20,84	-152,44
19,84	20,85	-152,43
19,85	20,86	-152,42
19,86	20,87	-152,41
19,87	20,88	-152,40
19,88	20,89	-152,39
19,89	20,90	-152,38
19,90	20,91	-152,37
19,91	20,92	-152,36
19,92	20,93	-152,35
19,93	20,94	-152,35
19,94	20,95	-152,34
19,95	20,96	-152,33
19,96	20,97	-152,32



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
19,97	20,98	-152,31
19,98	20,99	-152,30
19,99	21,00	-152,29
20,00	21,01	-152,28
20,01	21,02	-152,27
20,02	21,03	-152,26
20,03	21,04	-152,25
20,04	21,05	-152,25
20,05	21,06	-152,24
20,06	21,07	-152,23
20,07	21,08	-152,22
20,08	21,09	-152,21
20,09	21,10	-152,20
20,10	21,11	-152,19
20,11	21,12	-152,18
20,12	21,13	-152,17
20,13	21,14	-152,16
20,14	21,15	-152,16
20,15	21,16	-152,15
20,16	21,17	-152,14
20,17	21,18	-152,13
20,18	21,19	-152,12
20,19	21,20	-152,11
20,20	21,21	-152,10
20,21	21,22	-152,09
20,22	21,23	-152,08
20,23	21,24	-152,07
20,24	21,25	-152,07
20,25	21,26	-152,06
20,26	21,27	-152,05
20,27	21,28	-152,04
20,28	21,29	-152,03
20,29	21,30	-152,02
20,30	21,31	-152,01
20,31	21,32	-152,00
20,32	21,33	-151,99
20,33	21,34	-151,98
20,34	21,35	-151,98
20,35	21,36	-151,97
20,36	21,37	-151,96
20,37	21,38	-151,95
20,38	21,39	-151,94
20,39	21,40	-151,93
20,40	21,41	-151,92



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,41	21,42	-151,91
20,42	21,43	-151,90
20,43	21,44	-151,90
20,44	21,45	-151,89
20,45	21,46	-151,88
20,46	21,47	-151,87
20,47	21,48	-151,86
20,48	21,49	-151,85
20,49	21,50	-151,84
20,50	21,51	-151,83
20,51	21,52	-151,82
20,52	21,53	-151,82
20,53	21,54	-151,81
20,54	21,55	-151,80
20,55	21,56	-151,79
20,56	21,57	-151,78
20,57	21,58	-151,77
20,58	21,59	-151,76
20,59	21,60	-151,75
20,60	21,61	-151,74
20,61	21,62	-151,74
20,62	21,63	-151,73
20,63	21,64	-151,72
20,64	21,65	-151,71
20,65	21,66	-151,70
20,66	21,67	-151,69
20,67	21,68	-151,68
20,68	21,69	-151,67
20,69	21,70	-151,66
20,70	21,71	-151,66
20,71	21,72	-151,65
20,72	21,73	-151,64
20,73	21,74	-151,63
20,74	21,75	-151,62
20,75	21,76	-151,61
20,76	21,77	-151,60
20,77	21,78	-151,59
20,78	21,79	-151,58
20,79	21,80	-151,58
20,80	21,81	-151,57
20,81	21,82	-151,56
20,82	21,83	-151,55
20,83	21,84	-151,54
20,84	21,85	-151,53



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
20,85	21,86	-151,52
20,86	21,87	-151,51
20,87	21,88	-151,51
20,88	21,89	-151,50
20,89	21,90	-151,49
20,90	21,91	-151,48
20,91	21,92	-151,47
20,92	21,93	-151,46
20,93	21,94	-151,45
20,94	21,95	-151,44
20,95	21,96	-151,44
20,96	21,97	-151,43
20,97	21,98	-151,42
20,98	21,99	-151,41
20,99	22,00	-151,40
21,00	22,01	-151,39
21,01	22,02	-151,38
21,02	22,03	-151,37
21,03	22,04	-151,37
21,04	22,05	-151,36
21,05	22,06	-151,35
21,06	22,07	-151,34
21,07	22,08	-151,33
21,08	22,09	-151,32
21,09	22,10	-151,31
21,10	22,11	-151,30
21,11	22,12	-151,30
21,12	22,13	-151,29
21,13	22,14	-151,28
21,14	22,15	-151,27
21,15	22,16	-151,26
21,16	22,17	-151,25
21,17	22,18	-151,24
21,18	22,19	-151,23
21,19	22,20	-151,23
21,20	22,21	-151,22
21,21	22,22	-151,21
21,22	22,23	-151,20
21,23	22,24	-151,19
21,24	22,25	-151,18
21,25	22,26	-151,17
21,26	22,27	-151,16
21,27	22,28	-151,16
21,28	22,29	-151,15



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
21,29	22,30	-151,14
21,30	22,31	-151,13
21,31	22,32	-151,12
21,32	22,33	-151,11
21,33	22,34	-151,10
21,34	22,35	-151,10
21,35	22,36	-151,09
21,36	22,37	-151,08
21,37	22,38	-151,07
21,38	22,39	-151,06
21,39	22,40	-151,05
21,40	22,41	-151,04
21,41	22,42	-151,03
21,42	22,43	-151,03
21,43	22,44	-151,02
21,44	22,45	-151,01
21,45	22,46	-151,00
21,46	22,47	-150,99
21,47	22,48	-150,98
21,48	22,49	-150,97
21,49	22,50	-150,97
21,50	22,51	-150,96
21,51	22,52	-150,95
21,52	22,53	-150,94
21,53	22,54	-150,93
21,54	22,55	-150,92
21,55	22,56	-150,91
21,56	22,57	-150,91
21,57	22,58	-150,90
21,58	22,59	-150,89
21,59	22,60	-150,88
21,60	22,61	-150,87
21,61	22,62	-150,86
21,62	22,63	-150,85
21,63	22,64	-150,85
21,64	22,65	-150,84
21,65	22,66	-150,83
21,66	22,67	-150,82
21,67	22,68	-150,81
21,68	22,69	-150,80
21,69	22,70	-150,79
21,70	22,71	-150,79
21,71	22,72	-150,78
21,72	22,73	-150,77



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
21,73	22,74	-150,76
21,74	22,75	-150,75
21,75	22,76	-150,74
21,76	22,77	-150,73
21,77	22,78	-150,73
21,78	22,79	-150,72
21,79	22,80	-150,71
21,80	22,81	-150,70
21,81	22,82	-150,69
21,82	22,83	-150,68
21,83	22,84	-150,67
21,84	22,85	-150,67
21,85	22,86	-150,66
21,86	22,87	-150,65
21,87	22,88	-150,64
21,88	22,89	-150,63
21,89	22,90	-150,62
21,90	22,91	-150,62
21,91	22,92	-150,61
21,92	22,93	-150,60
21,93	22,94	-150,59
21,94	22,95	-150,58
21,95	22,96	-150,57
21,96	22,97	-150,56
21,97	22,98	-150,56
21,98	22,99	-150,55
21,99	23,00	-150,54
22,00	23,01	-150,53
22,01	23,02	-150,52
22,02	23,03	-150,51
22,03	23,04	-150,50
22,04	23,05	-150,50
22,05	23,06	-150,49
22,06	23,07	-150,48
22,07	23,08	-150,47
22,08	23,09	-150,46
22,09	23,10	-150,45
22,10	23,11	-150,45
22,11	23,12	-150,44
22,12	23,13	-150,43
22,13	23,14	-150,42
22,14	23,15	-150,41
22,15	23,16	-150,40
22,16	23,17	-150,40



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,17	23,18	-150,39
22,18	23,19	-150,38
22,19	23,20	-150,37
22,20	23,21	-150,36
22,21	23,22	-150,35
22,22	23,23	-150,34
22,23	23,24	-150,34
22,24	23,25	-150,33
22,25	23,26	-150,32
22,26	23,27	-150,31
22,27	23,28	-150,30
22,28	23,29	-150,29
22,29	23,30	-150,29
22,30	23,31	-150,28
22,31	23,32	-150,27
22,32	23,33	-150,26
22,33	23,34	-150,25
22,34	23,35	-150,24
22,35	23,36	-150,24
22,36	23,37	-150,23
22,37	23,38	-150,22
22,38	23,39	-150,21
22,39	23,40	-150,20
22,40	23,41	-150,19
22,41	23,42	-150,19
22,42	23,43	-150,18
22,43	23,44	-150,17
22,44	23,45	-150,16
22,45	23,46	-150,15
22,46	23,47	-150,14
22,47	23,48	-150,13
22,48	23,49	-150,13
22,49	23,50	-150,12
22,50	23,51	-150,11
22,51	23,52	-150,10
22,52	23,53	-150,09
22,53	23,54	-150,08
22,54	23,55	-150,08
22,55	23,56	-150,07
22,56	23,57	-150,06
22,57	23,58	-150,05
22,58	23,59	-150,04
22,59	23,60	-150,04
22,60	23,61	-150,03



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
22,61	23,62	-150,02
22,62	23,63	-150,01
22,63	23,64	-150,00
22,64	23,65	-149,99
22,65	23,66	-149,99
22,66	23,67	-149,98
22,67	23,68	-149,97
22,68	23,69	-149,96
22,69	23,70	-149,95
22,70	23,71	-149,94
22,71	23,72	-149,94
22,72	23,73	-149,93
22,73	23,74	-149,92
22,74	23,75	-149,91
22,75	23,76	-149,90
22,76	23,77	-149,89
22,77	23,78	-149,89
22,78	23,79	-149,88
22,79	23,80	-149,87
22,80	23,81	-149,86
22,81	23,82	-149,85
22,82	23,83	-149,84
22,83	23,84	-149,84
22,84	23,85	-149,83
22,85	23,86	-149,82
22,86	23,87	-149,81
22,87	23,88	-149,80
22,88	23,89	-149,79
22,89	23,90	-149,79
22,90	23,91	-149,78
22,91	23,92	-149,77
22,92	23,93	-149,76
22,93	23,94	-149,75
22,94	23,95	-149,75
22,95	23,96	-149,74
22,96	23,97	-149,73
22,97	23,98	-149,72
22,98	23,99	-149,71
22,99	24,00	-149,70
23,00	24,01	-149,70
23,01	24,02	-149,69
23,02	24,03	-149,68
23,03	24,04	-149,67
23,04	24,05	-149,66



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,05	24,06	-149,66
23,06	24,07	-149,65
23,07	24,08	-149,64
23,08	24,09	-149,63
23,09	24,10	-149,62
23,10	24,11	-149,61
23,11	24,12	-149,61
23,12	24,13	-149,60
23,13	24,14	-149,59
23,14	24,15	-149,58
23,15	24,16	-149,57
23,16	24,17	-149,57
23,17	24,18	-149,56
23,18	24,19	-149,55
23,19	24,20	-149,54
23,20	24,21	-149,53
23,21	24,22	-149,52
23,22	24,23	-149,52
23,23	24,24	-149,51
23,24	24,25	-149,50
23,25	24,26	-149,49
23,26	24,27	-149,48
23,27	24,28	-149,48
23,28	24,29	-149,47
23,29	24,30	-149,46
23,30	24,31	-149,45
23,31	24,32	-149,44
23,32	24,33	-149,43
23,33	24,34	-149,43
23,34	24,35	-149,42
23,35	24,36	-149,41
23,36	24,37	-149,40
23,37	24,38	-149,39
23,38	24,39	-149,39
23,39	24,40	-149,38
23,40	24,41	-149,37
23,41	24,42	-149,36
23,42	24,43	-149,35
23,43	24,44	-149,35
23,44	24,45	-149,34
23,45	24,46	-149,33
23,46	24,47	-149,32
23,47	24,48	-149,31
23,48	24,49	-149,31



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,49	24,50	-149,30
23,50	24,51	-149,29
23,51	24,52	-149,28
23,52	24,53	-149,27
23,53	24,54	-149,26
23,54	24,55	-149,26
23,55	24,56	-149,25
23,56	24,57	-149,24
23,57	24,58	-149,23
23,58	24,59	-149,22
23,59	24,60	-149,22
23,60	24,61	-149,21
23,61	24,62	-149,20
23,62	24,63	-149,19
23,63	24,64	-149,18
23,64	24,65	-149,18
23,65	24,66	-149,17
23,66	24,67	-149,16
23,67	24,68	-149,15
23,68	24,69	-149,14
23,69	24,70	-149,14
23,70	24,71	-149,13
23,71	24,72	-149,12
23,72	24,73	-149,11
23,73	24,74	-149,10
23,74	24,75	-149,10
23,75	24,76	-149,09
23,76	24,77	-149,08
23,77	24,78	-149,07
23,78	24,79	-149,06
23,79	24,80	-149,06
23,80	24,81	-149,05
23,81	24,82	-149,04
23,82	24,83	-149,03
23,83	24,84	-149,02
23,84	24,85	-149,02
23,85	24,86	-149,01
23,86	24,87	-149,00
23,87	24,88	-148,99
23,88	24,89	-148,98
23,89	24,90	-148,98
23,90	24,91	-148,97
23,91	24,92	-148,96
23,92	24,93	-148,95



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
23,93	24,94	-148,94
23,94	24,95	-148,94
23,95	24,96	-148,93
23,96	24,97	-148,92
23,97	24,98	-148,91
23,98	24,99	-148,90
23,99	25,00	-148,90
24,00	25,01	-148,89
24,01	25,02	-148,88
24,02	25,03	-148,87
24,03	25,04	-148,86
24,04	25,05	-148,86
24,05	25,06	-148,85
24,06	25,07	-148,84
24,07	25,08	-148,83
24,08	25,09	-148,82
24,09	25,10	-148,82
24,10	25,11	-148,81
24,11	25,12	-148,80
24,12	25,13	-148,79
24,13	25,14	-148,78
24,14	25,15	-148,78
24,15	25,16	-148,77
24,16	25,17	-148,76
24,17	25,18	-148,75
24,18	25,19	-148,74
24,19	25,20	-148,74
24,20	25,21	-148,73
24,21	25,22	-148,72
24,22	25,23	-148,71
24,23	25,24	-148,71
24,24	25,25	-148,70
24,25	25,26	-148,69
24,26	25,27	-148,68
24,27	25,28	-148,67
24,28	25,29	-148,67
24,29	25,30	-148,66
24,30	25,31	-148,65
24,31	25,32	-148,64
24,32	25,33	-148,63
24,33	25,34	-148,63
24,34	25,35	-148,62
24,35	25,36	-148,61
24,36	25,37	-148,60



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,37	25,38	-148,59
24,38	25,39	-148,59
24,39	25,40	-148,58
24,40	25,41	-148,57
24,41	25,42	-148,56
24,42	25,43	-148,56
24,43	25,44	-148,55
24,44	25,45	-148,54
24,45	25,46	-148,53
24,46	25,47	-148,52
24,47	25,48	-148,52
24,48	25,49	-148,51
24,49	25,50	-148,50
24,50	25,51	-148,49
24,51	25,52	-148,48
24,52	25,53	-148,48
24,53	25,54	-148,47
24,54	25,55	-148,46
24,55	25,56	-148,45
24,56	25,57	-148,45
24,57	25,58	-148,44
24,58	25,59	-148,43
24,59	25,60	-148,42
24,60	25,61	-148,41
24,61	25,62	-148,41
24,62	25,63	-148,40
24,63	25,64	-148,39
24,64	25,65	-148,38
24,65	25,66	-148,38
24,66	25,67	-148,37
24,67	25,68	-148,36
24,68	25,69	-148,35
24,69	25,70	-148,34
24,70	25,71	-148,34
24,71	25,72	-148,33
24,72	25,73	-148,32
24,73	25,74	-148,31
24,74	25,75	-148,30
24,75	25,76	-148,30
24,76	25,77	-148,29
24,77	25,78	-148,28
24,78	25,79	-148,27
24,79	25,80	-148,27
24,80	25,81	-148,26



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
24,81	25,82	-148,25
24,82	25,83	-148,24
24,83	25,84	-148,23
24,84	25,85	-148,23
24,85	25,86	-148,22
24,86	25,87	-148,21
24,87	25,88	-148,20
24,88	25,89	-148,20
24,89	25,90	-148,19
24,90	25,91	-148,18
24,91	25,92	-148,17
24,92	25,93	-148,17
24,93	25,94	-148,16
24,94	25,95	-148,15
24,95	25,96	-148,14
24,96	25,97	-148,13
24,97	25,98	-148,13
24,98	25,99	-148,12
24,99	26,00	-148,11
25,00	26,01	-148,10
25,01	26,02	-148,10
25,02	26,03	-148,09
25,03	26,04	-148,08
25,04	26,05	-148,07
25,05	26,06	-148,06
25,06	26,07	-148,06
25,07	26,08	-148,05
25,08	26,09	-148,04
25,09	26,10	-148,03
25,10	26,11	-148,03
25,11	26,12	-148,02
25,12	26,13	-148,01
25,13	26,14	-148,00
25,14	26,15	-148,00
25,15	26,16	-147,99
25,16	26,17	-147,98
25,17	26,18	-147,97
25,18	26,19	-147,96
25,19	26,20	-147,96
25,20	26,21	-147,95
25,21	26,22	-147,94
25,22	26,23	-147,93
25,23	26,24	-147,93
25,24	26,25	-147,92



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
25,25	26,26	-147,91
25,26	26,27	-147,90
25,27	26,28	-147,90
25,28	26,29	-147,89
25,29	26,30	-147,88
25,30	26,31	-147,87
25,31	26,32	-147,86
25,32	26,33	-147,86
25,33	26,34	-147,85
25,34	26,35	-147,84
25,35	26,36	-147,83
25,36	26,37	-147,83
25,37	26,38	-147,82
25,38	26,39	-147,81
25,39	26,40	-147,80
25,40	26,41	-147,80
25,41	26,42	-147,79
25,42	26,43	-147,78
25,43	26,44	-147,77
25,44	26,45	-147,77
25,45	26,46	-147,76
25,46	26,47	-147,75
25,47	26,48	-147,74
25,48	26,49	-147,73
25,49	26,50	-147,73
25,50	26,51	-147,72
25,51	26,52	-147,71
25,52	26,53	-147,70
25,53	26,54	-147,70
25,54	26,55	-147,69
25,55	26,56	-147,68
25,56	26,57	-147,67
25,57	26,58	-147,67
25,58	26,59	-147,66
25,59	26,60	-147,65
25,60	26,61	-147,64
25,61	26,62	-147,64
25,62	26,63	-147,63
25,63	26,64	-147,62
25,64	26,65	-147,61
25,65	26,66	-147,61
25,66	26,67	-147,60
25,67	26,68	-147,59
25,68	26,69	-147,58



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
25,69	26,70	-147,58
25,70	26,71	-147,57
25,71	26,72	-147,56
25,72	26,73	-147,55
25,73	26,74	-147,54
25,74	26,75	-147,54
25,75	26,76	-147,53
25,76	26,77	-147,52
25,77	26,78	-147,51
25,78	26,79	-147,51
25,79	26,80	-147,50
25,80	26,81	-147,49
25,81	26,82	-147,48
25,82	26,83	-147,48
25,83	26,84	-147,47
25,84	26,85	-147,46
25,85	26,86	-147,45
25,86	26,87	-147,45
25,87	26,88	-147,44
25,88	26,89	-147,43
25,89	26,90	-147,42
25,90	26,91	-147,42
25,91	26,92	-147,41
25,92	26,93	-147,40
25,93	26,94	-147,39
25,94	26,95	-147,39
25,95	26,96	-147,38
25,96	26,97	-147,37
25,97	26,98	-147,36
25,98	26,99	-147,36
25,99	27,00	-147,35
26,00	27,01	-147,34
26,01	27,02	-147,33
26,02	27,03	-147,33
26,03	27,04	-147,32
26,04	27,05	-147,31
26,05	27,06	-147,30
26,06	27,07	-147,30
26,07	27,08	-147,29
26,08	27,09	-147,28
26,09	27,10	-147,27
26,10	27,11	-147,27
26,11	27,12	-147,26
26,12	27,13	-147,25



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
26,13	27,14	-147,24
26,14	27,15	-147,24
26,15	27,16	-147,23
26,16	27,17	-147,22
26,17	27,18	-147,21
26,18	27,19	-147,21
26,19	27,20	-147,20
26,20	27,21	-147,19
26,21	27,22	-147,18
26,22	27,23	-147,18
26,23	27,24	-147,17
26,24	27,25	-147,16
26,25	27,26	-147,15
26,26	27,27	-147,15
26,27	27,28	-147,14
26,28	27,29	-147,13
26,29	27,30	-147,12
26,30	27,31	-147,12
26,31	27,32	-147,11
26,32	27,33	-147,10
26,33	27,34	-147,09
26,34	27,35	-147,09
26,35	27,36	-147,08
26,36	27,37	-147,07
26,37	27,38	-147,06
26,38	27,39	-147,06
26,39	27,40	-147,05
26,40	27,41	-147,04
26,41	27,42	-147,04
26,42	27,43	-147,03
26,43	27,44	-147,02
26,44	27,45	-147,01
26,45	27,46	-147,01
26,46	27,47	-147,00
26,47	27,48	-146,99
26,48	27,49	-146,98
26,49	27,50	-146,98
26,50	27,51	-146,97
26,51	27,52	-146,96
26,52	27,53	-146,95
26,53	27,54	-146,95
26,54	27,55	-146,94
26,55	27,56	-146,93
26,56	27,57	-146,92



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
26,57	27,58	-146,92
26,58	27,59	-146,91
26,59	27,60	-146,90
26,60	27,61	-146,89
26,61	27,62	-146,89
26,62	27,63	-146,88
26,63	27,64	-146,87
26,64	27,65	-146,87
26,65	27,66	-146,86
26,66	27,67	-146,85
26,67	27,68	-146,84
26,68	27,69	-146,84
26,69	27,70	-146,83
26,70	27,71	-146,82
26,71	27,72	-146,81
26,72	27,73	-146,81
26,73	27,74	-146,80
26,74	27,75	-146,79
26,75	27,76	-146,78
26,76	27,77	-146,78
26,77	27,78	-146,77
26,78	27,79	-146,76
26,79	27,80	-146,75
26,80	27,81	-146,75
26,81	27,82	-146,74
26,82	27,83	-146,73
26,83	27,84	-146,73
26,84	27,85	-146,72
26,85	27,86	-146,71
26,86	27,87	-146,70
26,87	27,88	-146,70
26,88	27,89	-146,69
26,89	27,90	-146,68
26,90	27,91	-146,67
26,91	27,92	-146,67
26,92	27,93	-146,66
26,93	27,94	-146,65
26,94	27,95	-146,64
26,95	27,96	-146,64
26,96	27,97	-146,63
26,97	27,98	-146,62
26,98	27,99	-146,62
26,99	28,00	-146,61
27,00	28,01	-146,60



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,01	28,02	-146,59
27,02	28,03	-146,59
27,03	28,04	-146,58
27,04	28,05	-146,57
27,05	28,06	-146,56
27,06	28,07	-146,56
27,07	28,08	-146,55
27,08	28,09	-146,54
27,09	28,10	-146,54
27,10	28,11	-146,53
27,11	28,12	-146,52
27,12	28,13	-146,51
27,13	28,14	-146,51
27,14	28,15	-146,50
27,15	28,16	-146,49
27,16	28,17	-146,48
27,17	28,18	-146,48
27,18	28,19	-146,47
27,19	28,20	-146,46
27,20	28,21	-146,46
27,21	28,22	-146,45
27,22	28,23	-146,44
27,23	28,24	-146,43
27,24	28,25	-146,43
27,25	28,26	-146,42
27,26	28,27	-146,41
27,27	28,28	-146,40
27,28	28,29	-146,40
27,29	28,30	-146,39
27,30	28,31	-146,38
27,31	28,32	-146,38
27,32	28,33	-146,37
27,33	28,34	-146,36
27,34	28,35	-146,35
27,35	28,36	-146,35
27,36	28,37	-146,34
27,37	28,38	-146,33
27,38	28,39	-146,32
27,39	28,40	-146,32
27,40	28,41	-146,31
27,41	28,42	-146,30
27,42	28,43	-146,30
27,43	28,44	-146,29
27,44	28,45	-146,28



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcolatrice.com		
27,45	28,46	-146,27
27,46	28,47	-146,27
27,47	28,48	-146,26
27,48	28,49	-146,25
27,49	28,50	-146,25
27,50	28,51	-146,24
27,51	28,52	-146,23
27,52	28,53	-146,22
27,53	28,54	-146,22
27,54	28,55	-146,21
27,55	28,56	-146,20
27,56	28,57	-146,20
27,57	28,58	-146,19
27,58	28,59	-146,18
27,59	28,60	-146,17
27,60	28,61	-146,17
27,61	28,62	-146,16
27,62	28,63	-146,15
27,63	28,64	-146,15
27,64	28,65	-146,14
27,65	28,66	-146,13
27,66	28,67	-146,12
27,67	28,68	-146,12
27,68	28,69	-146,11
27,69	28,70	-146,10
27,70	28,71	-146,09
27,71	28,72	-146,09
27,72	28,73	-146,08
27,73	28,74	-146,07
27,74	28,75	-146,07
27,75	28,76	-146,06
27,76	28,77	-146,05
27,77	28,78	-146,04
27,78	28,79	-146,04
27,79	28,80	-146,03
27,80	28,81	-146,02
27,81	28,82	-146,02
27,82	28,83	-146,01
27,83	28,84	-146,00
27,84	28,85	-145,99
27,85	28,86	-145,99
27,86	28,87	-145,98
27,87	28,88	-145,97
27,88	28,89	-145,97



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalcatrice.com		
27,89	28,90	-145,96
27,90	28,91	-145,95
27,91	28,92	-145,95
27,92	28,93	-145,94
27,93	28,94	-145,93
27,94	28,95	-145,92
27,95	28,96	-145,92
27,96	28,97	-145,91
27,97	28,98	-145,90
27,98	28,99	-145,90
27,99	29,00	-145,89
28,00	29,01	-145,88
28,01	29,02	-145,87
28,02	29,03	-145,87
28,03	29,04	-145,86
28,04	29,05	-145,85
28,05	29,06	-145,85
28,06	29,07	-145,84
28,07	29,08	-145,83
28,08	29,09	-145,82
28,09	29,10	-145,82
28,10	29,11	-145,81
28,11	29,12	-145,80
28,12	29,13	-145,80
28,13	29,14	-145,79
28,14	29,15	-145,78
28,15	29,16	-145,77
28,16	29,17	-145,77
28,17	29,18	-145,76
28,18	29,19	-145,75
28,19	29,20	-145,75
28,20	29,21	-145,74
28,21	29,22	-145,73
28,22	29,23	-145,73
28,23	29,24	-145,72
28,24	29,25	-145,71
28,25	29,26	-145,70
28,26	29,27	-145,70
28,27	29,28	-145,69
28,28	29,29	-145,68
28,29	29,30	-145,68
28,30	29,31	-145,67
28,31	29,32	-145,66
28,32	29,33	-145,65



R729		
V1.0_R729		
Pression relative (bar)	Pression absolue (bar)	Température (°C)
cvccalatrice.com		
28,33	29,34	-145,65
28,34	29,35	-145,64
28,35	29,36	-145,63
28,36	29,37	-145,63
28,37	29,38	-145,62
28,38	29,39	-145,61
28,39	29,40	-145,61
28,40	29,41	-145,60
28,41	29,42	-145,59
28,42	29,43	-145,58
28,43	29,44	-145,58
28,44	29,45	-145,57
28,45	29,46	-145,56
28,46	29,47	-145,56
28,47	29,48	-145,55
28,48	29,49	-145,54
28,49	29,50	-145,54
28,50	29,51	-145,53
28,51	29,52	-145,52
28,52	29,53	-145,51
28,53	29,54	-145,51
28,54	29,55	-145,50